



315 S. Chapel St.  
Newark, DE 19711

Phone  
302.738.7172

Fax  
302.738.7175

[www.dedc-eng.com](http://www.dedc-eng.com)

**BAYLOR WOMEN'S CORRECTIONAL INSTITUTION (BWCI)  
DOOR CONTROL SYSTEM UPGRADE  
OMB/DFM # MC3804000049  
ADDENDUM #2 - REBID**

**CLARIFICATIONS:**

1. The new UPS shall cover all network switches, PLC's, and workstations. The building has an emergency generator which will start up in a matter of seconds if the building were to lose power. The UPS is just needed to cover the access control components during a brief electrical outage so the system will not need to be restarted.
2. The Cat 6 fiber runs from the Central Control Area to each of the outer buildings (Unit #3, Unit #4, Unit #9) will be furnished and installed in a separate project by others. The contractor will pull and test the wire as part of the separate project. Inside each mechanical room, the contractor will run the wire through innerduct over to each control cabinet in each of the (3) units as part of the separate project. A 20' length of wire will be coiled up inside each cabinet. In the Central Command area, a 20' length of wire will be coiled up and left for installation by a contractor as part of the door control system upgrade project.

Summarized By:     DED DC, LLC  
                          David Barton  
Date:                 10/30/14