



315 S. Chapel St.
Newark, DE 19711
Phone
302.738.7172
Fax
302.738.7175
www.dedc-eng.com

VAUGHN CORRECTIONAL CENTER – SEWER PLANT UPGRADES
OMB/DFM CONTRACT #'S MC3804000088
ADDENDUM #2

Bids to be extended:

- A. Per requests from some of the bidding contractors the bid duration has been extended. The new bid date is Tuesday July 25, 2017 at 2:30.

Questions and Clarifications

- A. The bid forms are missing a bond request form. Are we just using the state form, or will you be issuing another set of bid documents?
- The bid bond, payment bond, and performance bond documentation is located in the project manual. These documents were not re-issued as part of Addendum #1 as they did not change.

Substitution Requests

- A. Bell and Gossett 4XWC submersible 4” non-clog explosion proof sewage pump has been accepted as an equal to P-1 and P-2

Addendum #2 - Contents

1. Addendum Information (this document) (1 page)
2. Bid Form (5 pages) – Updated bid dates

Summarized By: DEDC, LLC
John R. Farina, P.E.
Date: July 13, 2017