



R G Architects, LLC

200 West Main Street
Middletown, DE 19709
302.376.8100
302.376.9851 fax
www.rgarchitects.net

RG A No. 17051
7 June, 2018

ADDENDUM NO. 2

STATE OF DELAWARE OMB/DFM
OMB/DFM Contract No. MC3806000012
Sussex Violation of Probation – Security Upgrades
Sussex Community Corrections Center
23207 DuPont Blvd. Georgetown, De 19947

R G Architects
200 West Main Street
Middletown, DE 19709
Phone: 302-376-8100 (phone)
Fax: 302-376-9851 (fax)
Email: oscar@rgarchitects.net

BIDS DUE:

2:00 p.m. local time on Thursday, June 21, 2018

LOCATION:

THOMAS COLLINS BUILDING
Division of Facilities Management Office
540 S. DuPont Highway, Suite 1 (Third Floor)
Dover, Delaware 19901
Attn: Mr. J Dean Seely

NOTICE TO ALL BIDDERS

1.0 GENERAL NOTES:

- 1.1 Bidders are hereby notified that this Addendum shall be and hereby becomes part of their Contract Documents, and shall be attached to the Project Manual for this project.
- 1.2 The following items are intended to revise and clarify the Drawings and Project Manual, and shall be included by the Bidder in their proposal.
- 1.3 Bidders shall verify that their Sub-bidders are in full receipt of the information contained herein.
- 1.4 A copy of the current bid set register is available upon request indicating individuals that have purchased project documents from R G architects.
- 1.5 All addenda will be sent out to the registered plan holders via email (or fax). Contractors are encouraged to keep an eye on their email accounts during the bidding period for such updates.
- 1.6 The owner has offered the contractors a tour of the facility, with the escort of the design team, on **Thursday, June 14, 2018 at 9:00 a.m.** Contractors who wish to attend are asked to complete their Security Clearance Forms (attached) and return them ASAP (in order to be approved on time) to Rick Ward at RichardW.Ward@state.de.us

2.0 Revisions to the SPECIFICATIONS

2.1 Not at this time.

3.0 Revisions to the DRAWINGS

3.1 Not at this time

4.0 Questions

4.1 Question – 1. Our supplier of the bullet resistance laminate needs to know if the glass is single or double pane? Also, is the glass tempered or annealed? Thickness of glass is needed before we can get pricing.

4.1.1 Answer – Per visual inspection architect assumes it is a 1/4” single panel tempered glass. Contractor may verify in field during the facility tour.

6.0 ATTACHMENT LIST:

A. None at this time.