

**Addendum
No. 2**

Addendum Date: November 8, 2017

Project: Autopsy HVAC Replacement at DFS Wilmington

DFM Project No: MC4501000001

The work herein shall be considered part of the bid documents for the referenced project and carried out in accordance with the following supplemental instructions issued in accordance with the Contract Documents without change in Contract Sum or Contract Time. Acknowledge receipt of addendum on the bid form as indicated.

Clarifications/General:

1. **THE BID DUE DATE HAS BEEN CHANGED FOR THIS PROJECT.** The updated bid date and time is as follows: Bids are now due at 11:00 AM on Thursday, November 30th. The bid location has not changed.
2. **THE RFI CUTOFF DATE HAS BEEN CHANGED FOR THIS PROJECT.** Questions must be received by 4:30 PM on Friday, November 24th.
3. **AN ADDITIONAL WALKTHROUGH HAS BEEN SCHEDULED.** A second walkthrough has been scheduled for Monday, November 13th at 1:00 PM.
4. **Project Progress Meetings:** It is anticipated that weekly coordination meetings will be required for this project once construction begins. Prior to construction start and post-occupancy, bi-weekly meetings will be sufficient for coordination purposes. Meeting lengths should be expected to be at least 2 hours in duration. These are estimates only and are subject to change based upon the project status.
5. **Temporary Facilities:** Each prime contractor for the four projects at the site will be responsible for maintaining temporary sanitary facilities, trash/dumpster service, etc. as specified in the project documents. The successful contractors may, at their discretion, choose to share these costs with the other successful bidders. However, it is solely the responsibility of the contractors to maintain the site facilities requirements as detailed in the project documents.
6. **Building permits:** As stated in the pre-bid meeting and in the project documents, contractors will be responsible for obtaining their own building permits as required by the City of Wilmington. The State of Delaware will provide supporting information regarding asbestos certification as required.

Changes to Drawings:

1. *Drawing M8.1* – At detail 1/8.1, delete vibration isolation curb. MAU-1 is to be provided with 36" high structural curb for side-discharge. Curb is to be anchored to slab. External vibration isolation is not required. No sketch is issued to reflect this change.

Changes to Specifications:

None.

END