

**ADDENDUM NO. 3
EMERGENCY GENERATOR
DELAWARE STATE POLICE- HEADQUARTERS AND ACADEMY
1441 N. DuPONT HIGHWAY, DOVER DE 19901
DHSS/DFM PROJECT NO.: MC4506000044/46
Date of Issue: October 20, 2014**

- 1.0 This addendum, Addendum No. 3, shall be made part of the Project Manual and Drawings dated September 29, 2014 for the Emergency Generator at the Delaware State Police- Headquarters and Academy.
- 2.0 Any provision in any of the Contract Documents which may be in conflict or be inconsistent with the contents of this Addendum shall be void to the extent of such conflicts or inconsistency.
- 3.0 **Bid Time & Date has not changed.** Sealed bids for OMB/DFM Project Nos. MC4506000044 - Delaware State Police Headquarters and MC4506000046 – Delaware State Police Academy – Emergency Generator, will be received by the State of Delaware, Office of Management and Budget, Division of Facilities Management, in the reception area of the Facilities Management Office in the Thomas Collins Building, 540 S. DuPont Highway, Suite 1 (Third Floor), Dover, DE 19901 until **2:00 p.m. local time on Thursday, October 23, 2014**, at which time they will be publicly opened and read aloud. Bidder bears the risk of late delivery. Any bids received after the stated time will be returned unopened.
- 4.0 Changes to prior Addenda
 - 4.1. There are no changes to prior addenda.
- 5.0 Changes to Specifications
 - 5.1 There are no changes to specifications.
- 6.0 Changes to Drawings:
 - 6.1 There are no changes to drawings.
- 7.0 Questions/Clarifications
 - 7.1 Q1. What is the location of the new generator annunciator and I-Watch Module?
A1. The new generator annunciator and I-Watch Control Panel shall be located in the generator enclosure. Contractor shall provide one (1)-1" conduit from the I-Watch Control Panel into the Academy Building for introduction of the Owner provided Cat-6 cable.
 - 7.2 Q2. Is the existing portable generator receptacle at the Academy Building being replaced?
A2. The existing portable generator receptacle and associated feeders shall be disconnected and removed in their entirety.

Addendum #3
Emergency Generator
Delaware State Police- Headquarters and Academy
Page 2 of 2

End of Addendum #3

13-1122 Addendum #3

cc: All Registered Plan Holders
P-File