

Addendum No. 5

Date: December 14, 2016
Project: DelDOT Kent County Administration Building
Renovation & OCR Compliance Project

The work herein shall be considered part of the bid documents for the referenced project and carried out in accordance with the following supplemental instructions issued in accordance with the Contract Documents without change in Contract Sum or Contract Time. Acknowledge receipt of addendum on the bid form as indicated.

Changes to Specification Manual:

1. Specifications Cover Page reissued.
2. *Specification 08 41 13* – C. Project Wind Loads. Delete Requirements for Project Wind Loads. Section is not reissued to reflect this change.
3. *Specification 09 21 16* – 2.04 Accessories. Revised section issued.
4. *Specification 21 05 00* – Add Section “Common Work Results for Fire Suppression.”
5. *Specification 21 05 53* – Add Section “Identification for Fire Suppression Piping and Equipment.”
6. *Specification 21 12 00* – Add Section “Fire-Suppression Standpipes.”
7. *Specification 21 13 00* – Add Section “Fire Suppression Sprinklers.”
8. *Specification 26 24 16* – 3.02; V: Delete item. Delete requirement for spare conduits out of each recessed panelboard. Section is not reissued to reflect this change.
9. *Specification 26 27 17* – 1.02; F: Add item – Related Requirement “Section 26 29 13 – Enclosed Controllers”. Section is not reissued to reflect this change.
10. *Specification 26 27 26* – Revised section issued:
 - a. Add 1.02, lines E and F – related requirements.
 - b. 2.05: Wall Dimmers – Revise manufacturers list.
 - c. Add 2.10, Access Floor Boxes.
 - d. Delete 3.04, lines H and I.
11. *Specification 26 51 00* –
 - a. Delete 1.02, lines D and E – related requirements.
 - b. Delete 3.03, line Y – References to air handling luminaires.
 - c. Section is not reissued to reflect these changes.
12. *Specification 31 10 00* – 1.02, C: Delete item. Delete related requirement to 32 93 00 Plants. Section is not reissued to reflect this change.
13. *Specification 32 13 13* – 2.04, B: Delete item. Delete. Section is not reissued to reflect this change. Reference to Section 03 30 00. Section is not reissued to reflect this change.

STATE OF DELAWARE
DELAWARE DEPARTMENT OF TRANSPORTATION

CONTRACT # MC 5511000014

SPECIFICATIONS
FOR

Renovation and OCR Compliance Project

At
DelDOT Administration Building
800 Bay Street
Dover, DE 19901

PREPARED
BY

StudioJAED Architects & Engineers

ISSUED FOR CONSTRUCTION

November 11, 2016

SECTION 09 21 16
GYPSUM BOARD ASSEMBLIES

PART 1 GENERAL

1.01 SECTION INCLUDES

- A. Metal stud wall, ceiling and soffit framing.
- B. Metal framing for top of wall bracing and ceiling framing.
- C. Acoustic insulation.
- D. Gypsum wallboard.
- E. Joint treatment and accessories.

1.02 RELATED REQUIREMENTS

- A. Section 06 10 00 - Rough Carpentry: Building Framing and Wood blocking .
- B. Section 06 10 00 - Rough Carpentry: Wood blocking product and execution requirements.

1.03 REFERENCE STANDARDS

- A. AISI SG02-1 - North American Specification for the Design of Cold-Formed Steel Structural Members; American Iron and Steel Institute. (replaced SG-971)
- B. ASTM A653/A653M - Standard Specification for Steel Sheet, Zinc-Coated (Galvanized) or Zinc-Iron Alloy-Coated (Galvannealed) by the Hot-Dip Process.
- C. ASTM C475/C475M - Standard Specification for Joint Compound and Joint Tape for Finishing Gypsum Board.
- D. ASTM C514 - Standard Specification for Nails for the Application of Gypsum Board.
- E. ASTM C645 - Standard Specification for Nonstructural Steel Framing Members.
- F. ASTM C665 - Standard Specification for Mineral-Fiber Blanket Thermal Insulation for Light Frame Construction and Manufactured Housing.
- G. ASTM C754 - Standard Specification for Installation of Steel Framing Members to Receive Screw-Attached Gypsum Panel Products.
- H. ASTM C840 - Standard Specification for Application and Finishing of Gypsum Board.
- I. ASTM C954 - Standard Specification for Steel Drill Screws for the Application of Gypsum Panel Products or Metal Plaster Bases to Steel Studs From 0.033 in. (0.84 mm) to 0.112 in. (2.84 mm) in Thickness.
- J. ASTM C1002 - Standard Specification for Steel Self-Piercing Tapping Screws for the Application of Gypsum Panel Products or Metal Plaster Bases to Wood Studs or Steel Studs.
- K. ASTM C1047 - Standard Specification for Accessories for Gypsum Wallboard and Gypsum Veneer Base.
- L. ASTM C1396/C1396M - Standard Specification for Gypsum Board.
- M. ASTM C1629/C1629 - Standard Classification for Abuse-Resistant Nondecorated Interior Gypsum Panel Products and Fiber-Reinforced Cement Panels.
- N. ASTM D3273 - Standard Test Method for Resistance to Growth of Mold on the Surface of Interior Coatings in an Environmental Chamber.
- O. ASTM E84 - Standard Test Method for Surface Burning Characteristics of Building Materials.
- P. ASTM E90 - Standard Test Method for Laboratory Measurement of Airborne Sound Transmission Loss of Building Partitions and Elements.
- Q. ASTM E413 - Classification for Rating Sound Insulation.

- R. GA-214 - Recommended Levels of Gypsum Board Finish; Gypsum Association.
- S. GA-216 - Application and Finishing of Gypsum Board; Gypsum Association.

1.04 SUBMITTALS

- A. See Section 01 30 00 - Administrative Requirements, for submittal procedures.
- B. Shop Drawings: Indicate special details associated with vertical deflection joints and acoustic seals. Provide special details for suspended ceilings. Indicate layout, anchorage to structure, type and location of fasteners, framed openings, accessories, and items of related work.
- C. Product Data: Provide data on metal framing, gypsum board, accessories, and joint finishing system.
- D. Product Data: Provide manufacturer's data on partition head to structure connectors, showing compliance with requirements.

1.05 QUALITY ASSURANCE

- A. Perform in accordance with ASTM C 840. Comply with requirements of GA-600 for fire-rated assemblies.
- B. Installer Qualifications: Company specializing in performing gypsum board application and finishing, with minimum 5 years of documented experience.

PART 2 PRODUCTS

2.01 GYPSUM BOARD ASSEMBLIES

- A. Provide completed assemblies per drawings.

2.02 METAL FRAMING MATERIALS

- A. Manufacturers - Metal Framing, Connectors, and Accessories:
 - 1. Clarkwestern Dietrich Building Systems LLC: www.clarkdietrich.com.
 - 2. Dietrich Metal Framing: www.dietrichindustries.com.
 - 3. Marino: www.marinoware.com.
 - 4. Substitutions: See Section 01 60 00 - Product Requirements.
- B. Non-Loadbearing Framing System Components: ASTM C645; galvanized sheet steel, of size and properties necessary to comply with ASTM C754 for the spacing indicated, with maximum deflection of wall framing of L/360 at 5 psf.
 - 1. Exception: The minimum metal thickness and section properties requirements of ASTM C 645 are waived provided steel of 40 ksi minimum yield strength is used, the metal is continuously dimpled, the effective thickness is at least twice the base metal thickness, and maximum stud heights are determined by testing in accordance with ASTM E 72 using assemblies specified by ASTM C 754.
 - a. Acceptable Products:
 - 1) Dietrich Metal Framing; UltraSteel (tm): www.dietrichindustries.com.
 - 2) Clark Western Building Systems; UltraSteel (tm): www.clarkwestern.com.
 - 2. Studs: "C" shaped with flat or formed webs with knurled faces.
 - 3. Runners: U shaped, sized to match studs.
 - 4. Ceiling Channels: C shaped.
 - 5. Furring: Hat-shaped sections, minimum depth of 7/8 inch.
- C. Ceiling Hangers: Type and size as specified in ASTM C754 for spacing required.
- D. Partition Head to Structure Connections: Provide mechanical anchorage devices that accommodate deflection using slotted holes, screws and anti-friction bushings, preventing rotation of studs while maintaining structural performance of partition.

1. Structural Performance: Maintain lateral load resistance and vertical movement capacity required by applicable code, when evaluated in accordance with AISI North American Specification for the Design of Cold-Formed Steel Structural Members.
2. Material: ASTM A653/A653M steel sheet, SS Grade 50/340, with G60/Z180 hot dipped galvanized coating.
3. Provide kickers / framing for top of wall and soffits as necessary.

2.03 BOARD MATERIALS

- A. Manufacturers - Gypsum-Based Board:
 1. CertainTeed Corporation: www.certainteed.com.
 2. Georgia-Pacific Gypsum: www.gpgypsum.com.
 3. National Gypsum Company: www.nationalgypsum.com.
 4. USG Corporation: www.usg.com.
 5. Substitutions: See Section 01 60 00 - Product Requirements.
- B. Gypsum Wallboard: Paper-faced gypsum panels as defined in ASTM C1396/C1396M; sizes to minimize joints in place; ends square cut.
 1. Application: Use for ceilings, unless otherwise indicated.
 2. Thickness:
 - a. Ceilings: 1/2 inch.
- C. Impact-Rated Wallboard: Tested to Level 3 soft-body and hard-body impact in accordance with ASTM C1629.
 1. Application: Walls.
 2. Paper-Faced Type: Gypsum wallboard as defined in ASTM C1396/C1396M.
 3. Thickness: 5/8 inch.
 4. Edges: Tapered.
 5. Products:
 - a. National Gypsum Company; Gold Bond Hi-Impact Brand XP Wallboard.
 - b. USG Corporation; Fiberock Brand Panels--VHI Abuse-Resistant.
- D. Gypsum Wallboard: ASTM C 1396/C 1396M. Sizes to minimize joints in place; ends square cut.
 1. Ceiling Board: Special sag-resistant type.
 - a. Application: Ceilings, and soffits.
 - b. Thickness: 1/2" inch.
 - c. Edges: Tapered.
 2. Abuse-Resistant Type: Gypsum wallboard especially formulated for increased impact resistance, with enhanced gypsum core and heavy duty face and back paper.
 - a. Application: Walls.
 - b. Core Type: Regular and Type X, as indicated.
 - c. Thickness: 5/8 inch.
 - d. Edges: Tapered.

2.04 ACCESSORIES

- A. Acoustic Insulation: ASTM C665; preformed glass fiber, friction fit type, unfaced.
- B. Acoustic Insulation: ASTM C 665; preformed glass fiber, friction fit type, unfaced. Thickness to fit cavity.
- C. Acoustic Sealant: As specified in Section 07 90 05.
- D. Finishing Accessories: ASTM C1047, rigid plastic, unless otherwise indicated.
 1. Types: As detailed or required for finished appearance.
 2. Special Shapes: In addition to conventional cornerbead and control joints, provide U-bead at exposed panel edges.

- E. Joint Materials: ASTM C475 and as recommended by gypsum board manufacturer for project conditions.
 - 1. Tape: 2 inch wide, coated glass fiber tape for joints and corners, except as otherwise indicated.
 - 2. Tape: 2 inch wide, creased paper tape for joints and corners, except as otherwise indicated.
 - 3. Ready-mixed vinyl-based joint compound.
 - 4. Powder-type vinyl-based joint compound.
 - 5. Chemical hardening type compound.
- F. Screws for Attachment to Steel Members Less Than 0.03 inch In Thickness, to Wood Members, and to Gypsum Board: ASTM C1002; self-piercing tapping type; cadmium-plated for exterior locations.
- G. Screws for Attachment to Steel Members From 0.033 to 0.112 Inch in Thickness: ASTM C954; steel drill screws for application of gypsum board to loadbearing steel studs.
- H. Screws: ASTM C 1002; self-piercing tapping type; cadmium-plated for exterior locations.
- I. Staples: ASTM C 840.
- J. Anchorage to Substrate: Tie wire, screws, and other metal supports, of type and size to suit application; to rigidly secure materials in place.

PART 3 EXECUTION

3.01 EXAMINATION

- A. Verify that project conditions are appropriate for work of this section to commence.

3.02 FRAMING INSTALLATION

- A. Metal Framing: Install in accordance with ASTM C754 and manufacturer's instructions.
- B. Suspended Ceilings and Soffits: Space framing and furring members as indicated.
 - 1. Level ceiling system to a tolerance of 1/600.
 - 2. Laterally brace entire suspension system, to structure above.
 - 3. Install bracing as required at exterior locations to resist wind uplift.
- C. Studs: Space studs as indicated.
 - 1. Extend partition framing to structure where indicated and to ceiling in other locations.
 - 2. Partitions Terminating at Ceiling: Attach ceiling runner securely to ceiling framing in accordance with details.
 - 3. Partitions Terminating at Structure: Attach extended leg top runner to structure, maintain clearance between top of studs and structure, and brace both flanges of studs with continuous bridging.
 - 4. Partitions Terminating at Structure: Attach top runner to structure, maintain clearance between top of studs and structure, and connect studs to track using specified mechanical devices in accordance with manufacturer's instructions; verify free movement of top of stud connections; do not leave studs unattached to track.
- D. Openings: Reinforce openings as required for weight of doors or operable panels, using not less than double studs at jambs.
- E. Connections: Minimum (4) #12 screws per connection of cold formed metal framing members.
- F. Blocking: Install blocking for support of plumbing fixtures, toilet partitions, wall cabinets, wood frame openings, toilet accessories, and hardware. Comply with Section 06 10 00 for wood blocking.

3.03 ACOUSTIC ACCESSORIES INSTALLATION

- A. Acoustic Insulation: Place tightly within spaces, around cut openings, behind and around electrical and mechanical items within partitions, and tight to items passing through partitions.
- B. Acoustic Sealant: Install as follows:
 - 1. Place two beads continuously on substrate before installation of perimeter framing members.
 - 2. Place continuous bead at perimeter of each layer of gypsum board.
 - 3. In non-fire-rated construction, seal around all penetrations by conduit, pipe, ducts, and rough-in boxes; and other penetrations.

3.04 BOARD INSTALLATION

- A. Comply with ASTM C 840 and manufacturer's instructions. Install to minimize butt end joints, especially in highly visible locations.
- B. Single-Layer Non-Rated: Install gypsum board in most economical direction, with ends and edges occurring over firm bearing.
 - 1. Exception: Tapered edges to receive joint treatment at right angles to framing.
- C. Installation on Metal Framing: Use screws for attachment of all gypsum board except face layer of non-rated double-layer assemblies, which may be installed by means of adhesive lamination.

3.05 INSTALLATION OF TRIM AND ACCESSORIES

- A. Control Joints: Place control joints consistent with lines of building spaces and as directed.
 - 1. Not more than 30 feet apart on walls and ceilings over 50 feet long.
- B. Corner Beads: Install at external corners, using longest practical lengths.
- C. Edge Trim: Install at locations where gypsum board abuts dissimilar materials and as indicated.

3.06 JOINT TREATMENT

- A. Paper Faced Gypsum Board: Use fiberglass joint tape, bedded with ready-mixed vinyl-based; or powder-type vinyl-based; or chemical hardening type joint compound and finished with ready-mixed vinyl-based; or powder-type vinyl-based; or chemical hardening type joint compound.
- B. Finish gypsum board in accordance with levels defined in ASTM C840, as follows:
 - 1. Level 4: Walls and ceilings to receive paint finish or wall coverings, unless otherwise indicated.
 - 2. Level 2: In utility areas, behind cabinetry, and on backing board to receive tile finish or where FRP panel to be installed.
 - 3. Level 1: Fire rated wall areas above finished ceilings, whether or not accessible in the completed construction.
- C. Finish gypsum board in scheduled areas in accordance with levels defined in GA-214; or ASTM C 840 and as scheduled below.
 - 1. Above Finished Ceilings Concealed From View: Level 1.
 - 2. Utility Areas and Areas Behind Cabinetry: Level 2.
 - 3. Walls and Ceilings to Receive Flat Paint Finish: Level 4.
- D. Tape, fill, and sand exposed joints, edges, and corners to produce smooth surface ready to receive finishes.
 - 1. Feather coats of joint compound so that camber is maximum 1/32 inch.
 - 2. Taping, filling, and sanding is not required at surfaces behind adhesive applied ceramic tile and fixed cabinetry.
 - 3. Taping, filling and sanding is not required at base layer of double layer applications.

3.07 TOLERANCES

- A. Maximum Variation of Finished Gypsum Board Surface from True Flatness: 1/8 inch in 10 feet in any direction.

3.08 FINISH LEVEL SCHEDULE (SEE 1.03 REFERENCES FOR DEFINITION)

- A. Level 1: Above finished ceilings concealed from view.
- B. Level 2: Utility areas and areas behind cabinetry or where FRP will be applied.
- C. Level 4: Walls and ceilings scheduled to receive flat paint finish.

END OF SECTION

SECTION 21 05 00

COMMON WORK RESULTS FOR FIRE SUPPRESSION

PART 1 GENERAL

1.01 SECTION INCLUDES

- A. Pipe, fittings, valves, and connections for sprinkler, standpipe and fire hose, and combination sprinkler and standpipe systems.

1.02 RELATED REQUIREMENTS

- A. Section 09 90 00 - Painting and Coating: Preparation and painting of fire protection piping systems.
- B. Section 21 05 53 - Identification for Fire Supp. Piping and Equipment: Piping identification.
- C. Section 22 05 53 - Identification for Plumbing Piping and Equipment: Piping identification.
- D. Section 21 13 00 - Fire-Suppression Sprinkler Systems: Sprinkler systems design.
- E. Section 21 12 00 - Fire-Suppression Standpipes: Standpipe design.

1.03 REFERENCE STANDARDS

- A. ASME (BPV IX) - Boiler and Pressure Vessel Code, Section IX - Welding and Brazing Qualifications; The American Society of Mechanical Engineers.
- B. ASME B16.1 - Gray Iron Pipe Flanges and Flanged Fittings: Classes 25, 125, and 250; The American Society of Mechanical Engineers.
- C. ASME B16.3 - Malleable Iron Threaded Fittings: Classes 150 and 300; The American Society of Mechanical Engineers.
- D. ASME B16.4 - Gray Iron Threaded Fittings; The American Society of Mechanical Engineers.
- E. ASME B16.5 - Pipe Flanges and Flanged Fittings; The American Society of Mechanical Engineers (ANSI/ASME B16.5).
- F. ASME B16.9 - Factory-made Wrought Steel Buttwelding Fittings; The American Society of Mechanical Engineers.
- G. ASME B16.11 - Forged Steel Fittings, Socket-welding and Threaded; The American Society of Mechanical Engineers.
- H. ASME B16.18 - Cast Copper Alloy Solder Joint Pressure Fittings; The American Society of Mechanical Engineers (ANSI B16.18).
- I. ASME B16.22 - Wrought Copper and Copper Alloy Solder Joint Pressure Fittings; The American Society of Mechanical Engineers.
- J. ASME B16.25 - Buttwelding Ends; The American Society of Mechanical Engineers.
- K. ASME B36.10M - Welded and Seamless Wrought Steel Pipe; The American Society of Mechanical Engineers.
- L. ASTM A47/A47M - Standard Specification for Ferritic Malleable Iron Castings.
- M. ASTM A53/A53M - Standard Specification for Pipe, Steel, Black and Hot-Dipped, Zinc-Coated, Welded and Seamless.
- N. ASTM A135/A135M - Standard Specification for Electric-Resistance Welded Steel Pipe.
- O. ASTM A234/A234M - Standard Specification for Piping Fittings of Wrought Carbon Steel and Alloy Steel for Moderate and High Temperature Service.
- P. ASTM A536 - Standard Specification for Ductile Iron Castings.
- Q. ASTM A795/A795M - Standard Specification for Black and Hot-Dipped Zinc-Coated (Galvanized) Welded and Seamless Steel Pipe for Fire Protection Use.

- R. ASTM B32 - Standard Specification for Solder Metal.
- S. ASTM B75/B75M - Standard Specification for Seamless Copper Tube.
- T. ASTM B75M - Standard Specification for Seamless Copper Tube (Metric).
- U. ASTM B88 - Standard Specification for Seamless Copper Water Tube.
- V. ASTM B88M - Standard Specification for Seamless Copper Water Tube (Metric).
- W. ASTM F438 - Standard Specification for Socket-Type Chlorinated Poly(Vinyl Chloride) (CPVC) Plastic Pipe Fittings, Schedule 40.
- X. ASTM F439 - Standard Specification for Chlorinated Poly(Vinyl Chloride) (CPVC) Plastic Pipe Fittings, Schedule 80.
- Y. ASTM F442/F442M - Standard Specification for Chlorinated Poly(Vinyl Chloride) (CPVC) Plastic Pipe (SDR-PR).
- Z. ASTM F493 - Standard Specification for Solvent Cements for Chlorinated Poly (Vinyl Chloride) (CPVC) Plastic Pipe and Fittings.
- AA. AWS A5.8/A5.8M - Specification for Filler Metals for Brazing and Braze Welding; American Welding Society.
- AB. AWS D1.1/D1.1M - Structural Welding Code - Steel.
- AC. AWWA C105/A21.5 - Polyethylene Encasement for Ductile-Iron Pipe Systems; American Water Works Association (ANSI/AWWA C105/A21.5).
- AD. AWWA C110/A21.10 - American National Standard for Ductile-Iron and Gray-Iron Fittings, 3 In. Through 48 In. (75 mm Through 1200 mm), for Water and Other Liquids; American Water Works Association.
- AE. AWWA C111/A21.11 - Rubber-Gasket Joints for Ductile-Iron Pressure Pipe and Fittings; American Water Works Association (ANSI/AWWA C111/A21.11).
- AF. AWWA C151/A21.51 - Ductile-Iron Pipe, Centrifugally Cast, for Water; American Water Works Association (ANSI/AWWA C151/A21.51).
- AG. NFPA 13 - Standard for the Installation of Sprinkler Systems; National Fire Protection Association.
- AH. NFPA 14 - Standard for the Installation of Standpipe and Hose Systems; National Fire Protection Association.
- AI. NFPA 24 - Standard for the Installation of Private Fire Service Mains and Their Appurtenances; National Fire Protection Association; 1995.
- AJ. UL (FPED) - Fire Protection Equipment Directory; Underwriters Laboratories Inc..
- AK. UL 262 - Gate Valves for Fire-Protection Service; Underwriters Laboratories Inc..
- AL. UL 312 - Check Valves for Fire-Protection Service; Underwriters Laboratories Inc..

1.04 SUBMITTALS

- A. Product Data: Provide manufacturers catalogue information. Indicate valve data and ratings.
- B. Project Record Documents: Record actual locations of components and tag numbering.
- C. Operation and Maintenance Data: Include installation instructions and spare parts lists.

1.05 QUALITY ASSURANCE

- A. Manufacturer Qualifications: Company specializing in manufacturing the Products specified in this section with minimum three years documented experience.
- B. Installer Qualifications: Company specializing in performing the work of this section with minimum 3 years experience. approved by manufacturer.

COMMON WORK RESULTS FOR FIRE SUPPRESSION

- C. Conform to UL requirements.
- D. Valves: Bear UL label or marking. Provide manufacturer's name and pressure rating marked on valve body.
- E. Products Requiring Electrical Connection: Listed and classified as suitable for the purpose specified and indicated.

1.06 DELIVERY, STORAGE, AND HANDLING

- A. Deliver and store valves in shipping containers, with labeling in place.
- B. Provide temporary protective coating on cast iron and steel valves.
- C. Provide temporary end caps and closures on piping and fittings. Maintain in place until installation.

1.07 EXTRA MATERIALS

- A. See Gilbane Project Manual.
- B. Provide two valve stem packings for each size and type of valve installed.

PART 2 PRODUCTS

2.01 FIRE PROTECTION SYSTEMS

- A. Sprinkler Systems: Conform work to NFPA 13.
- B. Standpipe and Hose Systems: Conform to NFPA 14.
- C. Welding Materials and Procedures: Conform to ASME Code.

2.02 BURIED PIPING

- A. Steel Pipe: ASTM A53/A53M Schedule 40, black, with AWWA C105 polyethylene jacket, or double layer, half-lapped polyethylene tape.
 - 1. Steel Fittings: ASME B16.9, wrought steel, butt welded; with double layer, half-lapped polyethylene tape.
 - 2. Cast Iron Fittings: ASME B16.1, flanges and flanged fittings.
 - 3. Joints: Welded in accordance with AWS D1.1.
 - 4. Casing: Closed glass cell insulation.
- B. Copper Tube: ASTM B75 (ASTM B75M), O60 or O50 temper.
 - 1. Type: Type K (A).
 - 2. Fittings: ASME B16.18, cast copper alloy, solder joint, pressure type.
 - 3. Joints: AWS A5.8 Classification BCuP-3 or BCuP-4 copper/silver braze.
 - 4. Casing: Closed glass cell insulation.
- C. Cast Iron Pipe: AWWA C151/A21.51.
 - 1. Fittings: AWWA C110, standard thickness.
 - 2. Joints: AWWA C111, rubber gasket.
 - 3. Mechanical Couplings: Shaped composition sealing gasket, steel bolts, nuts, and washers.

2.03 ABOVE GROUND PIPING

- A. Steel Pipe: ASTM A795 Schedule 10 or ASTM A53 Schedule 40, black.
 - 1. Steel Fittings: ASME B16.9, wrought steel, butt welded.
 - 2. Cast Iron Fittings: ASME B16.1, flanges and flanged fittings.
 - 3. Malleable Iron Fittings: ASME B16.3, threaded fittings.
 - 4. Mechanical Grooved Couplings: Malleable iron housing clamps to engage and lock, "C" shaped elastomeric sealing gasket, steel bolts, nuts, and washers; galvanized for galvanized pipe.

5. Mechanical Formed Fittings: Carbon steel housing with integral pipe stop and O-ring pocked and O-ring, uniformly compressed into permanent mechanical engagement onto pipe.
- B. Copper Tube: ASTM B88 (ASTM B88M), Type K (A), H58 drawn.
 1. Fittings: ASME B16.18, cast copper alloy, grooved.
 2. Mechanical Grooved Couplings: Ductile iron housing with alkyd enamel paint coating clamps to engage and lock, "C" shaped elastomeric sealing gasket, steel bolts, nuts, and washers.
- C. CPVC Pipe: ASTM F442/F442M, SDR 13.5.
 1. Fittings: ASTM F438 Schedule 40, or ASTM F439 schedule 80, CPVC.
 2. Joints: Solvent welded, using ASTM F493 cement.
- D. Cast Iron Pipe: AWWA C151/A21.51.
 1. Fittings: AWWA C110/A21.10, standard thickness.
 2. Joints: AWWA C111, rubber gasket.
 3. Mechanical Grooved Couplings: Malleable iron housing clamps to engage and lock, "C" shaped composition sealing gasket, steel bolts, nuts, and washers; galvanized for galvanized pipe.

2.04 PIPE HANGERS AND SUPPORTS

- A. Hangers for Pipe Sizes 1/2 to 1-1/2 inch: Malleable iron, adjustable swivel, split ring.
- B. Hangers for Pipe Sizes 2 inches and Over: Carbon steel, adjustable, clevis.
- C. Multiple or Trapeze Hangers: Steel channels with welded spacers and hanger rods.
- D. Wall Support for Pipe Sizes to 3 inches: Cast iron hook.
- E. Wall Support for Pipe Sizes 4 inches and Over: Welded steel bracket and wrought steel clamp.
- F. Vertical Support: Steel riser clamp.
- G. Floor Support: Cast iron adjustable pipe saddle, lock nut, nipple, floor flange, and concrete pier or steel support.
- H. Copper Pipe Support: Carbon steel ring, adjustable, copper plated.

2.05 GATE VALVES

- A. Up to and including 2 inches:
 1. Bronze body, bronze trim, rising stem, handwheel, solid wedge or disc, threaded ends.
- B. Over 2 inches:
 1. Iron body, bronze trim, rising stem pre-grooved for mounting tamper switch, handwheel, OS&Y, solid rubber covered bronze or cast iron wedge, flanged ends.
- C. Over 4 inches:
 1. Iron body, bronze trim, non-rising stem with bolted bonnet, solid bronze wedge, flanged ends, iron body indicator post assembly.

2.06 GLOBE VALVES

- A. Up to and including 2 inches:
 1. Bronze body, bronze trim, rising stem and handwheel, inside screw, renewable rubber disc, threaded ends, with backseating capacity repackable under pressure.
- B. Over 2 inches:
 1. Iron body, bronze trim, rising stem, handwheel, OS&Y, plug-type disc, flanged ends, renewable seat and disc.

2.07 BALL VALVES

- A. Up to and including 2 inches:

COMMON WORK RESULTS FOR FIRE SUPPRESSION

1. Bronze two piece body, brass, chrome plated bronze, or stainless steel ball, teflon seats and stuffing box ring, lever handle and balancing stops, threaded ends .
- B. Over 2 inches:
 1. Cast steel body, chrome plated steel ball, teflon seat and stuffing box seals, lever handle or gear drive handwheel for sizes 10 inches and over, flanged.

2.08 BUTTERFLY VALVES

- A. Bronze Body:
 1. Stainless steel disc, resilient replaceable seat, threaded or grooved ends, extended neck, handwheel and gear drive and integral indicating device, and built-in tamper proof switch rated 10 amp at 115 volt AC.
- B. Cast or Ductile Iron Body
 1. Cast or ductile iron, chrome or nickel plated ductile iron or aluminum bronze disc, resilient replaceable EPDM seat, wafer, lug, or grooved ends, extended neck, handwheel and gear drive and integral indicating device, and internal tamper switch rated 10 amp at 115 volt AC.

2.09 CHECK VALVES

- A. Up to and including 2 inches:
 1. Bronze body and swing disc, rubber seat, threaded ends.
- B. Over 2 inches:
 1. Iron body, bronze trim, swing check with rubber disc, renewable disc and seat, flanged ends with automatic ball check.
- C. 4 inches and Over:
 1. Iron body, bronze disc, stainless steel spring, resilient seal, threaded, wafer, or flanged ends.

2.10 DRAIN VALVES

- A. Compression Stop:
 1. Bronze with hose thread nipple and cap.
- B. Ball Valve:
 1. Brass with cap and chain, 3/4 inch hose thread.

PART 3 EXECUTION

3.01 PREPARATION

- A. Ream pipe and tube ends. Remove burrs. Bevel plain end ferrous pipe.
- B. Remove scale and foreign material, from inside and outside, before assembly.
- C. Prepare piping connections to equipment with flanges or unions.

3.02 INSTALLATION

- A. Install sprinkler system and service main piping, hangers, and supports in accordance with NFPA 13.
- B. Install standpipe piping, hangers, and supports in accordance with NFPA 14.
- C. Route piping in orderly manner, plumb and parallel to building structure. Maintain gradient.
- D. Install piping to conserve building space, to not interfere with use of space and other work.
- E. Group piping whenever practical at common elevations.
- F. Sleeve pipes passing through partitions, walls, and floors.
- G. Install piping to allow for expansion and contraction without stressing pipe, joints, or connected equipment.

- H. Inserts:
 - 1. Provide inserts for placement in concrete formwork.
 - 2. Provide inserts for suspending hangers from reinforced concrete slabs and sides of reinforced concrete beams.
 - 3. Provide hooked rod to concrete reinforcement section for inserts carrying pipe over 4 inches.
 - 4. Where concrete slabs form finished ceiling, locate inserts flush with slab surface.
 - 5. Where inserts are omitted, drill through concrete slab from below and provide through-bolt with recessed square steel plate and nut flush with top of slab.
- I. Pipe Hangers and Supports:
 - 1. Install hangers to provide minimum 1/2 inch space between finished covering and adjacent work.
 - 2. Place hangers within 12 inches of each horizontal elbow.
 - 3. Use hangers with 1-1/2 inch minimum vertical adjustment. Design hangers for pipe movement without disengagement of supported pipe.
 - 4. Support vertical piping at every floor. Support riser piping independently of connected horizontal piping.
 - 5. Where several pipes can be installed in parallel and at same elevation, provide multiple or trapeze hangers.
 - 6. Provide copper plated hangers and supports for copper piping.
 - 7. Prime coat exposed steel hangers and supports. Hangers and supports located in crawl spaces, pipe shafts, and suspended ceiling spaces are not considered exposed.
- J. Slope piping and arrange systems to drain at low points. Use eccentric reducers to maintain top of pipe level.
- K. Prepare pipe, fittings, supports, and accessories for finish painting. Where pipe support members are welded to structural building framing, scrape, brush clean, and apply one coat of zinc rich primer to welding. Refer to Section 09 90 00.
- L. Do not penetrate building structural members unless indicated.
- M. Provide sleeves when penetrating footings, floors, and walls. Seal pipe and sleeve penetrations to achieve fire resistance equivalent to fire separation required.
- N. Escutcheons:
 - 1. Install and firmly attach escutcheons at piping penetrations into finished spaces.
 - 2. Provide escutcheons on both sides of partitions separating finished areas through which piping passes.
 - 3. Use chrome plated escutcheons in occupied spaces and to conceal openings in construction.
- O. When installing more than one piping system material, ensure system components are compatible and joined to ensure the integrity of the system. Provide necessary joining fittings. Ensure flanges, union, and couplings for servicing are consistently provided.
- P. Die cut threaded joints with full cut standard taper pipe threads with red lead and linseed oil or other non-toxic joint compound applied to male threads only.
- Q. Install valves with stems upright or horizontal, not inverted. Remove protective coatings after installation.
- R. Provide gate, ball, or butterfly valves for shut-off or isolating service.
- S. Provide drain valves at main shut-off valves, low points of piping and apparatus.

END OF SECTION

SECTION 21 05 53

IDENTIFICATION FOR FIRE SUPP. PIPING AND EQUIPMENT

PART 1 GENERAL

1.01 SECTION INCLUDES

- A. Nameplates.
- B. Tags.
- C. Stencils.
- D. Pipe Markers.

1.02 RELATED REQUIREMENTS

- A. Section 09 90 00 - Painting and Coating: Identification painting.

1.03 REFERENCE STANDARDS

- A. ASME A13.1 - Scheme for the Identification of Piping Systems; The American Society of Mechanical Engineers.

1.04 SUBMITTALS

- A. List: Submit list of wording, symbols, letter size, and color coding for mechanical identification.
- B. Chart and Schedule: Submit valve chart and schedule, including valve tag number, location, function, and valve manufacturer's name and model number.
- C. Product Data: Provide manufacturers catalog literature for each product required.
- D. Manufacturer's Installation Instructions: Indicate special procedures, and installation.
- E. Project Record Documents: Record actual locations of tagged valves.

PART 2 PRODUCTS

2.01 MANUFACTURERS

- A. Brady Corporation: www.bradycorp.com.
- B. Champion America, Inc: www.Champion-America.com.
- C. Seton Identification Products: www.seton.com/aec.
- D. Substitutions: See Section 01 60 00 - Product Requirements.

2.02 NAMEPLATES

- A. Description: Laminated three-layer plastic with engraved letters.
 - 1. Letter Color: White.
 - 2. Letter Height: 1/4 inch.
 - 3. Background Color: Black.

2.03 TAGS

- A. Plastic Tags: Laminated three-layer plastic with engraved black letters on light contrasting background color. Tag size minimum 1-1/2 inch diameter.
- B. Metal Tags: Brass with stamped letters; tag size minimum 1-1/2 inch diameter with smooth edges.
- C. Valve Tag Chart: Typewritten letter size list in anodized aluminum frame.

2.04 STENCILS

- A. Stencils: With clean cut symbols and letters of following size:
 - 1. 3/4 to 1-1/4 inch Outside Diameter of Insulation or Pipe: 8 inch long color field, 1/2 inch high letters.

2. 1-1/2 to 2 inch Outside Diameter of Insulation or Pipe: 8 inch long color field, 3/4 inch high letters.
 3. 2-1/2 to 6 inch Outside Diameter of Insulation or Pipe: 12 inch long color field, 1-1/4 inch high letters.
 4. 8 to 10 inch Outside Diameter of Insulation or Pipe: 24 inch long color field, 2-1/2 inch high letters.
 5. Over 10 inch Outside Diameter of Insulation or Pipe: 32 inch long color field, 3-1/2 inch high letters.
 6. Equipment: 2-1/2 inch high letters.
- B. Stencil Paint: As specified in Section 09 90 00, semi-gloss enamel, colors conforming to ASME A13.1.

2.05 PIPE MARKERS

- A. Color: Conform to ASME A13.1.
- B. Plastic Pipe Markers: Factory fabricated, flexible, semi-rigid plastic, preformed to fit around pipe or pipe covering; minimum information indicating flow direction arrow and identification of fluid being conveyed.
- C. Plastic Tape Pipe Markers: Flexible, vinyl film tape with pressure sensitive adhesive backing and printed markings.
- D. Underground Plastic Pipe Markers: Bright colored continuously printed plastic ribbon tape, minimum 6 inches wide by 4 mil thick, manufactured for direct burial service.

2.06 CEILING TACKS

- A. Description: Steel with 3/4 inch diameter color coded head.

PART 3 EXECUTION

3.01 PREPARATION

- A. Degrease and clean surfaces to receive adhesive for identification materials.
- B. Prepare surfaces in accordance with Section 09 90 00 for stencil painting.

3.02 INSTALLATION

- A. Install nameplates with corrosive-resistant mechanical fasteners, or adhesive. Apply with sufficient adhesive to ensure permanent adhesion and seal with clear lacquer.
- B. Install tags with corrosion resistant chain.
- C. Apply stencil painting in accordance with Section 09 90 00.
- D. Install plastic pipe markers in accordance with manufacturer's instructions.
- E. Install plastic tape pipe markers complete around pipe in accordance with manufacturer's instructions.
- F. Install underground plastic pipe markers 6 to 8 inches below finished grade, directly above buried pipe.
- G. Identify pumps and valves with plastic nameplates. Small devices, such as in-line pumps, may be identified with tags.
- H. Identify control panels and major control components outside panels with plastic nameplates.
- I. Identify thermostats relating to terminal boxes or valves with nameplates.
- J. Identify valves in main and branch piping with tags.
- K. Tag automatic controls, instruments, and relays. Key to control schematic.
- L. Identify piping, concealed or exposed, with plastic pipe markers. Use tags on piping 3/4 inch diameter and smaller. Identify service, flow direction, and pressure. Install in clear view and

IDENTIFICATION FOR FIRE SUPP. PIPING AND EQUIPMENT

align with axis of piping. Locate identification not to exceed 20 feet on straight runs including risers and drops, adjacent to each valve and Tee, at each side of penetration of structure or enclosure, and at each obstruction.

- M. Locate ceiling tacks to locate valves above T-bar type panel ceilings. Locate in corner of panel closest to equipment.

END OF SECTION

SECTION 21 12 00
FIRE-SUPPRESSION STANDPIPES

PART 1 GENERAL

1.01 SECTION INCLUDES

- A. Standpipe system.
- B. Fire department connection.
- C. Fire extinguishers located in hose cabinets.

1.02 RELATED REQUIREMENTS

- A. Section 10 44 00 - Fire Protection Specialties.
- B. Section 21 05 00 - Common Work Results for Fire Suppression: Fire protection piping.
- C. Section 21 05 23 - General-Duty Valves for Water-Based Fire-Suppression Piping.
- D. Section 21 05 53 - Identification for Fire Supp. Piping and Equipment.
- E. Section 21 30 00 - Fire Pumps.
- F. Section 21 13 00 - Fire-Suppression Sprinkler Systems.
- G. Section 22 05 53 - Identification for Plumbing Piping and Equipment.
- H. Section 26 27 17 - Equipment Wiring: Electrical characteristics and wiring connections.

1.03 REFERENCE STANDARDS

- A. FM P7825 - Approval Guide; Factory Mutual Research Corporation.
- B. ITS (DIR) - Directory of Listed Products; Intertek Testing Services NA, Inc..
- C. NFPA 10 - Standard for Portable Fire Extinguishers; National Fire Protection Association.
- D. NFPA 14 - Standard for the Installation of Standpipe and Hose Systems; National Fire Protection Association.
- E. UL (FPED) - Fire Protection Equipment Directory; Underwriters Laboratories Inc..

1.04 SUBMITTALS

- A. Product Data: Provide manufacturer's catalog sheet for equipment indicating rough-in size, finish, and accessories.
- B. Shop Drawings: Indicate supports, components, accessories, and sizes.
 - 1. Submit shop drawings and product data to Owner's insurance underwriter for approval.
 - 2. Submit proof of approval to Architect.
- C. Project Record Documents: Record actual locations of components.
- D. Operation Data: Include manufacturer's data.
- E. Maintenance Data: Include servicing requirements and test schedule.
- F. Certificates: Provide certificate of compliance from authority having jurisdiction indicating approval of field acceptance tests.

1.05 QUALITY ASSURANCE

- A. Perform Work in accordance with NFPA 14. Maintain one copy on site.
- B. Installer Qualifications: Company specializing in performing the work of this section with minimum three years experience approved by manufacturer.

1.06 PRE-INSTALLATION MEETING

- A. Convene one week before starting work of this section.

1.07 DELIVERY, STORAGE, AND HANDLING

- A. Deliver and store products in shipping packaging until installation.

1.08 EXTRA MATERIALS

- A. Provide two extra hose nozzles and hoses.

PART 2 PRODUCTS

2.01 FIRE HOSE CABINETS

- A. Hose Cabinets:
 - 1. Style: Recessed mounted.
 - 2. Tub: 16 gage thick steel, prepared for pipe and accessory rough-in.
 - 3. Door: 12 gage thick steel, flush, ; hinged, positive latch device.
 - 4. Finish: Prime Coated.
- B. Hose Rack: Steel with polished chrome finish; swivel type with pins and water stop.
- C. Hose: 1 inch diameter, 50 feet long, of linen hose; mildew and rot-resistant.
- D. Nozzle: Chrome plated brass; combination fog, straight stream, and adjustable shut-off.

2.02 VALVES

- A. Hose Station Valve: Angle type, brass finish, 1-1/2 inch nominal size with automatic ball drip; refer to Section 21 05 00.
- B. Hose Connection Valve: Angle type; brass finish; 2-1/2 inch size, thread to match fire department hardware, 300 psi working pressure, with threaded cap and chain of same material and finish; refer to Section 21 05 00.
- C. Pressure Reducing Valve: Angle type; brass finish with inner hydraulic controls; 1-1/2 inch size, thread to match fire department hardware, 400 psi inlet pressure, with threaded cap and chain of same material and finish; refer to Section 21 05 00.
- D. Hose Connection Valve Cabinets:
 - 1. Style: Recessed mounted.
 - 2. Tub: 16 gage thick steel, prepared for pipe and accessory rough-in.
 - 3. Door: 12 gage thick steel, flush, ; hinged, positive latch device.
 - 4. Finish: Prime Coated.

2.03 FIRE DEPARTMENT CONNECTION

- A. Type: Flush mounted wall type with brass finish.
- B. Outlets: Two way with thread size to suit fire department hardware; threaded dust cap and chain of matching material and finish.
- C. Drain: 3/4 inch automatic drip, outside.
- D. Label: "Standpipe - Fire Department Connection".

2.04 FIRE EXTINGUISHERS

- A. General: Comply with NFPA 10; UL listed.
- B. Water Type: Copper container with positive displacement pump and discharge hose.
 - 1. 2-1/2 gallon capacity with 2A rating.
 - 2. 5 gallon capacity with 4A rating.
- C. Carbon Dioxide Type: Insulated handle, hose and horn discharge assembly, self-closing lever or squeeze grip operated, insulated handle.
 - 1. 5 pound capacity with 5BC rating.
 - 2. 10 pound capacity with 10BC rating.
 - 3. 15 pound capacity with 10BC rating.

4. 20 pound capacity with 10BC rating.
- D. Multi-Purpose Dry Chemical Type: Cartridge operated with hose and shut-off nozzle or integral shut-off nozzle.
 1. 2-1/2 pound capacity with 1A:10BC rating.
 2. 5 pound capacity with 2A:10BC rating.
 3. 6 pound capacity with 3A:40BC rating.
 4. 10 pound capacity with 4A:60BC rating.
 5. 20 pound capacity with 20A:120BC rating.

PART 3 EXECUTION

3.01 INSTALLATION

- A. Install in accordance with manufacturer's instructions.
- B. Install in accordance with NFPA 14.
- C. Locate and secure cabinets plumb and level. Establish top of cabinet (inside horizontal) surface 66 inches above finished floor.
- D. Locate hose station valve in cabinet at 60 inches above finished floor.
- E. Connect standpipe system to water source ahead of domestic water connection.
- F. Where static pressure exceeds 100 psi but is less than 100 psi at any hose station, provide pressure orifice disc in discharge of hose station valve to prevent pressure on hose exceeding 90 psi.
- G. Where static pressure exceeds 100 psi at any hose station, provide pressure reducing valve to prevent pressure on hose exceeding 90 psi.
- H. Provide two way fire department outlet connection on roof.
- I. Flush entire system of foreign matter.

3.02 FIELD QUALITY CONTROL

- A. Perform field inspection and testing in accordance with Section 01 40 00.
- B. Test entire system in accordance with NFPA 14.
- C. Test shall be witnessed by authority having jurisdiction.

END OF SECTION

SECTION 21 13 00
FIRE SUPPRESSION SPRINKLERS

PART 1 GENERAL

1.01 SECTION INCLUDES

- A. Wet-pipe sprinkler system.
- B. System design, installation, and certification.

1.02 RELATED REQUIREMENTS

- A. Section 28 31 00 - Fire Detection and Alarm.
- B. Section 21 05 00 - Common Work Results for Fire Suppression: Pipe, fittings, and valves.
- C. Section 21 05 48 - Vibration and Seismic Controls for Fire Suppression Piping and Equipment.
- D. Section 21 05 53 - Identification for Fire Supp. Piping and Equipment.
- E. Section 21 30 00 - Fire Pumps.
- F. Section 21 12 00 - Fire-Suppression Standpipes.
- G. Section 14 91 00 - Facility Chutes: Sprinkler heads inside chutes.
- H. Section 22 05 48 - Vibration and Seismic Controls for Plumbing Piping and Equipment.
- I. Section 22 05 53 - Identification for Plumbing Piping and Equipment.
- J. Section 26 27 17 - Equipment Wiring: Electrical characteristics and wiring connections.

1.03 REFERENCE STANDARDS

- A. FM P7825 - Approval Guide; Factory Mutual Research Corporation.
- B. ITS (DIR) - Directory of Listed Products; Intertek Testing Services NA, Inc..
- C. NFPA 13 - Standard for the Installation of Sprinkler Systems; National Fire Protection Association.
- D. NFPA 13R - Standard for the Installation of Sprinkler Systems in Residential Occupancies up to and Including Four Stories in Height; National Fire Protection Association.
- E. UL (FPED) - Fire Protection Equipment Directory; Underwriters Laboratories Inc..

1.04 SUBMITTALS

- A. Product Data: Provide data on sprinklers, valves, and specialties, including manufacturers catalog information. Submit performance ratings, rough-in details, weights, support requirements, and piping connections.
- B. Shop Drawings:
 - 1. Submit preliminary layout of finished ceiling areas indicating only sprinkler locations coordinated with ceiling installation.
 - 2. Indicate hydraulic calculations, detailed pipe layout, hangers and supports, sprinklers, components and accessories. Indicate system controls.
 - 3. Submit shop drawings and hydraulic calculations to authority having jurisdiction and Fire Marshall for approval. Submit proof of approval to Architect.
- C. Samples: Submit one of each style of sprinkler specified.
- D. Project Record Documents: Record actual locations of sprinklers and deviations of piping from drawings. Indicate drain and test locations.
- E. Manufacturer's Certificate: Certify that system has been tested and meets or exceeds specified requirements and code requirements.

- F. Operation and Maintenance Data: Include components of system, servicing requirements, record drawings, inspection data, replacement part numbers and availability, and location and numbers of service depot.
- G. Maintenance Materials: Furnish the following for Owner's use in maintenance of project.
 - 1. Extra Sprinklers: Type and size matching those installed, in quantity required by referenced NFPA design and installation standard.
 - 2. Sprinkler Wrenches: For each sprinkler type.

1.05 QUALITY ASSURANCE

- A. Maintain one copy of referenced design and installation standard on site.
- B. Conform to UL requirements.
- C. Designer Qualifications: Design system under direct supervision of a Professional Engineer experienced in design of this type of work and licensed in the State in which the Project is located.
- D. Manufacturer Qualifications: Company specializing in manufacturing the Products specified in this section with minimum three years documented experience.
- E. Installer Qualifications: Company specializing in performing the work of this section with minimum three years experience approved by manufacturer.
- F. Equipment and Components: Provide products that bear UL label or marking.
- G. Products Requiring Electrical Connection: Listed and classified by Underwriters' Laboratories Inc. or testing firm acceptable to the authority having jurisdiction as suitable for the purpose specified and indicated.

1.06 MOCK-UP

- A. Provide components for installation in mock-up.
- B. Mock-up may not remain as part of the Work.

1.07 PRE-INSTALLATION MEETING

- A. Convene one week before starting work of this section.

1.08 DELIVERY, STORAGE, AND HANDLING

- A. Store products in shipping containers and maintain in place until installation. Provide temporary inlet and outlet caps. Maintain caps in place until installation.

1.09 EXTRA MATERIALS

- A. Provide extra sprinklers of type and size matching those installed, in quantity required by referenced NFPA design and installation standard.
- B. Provide suitable wrenches for each sprinkler type.
- C. Provide metal storage cabinet located adjacent to alarm valve.

PART 2 PRODUCTS

2.01 SPRINKLER SYSTEM

- A. Sprinkler System: Provide coverage for building areas noted.
- B. Occupancy: comply with NFPA 13.
- C. Water Supply: Determine volume and pressure from water flow test data.
 - 1. Revise design when test data available prior to submittals.
- D. Interface system with building fire and smoke alarm system.
- E. Provide fire department connections where indicated.
- F. Storage Cabinet for Spare Sprinklers and Tools: Steel, located adjacent to alarm valve.

2.02 SPRINKLERS

- A. Suspended Ceiling Type: Recessed-type, chrome-plated with push on, clamp, or screw type escutcheon plates.
 - 1. Finish: Chrome plated.
 - a. Within Standard Acoustical Tile Ceilings: White with White Estuccheon Plate
 - b. Within Wooden Finish Acoustical Clouds: Chrome Plated with Chrome Plated Estuccheon Plate
 - 2. Fusible Link: Fusible solder link type temperature rated for specific area hazard.
- B. Exposed Area Type: Standard upright type with guard.
 - 1. Finish: Chrome plated.
 - 2. Fusible Link: Fusible solder link type temperature rated for specific area hazard.
- C. Sidewall Type: Standard, Semi-recessed or Recessed horizontal sidewall type with matching push on escutcheon plate and guard.
 - 1. Finish: Chrome plated.
 - 2. Escutcheon Plate Finish: Chrome plated.
 - 3. Fusible Link: Fusible solder link type temperature rated for specific area hazard.
- D. Dry Sprinklers: Standard, Recessed or Exposed pendant type with matching push on escutcheon plate.
 - 1. Finish: Chrome plated.
 - 2. Escutcheon Plate Finish: Chrome plated.
 - 3. Fusible Link: Fusible solder link type temperature rated for specific area hazard.
- E. Guards: Finish to match sprinkler finish.
- F. Spray Nozzles: Brass with solid cone discharge, 30 degrees of arc with blow-off dust cap.

2.03 PIPING SPECIALTIES

- A. Wet Pipe Sprinkler Alarm Valve: Check type valve with divided seat ring, rubber faced clapper to automatically actuate water motor alarm and electric alarm, with pressure retard chamber and variable pressure trim; with test and drain valve.
- B. Flooding Deluge Valve: Gate type valve with rubber faced disc actuated manually with water motor alarm and electric alarm, with alarm testing trim.
- C. Water Motor Alarm: Hydraulically operated impeller type alarm with aluminum alloy chrome plated gong and motor housing, nylon bearings, and inlet strainer.
- D. Electric Alarm: Electrically operated chrome plated gong with pressure alarm switch.
- E. Water Flow Switch: Vane type switch for mounting horizontal or vertical, with two contacts; rated 10 amp at 125 volt AC and 2.5 amp at 24 volt DC.
- F. Fire Department Connections:
 - 1. Type: Flush mounted wall type with brass finish.
 - 2. Outlets: Two way with thread size to suit fire department hardware; threaded dust cap and chain of matching material and finish.
 - 3. Drain: 3/4 inch automatic drip, outside.
 - 4. Label: "Sprinkler - Fire Department Connection".
- G. Supervisory Switches:
- H. Water Level Supervisory Switches:
- I. Tank Temperature Supervisory Switches:
- J. Room Temperature Supervisory Switches:

2.04 PRESSURE MAINTENANCE PUMP

- A. Type: Close coupled motor and positive displacement pump unit.
- B. Construction: Bronze with stainless steel shafts, carbon bearings.
- C. Motor: Open drip proof, permanently lubricated.
- D. Electrical Characteristics:
 - 1. 0.33 hp.
 - 2. 115 volts, single phase, 60 Hz.
- E. Accessories: Include flexible hose connections, inlet strainer, and relief valve.
- F. Operation: Manual or Automatic with pressure switch actuation.

PART 3 EXECUTION

3.01 INSTALLATION

- A. Install in accordance with referenced NFPA design and installation standard.
- B. Install equipment in accordance with manufacturer's instructions.
- C. Place pipe runs to minimize obstruction to other work.
- D. Place piping in concealed spaces above finished ceilings.
- E. Center sprinklers in two directions in ceiling tile and provide piping offsets as required.
- F. Apply masking tape or paper cover to ensure concealed sprinklers, cover plates, and sprinkler escutcheons do not receive field paint finish. Remove after painting. Replace painted sprinklers.
- G. Install and connect to fire pump system in accordance with Section 21 30 00.
- H. Flush entire piping system of foreign matter.
- I. Install guards on sprinklers where indicated.
- J. Hydrostatically test entire system.
- K. Require test be witnessed by Fire Marshal and authority having jurisdiction.

3.02 INTERFACE WITH OTHER PRODUCTS

- A. Ensure required devices are installed and connected as required to fire alarm system.

END OF SECTION

SECTION 26 27 26
WIRING DEVICES

PART 1 GENERAL

1.01 SECTION INCLUDES

- A. Wall switches.
- B. Wall dimmers.
- C. Receptacles.
- D. Wall plates.
- E. Floor box service fittings.

1.02 RELATED REQUIREMENTS

- A. Section 26 05 26 - Grounding and Bonding for Electrical Systems.
- B. Section 26 05 37 - Boxes.
- C. Section 26 05 53 - Identification for Electrical Systems: Identification products and requirements.
- D. Section 26 27 17 - Equipment Wiring: Cords and plugs for equipment.

1.03 REFERENCE STANDARDS

- A. FS W-C-596 - Connector, Electrical, Power, General Specification for; Federal Specification.
- B. FS W-S-896 - Switches, Toggle (Toggle and Lock), Flush-mounted (General Specification); Federal Specification.
- C. NECA 1 - Standard for Good Workmanship in Electrical Construction; National Electrical Contractors Association.
- D. NEMA WD 1 - General Color Requirements for Wiring Devices; National Electrical Manufacturers Association.
- E. NEMA WD 6 - Wiring Device -- Dimensional Specifications; National Electrical Manufacturers Association.
- F. NFPA 70 - National Electrical Code; National Fire Protection Association.
- G. UL 20 - General-Use Snap Switches.
- H. UL 498 - Attachment Plugs and Receptacles.
- I. UL 514D - Cover Plates for Flush-Mounted Wiring Devices.
- J. UL 943 - Ground-Fault Circuit-Interrupters.
- K. UL 1472 - Solid-State Dimming Controls.

1.04 ADMINISTRATIVE REQUIREMENTS

- A. Coordination:
 - 1. Coordinate the placement of outlet boxes with millwork, furniture, equipment, etc. installed under other sections or by others.
 - 2. Coordinate wiring device ratings and configurations with the electrical requirements of actual equipment to be installed.
 - 3. Coordinate the installation and preparation of uneven surfaces, such as split face block, to provide suitable surface for installation of wiring devices.
 - 4. Notify Architect of any conflicts or deviations from the contract documents to obtain direction prior to proceeding with work.

1.05 SUBMITTALS

- A. See Section 01 30 00 - Administrative Requirements, for submittal procedures.

- B. Product Data: Provide manufacturer's catalog information showing dimensions, colors, and configurations.
- C. Manufacturer's Installation Instructions: Indicate application conditions and limitations of use stipulated by product testing agency. Include instructions for storage, handling, protection, examination, preparation, and installation of product.

1.06 QUALITY ASSURANCE

- A. Conform to requirements of NFPA 70.
- B. Maintain at the project site a copy of each referenced document that prescribes execution requirements.
- C. Manufacturer Qualifications: Company specializing in manufacturing the products specified in this section with minimum three years documented experience.

1.07 DELIVERY, STORAGE, AND PROTECTION

- A. Store in a clean, dry space in original manufacturer's packaging until ready for installation.

1.08 EXTRA MATERIALS

- A. See Section 01 60 00 - Product Requirements, for additional provisions.
- B. Furnish two of each style, size, and finish wall plate.

PART 2 PRODUCTS

2.01 MANUFACTURERS

- A. Hubbell Incorporated; : www.hubbell-wiring.com.
- B. Leviton Manufacturing Company, Inc; : www.leviton.com.
- C. Lutron Electronics Company, Inc: www.lutron.com.
- D. Pass & Seymour, a brand of Legrand North America, Inc; : www.legrand.us
- E. Cooper Wiring Devices: www.cooperwiringdevices.com.
- F. Leviton Manufacturing, Inc: www.leviton.com.
- G. Substitutions: See Section 01 60 00 - Product Requirements.
- H. Source Limitations: Where possible, for each type of wiring device furnish products produced by a single manufacturer and obtained from a single supplier.

2.02 APPLICATIONS

- A. Provide wiring devices suitable for intended use and with ratings adequate for load served.
- B. For single receptacles installed on an individual branch circuit, provide receptacle with ampere rating not less than that of the branch circuit.
- C. Provide weather resistant GFI receptacles with specified weatherproof covers for all receptacles installed outdoors or in damp or wet locations.
- D. Provide GFI protection for all receptacles installed within 6 feet of sinks.
- E. Unless noted otherwise, do not use combination switch/receptacle devices.
- F. For flush floor service fittings, use carpet flanges for installations in carpeted floors.

2.03 ALL WIRING DEVICES

- A. Provide products listed and classified by Underwriters Laboratories Inc. as suitable for the purpose specified and indicated.
- B. Finishes:

2.04 WALL SWITCHES

- A. Manufacturers:
 - 1. Hubbell Incorporated; : www.hubbell-wiring.com.
 - 2. Leviton Manufacturing Company, Inc; : www.leviton.com.
 - 3. Pass & Seymour, a brand of Legrand North America, Inc; : www.legrand.us
 - 4. Substitutions: See Section 01 60 00 - Product Requirements.
- B. All Wall Switches: AC only, quiet operating, general-use snap switches with silver alloy contacts, complying with NEMA WD 1 and NEMA WD 6, and listed as complying with UL 20 and where applicable, FS W-S-896; types as indicated on the drawings.
 - 1. Wiring Provisions: Terminal screws for side wiring and screw actuated binding clamp for back wiring with separate ground terminal screw.
- C. Standard Wall Switches: Commercial specification grade, 20 A, 120/277 V with standard toggle type switch actuator and maintained contacts; single pole single throw, double pole single throw, three way, or four way as indicated on the drawings.
- D. Wall Switches: Heavy Duty, AC only general-use snap switch, complying with NEMA WD 6 and WD 1.
 - 1. Body and Handle: White plastic with toggle handle.
 - 2. Ratings:
 - a. Voltage: 120 - 277 volts, AC.
 - b. Current: 20 amperes.
 - 3. Ratings: Match branch circuit and load characteristics.
- E. Switch Types: Single pole, double pole, 3-way, and 4-way.

2.05 WALL DIMMERS

- A. Manufacturers:
 - 1. Lutron Electronics Company, Inc; Maestro Series: www.lutron.com.
 - 2. Substitutions: See Section 01 60 00 - Product Requirements.
- B. All Wall Dimmers: Solid-state with continuous full-range even control following square law dimming curve, integral radio frequency interference filtering, power failure preset memory, air gap switch accessible without removing wall plate, complying with NEMA WD 1 and NEMA WD 6, and listed as complying with UL 1472; types and ratings suitable for load controlled as indicated on the drawings.
- C. Control: Slide control type with separate on/off switch.

2.06 RECEPTACLES

- A. Manufacturers:
 - 1. Hubbell Incorporated; : www.hubbell-wiring.com.
 - 2. Leviton Manufacturing Company, Inc; : www.leviton.com.
 - 3. Pass & Seymour, a brand of Legrand North America, Inc; : www.legrand.us
 - 4. Substitutions: See Section 01 60 00 - Product Requirements.
- B. All Receptacles: Self-grounding, complying with NEMA WD 1 and NEMA WD 6, and listed as complying with UL 498, and where applicable, FS W-C-596; types as indicated on the drawings.
 - 1. Wiring Provisions: Terminal screws for side wiring or screw actuated binding clamp for back wiring with separate ground terminal screw.
 - 2. NEMA configurations specified are according to NEMA WD 6.
- C. GFI Receptacles:
 - 1. All GFI Receptacles: Provide with feed-through protection, light to indicate ground fault tripped condition and loss of protection, and list as complying with UL 943, class A.
- D. Receptacles: Heavy duty, complying with NEMA WD 6 and WD 1.

1. Device Body: Black plastic.
 2. Configuration: NEMA WD 6, type as specified and indicated.
- E. Convenience Receptacles: Type 5 - 20.
- F. Single Convenience Receptacles.
- G. Duplex Convenience Receptacles.
- H. GFCI Receptacles: Convenience receptacle with integral ground fault circuit interrupter to meet regulatory requirements.

2.07 TELEPHONE JACKS

- A. Product: AMP manufacturing
- B. Substitutions: See Section 01 60 00 - Product Requirements.

2.08 WALL PLATES

- A. Manufacturers:
1. Hubbell Incorporated; : www.hubbell-wiring.com.
 2. Leviton Manufacturing Company, Inc; : www.leviton.com.
 3. Pass & Seymour, a brand of Legrand North America, Inc; : www.legrand.us
 4. Substitutions: See Section 01 60 00 - Product Requirements.
- B. All Wall Plates: Comply with UL 514D.
1. Configuration: One piece cover as required for quantity and types of corresponding wiring devices.
 2. Size: Standard; .
 3. Screws: Metal with slotted heads finished to match wall plate finish.
- C. Stainless Steel Wall Plates: Brushed satin finish, Type 302 stainless steel.
- D. Decorative Cover Plates: stainless steel.
- E. Jumbo Cover Plates: stainless steel.
- F. Weatherproof Cover Plates: Gasketed cast metal with hinged cover.

2.09 FLOOR BOX SERVICE FITTINGS

- A. Manufacturers:
1. Hubbell Incorporated; : www.hubbell-wiring.com.
 2. Thomas & Betts Corporation; : www.tnb.com.
 3. Wiremold, a brand of Legrand North America, Inc; : www.legrand.us
 4. Substitutions: See Section 01 60 00 - Product Requirements.
- B. Description: Service fittings compatible with floor boxes provided under Section 26 05 37 with all components, adapters, and trims required for complete installation.
- C. Flush Floor Service Fittings:
1. Dual Service Flush Combination Outlets:
 - a. Cover: Rectangular.
 - b. Configuration:
 - 1) Power: One standard convenience duplex receptacle(s) with duplex flap opening(s).
 2. Accessories:
 - a. Carpet Flanges: Finish to match covers; configuration as required to accommodate specified covers.

2.10 ACCESS FLOOR BOXES

- A. **Furniture Power and IT Feed Box**
1. Hubbell Incorporated : www.hubbell-wiring.com

2. Legrand : www.legrand.us/wiremold
3. Description: 2-Gang recessed floor box with divider and cover assembly; Legrand Evolution Series or approved equal
4. Legrand Catalog NO: Box -EFBFF
5. Divider- EFBFF-DIV
6. Cover Assembly- FPFFTC-XX

B. Multiservice Recessed Floor Box.

1. Manufacturers: Multiservice Recessed Floor Box
2. Hubbell Incorporated: www.hubbell-wiring.com
3. Legrand : www.legrand.us/wiremold
4. Description: 6- Gang floor box with divider ,cover assembly, devices and device plates. Legrand Evolution series or approved equal
5. Legrand Catalog No: Box- EFB6S
6. Divider-EFB6-Div
7. Cover Assembly-EFB610BTC-XX
8. Module- EFB6M
9. Mounting Bracket- EFB6-MB
10. Each Box requires: (3) NEMA5-20R Duplex receptacles
11. (1)NEMA 5-20R Isolated Ground Type Receptacle
12. (1) Single Gang IT Outlet with 2 Jacks
13. (1) Blank Plate

PART 3 EXECUTION

3.01 EXAMINATION

- A. Verify that field measurements are as shown on the drawings.
- B. Verify that outlet boxes are installed in proper locations and at proper mounting heights and are properly sized to accommodate devices and conductors in accordance with NFPA 70.
- C. Verify that wall openings are neatly cut and will be completely covered by wall plates.
- D. Verify that final surface finishes are complete, including painting.
- E. Verify that floor boxes are adjusted properly.
- F. Verify that branch circuit wiring installation is completed, tested, and ready for connection to wiring devices.
- G. Verify that openings in access floor are in proper locations.
- H. Verify that conditions are satisfactory for installation prior to starting work.

3.02 PREPARATION

- A. Provide extension rings to bring outlet boxes flush with finished surface.
- B. Clean dirt, debris, plaster, and other foreign materials from outlet boxes.

3.03 INSTALLATION

- A. Perform work in a neat and workmanlike manner in accordance with NECA 1 and, where applicable, NECA 130, including mounting heights specified in those standards unless otherwise indicated.
- B. Perform work in a neat and workmanlike manner in accordance with NECA 1, including mounting heights specified in that standard unless otherwise indicated.
- C. Coordinate locations of outlet boxes provided under Section 26 05 37 as required for installation of wiring devices provided under this section.
- D. Install wiring devices in accordance with manufacturer's instructions.

- E. Install permanent barrier between ganged wiring devices when voltage between adjacent devices exceeds 300 V.
- F. Where required, connect wiring devices using pigtails not less than 6 inches long. Do not connect more than one conductor to wiring device terminals.
- G. Connect wiring devices by wrapping conductor clockwise 3/4 turn around screw terminal and tightening to proper torque specified by the manufacturer. Where present, do not use push-in pressure terminals that do not rely on screw-actuated binding.
- H. Unless otherwise indicated, connect wiring device grounding terminal to branch circuit equipment grounding conductor and to outlet box with bonding jumper.
- I. Install securely, in a neat and workmanlike manner, as specified in NECA 1.
- J. Install wiring devices plumb and level with mounting yoke held rigidly in place.
- K. Install wall switches with OFF position down.
- L. Do not share neutral conductor on branch circuits utilizing wall dimmers.
- M. Install vertically mounted receptacles with grounding pole on top and horizontally mounted receptacles with grounding pole on left.
- N. Install wall plates to fit completely flush to wall with no gaps and rough opening completely covered without strain on wall plate. Repair or reinstall improperly installed outlet boxes or improperly sized rough openings. Do not use oversized wall plates in lieu of meeting this requirement.
- O. Install blank wall plates on junction boxes and on outlet boxes with no wiring devices installed or designated for future use.
- P. Install receptacles with grounding pole on top.
- Q. Connect wiring device grounding terminal to outlet box with bonding jumper.
- R. Install decorative plates on switch, receptacle, and blank outlets in finished areas.
- S. Connect wiring devices by wrapping conductor around screw terminal.
- T. Use jumbo size plates for outlets installed in masonry walls.
- U. Install galvanized steel plates on outlet boxes and junction boxes in unfinished areas, above accessible ceilings, and on surface mounted outlets.

3.04 INTERFACE WITH OTHER PRODUCTS

- A. Coordinate locations of outlet boxes provided under Section 26 05 37 to obtain mounting heights.
- B. Install wall switch 48 inches above finished floor.
- C. Install convenience receptacle 18 inches above finished floor.
- D. Install convenience receptacle 6 inches above backsplash of counter.
- E. Install telephone jack 18 inches above finished floor.
- F. Install telephone jack for side-reach wall telephone to position top of telephone at 54 inches above finished floor.
- G. Install telephone jack for forward-reach wall telephone to position top of telephone at 48 inches above finished floor.

3.05 FIELD QUALITY CONTROL

- A. Perform field inspection, testing, adjusting, and balancing in accordance with Section 01 40 00.
- B. Inspect each wiring device for damage and defects.

- C. Operate each wall switch, wall dimmer, and fan speed controller with circuit energized to verify proper operation.
- D. Operate each wall switch with circuit energized and verify proper operation.
- E. Verify that each receptacle device is energized.
- F. Test each receptacle to verify operation and proper polarity.
- G. Test each GFCI receptacle for proper tripping operation according to manufacturer's instructions.
- H. Correct wiring deficiencies and replace damaged or defective wiring devices.
- I. Verify that each telephone jack is properly connected and circuit is operational.

3.06 ADJUSTING

- A. Adjust devices and wall plates to be flush and level.

3.07 CLEANING

- A. Clean exposed surfaces to remove dirt, paint, or other foreign material and restore to match original factory finish.

END OF SECTION