

January 31, 2015

To: All Contractors

From: Professional Roof Services (*ejem*)

Re: Addendum #3
Roof Replacement Project
The Laundry Building
Herman M. Holloway Sr. Campus - Contract No. MJ3505000027

1. The capped curb located in the northeast corner of the roof that the air conditioning unit and pitch pockets will be removed from as referenced in Addendum # 2 is a structural concrete curb. This curb will then be flashed using the Tuff Flash Flashing System at I Beam Locations detail given in the specification #D-SC-610.
2. On page # 11 of the Method Specifications under General Installation Requirements the Holloway Campus Kitchen Building is referenced. The Holloway Campus Laundry Building is what should have been referenced.
3. Because of the large number of changes to the original specification and drawing for this job due to the significant amount of mechanical work that occurred. The last day for questions will be extended from Monday, February 2, 2015 until Wednesday, February 4, 2015 at the close of business.

End of Addendum

Cc: Dean Seely, State of DE - OMB
David Miller, State of DE - OMB
Stephen King, State of DE – OMB
Mike Sanders, Harvard Environmental
Mike Kenefic, Kenefic Sales Associates
Brad Smith, PRSI
Blaine Chipola, PRSI
Mike McGonigle, PRSI
File