

January 22, 2015

To: All Contractors

From: Professional Roof Services (*ejem*)

Re: Addendum #1
Roof Replacement Project
The Laundry Building
Herman M. Holloway Sr. Campus - Contract No. MJ3505000027

1. Prebid sign-in sheet is attached.
2. Bids are due on Friday, February 6, 2015 at 2:00 P.M. Location is the State of Delaware, Office of Management and Budget, Division of Facilities Management, at the Thomas Collins Building, 540 S. DuPont Highway, Suite 1 (Third Floor), Dover, DE 19901.
3. Last day of questions will be Monday, February 2, 2015 at the close of business.
4. Any additional appointments to visit the site must be made through Mr. David Miller, his contact info can be found on the attached sign-in sheet. Please give him at least 24 hours advance notice prior to scheduling your visit.
5. The color of the metal for all projects at the Herman M. Holloway Sr. Campus should be Mansard Brown.
6. The information given in Part 2 – Products for the Modified Built Up Roof System is incorrect. Type IV glass felt is referenced for the Base Sheet, Type VI glass felt is the type that should have been referenced. Also 145 mil, smooth surfaced rubber modified roofing membrane is the description of the Cap Sheet that can be found in this section and in the physical properties section under Letter B. The mineral surface version of this membrane is what should have been referenced in this section and the correct mil thickness of the product specified is 155 mil.

End of Addendum

Cc: Dean Seely, State of DE - OMB
David Miller, State of DE - OMB
Stephen King, State of DE – OMB
Mike Sanders, Harvard Environmental
Mike Kenefic, Kenefic Sales Associates
Brad Smith, PRSI
Blaine Chipola, PRSI
Mike McGonigle, PRSI
File