

SECTION 011000 - SUMMARY

PART 1 - GENERAL

1.1 RELATED DOCUMENTS

- A. Drawings and general provisions of the Contract, including General and Supplementary Conditions and other Division 01 Specification Sections, apply to this Section.

1.2 SUMMARY

A. Section Includes:

1. Project information.
2. Work covered by Contract Documents.
3. Work by Owner.
4. Work under separate contracts.
5. Owner-furnished products.
6. Access to site.
7. Work restrictions.
8. Specification and drawing conventions.
9. Miscellaneous provisions.

B. Related Requirements:

1. Section 015000 "Temporary Facilities and Controls" for limitations and procedures governing temporary use of Owner's facilities.

1.3 PROJECT INFORMATION

A. Project Identification: William F. Cooke, Jr. Elementary School.

1. Project Location: 2025 Graves Road, Hockessin, Delaware 19707.

B. Owner: Red Clay Consolidated School District.

1. Owner's Representative: Marcin Michalski, Manager of Facilities and Maintenance, 1798 Limestone Road, Wilmington, DE 19804, (302) 892-3284.

C. Architect: Becker Morgan Group, Inc., 309 S. Governors Avenue, Dover, DE 19904, (302) 734-7950 | 312 West Main Street, Suite 300, Salisbury, MD 21801, (410) 546-9100.

D. Architect's Consultants: The Architect has retained the following design professionals who have prepared designated portions of the Contract Documents:

1. Fire Protection, Plumbing, Mechanical, Electrical, and Information Technology Engineers: Studio JAED, 2500 Wrangle Hill Road, Fox Run Office Plaza, Suite 110, Bear, DE 19701, (302) 832-1652.

2. Structural Engineer: Baker, Ingram & Associates: 1050S. State Street, Dover, DE 19901, (302) 734-7400.
 3. Food Services Consultant: Nyikos Associates, Inc., 18219-A Flower Hill Way, Gaithersburg, MD 20879, (240) 683-9530.
- E. Construction Manager: The Whiting-Turner Contracting Company, 131 Continental Drive, Suite 404, Newark, DE 19731, (302) 292-0676.
1. Construction Manager has been engaged for this Project to serve as an advisor to Owner and to provide assistance in administering the Contract for Construction between Owner and each Contractor, according to a separate contract between Owner and Construction Manager.
 2. Construction Manager for this Project is Project's constructor. The terms "Construction Manager" and "Contractor" are synonymous.
- F. Project Web Site: A project Web site administered by Construction Manager will be used for purposes of managing communication and documents during the construction stage.
1. See Section 013100 "Project Management and Coordination." for requirements for using the Project Web site.

1.4 WORK COVERED BY CONTRACT DOCUMENTS

- A. The Work of Project is defined by the Contract Documents and consists of the following:
1. The new construction of a two-story elementary educational facility and associated site work.
- B. Type of Contract:
1. Project will be constructed under coordinated, concurrent multiple contracts. See Section 011200 "Multiple Contract Summary" for a description of work included under each of the multiple contracts and for the responsibilities of Project coordinator. Contracts for this Project include the following:
 - a. Contract 03A - Concrete.
 - b. Contract 04A - Masonry.
 - c. Contract 05A - Steel.
 - d. Contract 06A - Carpentry.
 - e. Contract 07A - Roofing.
 - f. Contract 07B - Caulking
 - g. Contract 07C - Metal Panels.
 - h. Contract 07D - Spray Insulation.
 - i. Contract 08A - Glass.
 - j. Contract 09A - Stud and Drywall.
 - k. Contract 09B - Ceilings.
 - l. Contract 09C - Flooring.
 - m. Contract 09D - Paint.
 - n. Contract 09E - Epoxy Floor.
 - o. Contract 11A - Kitchen Equipment.
 - p. Contract 11B - Gym Equipment.
 - q. Contract 12A - Casework.
 - r. Contract 12B - Window Treatments.
 - s. Contract 14A - Elevator.
 - t. Contract 21A = Sprinklers.

- u. Contract 23A – Mechanical.
- v. Contract 23B – Balancing.
- w. Contract 26A – Electrical.
- x. Contract 31A – Sitework.
- y. Contact 31B – Landscaping.

1.5 WORK BY OWNER

- A. General: Cooperate fully with Owner so work may be carried out smoothly, without interfering with or delaying work under this Contract or work by Owner. Coordinate the Work of this Contract with work performed by Owner.
- B. Subsequent Work: Owner will perform the following additional work at site after Substantial Completion. Completion of that work will depend on successful completion of preparatory work under this Contract.
 - 1. Owner's Contractor(s) will install all Furniture, Fixtures, and Equipment not included under the construction contract, but requires coordination with in place work.
 - 2. Owner's Contractor(s) will install all Patch Cabling except for Wireless Access Points, all Ethernet and FO switches, and all TV Tuners.

1.6 WORK UNDER SEPARATE CONTRACTS

- A. General: Cooperate fully with separate contractors so work on those contracts may be carried out smoothly, without interfering with or delaying work under this Contract or other contracts. Coordinate the Work of this Contract with work performed under separate contracts.
- B. Concurrent Work: Owner will award separate contracts for the following construction operations at Project site. Those operations will be conducted simultaneously with work under this Contract.
 - 1. Security & CCTV Systems Equipment and Installation: ADT Security, (302) 395-3515.
 - 2. Card Access System Equipment and Installation: Advantech, Inc., (302) 674-8405.
 - 3. Phone System Equipment and Installation: Collins Business Systems, Inc., (302) 658-1700.

1.7 OWNER-FURNISHED PRODUCTS

- A. Owner will furnish products indicated. The Work includes receiving, unloading, handling, storing, protecting, and installing Owner-furnished products and making building services connections.
- B. Owner-Furnished Products:
 - 1. Residential Appliances.
 - 2. Toilet Accessory Dispensers: Soap, Paper Towel and Toilet Tissue.
 - 3. Kiln.
 - 4. Wireless Access Points (WAPs).
 - 5. WAP Covers.
 - 6. Interactive Projectors.
 - 7. Rear Projector at Stage.
 - 8. Kiosk at Administration Office.
 - 9. MDF Racks (2).
 - 10. IDF 1A Rack (1)
 - 11. Televisions.

1.8 ACCESS TO SITE

- A. General: Contractor shall have full use of Project site for construction operations during construction period. Contractor's use of Project site is limited only by Owner's right to perform work or to retain other contractors on portions of Project.
 - 1. Limits: Limit site disturbance, including earthwork and clearing of vegetation, to 40 feet (12.2 m) beyond building perimeter; 10 feet (3 m) beyond surface walkways, patios, surface parking, and utilities less than 12 inches (300 mm) in diameter; 15 feet (4.5 m) beyond primary roadway curbs and main utility branch trenches; and 25 feet (7.6 m) beyond constructed areas with permeable surfaces (such as pervious paving areas, stormwater detention facilities, and playing fields) that require additional staging areas in order to limit compaction in the constructed area.

1.9 WORK RESTRICTIONS

- A. Work Restrictions, General: Comply with restrictions on construction operations.
 - 1. Comply with limitations on use of public streets and with other requirements of authorities having jurisdiction.
- B. Controlled Substances: Use of tobacco products and other controlled substances on Project site is not permitted.
- C. Employee Identification: Provide identification tags for Contractor personnel working on Project site. Require personnel to use identification tags at all times.
- D. Employee Screening: Comply with Owner's requirements for drug and background screening of Contractor personnel working on Project site.
 - 1. Maintain list of approved screened personnel with Owner's representative.

1.10 SPECIFICATION AND DRAWING CONVENTIONS

- A. Specification Content: The Specifications use certain conventions for the style of language and the intended meaning of certain terms, words, and phrases when used in particular situations. These conventions are as follows:
 - 1. Imperative mood and streamlined language are generally used in the Specifications. The words "shall," "shall be," or "shall comply with," depending on the context, are implied where a colon (:) is used within a sentence or phrase.
 - 2. Specification requirements are to be performed by Contractor unless specifically stated otherwise.
- B. Division 01 General Requirements: Requirements of Sections in Division 01 apply to the Work of all Sections in the Specifications.
- C. Drawing Coordination: Requirements for materials and products identified on Drawings are described in detail in the Specifications. One or more of the following are used on Drawings to identify materials and products:
 - 1. Terminology: Materials and products are identified by the typical generic terms used in the individual Specifications Sections.

2. Abbreviations: Materials and products are identified by abbreviations published as part of the U.S. National CAD Standard and scheduled on Drawings.
3. Keynoting: Materials and products are identified by reference keynotes referencing Specification Section numbers found in this Project Manual.

PART 2 - PRODUCTS (Not Used)

PART 3 - EXECUTION (Not Used)

END OF SECTION 011000

SECTION 011200– SUMMARY OF CONTRACTS / SCOPES OF WORK

Bid Packages: The following is a list of Bid Packages for the RCCSD – William F. Cooke Elementary School:

UNIT OF WORK #	TITLE	BRIEF DESCRIPTION (See Specific Scope for full Description)
01A	General Scope of Work	General Scope of Work Applicable to All Trades
23C	Automatic Temperature Controls	Automatic temperature controls for building HVAC systems

Request for clarifications: Direct all questions or concerns in writing to:
The Whiting-Turner Contracting Co., Construction Manager, Attention: Frank Lerro
via fax 302-292-0683 or email, frank.lerro@whiting-turner.com.
All responses will be in the form of an Addendum.

END OF SECTION 011200
(ATTACHMENTS FOLLOW – GENERAL SCOPE AND SPECIFIC SCOPES OF WORK)

SECTION 011200-01A – GENERAL SCOPE OF WORK

All work is to be done in accordance with the Contract Documents, including the drawings and the specifications, this scope of work, and all addenda if any. Each trade must comply fully with all sections of the Division 1 general requirements.

This scope is intended as a reference to assist in the bidding process. The Contractor is responsible for all labor, material, tools, equipment, hoisting, storage, layout, incidental work, and associated services necessary to fully complete all of the work described and shown in the Contract Documents. This contractor is responsible to review and include all items in their attached specific scope of work and to also review the work of other trades.

This work includes but is not limited to:

1. All bidders are required to provide 10% bid bond for each bid package submitted.
2. All contractors are required to provide 100% payment and performance bonds for their contract.
3. All contractor employees will be required to sign-in each day on the jobsite.
4. Work hours are 7:00 am to 3:30 pm. All contractors are required to work minimum 5 days per week, 8 hours per day. If day(s) are lost during the work week, all contractors are required to work Saturdays to make up for all lost days at no added cost.
5. Each contractor, upon award, is to forward budget costs for each individual item of work, in s.f. or l.f. costs for accounting only. A list will be forwarded to each sub from Whiting-Turner.
6. Each foreman is required to complete daily field reports and turn them into WT daily. This report states where and what work was performed. Failure to submit reports on a daily basis may delay contractor payment.
7. All deliveries must be scheduled in advance with Whiting-Turner. Major deliveries, those that may impact or disrupt the work of other trades, require seven (7) days notice to WT. Minor deliveries require two (2) days notice to WT. WT shall coordinate storage locations for all deliveries.
8. This contractor will execute an AIA contract with no changes.
9. All contractor employees will meet with the WT Superintendent for a short safety orientation upon starting their work on site. All contractor employees are required to attend this orientation.
10. The foreman and project manager will need to meet with the superintendent for a “pre-start” job meeting.
11. This contractor is responsible for all existing site conditions in existence as of the bid due date. These conditions may not be identified on the drawings or in this scope of work. Examine prior to the bid.
12. All contractors are required to perform all layout required for their work.
13. No gasoline-powered equipment can be used at any time within buildings. All equipment you plan to use must be reviewed with the Superintendent for safety concerns.
14. MSDS must be forwarded prior to starting work. No chemicals can be used at any time without properly reviewing them with WT first.
15. All contractors are required to perform any necessary dewatering in order to complete their work.
16. All subcontractors are responsible for daily cleanup of their debris to the jobsite dumpster. This means that no trash or excess construction materials can be left on site or in buildings at the end of the day.
17. The Construction Manager will supply a dumpster for the work, the contractor is responsible for placing debris in the dumpster.
18. Storage space will be limited. Materials and gang boxes cannot be in the way of other trades, traffic, fire lanes, access, etc. Review location and requirements with WT. Provide storage trailers or off site storage when necessary.
19. Furnish attic stock as required by the drawings, specifications, or the scope of work.

20. Jobsite security and security of materials, equipment, tools, etc. is the responsibility of each contractor.
21. Contractors are required to coordinate with other trades and with Whiting-Turner.
22. Contractors are required to comply with all safety regulations as required by OSHA, State of Delaware, Red Clay Consolidated School District, Whiting-Turner, and as noted in the specifications. Provide all safety devices necessary for your work.
23. All change order pricing must be accompanied by a labor and material breakdown and with subcontractor quotes.
24. Care must be taken to not mark or damage finished surfaces. Contractors will be backcharged or will need to pay for repairs to the work of others. Protect the owner's property.
25. Roof protection must be provided by any contractor working on top of the completed roof systems. Minimum protection required is 2" rigid insulation and 3/4" plywood.
26. All safety, barricades, floor opening protection, etc., installed by this contractor or by others is the responsibility of this contractor if moved or damaged by this contractor.
27. Provide all testing, guarantees, warranties, as-built drawings, O&M manuals, commissioning tests, close-out documentation, and start-up services necessary to put all work into first class operating condition per the contract documents including any final cleanup required.
28. As-built drawings must be maintained on the job-site and updated on a daily basis for review by Whiting-Turner. At contract completion, contractor must submit as-built drawings and O&M Manuals as required by specifications.
29. Owner training required by specifications. Training must be videotaped.
30. Where furnishing and installation of work is indicated by separate parties include:
 - Furnishing Party – delivery to jobsite including freight and taxes
 - Installing Party – receiving, unloading, inventory, storage, handling, and installation.
31. Core drilling, cutting & patching as required to perform work. Include restoration of surfaces to original condition if required. Cutting to be performed as to minimize patching.
32. Sealants, caulking, and firestopping integral with work.
33. Permit fees and licenses required for work, other than the building permit, shall be furnished by the contractor whose work requires such permits.
34. General temporary lighting, 120V power & water will be provided. Any contractor requiring temporary services above and beyond those noted shall provide the necessary temporary service required for their work. Refer to specific scopes of work for contractors that will be required to provide all temporary power and lighting for the duration of their work.
35. Each contractor shall provide scaffolding, hoists, lifts, cranes, and other means of access for own work.
36. Premium cost for shutdowns or any other off-hour work. All shutdowns must be scheduled at least two (2) weeks in advance.
37. Phasing and remobilization per the project schedule and as required to properly coordinate and complete the work.
38. Field measurements and verification of existing conditions.
39. Temporary weather and dust protection for own work.
40. Perform any snow removal for access to your work, beyond road areas normally maintained by State.
41. Compliance with local noise restrictions.
42. Temporary sheeting, shoring & bracing as required to perform this work. Engineering calculations/PE certifications if specified.
43. Submittals and mock-ups as specified.
44. Warrantees as specified commencing on date of substantial completion.
45. Insurance as required by specifications. Maintain throughout project. Professional liability insurance for any design/engineering work.
46. All applicable sales, use & excise taxes.

47. Surface preparation and inspection for proper installation of the work. Include clean-up, etching, flash patching, moisture testing, etc. as required per specification and manufacturers instructions. Commencement of work shall constitute acceptance of the substrate as suitable for this work.
48. Sleeves, inserts, and anchors for this work.
49. Additional reinforcement/supports for this work which is not detailed on the architectural and structural drawings.
50. Comply with all Whiting-Turner and Owner Quality Control Program requirements for this work.
51. The contractor must have on site at all times during own work a supervisor or foreman responsible to coordinate the work with all other trades to meet the project schedule, to perform the work to meet the contract documents and to effectively communicate with the construction manager and other trades. The decision of that individual shall be binding upon the contractor.
52. Attendance at foreman meetings by the supervisor or foreman is mandatory.
53. Attendance at progress meetings by your project manager is mandatory. Meetings may be tape recorded.
54. After bids are received, contractors will need to attend a scope review meeting with Whiting-Turner, the Owner, and the Architect.
55. The successful contractor must forward Whiting-Turner a copy of their safety program.
56. During this project, hot work permits will need to be obtained from Whiting-Turner prior to proceeding with any such work on a daily basis.
57. All contractors are responsible for their work as shown on any and all drawings.
58. Each contractor must have a line item on their invoice schedule of values that allows 3% of the total contract amount for close-out documents (as-builts, warranties, operations and maintenance manuals, punchlists, etc.) in addition to 5% retention.
59. Building or site commissioning is to be performed separately from owner training.
60. All subcontractor foremen and project manager are required to remain as such throughout the duration of the project unless otherwise approved by WT and RCCSD.
61. The following documents will be required at project start-up and need to be submitted with-in two weeks of the notice to proceed:
 - A. Fully executed Contract.
 - B. Copy of State of DE Business License
 - C. Insurance Certificate indicating coverage and limits, as specified in Contract Documents.
 - D. Permits or permit filing receipts as required by the contract documents, New Castle County, State of Delaware or any other regulatory agencies having jurisdiction. (Building permit is by CM)
 - E. Payment Bond and Performance Bond
 - F. Emergency Telephone Numbers for project manager and foremen
 - G. MSDS Information
 - H. Attendance of Onsite Safety Orientation
 - I. Copy of Written Safety program and policy
 - J. List of all applicable labor rates
 - K. Detailed Schedule for the work
 - L. Schedule of Values for invoicing
 - M. Subcontractor List
 - N. Supplier List
62. The following documents (other than submittals) will be required prior to billing for the close-out documents.
 - A. Signed-off copy of the punchlist.
 - B. Attic stock delivery confirmation (if required by the specifications)
 - C. As-built Drawings
 - D. Testing Reports and/or Equipment Start-up reports
 - E. Operation and Maintenance Manuals

- F. Owner Training Sessions & video tapes as specified.
- G. Standard Guarantee/Warranty for this Trade Contractor and subcontractors (attached)
- H. Specific Warranties from individual suppliers or manufacturers
- I. Affidavit that all taxes have been paid
- J. AIA Document G706 – Affidavit of Payment of Debts and Claims (Original available from AIA)
- K. AIA Document G706A – Affidavit of Release of Liens (Original available from AIA)
 - Complete and attach the ‘Trade Contractor’s Final Release and Affidavit’
 - Complete and attach the ‘Final Waiver and Release for Second Tier subcontractors and suppliers’ (1 needed from each subcontractor / supplier utilized.)
- L. AIA Document G707, Consent of Surety of Final Payment (Original available from AIA)

END OF SECTION 011200-01A

SECTION 011200-23C – SPECIFIC SCOPE OF WORK – AUTOMATIC TEMPERATURE CONTROLS

SPECIFIC SCOPE – AUTOMATIC TEMPERATURE CONTROLS:

- A. The provisions outlined in the General Scope of Work shall apply to all items of this section. All work shall be in accordance with the schedule.
- B. This work shall include all labor, supervision, material, tools, equipment, shop drawings, submittals, layout, unloading, scaffolding, ladders, hoisting, transportation, taxes, permits, engineering, support functions, insurance, bonds, and any other items or services necessary for and reasonably incidental to the proper execution and completion of the work, whether temporary or permanent, in accordance with all drawings, specifications, addenda, general conditions, requirements, and other related documents as indicated herein. All work shall be furnished and installed unless noted otherwise herein. The scope of work shall include but not be limited to the following specific scope of work:

SPECIFICATION SECTIONS

Prepared by Becker Morgan Group, dated September 9, 2013:

Volume 1: Divisions 00 – 01

Volume 2: Divisions 02 – 14

Volume 3: Divisions 21 – 33

The contractor is fully responsible for the technical specification sections as listed below for this Unit of Work. The exception to this is when the note “As Applicable” follows a technical specification section. In that case, other units of work, as defined by the Scope, may also have some responsibility for that particular section. General Conditions, Supplementary Conditions, General Requirements and General Scope Items apply to each and all of the Individual Units of Work.

Section	Description	Responsibility
Division 00	Bidding and Contract Requirements	In Its Entirety
Division 01	General Requirements	In Its Entirety
Division 22	Plumbing	As Applicable
Division 23	HVAC	As Applicable
230800	Commissioning of HVAC	As Applicable
230913	Instrumentation and Control Devices for HVAC	In Its Entirety
230923	Direct Digital Control System for HVAC	In Its Entirety
230993	Sequence of Operations for HVAC Controls	In Its Entirety
Division 26	Electrical	As Applicable

NARRATIVE:

1. Include the cost of performance and payment bonds in the base bid.
2. This contractor shall provide all design, engineering and certifications as required for this work.
3. Daily Cleanup of debris. If this contractor does not clean the site to the satisfaction of Whiting Turner, Whiting Turner reserves the right to clean the site with their own forces at the expense of this contractor. Site must be maintained and cleaned daily.
4. All trucks are required to clean their tires prior to leaving the project site.
5. This contractor is responsible for all fall protection and safety requirements associated with roof work. When working from either lifts and harnesses, or tie-offs provided by this Contractor, OSHA and Whiting-Turner standards must be met and followed at all times.

6. Provide complete automatic temperature control system per drawings and specifications. Include all wiring and conduit as required.
7. Provide labels and tags for all devices and equipment.
8. Perform start-up and commissioning of all equipment.
9. Patch piping or duct insulation damaged as a result of this work.
10. Perform owner training of all equipment and systems.
11. Provide all computers and software as specified.
12. Provide all motor-operated dampers, control valves, thermostats, sensors, etc.
13. Coordinate power requirements with electrical contractor.
14. Review mechanical equipment submittals to provide proper system functionality.
15. All controls for VRF system and equipment are by others. This contractor shall connect to VRF controllers and provide interface with VRF system as specified. This contractor to provide complete automatic temperature controls for all other equipment.
16. ATC system shall communicate and function with district-wide head-end system provided and maintained by others

ALLOWANCES

Include the following allowances in the base bid. They will be billed against on a time and material basis during the project with labor rates and unit prices that will include the allowable overhead and profit. Any unused portion will be credited from the contract. The allowances can be used for another purpose at the discretion of the CM at any time:

1. None.

ALTERNATES

Insert the following alternate prices into the spaces provided on the bid form.

ALTERNATE NO. 1A: Provide Multi-Purpose Room. Provide construction for multi-purpose room as indicated on A110 series drawings, all disciplines.

UNIT PRICES

None.

SECTION 012300 - ALTERNATES

PART 1 - GENERAL

1.1 RELATED DOCUMENTS

- A. Drawings and general provisions of the Contract, including General and Supplementary Conditions and other Division 01 Specification Sections, apply to this Section.

1.2 SUMMARY

- A. Section includes administrative and procedural requirements for alternates.

1.3 DEFINITIONS

- A. Alternate: An amount proposed by bidders and stated on the Bid Form for certain work defined in the bidding requirements that may be added to or deducted from the base bid amount if Owner decides to accept a corresponding change either in the amount of construction to be completed or in the products, materials, equipment, systems, or installation methods described in the Contract Documents.
 - 1. Alternates described in this Section are part of the Work only if enumerated in the Agreement.
 - 2. The cost or credit for each alternate is the net addition to or deduction from the Contract Sum to incorporate alternate into the Work. No other adjustments are made to the Contract Sum.

1.4 PROCEDURES

- A. Coordination: Revise or adjust affected adjacent work as necessary to completely integrate work of the alternate into Project.
 - 1. Include as part of each alternate, miscellaneous devices, accessory objects, and similar items incidental to or required for a complete installation whether or not indicated as part of alternate.
- B. Notification: Immediately following award of the Contract, notify each party involved, in writing, of the status of each alternate. Indicate if alternates have been accepted, rejected, or deferred for later consideration. Include a complete description of negotiated revisions to alternates.
- C. Execute accepted alternates under the same conditions as other work of the Contract.
- D. Schedule: A schedule of alternates is included at the end of this Section. Specification Sections referenced in schedule contain requirements for materials necessary to achieve the work described under each alternate.

PART 2 - PRODUCTS (Not Used)

PART 3 - EXECUTION

3.1 SCHEDULE OF ALTERNATES

A. Alternate No. 1: Multipurpose Room A120

1. Base Bid: Provide construction indicated in area framed by column lines B5 to B6 and BQ to BS indicated on 101A series drawings, all disciplines.
2. Alternate 1A: Provide construction indicated on drawing A110 and related drawings by all disciplines. Work includes concrete footings, slab-on-grade, masonry, steel, carpentry, roofing, caulking, spray foam insulation, doors/frames/hardware, windows, studs and drywall, vinyl composition tile flooring, epoxy flooring, acoustical ceilings, rubber base, painting, specialties, manual roller shades, casework, sprinkler system, plumbing, HVAC, electrical and special systems.
3. Alternate 1B: Delete vinyl composition tile flooring. Provide resilient quartz tile flooring as specified in Section 096519 Resilient Tile Flooring.
4. Alternate 1C: Delete vinyl composition tile flooring. Provide rubber tile flooring as specified in Section 096519 Resilient Tile Flooring.

B. Alternate No. 2: Second Floor Flex Space D200B

1. Base Bid: Provide construction indicated in area framed by column lines D2 to D6 and DF to DJ indicated on 102D series drawings, all disciplines.
2. Alternate 2A: Provide construction indicated on drawing A111 and related drawings by all disciplines. Work includes concrete slab-on-deck, masonry, steel, carpentry, roofing, caulking, spray foam insulation, doors/frames/hardware, windows, studs and drywall, vinyl composition tile flooring, acoustical ceilings, rubber base, painting, manual roller shades, sprinkler system, HVAC, electrical and special systems.
3. Alternate 2B: Delete vinyl composition tile flooring. Provide resilient quartz tile flooring as specified in Section 096519 Resilient Tile Flooring.
4. Alternate 2C: Delete vinyl composition tile flooring. Provide rubber tile flooring as specified in Section 096519 Resilient Tile Flooring.

C. Alternate No. 3: Athletic Field Grading and Parking

1. Base Bid: Do not provide play field grading and seeding, or the pavement, curbing, striping, catch basins and storm drain piping for the 19 adjacent parking spaces indicated on drawing C202, C302 and C402. Proposed curbing on south side of entrance road shall be terminated at the beginning of the proposed parking spaces.
2. Alternate 3: Provide play field grading and seeding, and the pavement, curbing, striping, catch basins and storm drain piping for the 19 adjacent parking spaces indicated on drawing C202, C302 and C402.

- D. Alternate No. 4: Metal Standing Seam Roofing System at Gymnasium/Student Dining.
1. Base Bid: Provide EPDM roofing system with ½" per 12" slope as indicated on drawing A103 and specified in Section 075323 Ethylene-Propylene-Diene-Monomer (EPDM) Roofing.
 2. Alternate 4: Delete EPDM roofing system. Provide metal standing seam roofing system as specified in Section 074113 Standing Seam Roof Panels and detailed on drawings.
- E. Alternate No. 5: Revised Flooring in Corridors
1. Base Bid: Provide vinyl composition floor tile in Corridors A100E, B100, C100B, C100C, C100D, D100, C200 and D200 as specified in Section 096519 Resilient Tile Flooring and indicated on A106 and A107 series drawings.
 2. Alternate 5A: Delete vinyl composition floor tile flooring in Corridors A100E, B100, C100B, C100C, C100D, D100, C200 and D200. Provide resilient quartz tile flooring as specified in Section 096519 Resilient Tile Flooring and indicated on series A106 and A107 drawings.
 3. Alternate 5B: Delete vinyl composition floor Tile flooring: Provide rubber tile flooring as specified in Section 096519 Resilient Tile Flooring and indicated on series A106 and A107 drawings.
- F. Alternate No. 6: Revised Flooring in Kindergarten, First, Second, Third, Fourth and Fifth Grade Classrooms
1. Base Bid: Provide vinyl composition floor tile flooring as specified in Section 096519 Resilient Tile Flooring and indicated on series A106 and A107 drawings.
 2. Alternate 5A: Delete vinyl composition floor tile flooring at all Classrooms. Provide resilient quartz tile flooring in Classrooms as specified in Section 096519 Resilient Tile Flooring and indicated on series A106 and A107 drawings.
 3. Alternate 5B: Delete vinyl composition floor tile flooring at Classrooms: Provide rubber tile flooring as specified in Section 096519 Resilient Tile Flooring and indicated on series A106 and A107 drawings.
- G. Alternate No. 7: Resilient Athletic Flooring at Gymnasium C116 and Student Dining C114
1. Base Bid: Provide vinyl composition floor tile flooring as specified in Section 096519 Resilient Tile Flooring and indicated on drawing A106C.
 2. Alternate 7: Delete vinyl composition floor tile. Provide Resilient Athletic Flooring as specified in Section 096566 Resilient Athletic Flooring.
- H. Alternate No. 8: Terrazzo at Main Lobby A100, Corridor A100C and Stair C100A.
1. Base Bid: Provide resilient quartz tile flooring as specified in Section 096519 Resilient Tile Flooring.
 2. Alternate 8: Delete resilient quartz tile flooring at Lobby A100, Corridor A100C and Stair C100A. Provide terrazzo flooring as specified in Section 096623 Resinous Matrix Terrazzo Flooring. Provide State of Delaware Map at floor center. See drawing A106A for floor pattern and graphic.
 3. Alternate 8A: Delete resilient quartz tile flooring at Lobby A100, Corridor A100C and Stair C100A. Provide solid color stained concrete floor.

I. Alternate No. 9: Sheet Metal Ductwork

1. Base Bid: Provide KoolDuct fabricated ductwork system at all concealed ductwork locations as specified in Section 233100 HVAC Ducts and Casing. Provide metal ductwork system at all exposed ductwork areas: Stair C100A, Media Center A115, Gymnasium C116, Student Dining C114, Music C123 and Art C125.
2. Alternate 9: Delete KoolDuct. Provide sheet metal ductwork at all concealed ductwork locations as specified in Section 233100 HVAC Ducts and Casings and indicated on mechanical plans.

J. Alternate No. 10: LED Site Lighting

1. Base Bid: Provide HID Site Lighting as indicated on drawings E000 and E700 and specified in Section 265600 Exterior Lighting.
2. Alternate 10: Provide LED Site Lighting as indicated on drawing E000 and E700 and specified in Section 265600 Exterior Lighting.

K. Alternate No. 11: Interior Stone Veneer at Main Stair

1. Base Bid: Provide metal wall panels at east wall of Stair C100A.
2. Alternate 11: Delete metal wall panels at east wall of Stair C100A. Provide interior stone veneer as specified in Section 047000 Architectural Stone Veneer.

L. Alternate No. 12: Stand-By Natural Gas-Fired Emergency Generator

1. Base Bid: No Emergency Generator.
2. Alternate 12: Provide Emergency Generator and concrete pad as specified in Section 263213 Engine Generators and Section 263600 Transfer Switches, and indicated by Note UE-2 on drawing C301 and details on drawings E500, E700 and EP101C.

M. Alternate No. 13: Additional Visual Display Surfaces in Classrooms

1. Base Bid: Provide only 5' high by 16' wide magnetic marker board at primary instruction wall at each Classroom as specified in Section 101100 Visual Display Surfaces and indicated on A106 and A107 series Finish Plans and Interior Elevations.
2. Alternate 13: Provide additional 4' high by 4' wide magnetic marker board and 4' high by 4' wide tack board at secondary instruction walls at all Kindergarten and 1st Grade Classrooms. Provide additional 4' high by 8' wide magnetic marker board and 4' high by 4' wide tack board at secondary instruction walls at all 2nd, 3rd, 4th, and 5th Grade Classrooms as specified in Section 101100 Visual Display Surfaces and indicated on A106 and A107 Finish Plans and Interior Elevations.

N. Alternate No. 14: Multi-Hue Exterior Flat Metal Accent Panels

1. Base Bid: Provide 3 colors for flat metal panels type MWP-2 specified in Section 074213 Metal Wall Panels and indicated on drawings.
2. Alternate 14: Provide 9 colors - 3 hues per 3 colors – for flat metal panels type MWP-2 specified in Section 074213 Metal Wall Panels and indicated on drawings. See details on drawing A203.

O. Alternate No. 15: Decorative Glazed CMU Base at Lockers

1. Base Bid: Provide decorative glazed CMU base at CMU walls in Corridors as specified in Section 042000 Unit Masonry. At all other locations provide metal legs and base plates at lockers as specified in Section 105113 Metal Lockers and detailed on drawings.
2. Alternate 15: Delete metal legs and base plates at lockers in Corridors. Provide concrete curbs and 4" high decorative glazed CMU base as specified in Section 042000 Unit Masonry and detailed on drawings.

END OF SECTION 012300

SECTION 012500 – CONTRACT MODIFICATION PROCEDURES

PART 1 - GENERAL

1.1 SUMMARY

- A. This Section specifies administrative and procedural requirements for handling and processing Contract modifications.

1.2 MINOR CHANGES IN THE WORK

- A. Architect will issue supplemental instructions authorizing Minor Changes in the Work, not involving adjustment to the Contract Sum or the Contract Time, on AIA Document G710, "Architect's Supplemental Instructions" or comparable form.

1.3 PROPOSAL REQUESTS

- A. Owner-Initiated Proposal Requests: Construction Manager will issue a detailed description of proposed changes in the Work that may require adjustment to the Contract Sum or the Contract Time. If necessary, the description will include supplemental or revised Drawings and Specifications.
 - 1. Proposal Requests issued by Construction Manager are for information only. Do not consider them instructions either to stop work in progress or to execute the proposed change.
 - 2. Within time specified in Proposal Request after receipt of Proposal Request, submit a quotation estimating cost adjustments to the Contract Sum and the Contract Time necessary to execute the change.
 - a. Include a list of quantities of products required or eliminated and unit costs, with total amount of purchases and credits to be made. If requested, furnish survey data to substantiate quantities.
 - b. Indicate applicable taxes, delivery charges, equipment rental, and amounts of trade discounts.
 - c. Include costs of labor and supervision directly attributable to the change.
 - d. Include an updated Contractor's Construction Schedule that indicates the effect of the change, including, but not limited to, changes in activity duration, start and finish times, and activity relationship. Use available total float before requesting an extension of the Contract Time.
- B. Contractor-Initiated Proposals: If latent or unforeseen conditions require modifications to the Contract, Contractor may propose changes by submitting a request for a change to Construction Manager.
 - 1. Include a statement outlining reasons for the change and the effect of the change on the Work. Provide a complete description of the proposed change. Indicate the effect of the proposed change on the Contract Sum and the Contract Time.
 - 2. Include a list of quantities of products required or eliminated and unit costs, with total amount of purchases and credits to be made. If requested, furnish survey data to substantiate quantities.
 - 3. Indicate applicable taxes, delivery charges, equipment rental, and amounts of trade discounts.
 - 4. Include costs of labor and supervision directly attributable to the change.
 - 5. Include an updated Contractor's Construction Schedule that indicates the effect of the change, including, but not limited to, changes in activity duration, start and finish times, and activity relationship. Use available total float before requesting an extension of the Contract Time.
 - 6. Comply with requirements in Division 1 Section "Product Requirements" if the proposed change requires substitution of one product or system for product or system specified.

- C. Proposal Request Form: Use AIA Document G709 or approved comparable forms for Proposal Requests.

1.4 CHANGE ORDER PROCEDURES

- A. On Owner's approval of a Proposal Request, Architect will issue a Change Order for signatures of Owner and Contractor on AIA Document G701.

1.5 CONSTRUCTION CHANGE DIRECTIVE

- A. Construction Change Directive: Construction Manager may issue a Construction Change Directive on AIA Document G714. Construction Change Directive instructs Contractor to proceed with a change in the Work, for subsequent inclusion in a Change Order.
 - 1. Construction Change Directive contains a complete description of change in the Work. It also designates method to be followed to determine change in the Contract Sum or the Contract Time.
- B. Documentation: Maintain detailed records on a time and material basis of work required by the Construction Change Directive.
 - 1. After completion of change, submit an itemized account and supporting data necessary to substantiate cost and time adjustments to the Contract.

PART 2 - PRODUCTS (Not Used)

PART 3 - EXECUTION (Not Used)

END OF SECTION 012500

SECTION 012550 - SUBSTITUTION PROCEDURES

PART 1 - GENERAL

1.1 RELATED DOCUMENTS

- A. Drawings and general provisions of the Contract, including General and Supplementary Conditions and other Division 01 Specification Sections, apply to this Section.

1.2 SUMMARY

- A. Section includes administrative and procedural requirements for substitutions.
- B. Related Requirements:
 - 1. Section 012300 "Alternates" for products selected under an alternate.
 - 2. Section 016000 "Product Requirements" for requirements for submitting comparable product submittals for products by listed manufacturers.

1.3 DEFINITIONS

- A. Substitutions: Changes in products, materials, equipment, and methods of construction from those required by the Contract Documents and proposed by Contractor.
 - 1. Substitutions for Cause: Changes proposed by Contractor that are required due to changed Project conditions, such as unavailability of product, regulatory changes, or unavailability of required warranty terms.
 - 2. Substitutions for Convenience: Changes proposed by Contractor or Owner that are not required in order to meet other Project requirements but may offer advantage to Contractor or Owner.

1.4 ACTION SUBMITTALS

- A. Substitution Requests: Submit three copies of each request for consideration. Identify product or fabrication or installation method to be replaced. Include Specification Section number and title and Drawing numbers and titles.
 - 1. Substitution Request Form: Use CSI Form 13.1A.
 - 2. Documentation: Show compliance with requirements for substitutions and the following, as applicable:
 - a. Statement indicating why specified product or fabrication or installation cannot be provided, if applicable.
 - b. Coordination information, including a list of changes or revisions needed to other parts of the Work and to construction performed by Owner and separate Contractors that will be necessary to accommodate proposed substitution.

- c. Detailed comparison of significant qualities of proposed substitution with those of the Work specified. Include annotated copy of applicable Specification Section. Significant qualities may include attributes such as performance, weight, size, durability, visual effect, sustainable design characteristics, warranties, and specific features and requirements indicated. Indicate deviations, if any, from the Work specified.
 - d. Product Data, including drawings and descriptions of products and fabrication and installation procedures.
 - e. Samples, where applicable or requested.
 - f. Certificates and qualification data, where applicable or requested.
 - g. List of similar installations for completed projects with project names and addresses and names and addresses of architects and owners.
 - h. Material test reports from a qualified testing agency indicating and interpreting test results for compliance with requirements indicated.
 - i. Research reports evidencing compliance with building code in effect for Project, from ICC-ES.
 - j. Detailed comparison of Contractor's construction schedule using proposed substitution with products specified for the Work, including effect on the overall Contract Time. If specified product or method of construction cannot be provided within the Contract Time, include letter from manufacturer, on manufacturer's letterhead, stating date of receipt of purchase order, lack of availability, or delays in delivery.
 - k. Cost information, including a proposal of change, if any, in the Contract Sum.
 - l. Contractor's certification that proposed substitution complies with requirements in the Contract Documents except as indicated in substitution request, is compatible with related materials, and is appropriate for applications indicated.
 - m. Contractor's waiver of rights to additional payment or time that may subsequently become necessary because of failure of proposed substitution to produce indicated results.
3. Architect's Action: If necessary, Architect will request additional information or documentation for evaluation within seven days of receipt of a request for substitution. Architect will notify Contractor of acceptance or rejection of proposed substitution within 15 days of receipt of request, or seven days of receipt of additional information or documentation, whichever is later.
- a. Forms of Acceptance: Change Order, Construction Change Directive, or Architect's Supplemental Instructions for minor changes in the Work.
 - b. Use product specified if Architect does not issue a decision on use of a proposed substitution within time allocated.

1.5 QUALITY ASSURANCE

- A. Compatibility of Substitutions: Investigate and document compatibility of proposed substitution with related products and materials. Engage a qualified testing agency to perform compatibility tests recommended by manufacturers.

1.6 PROCEDURES

- A. Coordination: Revise or adjust affected work as necessary to integrate work of the approved substitutions.

PART 2 - PRODUCTS

2.1 SUBSTITUTIONS

- A. Substitutions for Cause: Submit requests for substitution immediately on discovery of need for change, but not later than 15 days prior to time required for preparation and review of related submittals.
 - 1. Conditions: Architect will consider Contractor's request for substitution when the following conditions are satisfied. If the following conditions are not satisfied, Architect will return requests without action, except to record noncompliance with these requirements:
 - a. Requested substitution is consistent with the Contract Documents and will produce indicated results.
 - b. Requested substitution provides sustainable design characteristics that specified product provided for achieving LEED prerequisites and credits.
 - c. Substitution request is fully documented and properly submitted.
 - d. Requested substitution will not adversely affect Contractor's construction schedule.
 - e. Requested substitution has received necessary approvals of authorities having jurisdiction.
 - f. Requested substitution is compatible with other portions of the Work.
 - g. Requested substitution has been coordinated with other portions of the Work.
 - h. Requested substitution provides specified warranty.
 - i. If requested substitution involves more than one contractor, requested substitution has been coordinated with other portions of the Work, is uniform and consistent, is compatible with other products, and is acceptable to all contractors involved.
- B. Substitutions for Convenience: Not allowed.

PART 3 - EXECUTION (Not Used)

END OF SECTION 012550

SECTION 012650 – CHANGE ORDER REQUEST SUBMISSION FORMAT

The following is a general listing of requirements relating to change order work. Refer to the Contract, General Conditions, Supplementary Conditions, General Scope, and Specification for full requirements.

1. Refer to the Supplementary General Conditions for the Allowable overhead and profit Mark-ups.
2. Any proposed change order / request for the project must be submitted in the format example shown in this specification section.
3. All labor and material costs must be separated with their applicable mark-ups detailed.
4. Whiting-Turner, the Owner, or the Architect may request additional breakdown information, back-up, etc., at their discretion at any time.
5. Each price submitted must include the following:
 - a. Detailed description of the issue.
 - b. Location in the building.
 - c. Reason why it's extra
 - d. Drawing, Specification or other documentation references.
 - e. RFI reference
 - f. Submittal reference
 - g. WT price request reference
6. For price requests or time and material work, obtain approval from the Whiting-Turner project manager in writing prior to proceeding with the extra work.
7. Notify Whiting-Turner in writing immediately (with 24 hours) upon discovering an extra work issue.
8. Any work authorized to proceed on a time and material basis must have the T+M tickets signed daily by Whiting-Turner.
9. Extra work prices or unsigned T+M tickets forwarded after the work is completed will not be accepted.
10. For emergency work that may impact the schedule, verbal cost budgets must be submitted immediately. The work may be authorized to proceed at the Whiting-Turner project manager's and/or owner's discretion.
11. Return extra work price requests in 5 days. Finalize T+M tickets in 5 days.
12. Any item of extra work that cannot be agreed upon at a fixed price will be performed on a time and material basis that is not to exceed an agreed upon budget.

Labor Bill Rates & Change Request Submission Formats

A. Labor Billing Rate Calculation – Example

Base Rate	\$17.40
Fringe Benefits *@% of base rate	<u>8.53</u>
Subtotal Rate	\$25.93
Insurance& taxes ** @% of subtotal rate	<u>9.07</u>
Subtotal - Labor Rate	\$35.00
Overhead & Profit @ 15%***	<u>5.25</u>
Total – Hourly Billing Rate	\$40.25

NOTE:

- * The fringe benefit includes health, welfare or retirement benefits, vacation, holiday or sick leave pay.
- ** The insurance and taxes include employer payment for unemployment insurance, worker's compensation, FICA, Bonds, Gross Receipts, etc.
- *** Allowable mark-up will decrease on a scale based on the total amount of the proposed change. Refer to the supplementary general conditions for additional information. This note is typical for all of the examples above and below.

B. Change Directive Calculation

1. Trade Contractor

Labor Billing Rate\$35/hr x 50 hrs	\$1,750.00
Fee (overhead & profit) @15%***	<u>262.50</u>
Subtotal Labor	\$2,012.50
Material or Equipment	\$2,000.00
Fee (overhead & profit) @15%***	<u>300.00</u>
Subtotal Material	\$2,300.00
Total Costs	\$4,312.50

2. Subcontractor / Trade Contractor

Sub- Labor Billing Rate \$35/hr x 50hrs	\$1,750.00
Fee (sub overhead & profit) @15%***	<u>265.50</u>
Subtotal-Labor	\$2,012.50
Sub-Material or Equipment	\$2,000.00
Fee (sub overhead & profit) @15%***	<u>300.00</u>
Subtotal-Material	\$2,300.00
Total Costs-Subcontractor	\$4,312.50
Fee payable to contractor	
Subcontractor Labor and Material	\$4,312.50
Contractor overhead & profit @ 5%	<u>215.62</u>
Total Costs	\$4,528.12

3. Sub-Subcontractor / Subcontractor / Trade Contractor

Sub-subcon. Labor Billing Rate \$35/hr x 50hrs	\$1,750.00
Fee (overhead & profit) @15%***	<u>262.50</u>
Subtotal- Labor	\$2,012.50
Sub-subcon. Material or Equipment	\$2,000.00
Fee (overhead & profit) @15%***	<u>300.00</u>
Subtotal-Material	\$2,300.00
Total Costs – Sub-subcontractor	\$4,312.50
Fee payable to Sub-Contractor	
Sub-subcontractor Labor and Material	\$4,312.50
Subcontractor overhead & profit @5%	<u>215.63</u>
Total Costs – Subcontractor	\$4,528.13
Fee payable to Trade Contractor	
Subcontractor Labor and Material	\$4,528.13
Contractor overhead & profit @5%	<u>226.41</u>
Total Costs	\$4,754.54

END OF SECTION 012650

SECTION 012900 – PAYMENT PROCEDURES

1. The following documents are included in section 006200:
 - A. AIA Document G732, Application and Certification for Payment, Construction Manager as Advisor Edition
 - B. AIA Document G703, Continuation Sheet
2. A **PENCIL** (Proof) copy of the proposed Application for Payment must be submitted by the 20TH of the month to the WT Project Manager.
3. Upon approval of the Pencil copy by the WT Project Manager, the **ORIGINAL** Application for Payment must be submitted by the 25TH of the month to:
The Whiting-Turner Contracting Company
131 Continental Drive, Suite 404
Newark, DE 19713.
Faxed copies are NOT acceptable.
4. Typical errors on invoice submissions are as follows. Please review this list prior to submitting your invoice. Invoices with errors will be returned. Typical errors:
 - A. AIA forms used must be the correct documents.
 - B. AIA forms must be original documents, not copies.
 - C. Invoice should reference the School District's Purchase Order number.
 - D. Math is incorrect.
 - E. Invoice is not notarized .
 - F. Schedule of Values needs to be approved in advance prior to submission of invoice. It should be broken down by phases, floors, areas, systems, materials, labor, allowances, alternates, etc.
 - G. Schedule of Values must list a line item for close-out documents: (As-Built, Warranties, Operations and Maintenance Manuals, Training Sessions, AIA close-out documents, etc.)
 - i. \$2,500 minimum, OR
 - ii. 1% of total contract amount, which ever is greater.
 - H. Retainage amount is incorrect. Should be 5%.
 - I. Amount billed does not match work in place on site (obtain WT's prior approval)
 - J. Invoice is addressed improperly, should be addressed to:
Red Clay Consolidated School District
1502 Spruce Avenue
Wilmington, DE 19805
(But delivered to Whiting-Turner)
 - K. Insurance certificate has expired. Current insurance must be on file.
 - L. Trade Contractor's Partial Release of Liens not attached.
 - M. Invoice is billing for stored materials, copies of shipping receipts, invoices, and an insurance certificate for the building which houses the materials must be attached.
 - N. Invoice is billing for extra work that has not yet appeared on an AIA G701 Change Order.
 - O. Second tier Contractors / Suppliers Partial Release not attached .
 - P. Daily field reports or Safety meeting minutes have not been forwarded to the WT superintendent.
 - Q. Copies of Certified payroll reports have not been submitted.
 - R. Punchlist is not complete (applicable at end of project).
 - S. Close out documents not received or incomplete (applicable at end of project).

END OF SECTION 012900

PAYMENT PROCEDURES

012900 - 1

SECTION 013100 – PROJECT MANAGEMENT AND COORDINATION

PART 1 - GENERAL

1.1 SUMMARY

- A. This Section includes administrative provisions for coordinating construction operations on Project including, but not limited to, the following:
 - 1. Coordination Drawings.
 - 2. Project meetings.
- B. See Division 1 Section "Execution Requirements" for procedures for coordinating general installation and field-engineering services, including establishment of benchmarks and control points.

1.2 COORDINATION

- A. Coordination: Coordinate construction operations included in different Sections of the Specifications to ensure efficient and orderly installation of each part of the Work. Coordinate construction operations, included in different Sections that depend on each other for proper installation, connection, and operation.
 - 1. Schedule construction operations in sequence required to obtain the best results where installation of one part of the Work depends on installation of other components, before or after its own installation.
 - 2. Coordinate installation of different components with other contractors to ensure maximum accessibility for required maintenance, service, and repair.
 - 3. Make adequate provisions to accommodate items scheduled for later installation.
 - 4. Where availability of space is limited, coordinate installation of different components to ensure maximum performance and accessibility for required maintenance, service, and repair of all components, including mechanical and electrical.
- B. Administrative Procedures: Coordinate scheduling and timing of required administrative procedures with other construction activities and activities of other contractors to avoid conflicts and to ensure orderly progress of the Work. Such administrative activities include, but are not limited to, the following:
 - 1. Preparation of Contractor's Construction Schedule.
 - 2. Preparation of the Schedule of Values.
 - 3. Installation and removal of temporary facilities and controls.
 - 4. Delivery and processing of submittals.
 - 5. Progress meetings.
 - 6. Pre-installation conferences.
 - 7. Project closeout activities.
 - 8. Startup and adjustment of systems.
 - 9. Project closeout activities.

1.3 SUBMITTALS

- A. Coordination Drawings: Prepare Coordination Drawings if limited space availability necessitates maximum utilization of space for efficient installation of different components or if coordination is required for installation of products and materials fabricated by separate entities.
1. Content: Project-specific information, drawn accurately to scale. Do not base Coordination Drawings on reproductions of the Contract Documents or standard printed data. Include the following information, as applicable:
 - a. Indicate functional and spatial relationships of components of architectural, structural, civil, mechanical, and electrical systems.
 - b. Indicate dimensions shown on the Contract Drawings and make specific note of dimensions that appear to be in conflict with submitted equipment and minimum clearance requirements. Provide alternate sketches to Architect for resolution of such conflicts. Minor dimension changes and difficult installations will not be considered changes to the Contract.
 2. Sheet Size: At least 8-1/2 by 11 inches but no larger than 30 by 40 inches.
 3. Number of Copies: Submit three opaque copies of each submittal. Architect will return one copy.
 4. Refer to individual Sections for Coordination Drawing requirements for Work in those Sections.

1.4 PROJECT MEETINGS

- A. General: Coordinate, schedule and conduct meetings and conferences at Project site with the Construction Manager.
1. Attendees: Inform participants and others involved, and individuals whose presence is required, of date and time of each meeting. Notify Construction Manager, Owner and Architect of scheduled meeting dates and times.
 2. Agenda: Prepare the meeting agenda. Distribute the agenda to all invited attendees.
 3. Minutes: Record significant discussions and agreements achieved. Distribute the meeting minutes to everyone concerned, including Construction Manager, Owner and Architect, within three days of the meeting.
- B. Pre-installation Conferences: Conduct a pre-installation conference at Project site before each construction activity that requires coordination with other construction.
1. Attendees: Installer and representatives of manufacturers and fabricators involved in or affected by the installation and its coordination or integration with other materials and installations that have preceded or will follow, shall attend the meeting. Advise Construction Manager and Architect of scheduled meeting dates.
 2. Agenda: Review progress of other construction activities and preparations for the particular activity under consideration, including requirements for the following:
 - a. The Contract Documents.
 - b. Options.
 - c. Related requests for interpretations (RFIs).
 - d. Related Change Orders.
 - e. Purchases.
 - f. Deliveries.
 - g. Submittals.
 - h. Review of mockups.
 - i. Possible conflicts.

- j. Compatibility problems.
 - k. Time schedules.
 - l. Weather limitations.
 - m. Manufacturer's written recommendations.
 - n. Warranty requirements.
 - o. Compatibility of materials.
 - p. Acceptability of substrates.
 - q. Temporary facilities and controls.
 - r. Space and access limitations.
 - s. Regulations of authorities having jurisdiction.
 - t. Testing and inspecting requirements.
 - u. Installation procedures.
 - v. Coordination with other work.
 - w. Required performance results.
 - x. Protection of adjacent work.
 - y. Protection of construction and personnel.
3. Record significant conference discussions, agreements, and disagreements, including required corrective measures and actions.
 4. Reporting: Distribute minutes of the meeting to each party present and to parties who should have been present.
 5. Do not proceed with installation if the conference cannot be successfully concluded. Initiate whatever actions are necessary to resolve impediments to performance of the Work and reconvene the conference at earliest feasible date.
- C. Progress Meetings: Conduct progress meetings at regular intervals. Coordinate dates of meetings with preparation of payment requests.
1. Attendees: In addition to representatives of Construction Manager, Owner and Architect, each contractor, subcontractor, supplier, and other entity concerned with current progress or involved in planning, coordination, or performance of future activities shall be represented at these meetings. All participants at the conference shall be familiar with Project and authorized to conclude matters relating to the Work.
 2. Agenda: Review and correct or approve minutes of previous progress meeting. Review other items of significance that could affect progress. Include topics for discussion as appropriate to status of Project.
 - a. Contractor's Construction Schedule: Review progress since the last meeting. Determine whether each activity is on time, ahead of schedule, or behind schedule, in relation to Contractor's Construction Schedule. Provide digital and hard copies of the construction schedule to the Construction Manager on a monthly basis unless indicated otherwise within the Construction Documents.
 - b. Determine how construction behind schedule will be expedited; secure commitments from parties involved to do so. Discuss whether schedule revisions are required to ensure that current and subsequent activities will be completed within the Contract Time.
 - 1) Review schedule for next period.
 - c. Review present and future needs of each entity present, including the following:
 - 1) Interface requirements.
 - 2) Sequence of operations.
 - 3) Status of submittals.
 - 4) Deliveries.
 - 5) Off-site fabrication.

- 6) Access.
 - 7) Site utilization.
 - 8) Temporary facilities and controls.
 - 9) Work hours.
 - 10) Hazards and risks.
 - 11) Progress cleaning.
 - 12) Quality and work standards.
 - 13) Status of correction of deficient items.
 - 14) Field observations.
 - 15) Requests for interpretations (RFIs).
 - 16) Status of proposal requests.
 - 17) Pending changes.
 - 18) Status of Change Orders.
 - 19) Pending claims and disputes.
 - 20) Documentation of information for payment requests.
3. Minutes: Record the meeting minutes.
 4. Reporting: Distribute minutes of the meeting to each party present and to parties who should have been present.
 - a. Schedule Updating: Revise Contractor's Construction Schedule after each progress meeting where revisions to the schedule have been made or recognized. Issue revised schedule concurrently with the report of each meeting.

PART 2 - PRODUCTS (Not Used)

PART 3 - EXECUTION (Not Used)

END OF SECTION 013100

SECTION 013110 – PROJECT COORDINATION

1.01 PROJECT COORDINATION

- A. Every Trade Contractor shall be responsible for the coordination of the progress of their work with the progress of all other Trade Contractor's work.
- B. Inasmuch as Project completion within the time limit is dependent upon cooperation of those engaged therein, it is imperative that each Trade Contractor perform his work at such time and in such a manner as not to delay or otherwise interfere with work progress of other Trade Contractors. If any Trade Contractor's work depends upon proper execution or results of another Trade Contractor's work, the former shall inspect the work and report any defects therein to the Construction Manager.
- C. Trade Contractors shall afford each other every reasonable opportunity for installation of their work, and shall work in conjunction with each other in order to facilitate proper and intelligent execution of work.
- D. Plans are generally diagrammatic, and each Trade Contractor shall coordinate his work with the work of others, so that interference between mechanical and electrical work and architectural and structural work does not occur. Each Trade Contractor shall furnish and install offsets, bends, turns, and the like in connection with his work to avoid interference with work of other Trade Contractors, to conceal work where required, and to secure necessary clearance and access for operation and maintenance. In case of interference or lack of clearance and access, the Construction Manager will be notified immediately, and shall, in turn, notify the Architect. The Architect will decide which work shall be relocated, regardless of which was installed first.
- E. Systems Coordination Drawings
 - 1. Systems Coordination Drawings are required from the Mechanical, Electrical, Fire Protection, and General Trade Contractors with the lead role assigned to the Mechanical Trade Contractor.
 - 2. The Mechanical Trade Contractor shall prepare 1/4" = 1ft. scale Reproducible Systems Coordination Drawings for all areas with piping and ductwork. At critical areas of coordination (risers/shafts, mechanical, electrical and communications rooms), larger scale drawings may be required as determined by all Trade Contractors. Drawings to indicate spatial relationship of all HVAC piping and ductwork.
 - 3. The Mechanical Trade Contractor shall prepare and submit, to the Construction Manager, a regularly updated schedule indicating the development and review of these drawings with other Trade Contractors. The drawing development and review schedule must follow the project construction schedule.
 - 4. The Mechanical Trade Contractor shall provide the Reproducible Systems Coordination Drawings to other Trade Contractors for their input and review. The routing is as follows: HVAC, Fire Protection, Plumbing, Electrical, and General Works with the drawings being returned to the Mechanical (HVAC) Trade Contractor.

5. Each Trade Contractor will add the work of his Contract on the System Coordination Drawings to avoid interferences. All piping, equipment, light fixtures, sprinkler heads and in-ceiling equipment, such as rolling gates, must be shown on these drawings to include elevations and dimensions. Trade Contractors shall also consider future access for maintenance clearances required around equipment. If there are items on the systems coordination drawings which modify the design of the contract drawings, each Trade Contractor must highlight these areas by clouding, numbering, and referencing them to the affected contract drawings to allow proper review by each Trade Contractor and the Architect/Engineer.
6. Prior to forwarding the Systems Coordination Drawings to the next Trade Contractor, an approval stamp, initialed and dated, should be affixed by the reviewing Trade Contractor. This approval shall signify that the Trade Contractor will install his work accordingly.
7. During the Systems Coordination Drawing process, the Construction Manager will conduct regularly scheduled meetings. Each Trade Contractor is required to attend these meetings. The Construction Manager is responsible for recording and distributing meeting minutes to all Trade Contractor and the Architect/Engineer. The purpose of the meetings will be to review and discuss interferences and conflicts which required modifications to the Systems Coordination Drawings. All resolutions of interferences and conflicts which required modifications, shall be initialed by the appropriate Trade Contractors on the Systems Coordination Drawings. Conflicts that result after the coordination drawings are signed-off will be the responsibility of the Contractor who installed the work improperly. Coordination participants that fail to cooperate in the coordination Drawings effort, will be responsible for all costs incurred for adjustments to the work made necessary to accommodate installations. Coordination drawings shall be updated on a periodic basis and shall reflect all changes. At each meeting, the Trade Contractors will review and update the Systems Coordination Drawing Schedule.
8. Once reviewed and approved by each Trade Contractor, the Mechanical Trade Contractor will prepare the Final Reproducible Systems Coordination Drawings with the work of all trades included. Submit the Reproducible drawings along with five (5) prints to the Construction Manager who will forward to the Architect for his review.
9. The Mechanical Trade Contractor shall indicate any unresolved conflicts or interferences on the Systems Coordination Drawings. Those should be delineated by clouding, number and referencing to the affected contract drawings.
10. The Architect will review and return to the Construction Manager. The Construction Manager will distribute the number of drawings to the Trade Contractors for installation of their work.
11. The Systems Coordination Drawings DO NOT REPLACE ANY SHOP DRAWINGS FABRICATION AND LAYOUT DRAWINGS REQUIRED BY SPECIFICATION SECTIONS.

1.02 FIELD ENGINEERING**A. Inspection:**

1. Each Trade Contractor shall verify locations of survey control points prior to starting work. Promptly notify Construction Manager of any discrepancies discovered.
2. The Trade Contractor shall verify all measurements of the building and shall be responsible for the correctness of same. No extra charge or compensation will be allowed on account of differences between actual dimensions and the measurements indicated on the drawings; any difference which may be found should be submitted to the Architect for consideration before proceeding with the work.

B. Survey Requirements: The Construction Manager shall secure a professional engineer or surveyor licensed in the State of Delaware to perform the following:

1. Verify grades, lines, levels, locations and dimensions as indicated. Report any errors or inconsistencies in the above, before commencing work.
2. Exercise care in laying out work to keep within lot and property lines. Be responsible for encroachments on rights or property of public or surrounding property owners.
3. Locate and layout building or facilities according to the drawings with respect to their location on property and elevation in relation to grade.
4. Provide and maintain well-built batter boards at corners (if applicable). Establish and safeguard benchmarks in at least two (2) widely separated places. As work progresses, establish benchmarks at each level. Give exact levels of various floors.
5. Maintain complete, accurate log of control and survey work as it progresses.

C. Construction Layout:

The Sitework Trade Contractor shall be responsible to perform the layout and elevations required to complete his work.

Each Trade Contractor shall layout the remainder of his own work and be responsible for all lines, levels, grades, elevations, and measurements.

1.03 TESTS

- A.** The Construction Manager has employed and will pay for the services of a testing agency to perform the following tests and inspection (field):

Soil compaction
 Concrete
 Steel
 Masonry

- B. Tests, other than those required by the Specifications to be performed by Construction Manager required by any law, ordinance, rule, regulation or order of any public authority having jurisdiction, shall be made at such time and in such manner as the public authority may require. Each Trade Contractor responsible for that Specification Section shall be solely responsible for such tests.
- C. Special tests may be ordered by the Architect in accordance with the General Conditions. Where specifications require testing by an independent testing laboratory, the Construction Manager shall be responsible for selection of the testing laboratory. The Construction Manager shall be responsible for the scheduling of all tests. Test reports should be given to the Construction Manager with copies for the Owner and Architect/Engineer.
- D. All costs of testing required by the Contract Documents shall be borne by the Trade Contractor except costs of special tests which shall be paid for as stipulated in the General Conditions or Specifications.

1.04 TRADE CONTRACTOR'S OBLIGATIONS

- A. The Trade Contractor must assume all risks and bear any loss occasioned by neglect or accident during the progress of the work until same shall have been completed and accepted by the Owner. The Trade Contractor agrees to indemnify, defend and save harmless the Owner, Architect, and Construction Manager from all suits and losses or injury to persons or property received or sustained from the Trade Contractor or his agents in the performance of the work under the progress of construction and make good all damage that may consequence the work herein specified. He must also assume all blame or loss by reason of neglect or violation of local or state laws, ordinances and regulations, encroachments upon neighbors, or from any other cause.
- B. The work, in every respect, shall be under the care of the Trade Contractor and at his risk. He shall properly safeguard against any or all injury or damage to the public, to any property, materials, or things, except where stipulated otherwise in the Specifications, and also be responsible for any such damage or injury from his undertaking of this work to any person or persons or thing connected therewith. He shall indemnify and save harmless the Owner, Architect, and Construction Manager from all claims, suits, damages, actions of law, in equity or otherwise (including the costs of defense thereof which shall be assumed by the Trade Contractor) or any kind whatsoever in connection with this work and agreement and shall, if required, show evidence of settlement of any such action before final payment is made hereunder by the Owner.

1.05 ALLOCATION OF WORK

- A. Sleeves, Hangers, and Inserts:
 - 1. Each Trade Contractor shall furnish sleeves and inserts required to accommodate his work, together with instructions regarding their placement and location in the structure. Sleeves and inserts shall be furnished promptly in accordance with the established construction schedule so that they may be built-in as construction progresses.

2. Trade Contractors to furnish all embeds, sleeves, inserts, etc., that are to be cast in concrete or built in masonry to the appropriate Trade Contractor for installation.
3. Each Trade Contractor shall furnish and install all hangers required to accommodate his work.

B. Chases and Recesses:

Each Trade Contractor shall provide all blockouts in his work shown on the Contract Documents and having either or both dimensions greater than 10". Any openings with dimensions smaller than 10" or not shown and required by Trade Contractor shall be the responsibility of the Trade Contractor to make provisions for. Each Trade Contractor shall provide chases and recesses as shown on the Contract Documents required to accommodate the work or the other Trade Contractors. It is the responsibility of the Trade Contractors requiring openings, chases, etc., of a Trade Contractor, to furnish information regarding the size and location promptly in accordance with the established construction schedule, so that they may be built-in as construction progresses and avoid delays. Failure to provide the information promptly will result in the responsible Trade Contractor incurring any costs associated with the delay.

Trade Contractors shall cooperate fully with each other in the performance of above work, as cutting and patching of new work is neither contemplated nor will it be tolerated.

C. Sealing of Penetrations:

Each Trade Contractor shall be responsible to seal his own penetrations in walls, floors, and ceilings, using fire resistant materials, as required, to achieve fire ratings as indicated.

D. Equipment Foundations:

The Concrete Contractor shall provide all foundations and housekeeping pads for equipment furnished under his contract and all interior/exterior foundations and housekeeping pads indicated on the Contract Documents (Architectural, Civil, Structural, Mechanical, Plumbing, and Electrical) for equipment provided by other Trade Contractors. All other foundations, equipment, and housekeeping pads not shown, but required, shall be by the Trade Contractor requiring the same.

Each Trade Contractor shall furnish anchor bolts and other accessories required to anchor his equipment in place, together with instructions regarding their placement and location in the foundation. Anchor bolts and other accessories shall be furnished promptly in accordance with the established construction schedule so that they may be built-in as construction progresses.

E. Roofing Penetrations:

All roofing work shall be performed by the Roofing Trade Contractor, including patching penetrations made by the Electrical, Plumbing, and HVAC Trade Contractors. Cutting of roof openings, structural reinforcement, roof curbs, and counterflashing, shall be provided and installed by each Trade Contractor whose work penetrates the roofing surface, including all additional blocking.

1.06 CORING, CUTTING AND PATCHING

A. Responsibility: A Trade Contractor requiring the cutting of openings in new work, or in the existing work installed by others shall have such openings cut and patched by the trade which installed the original work, and such cutting and patching shall be at the expense of the Trade Contractor requiring the opening.

B. Approval: Approval to do such cutting and patching shall be received from the Architect through the Construction Manager prior to proceeding with the work.

C. Inspection:

1. Inspect existing conditions, including elements subject to damage or movement during cutting and patching.
2. After uncovering, inspect conditions affecting performance of work.

D. Preparation:

Provide supports to assure structural integrity of surroundings, devices, and methods, to protect other portions of Project from damage.

Provide protection from elements for areas which may be exposed by uncovering work; maintain excavations free of water.

E. Performance:

Execute work by methods to avoid damage to other work and which provide proper surfaces to receive patching and finishing.

Employ original installer to perform cutting and patching for weather-exposed and moisture-resistant elements and sight-exposed surfaces.

Restore work with new products in accordance with requirements to Contract Documents.

Fit work tightly to pipes, sleeves, ducts, conduit and other penetrations through surfaces.

At penetrations of fire-rated wall, ceiling or floor construction, completely seal voids with fire-resistant materials as required to achieve fire-rating indicated.

Where fire protection materials are damaged or removed, reapply fire protection materials to achieve a rating equivalent to existing construction or as noted.

Refinish surfaces to match adjacent finishes. For continuous surfaces, refinish to nearest intersection; for an assembly, refinish entire unit.

F. Access Doors and Panels

Access doors and panels, SHOWN ON ANY DRAWING, shall be furnished and installed by the Drywall Contractor.

Access doors and panels, NOT SHOWN ON DRAWINGS, but required by the Specifications to access concealed valves, dampers, traps, devices, etc., shall be furnished by the Trade Contractor requiring the same for installation by the Drywall Contractor.

G. Final Cleaning

Final cleaning shall be performed by Construction Manager. Daily cleaning will be by the Trade Contractor(s) and their subcontractor(s).

END OF SECTION 013110

SECTION 013200 – CONSTRUCTION PROGRESS DOCUMENTATION

PART 1 - GENERAL

1.1 SUMMARY

- A. This Section includes administrative and procedural requirements for documenting the progress of construction during performance of the Work, including the following:
 - 1. Construction Schedule.
 - 2. Submittals Schedule.
 - 3. Daily construction reports.
 - 4. Field condition reports.

1.2 SUBMITTALS

- A. Submittals Schedule: Submit three copies of schedule. Arrange the following information in a tabular format:
 - 1. Scheduled date for first submittal.
 - 2. Specification Section number and title.
 - 3. Submittal category (action or informational).
 - 4. Name of subcontractor.
 - 5. Description of the Work covered.
 - 6. Scheduled date for Architect's final release or approval.
- B. Contractor's Construction Schedule: Submit two opaque copies of initial schedule, large enough to show entire schedule for entire construction period and a copy of the digital file on CD.
- C. Daily Construction Reports: Submit two copies at weekly monthly intervals.
- D. Field Condition Reports: Submit two copies at time of discovery of differing conditions.

1.3 COORDINATION

- A. Coordinate preparation and processing of schedules and reports with performance of construction activities and with scheduling and reporting of separate contractors.
- B. Coordinate Contractor's Construction Schedule with the Schedule of Values, list of subcontracts, Submittals Schedule, progress reports, payment requests, and other required schedules and reports.
 - 1. Secure time commitments for performing critical elements of the Work from parties involved.
 - 2. Coordinate each construction activity in the network with other activities and schedule them in proper sequence.

PART 2 - PRODUCTS

2.1 SUBMITTALS SCHEDULE

- A. Preparation: Submit a schedule of submittals to Construction Manager, arranged in chronological order by dates required by construction schedule. Include time required for review, re-submittal, ordering, manufacturing, fabrication, and delivery when establishing dates.
1. Coordinate Submittals Schedule with list of subcontracts, the Schedule of Values, and Contractor's Construction Schedule.
 2. Submit concurrently with the first complete submittal of Contractor's Construction Schedule.

2.2 CONTRACTOR'S CONSTRUCTION SCHEDULE, GENERAL

- A. Time Frame: Extend schedule from date established for commencement of the Work to date of Substantial Completion.
1. Contract completion date shall not be changed by submission of a schedule that shows an early completion date, unless specifically authorized by Change Order.
- B. Activities: Treat each story or separate area as a separate numbered activity for each principal element of the Work. Comply with the following:
1. Activity Duration: Define activities so no activity is longer than 20 days, unless specifically allowed by Architect.
 2. Procurement Activities: Include procurement process activities for long lead items and major items, requiring a cycle of more than 60 days, as separate activities in schedule. Procurement cycle activities include, but are not limited to, submittals, approvals, purchasing, fabrication, and delivery.
 3. Submittal Review Time: Include review and resubmittal times indicated in Division 1 Section "Submittal Procedures" in schedule. Coordinate submittal review times in Contractor's Construction Schedule with Submittals Schedule.
 4. Startup and Testing Time: Include not less than 10 days for startup and testing.
 5. Substantial Completion: Indicate completion in advance of date established for Substantial Completion, and allow time for Architect's administrative procedures necessary for certification of Substantial Completion.
- C. Milestones: Include milestones indicated in the Contract Documents in schedule, including, but not limited to, the Notice to Proceed, Substantial Completion, and Final Completion
- D. Contract Modifications: For each proposed contract modification and concurrent with its submission, prepare a time-impact analysis using fragments to demonstrate the effect of the proposed change on the overall project schedule.

2.3 CONTRACTOR'S CONSTRUCTION SCHEDULE (GANTT CHART)

- A. Gantt-Chart Schedule: Submit a comprehensive, fully developed, horizontal Gantt-chart-type, Contractor's Construction Schedule within 30 days of date established for commencement of the Work unless otherwise indicated. Base schedule on the Preliminary Construction Schedule and whatever updating and feedback was received since the start of Project.

- B. Preparation: Indicate each significant construction activity separately. Identify first workday of each week with a continuous vertical line.
 - 1. For construction activities that require 3 months or longer to complete, indicate an estimated completion percentage in 10 percent increments within time bar.

2.4 REPORTS

- A. Daily Construction Reports: Prepare and issue a daily construction report recording the following information concerning events at Project site to the Construction Manager:
 - 1. List of subcontractors at Project site.
 - 2. Equipment at Project site.
 - 3. Material deliveries.
 - 4. High and low temperatures and general weather conditions.
 - 5. Accidents.
 - 6. Stoppages, delays, shortages, and losses.
 - 7. Meter readings and similar recordings.
 - 8. Orders and requests of authorities having jurisdiction.
 - 9. Services connected and disconnected.
 - 10. Equipment or system tests and startups.
- B. Field Condition Reports: Immediately on discovery of a difference between field conditions and the Contract Documents, prepare and submit to Construction Manager a detailed report. Submit with a request for interpretation on CSI Form 13.2A or comparable form approved by Architect. Include a detailed description of the differing conditions, together with recommendations for changing the Contract Documents.

PART 3 - EXECUTION

3.1 CONTRACTOR'S CONSTRUCTION SCHEDULE

- A. Contractor's Construction Schedule Updating: At monthly intervals, update schedule to reflect actual construction progress and activities. Issue schedule to Construction Manager one week before each regularly scheduled progress meeting.
 - 1. Revise schedule immediately after each meeting or other activity where revisions have been recognized or made. Issue updated schedule concurrently with the report of each such meeting.
 - 2. Include a report with updated schedule that indicates every change, including, but not limited to, changes in logic, durations, actual starts and finishes, and activity durations.
 - 3. As the Work progresses, indicate Actual Completion percentage for each activity.
- B. Distribution: Distribute copies of approved schedule to Construction Manager, Architect and Owner, separate contractors, testing and inspecting agencies, and other parties identified by Contractor with a need-to-know schedule responsibility.
 - 1. Post copies in Project meeting rooms and temporary field offices.
 - 2. When revisions are made, distribute updated schedules to the same parties and post in the same locations. Delete parties from distribution when they have completed their assigned portion of the Work and are no longer involved in performance of construction activities.

END OF SECTION 013200

SECTION 013210 – CONSTRUCTION SCHEDULE

PART 1 - GENERAL

1.1 Construction Schedule

1. The following William F. Cooke Elementary School Schedule is applicable to all bidders. The durations in the schedule are based on 5 day work weeks.
2. Liquidated damages of \$1,000 per day will be assessed if final completion date, as adjusted by the Construction Manager is not met. Liquidated damages shall apply to all trade contracts. Liquidated damages will be assessed for each day beyond the scheduled date of completion for each trade contractor's item of work. Assessment will occur upon completion of all contracts and may be incurred by one or multiple contractors determined by the Construction Manager.
3. The Construction Schedule as approved by the Construction Manager and Owner will be an integral part of the Contract, and will establish interim work completion dates for the various activities.
4. The Construction Schedule may vary in accordance with construction conditions. Each Trade Contractor shall delay or expedite material and equipment deliveries, and modify the required labor forces to accommodate these varying conditions.
5. Work is to commence upon receipt of the Letter of Authorization to proceed.
6. Within fifteen (15) days after receipt of a "Letter of Authorization to proceed", each trade Contractor shall submit a detailed preliminary Construction Schedule to the Construction Manager. The schedule will include breakdowns of total man days of field labor into major categories of work, time estimates of various categories of work, and the crew size for each category.
7. Each Trade Contractor shall organize his Construction Schedule per Phase, Building, Area, and/or Floor as required by the Construction Manager.
8. The Construction Manager shall schedule a meeting with the Trade Contractor to receive the contents of each Trade Contractor's preliminary Construction Schedule, coordinate the sequence of work, and make all revisions required. The Construction Manager shall have the final authority concerning the sequence of work and durations of each activity. Each Trade Contractor shall revise his schedule in accordance with that meeting and submit his schedule to the Construction Manager for approval. The Construction Manager will then develop the Project Construction Schedule. Each Trade Contractor shall schedule and perform his work in accordance with the Construction Manager's Project Construction Schedule.
9. The Schedule shall be the basis for the dates to start and complete work for various portions of each contract, and to complete work (including changes) for the Project. It shall be the duty of the Trade Contractor to conform to the approved Schedule and to arrange his work in such a manner that it will be installed in accordance with the Schedule.
10. Each Trade Contractor shall submit two (2) copies of an updated Construction Schedule comparing the original schedule to actual work in progress and projected work along with the preliminary application for payment.
11. A representative of each Trade Contractor shall meet with the Construction Manager and furnish to him information necessary for such re-evaluating and updating and, if applicable, information with regard to changes in the work and the Trade Contractor's proposed effort to overcome any delays incurred.
12. Should any work not be started or completed within five (5) days of the stated scheduled date, the Construction Manger shall have the right to order the Trade Contractor to expedite start and completion of the work by whatever means the Construction Manager deems appropriate and necessary, without additional compensation to the Trade Contractor.

13. Should any work to ten (10) or more days behind schedule, the Construction Manger shall have the right to perform the work or have the work performed by whatever method the Construction Manager deem appropriate.
14. Costs incurred by the Construction Manager in connection with “maintaining the Construction Schedule” under this section shall be reimbursed to the Construction Manager by the Trade Contractor.
15. It is expressly understood and agreed that failure by the Construction Manager to exercise the option to either order the Trade Contractor to expedite work, or to expedite the work by other means, shall not be considered precedent-setting for any other activities.
16. The following Construction Schedule is critical to the successful completion of the Project and is an integral portion of the Construction Documents. The Construction Schedule may vary in accordance with the construction conditions. The Trade Contractor shall delay or expedite his material and equipment deliveries and modify the required work forces to accommodate these varying conditions. The attached schedule is a milestone schedule with durations that portions of the project must be completed in. A more detailed construction schedule will be generated after all contracts have been awarded. By submitting a bid, each Trade Contractor is acknowledging that they can complete this work within the durations outlined in the milestone schedule.
17. The schedule is of the essence on this project and each contractor is responsible for completion of its work in coordination with the work of all other contractors within the required sequence and time frame so that the established schedule is met. Each contractor agrees to provide sufficient labor crew size, equipment and/or work overtime, weekends, or shiftwork as necessary to meet the activity durations on this schedule.
18. The attached schedule includes “estimated” start dates for the construction activities. In the interest of the overall project, W-T reserves the right to alter the sequencing of activities in order to accommodate project conditions and/or Owner requirements. It is understood that the contractor shall be obligated to complete its activities within the specified duration regardless of the actual start date.
19. All submittals and shop drawings must be submitted within a minimum of **two (2) weeks** of the notice to proceed with this subcontract, or the dates indicated on the schedule or scope of work, whichever occurs first. All expediting of materials and equipment to meet this schedule is the responsibility of the contractor. Contractor to pay for any quick ship charges if necessary.
20. All critical path materials such as storm water structures, rebar, steel, brick, door frames, electrical gear and lighting, mechanical equipment and ductwork, roofing material, kitchen equipment, etc., must be expedited from the beginning of the project. Delays in critical path materials will not be accepted.
21. All work, or applicable portions of the work, shall be sufficiently complete for Owner’s use and occupancy and all required approvals and permits for use and occupancy shall have been issued by the appropriate authorities by the established “Date of Substantial Completion” of the work, or applicable portion thereof.
22. All punchlist work and project closeout documentation shall be completed and approved by the Owner and Architect by the “Date of Final Completion”: which shall be no later than 21 days after the Date of Substantial Completion. Any uncompleted punchlist items after this date will be completed by Whiting-Turner and backcharged to the appropriate contractor or vendor. Final invoices will not be processed until final completion of the work and certification of same by the Owner and Architect.
23. If a contractor misses any portion of a workday due to weather, manpower, or scheduling conflicts, they must make-up this lost time during the same week.

24. Sundays are not regular work days. Approval must be obtained from Whiting-Turner prior to working. It is expected that contractors will work Saturdays, Sundays, and overtime when days are lost during the week.
25. Failure to properly man the project during normal week days may result in charges for CM supervision on weekends, at the discretion of the CM.
26. The contractor must schedule their work forces to work on all available work at a given time. Therefore, if an area of the building is ready for the contractor's work to begin or continue, the contractor must have manpower onsite working. Contractors will not have the "entire" work area at one time.
27. Each contractor must request information or clarifications in a timely manner, at least two weeks prior to needing the information, so that the time required to receive the clarification does not impact the work. No delays will be accepted related to this issue.
28. Each contractor is required to include in their bid the necessary overtime costs if they are needed to meet the schedule durations in this section.

2.1 Time of Completion

1. The Trade Contractor shall commence work upon receipt of a Letter of Authorization to proceed from either Red Clay Consolidated School District or The Whiting-Turner Contracting Company.
2. All work shall be 100 percent (100%) complete and sequenced per the attached schedule unless agreed upon by the Construction Manager prior to the executing of the contract.
3. Work can be completed on Saturdays and Sundays and at extended hours during the week. The Owner shall not be responsible for additional costs for overtime.
4. Normal work hours shall be from 7:00 a.m. to 3:30 p.m., Monday to Friday, and 7:00 a.m. to 3:30 pm on Saturday, when applicable. Work may be completed beyond these hours, as approved by the Construction Manager.
5. Weather Delays: The project substantial completion date, shall only be adjusted due to weather conditions if there are delays above and beyond the following "Adverse Day" allowances based on a seven day work week:
 - A. January (12), February (10), March (5), April (5), May (4), June (2), July (4), August (3 days), September (4 days), October (3 days), November (2 days), and December (6 days). These "Adverse Days" are based on the following reference: State of Delaware Department of Transportation's Standard: "763508 Project Control System."
 - B. Delays requested due to weather must be related to the critical path activity as indicated on the Contractor's Project Schedule.
 - C. Delays due to weather must be reported by the contractor on the day they occur in a written report.
 - D. Any day lost during the week must be made up the same week by overtime and /or weekend work. If the weather is bad on the make-up day, the lost day must be made up the following week.
 - E. The allowance days listed above carry over to the next month if they are not used. Therefore, if only 1 allowance day is used in November, there are (7) days in December. Therefore, there is a total of 60 allowance days in a year.

END OF SECTION 013210

(SCHEDULE ATTACHED)

SECTION 013300 - SUBMITTAL PROCEDURES

PART 1 - GENERAL

1.1 RELATED DOCUMENTS

- A. Drawings and general provisions of the Contract, including General and Supplementary Conditions and other Division 01 Specification Sections, apply to this Section.

1.2 SUMMARY

- A. Section includes requirements for the submittal schedule and administrative and procedural requirements for submitting Shop Drawings, Product Data, Samples, and other submittals.
- B. Related Requirements:
 - 1. Section 012900 "Payment Procedures" for submitting Applications for Payment and the schedule of values.
 - 2. Section 013200 "Construction Progress Documentation" for submitting schedules and reports, including Contractor's construction schedule.
 - 3. Section 017823 "Operation and Maintenance Data" for submitting operation and maintenance manuals.
 - 4. Section 017839 "Project Record Documents" for submitting record Drawings, record Specifications, and record Product Data.
 - 5. Section 017900 "Demonstration and Training" for submitting video recordings of demonstration of equipment and training of Owner's personnel.

1.3 DEFINITIONS

- A. Action Submittals: Written and graphic information and physical samples that require Architect's responsive action. Action submittals are those submittals indicated in individual Specification Sections as "action submittals."
- B. Informational Submittals: Written and graphic information and physical samples that do not require Architect's and Construction Manager's responsive action. Submittals may be rejected for not complying with requirements. Informational submittals are those submittals indicated in individual Specification Sections as "informational submittals."
- C. Project Website: Internet website, requiring user name and password for log in, used for the controlled transmission and exchange of project-related information and data including Requests for Information, Submittals, Field Bulletins, etc., between Owner, Contractor, Architect, and other authorized parties.
- D. Portable Document Format (PDF): An open standard file format licensed by Adobe Systems used for representing documents in a device-independent and display resolution-independent fixed-layout document format.

1.4 ACTION SUBMITTALS

- A. Submittal Schedule: Submit a schedule of submittals, arranged in chronological order by dates required by construction schedule. Include time required for review, ordering, manufacturing, fabrication, and delivery when establishing dates. Include additional time required for making corrections or revisions to submittals noted by Architect and additional time for handling and reviewing submittals required by those corrections.
1. Coordinate submittal schedule with list of subcontracts, the schedule of values, and Contractor's construction schedule.
 2. Initial Submittal: Submit concurrently with startup construction schedule. Include submittals required during the first 60 days of construction. List those submittals required to maintain orderly progress of the Work and those required early because of long lead time for manufacture or fabrication.
 3. Final Submittal: Submit concurrently with the first complete submittal of Contractor's construction schedule.
 - a. Submit revised submittal schedule to reflect changes in current status and timing for submittals.
 - 1) Revisions shall be provided to Architect and Owner not less than once per month during the submittal process.
 - 2) Contractor may suspend revision of submittal schedule upon completion of required construction-phase submittals, but shall resume revisions at Architect's direction for close-out submittals.
 4. Format: Arrange the following information in a tabular format:
 - a. Submittal number.
 - b. Specification Section number.
 - c. Specification Section title.
 - d. Scheduled date for first submittal.
 - e. Scheduled date for Architect's final release or approval.
 - f. Description of the Work covered.
 - g. Name of subcontractor.
 - h. Submittal category: Action, informational.

1.5 SUBMITTAL ADMINISTRATIVE REQUIREMENTS

- A. Architect's Digital Data Files: Electronic digital data files of the Contract Drawings will be provided by Architect for Contractor's use in preparing submittals upon specific request of the Contractor.
1. Architect will furnish Contractor one set of digital data drawing files of the Contract Drawings for use in preparing Shop Drawings.
 - a. Architect makes no representations as to the accuracy or completeness of digital data drawing files as they relate to the Contract Drawings.

- b. Digital Drawing Software Program: The Contract Drawings are available in AutoCAD 2004, 2007, or 2010 DWG.
 - c. Contractor shall execute a data licensing agreement in the form of Agreement included in Project Manual.
 - d. Charges for digital data files shall be as described in the data licensing agreement, and shall be the responsibility of the Contractor requesting the files
 - 1) Charge: \$200 per electronic file.
 - e. Contractor shall follow the prescribed Digital Data File request procedure.
 - 1) Contractor shall inform Architect that digital data files will be requested, including information required for Architect to complete data licensing agreement.
 - a) Name of Contractor
 - b) Name and Title of Contractor's agent will sign form.
 - c) Email address and name of person to receive digital data files.
 - d) File Format: DWG 2004, DWG 2007, DWG 2010
 - e) List of drawings for which digital data files are being requested.
 - 2) Architect will provide data licensing agreement(s) to Contractor and indicated charges.
 - 3) Contractor shall sign data licensing agreement(s) and return to Architect along with payment for charges.
 - 4) Upon receipt of signed agreement(s) and payment for charges, Architect will convert files and send to Contractor through project website.
- B. Coordination: Coordinate preparation and processing of submittals with performance of construction activities.
- 1. Coordinate each submittal with fabrication, purchasing, testing, delivery, other submittals, and related activities that require sequential activity.
 - 2. Submit all submittal items required for each Specification Section concurrently unless partial submittals for portions of the Work are indicated on approved submittal schedule.
 - 3. Submit action submittals and informational submittals required by the same Specification Section as separate packages under separate transmittals.
 - 4. Coordinate transmittal of different types of submittals for related parts of the Work so processing will not be delayed because of need to review submittals concurrently for coordination.
 - a. Architect reserves the right to withhold action on a submittal requiring coordination with other submittals until related submittals are received.
- C. Processing Time: Allow time for submittal review, including time for resubmittals, as follows. Time for review shall commence on Architect's receipt of submittal. No extension of the Contract Time will be authorized because of failure to transmit submittals enough in advance of the Work to permit processing, including resubmittals.

1. Initial Review: Allow 15 days average for initial review of each submittal. Allow additional time if coordination with subsequent submittals is required. Architect will advise Contractor when a submittal being processed must be delayed for coordination.
 2. Intermediate Review: If intermediate submittal is necessary, process it in same manner as initial submittal.
 3. Resubmittal Review: Allow 15 days average for review of each resubmittal.
- D. Identification and Information: Identify and incorporate information in each electronic submittal file as follows:
1. Assemble complete submittal package into a single indexed file with links enabling navigation to each item.
 2. Name file with submittal number or other unique identifier, including revision identifier.
 - a. File name shall use project identifier and Specification Section number followed by a dash and then a sequential number. Resubmittals shall include an alphabetic suffix.
 3. Provide means for insertion to permanently record Contractor's review and approval markings and action taken by Architect.
 4. Include the following information on an inserted cover sheet:
 - a. Project name.
 - b. Date.
 - c. Name of Architect.
 - d. Name of Contractor.
 - e. Name of firm or entity that prepared submittal.
 - f. Name of subcontractor.
 - g. Name of supplier.
 - h. Name of manufacturer.
 - i. Submittal number, including revision identifier.
 - j. Number and title of appropriate Specifications Section.
 - k. Drawing number and detail references, as appropriate.
 - l. Location(s) where product is to be installed, as appropriate.
 - m. Related physical samples submitted directly.
 - 1) Submittal Number and Name
 - n. Other necessary identification
- E. Options: Identify options requiring selection by Architect.
- F. Deviations: Identify deviations from the Contract Documents on submittals
1. **Deviations not explicitly noted on submittal and not explicitly approved by Architect, shall be considered disapproved regardless of whatever action is indicated for submittal.**
- G. Additional Copies: Unless additional copies are required for final submittal, and unless Architect observes noncompliance with provisions in the Contract Documents, initial submittal may serve as final submittal.
- H. Resubmittals: Make resubmittals in same form as initial submittal.

1. Note date and content of previous submittal.
 2. Note date and content of revision in label or title block and clearly indicate extent of revision.
 3. Resubmit submittals until they are marked with approval notation from Architect's action stamp.
- I. Distribution: Furnish copies of final submittals to manufacturers, subcontractors, suppliers, fabricators, installers, authorities having jurisdiction, and others as necessary for performance of construction activities. Show distribution on transmittal forms.
- J. Use for Construction: Retain complete copies of submittals on Project site. Use only final action submittals that are marked with approval notation from Architect's action stamp.

PART 2 - PRODUCTS

2.1 SUBMITTAL PROCEDURES

- A. General Submittal Procedure Requirements: Prepare and submit submittals required by individual Specification Sections. Types of submittals are indicated in individual Specification Sections.
1. Post electronic submittals as PDF electronic files directly to Project Web site specifically established for Project.
 - a. Architect will return annotated file.
 - b. Annotate and retain one copy of file as an electronic Project record document file.
 - c. At conclusion of project, provide one hard copy and one electronic copy of annotated electronic Project record document files.
 - 1) Assemble into three ring, D-style binders.
 - 2) Collate by specification section and submittal number.
 - 3) Provide tab dividers and label (number only) for each specification sheet.
 - 4) Within each specification section, pages may be printed single or double sided, up to two (2) submittal pages per side of 8 1/2" x 11" printed sheet.
 - a) Large format and complex submittals shall be printed full size.
 - 5) Provide DVD or CD with annotated electronic files. Organize files into folders arranged by MasterFormat 2011 Divisions, as used in the Project Manual. Provide printed labels, identifying disc contents. Assemble DVD(s) or CD(s) in binder in CD binder sheets.
 2. Paper Copies of Submittals: Only where specifically indicated in technical specification requirements, and as a supplement to PDF electronic files, provide two paper copies of each submittal for Architect's use. Unless otherwise indicated, Architect will not return copies.
 3. Closeout Submittals and Maintenance Material Submittals: Comply with requirements specified in Division 01 Section "Closeout Procedures."

4. Certificates and Certifications Submittals: Provide a statement that includes signature of entity responsible for preparing certification. Certificates and certifications shall be signed by an officer or other individual authorized to sign documents on behalf of that entity.
 - a. Provide a digital signature with digital certificate on electronically submitted certificates and certifications where indicated.
- B. Product Data: Collect information into a single submittal for each element of construction and type of product or equipment.
 1. If information must be specially prepared for submittal because standard published data are not suitable for use, submit as Shop Drawings, not as Product Data.
 2. Mark each copy of each submittal to show which products and options are applicable.
 3. Include the following information, as applicable:
 - a. Manufacturer's catalog cuts.
 - b. Manufacturer's product specifications.
 - c. Standard color charts.
 - d. Statement of compliance with specified referenced standards.
 - e. Testing by recognized testing agency.
 - f. Application of testing agency labels and seals.
 - g. Notation of coordination requirements.
 - h. Availability and delivery time information.
 4. For equipment, include the following in addition to the above, as applicable:
 - a. Wiring diagrams showing factory-installed wiring.
 - b. Printed performance curves.
 - c. Operational range diagrams.
 - d. Clearances required to other construction, if not indicated on accompanying Shop Drawings.
 5. Submit Product Data before or concurrent with Samples.
 6. Submit Product Data in the following format:
 - a. PDF electronic file.
- C. Shop Drawings: Prepare Project-specific information, drawn accurately to scale. Do not base Shop Drawings on reproductions of the Contract Documents or standard printed data, unless submittal based on Architect's digital data drawing files is otherwise permitted.
 1. Preparation: Fully illustrate requirements in the Contract Documents. Include the following information, as applicable:
 - a. Identification of products.
 - b. Schedules.
 - c. Compliance with specified standards.
 - d. Notation of coordination requirements.
 - e. Notation of dimensions established by field measurement.
 - f. Relationship and attachment to adjoining construction clearly indicated.

color, texture, and pattern; color range sets; and components used for independent testing and inspection.

- a. Number of Samples: Submit three sets of Samples. Architect will retain one Sample set; remainder will be returned. Mark up and retain one returned Sample set as a project record sample.
 - 1) Submit a single Sample where assembly details, workmanship, fabrication techniques, connections, operation, and other similar characteristics are to be demonstrated.
 - 2) If variation in color, pattern, texture, or other characteristic is inherent in material or product represented by a Sample, submit at least three sets of paired units that show approximate limits of variations.
 - 3) In addition to samples, submit transmittal form, submittal identification and information sheet, and other relevant information in PDF electronic file. Architect will indicate selection through electronic submittal.

- E. Product Schedule: As required in individual Specification Sections, prepare a written summary indicating types of products required for the Work and their intended location. Include the following information in tabular form:
 1. Type of product. Include unique identifier for each product indicated in the Contract Documents or assigned by Contractor if none is indicated.
 2. Manufacturer and product name, and model number if applicable.
 3. Number and name of room or space.
 4. Location within room or space.
 5. Submit product schedule in the following format:
 - a. PDF electronic file.

- F. Coordination Drawing Submittals: Comply with requirements specified in Section 013100 "Project Management and Coordination."

- G. Contractor's Construction Schedule: Comply with requirements specified in Section 013200 "Construction Progress Documentation."

- H. Application for Payment and Schedule of Values: Comply with requirements specified in Section 012900 "Payment Procedures."

- I. Test and Inspection Reports and Schedule of Tests and Inspections Submittals: Comply with requirements specified in Section 014000 "Quality Requirements."

- J. Closeout Submittals and Maintenance Material Submittals: Comply with requirements specified in Section 017700 "Closeout Procedures."

- K. Maintenance Data: Comply with requirements specified in Section 017823 "Operation and Maintenance Data."

- L. Qualification Data: Prepare written information that demonstrates capabilities and experience of firm or person. Include lists of completed projects with project names and addresses, contact information of architects and owners, and other information specified.

- M. Welding Certificates: Prepare written certification that welding procedures and personnel comply with requirements in the Contract Documents. Submit record of Welding Procedure Specification and Procedure Qualification Record on AWS forms. Include names of firms and personnel certified.
- N. Installer Certificates: Submit written statements on manufacturer's letterhead certifying that Installer complies with requirements in the Contract Documents and, where required, is authorized by manufacturer for this specific Project.
- O. Manufacturer Certificates: Submit written statements on manufacturer's letterhead certifying that manufacturer complies with requirements in the Contract Documents. Include evidence of manufacturing experience where required.
- P. Product Certificates: Submit written statements on manufacturer's letterhead certifying that product complies with requirements in the Contract Documents.
- Q. Material Certificates: Submit written statements on manufacturer's letterhead certifying that material complies with requirements in the Contract Documents.
- R. Material Test Reports: Submit reports written by a qualified testing agency, on testing agency's standard form, indicating and interpreting test results of material for compliance with requirements in the Contract Documents.
- S. Product Test Reports: Submit written reports indicating that current product produced by manufacturer complies with requirements in the Contract Documents. Base reports on evaluation of tests performed by manufacturer and witnessed by a qualified testing agency, or on comprehensive tests performed by a qualified testing agency.
- T. Research Reports: Submit written evidence, from a model code organization acceptable to authorities having jurisdiction, that product complies with building code in effect for Project. Include the following information:
 - 1. Name of evaluation organization.
 - 2. Date of evaluation.
 - 3. Time period when report is in effect.
 - 4. Product and manufacturers' names.
 - 5. Description of product.
 - 6. Test procedures and results.
 - 7. Limitations of use.
- U. Schedule of Tests and Inspections: Comply with requirements specified in Division 01 section "Quality Requirements."
- V. Preconstruction Test Reports: Submit reports written by a qualified testing agency, on testing agency's standard form, indicating and interpreting results of tests performed before installation of product, for compliance with performance requirements in the Contract Documents.
- W. Compatibility Test Reports: Submit reports written by a qualified testing agency, on testing agency's standard form, indicating and interpreting results of compatibility tests performed before installation of product. Include written recommendations for primers and substrate preparation needed for adhesion.

- X. Field Test Reports: Submit written reports indicating and interpreting results of field tests performed either during installation of product or after product is installed in its final location, for compliance with requirements in the Contract Documents.
- Y. Maintenance Data: Comply with requirements specified in Division 01 section "Operation and Maintenance Data."
- Z. Design Data: Prepare and submit written and graphic information, including, but not limited to, performance and design criteria, list of applicable codes and regulations, and calculations. Include list of assumptions and other performance and design criteria and a summary of loads. Include load diagrams if applicable. Provide name and version of software, if any, used for calculations. Include page numbers.

2.2 DELEGATED-DESIGN SERVICES

- A. Performance and Design Criteria: Where professional design services or certifications by a design professional are specifically required of Contractor by the Contract Documents, provide products and systems complying with specific performance and design criteria indicated.
 - 1. If criteria indicated are not sufficient to perform services or certification required, submit a written request for additional information to Architect.
- B. Delegated-Design Services Certification: In addition to Shop Drawings, Product Data, and other required submittals, submit digitally signed PDF electronic file and three paper copies of certificate, signed and sealed by the responsible design professional, for each product and system specifically assigned to Contractor to be designed or certified by a design professional.
 - 1. Indicate that products and systems comply with performance and design criteria in the Contract Documents. Include list of codes, loads, and other factors used in performing these services.

PART 3 - EXECUTION

3.1 CONTRACTOR'S REVIEW

- A. Action and Informational Submittals: Review each submittal and check for coordination with other Work of the Contract and for compliance with the Contract Documents. Note corrections and field dimensions. Mark with approval stamp before submitting to Architect.
- B. Project Closeout and Maintenance Material Submittals: See requirements in Section 017700 "Closeout Procedures."
- C. Approval Stamp: Stamp each submittal with a uniform, approval stamp. Include Project name and location, submittal number, Specification Section title and number, name of reviewer, date of Contractor's approval, and statement certifying that submittal has been reviewed, checked, and approved for compliance with the Contract Documents.

3.2 ARCHITECT'S ACTION

- A. Action Submittals: Architect will review each submittal, make marks to indicate corrections or revisions required, and return it. Architect will stamp each submittal with an action stamp and will mark stamp appropriately to indicate action, as follows:
1. Approved: No further action on submittal is required.
 2. Approved as Noted: Incorporate corrections and comments noted into Work and indicate in record drawings. If corrections cannot be incorporated into Work, resubmit with explanation of why corrections cannot be complied with and indicate proposed response to address intent of corrections.
 3. Received for Record / Not Reviewed: Submittal provided to satisfy record submittal requirement from previous submittal notes or Contract Documents, or submittal not required by Contract Documents and not reviewed. Any notes provided are for Contractor's reference, but do not imply any level of review by Architect.
 4. Revise and Resubmit: Incorporate corrections and comments noted in Work and resubmit.
 5. Disapproved: Submittal does not meet intent of Contract Documents. Correct deficiencies noted and resubmit.
- B. Informational Submittals: Architect will review each submittal and will not return it, or will return it if it does not comply with requirements. Architect will forward each submittal to appropriate party.
- C. Partial submittals prepared for a portion of the Work will be reviewed when use of partial submittals has received prior approval from Architect.
- D. Incomplete submittals are unacceptable, will be considered nonresponsive, and will be returned for resubmittal without review.
- E. Submittals not required by the Contract Documents may be returned by the Architect without action.

END OF SECTION 013300

SECTION 013500 – SPECIAL PROJECT PROCEDURES

1.0 PROCEDURES1.1 CONSTRUCTION MANAGER

- A. The Construction Manager shall control, enforce, direct, instruct, and otherwise implement regulations and restrictions as set forth in this section.

1.2 OWNER'S REPRESENTATIVE

- A. All communications with the owner and owner's representative(s) and consultant(s) shall be through the Construction Manager unless otherwise noted in the General Conditions.

1.3 NOISE CONTROL

- A. The Contractor shall execute the Work in this Contract as quietly as practicable to avoid unnecessary disturbances.
- B. Any complaints duly registered by the Construction Manager of unacceptable noise levels shall be cause for the use of special precautions and methods of operation by the Contractor to reduce noise to acceptable levels.
- C. The Owner and Construction Manager shall be the sole judge of the tolerability of noise levels.
- D. Use of portable radios or tape recorders will not be allowed on the premises other than two-way communication radios.
- E. The Contractor shall prepare a "Noise Schedule" as soon as practicable indicating the type of noise inducing work showing the dates, times and duration of such work. The Contractor should note any special instruction and/or time requirement in Scopes of Work.

1.4 PERSONNEL IDENTIFICATION

- A. All employees of the Contractor and all subcontractors may be required to wear numbered identification badges while on the premises of existing buildings.
- B. The identification badges shall be conspicuously fixed to outer garments above elbow level.
- C. Any of the Contractor's personnel or subcontractor's personnel who do not comply with this requirement at all times will be denied access to the facility or will be escorted off the premises by Security Guards or owner representative(s).

1.5 PERSONNEL PARKING

- A. At no time shall the employees of the Contractor or subcontractor employed by Contractor be allowed to park their vehicles on-site without prior approval from the Construction Manager.

2.0 LIMIT OF OPERATIONS

- A. It shall be noted that, adjacent streets will remain open throughout the duration of this Project. The Construction Manager will provide a perimeter fence, which will establish limits of operation.
- B. The Contractor's normal limit of operations shall be confined within the Limits of Work Area as designated on the drawings.
- C. The Owner, Architect, and other Contractors performing Work within these limits of operation, shall be allowed access at all times.
- D. Construction operations must be planned and executed in a manner which allows emergency access to project.

3.0 SCHEDULING AND COORDINATION

3.1 SCHEDULING

- A. All arrangements for work which will involve interference with normal Owner or adjacent properties functions, particularly in occupied areas, or adjacent thereto, shall be scheduled a minimum of 14 days in advance with the Construction Manager to provide for minimum of disruption and inconvenience.

3.2 OUTAGES

- A. Utility and service outages shall be kept to a minimum, and will be permitted only with written approval of the Construction Manager and the Owner.
- B. All requests for the outages shall be made a minimum of fourteen working days in advance of their need.
- C. Requests for outages will not be considered unless they include an identification of all areas which will be affected by the proposed outage. Blank outage forms will be provided by the Construction Manager upon request.
- D. All outages shall occur **after normal working hours**. All costs including premium time shall be included in the Bid amounts.

END OF SECTION 013500

SECTION 013520 – SAFETY REQUIREMENTS AND LOSS CONTROL

The major goal of the Loss Control Program is to prevent losses. Prevention of accidents and elimination of hazards will, in turn, prevent pain, suffering and direct loss in terms of dollars. A safe work place must be maintained for all employees and visitors. High quality work standards and on-time performance are facilitated by an effective Loss Control Program.

Controlling conditions which result in losses is the responsibility of all parties. The Construction Manager will designate a job site safety officer responsible for program management. The responsibility for program implementation is the responsibility of all employees of the Owner, Construction Manager, Contractors and all Subcontractors. The following summary identifies objectives requiring a firm commitment to insure a continuing and comprehensive Loss Control Program.

Construction Manager Duties:

1. Designate jobsite safety officer.
2. Loss reporting and summaries.
3. Accident investigation.
4. Establish project procedures.
5. Inspections, notifications and follow-up.
6. Weekly "Tool Box" talks.
7. Weekly Superintendents meetings.
8. Monthly summary report.

Contractors Duties:

1. Designate on-site safety representative.
2. Consult with insurance carrier for construction operations.
3. Involve foreman and employees.
4. Safety training of all employees.
5. Adherence to safety standards, rules and government regulations.
6. Report conditions or practices which might cause injury or damage.
7. Report all safety related incidents.
8. Participate in all accident investigations.
9. All employees attend weekly Tool Box talks.
10. Attend weekly Superintendents/Foreman's Meetings.
11. Request permission to move barricades and floor opening protection. *
12. Maintain fire watch for all burning operations *
13. Properly store and protect hazardous chemicals and flammable substances.
14. Insure performance of these duties by subcontractors.
15. Maintain good housekeeping practices.
16. Prohibit the use of drugs and/or intoxicating beverages.
17. Maintain equipment in safe condition.

* See the Whiting-Turner Forms for these issues in the On-Site Safety Orientation Package

In order for our accident prevention program to be effective, management at all levels must personally take a serious interest in the prevention of accidents. They must also provide the leadership to which supervisory personnel and employees will respond by developing a positive safety attitude.

THE WHITING-TURNER CONTRACTING COMPANY
SAFETY/HARASSMENT POLICY

I. SAFETY REQUIREMENTS

The Contractor agrees to fully comply with all applicable standards of the Occupational Safety and Health Administration, all safety codes, laws or ordinances applicable to any public authority and to ensure that its employees and Sub-Contractors abide by the same regulations. The Contractor further agrees that if so ordered by the Whiting-Turner Project Manager or Superintendent, it will immediately stop work and correct any serious safety violations immediately before resuming work. The Contractor expressly agrees and understands that Contractor shall be solely responsible for the safety conditions of its work areas and working forces.

The Contractor further agrees to comply with the following specific safety rules of Whiting-Turner which shall in no way limit the Contractor’s liability for safety.

Each contractor and their subcontractors are to designate a safety representative, in writing, and provide a written safety program which identifies their organization and safety policies. All contractors are required to review the following rules and requirements with their on site employees:

CONTAINERS

- A. No glass containers allowed on site.

CRANES

- A. All lifts must use tag lines.
- B. No open hooks used on lifts.

EQUIPMENT

- A. Absolutely no riding on equipment not equipped with proper seating.
- B. Site Speed not to exceed 10 MPH.

FIRE CONTROL

- A. No open fires, fire barrels, or hot boxes.
- B. Fire extinguishers in:
Trailers/offices minimum 10 lb ABC
Equipment minimum 5 lb ABC
Fire Watch minimum 20 lb ABC

HARDHATS

- A. Wear on site at all times, must have Z89.1 rating.
- B. No metal hardhats or bump caps authorized.

FOOT PROTECTION

- A. Substantial leather boots required.
- B. Loafers, sandals, tennis shoes (including steel toe type) are not allowed.

LADDERS

- A. No metal ladders allowed on site.
- B. Damaged ladders must be immediately removed from site or destroyed.

SCAFFOLDING

Full handrails, mid-rails, toeboards, full decking required on all scaffolds, according to standards.

SIGNAGE

- A. Post safety or hazard signs (bilingual if necessary).
- B. Use Whiting-Turner Supplied (Do Not Remove) signs on floor openings.

TRUCKS

- A. No more than three (3) persons in cab of truck.
- B. No riding in back of truck unless truck is equipped with seats and safety belts.

WORK CLOTHING

- A. All shirts must have a minimum four (4) inches sleeve length over shoulders.
- B. No shorts, cut offs, tank tops, net shirts, etc.

ELECTRICAL PROTECTION

- A. No cut, frayed or damaged extension cords permitted.
- B. All extension cords must have a U.L. approved GFCI (Ground Fault Circuit Interpreter)

SAFETY ORIENTATION / SAFETY MEETINGS

- A. Each employee is required to attend a safety orientation and wear a sticker on his or her hardhat.
- B. Each Foreman is required to hold weekly safety meetings with their employees and forward copies of the sign-in sheet.

DAILY REPORTS

- A. Foreman are required to turn in a daily report for their work at the end of each workday. All employees are required to sign this sheet.

PARKING

- A. Parking is limited on site – Coordinate with WT Superintendent for locations.
- B. NO PARKING at the adjacent properties or roadways or any property not owned by the project owner.
- C. Do not block handicap spaces or fire lanes.
- D. Obtain necessary parking permits if applicable.

PERMITS

- A. HOT WORK Permit must be filled out for any burning, welding, soldering, cutting, etc. that may generate a spark.
- B. SAFE WORK Permit must be filled out for any other potentially dangerous work. Crane lifts, shaft cutting, hazardous chemicals, off-hour work, etc. If work occurs in an OSHA defined confined space, obtain a confined space permit.

- C. SAFETY BARRICADE / FALL PROTECTION Permit must be filled out when creating an open hole or removing fall protection.
- D. UTILITY SHUTDOWN Permit must be filled out when turning off any utilities to the building. A two-week notice is required for all outages.
- E. ALL PERMITS must be filled out with Whiting-Turner in advance and posted in the work area.

ASBESTOS / HAZARDOUS MATERIALS

- A. It is possible that there could be existing unforeseen asbestos or other hazardous materials either buried underground or laying on the project site from previous activities on the property.
- B. It is possible that a hazardous material could be brought to the site by others.
- C. Anyone who uncovers or notices a suspected hazardous material should leave it undisturbed and notify WT immediately.
- D. An authorized contractor must dispose of asbestos or other hazardous materials or contaminated debris.

MISCELLANEOUS RULES

- A. Do not block any hallways, stairs or exit doors. Maintain fire egress.
- B. Use all proper personal protection equipment (hard hats, gloves, glasses, etc.)
- C. Smoking is prohibited within the building once 50% of the building façade is covered (new building construction). For renovation projects, smoking is prohibited at all times inside the building, on the roof, or within 20' of the building. Violators will be warned in writing one time. Written warning will be copied to their office. The second violation will result in removal from project. Designated smoking areas will be established outside of the building.
- D. Eating in designated areas only
- E. Use temporary toilets only
- F. Clean the work site daily, trash and debris to the dumpster daily
- G. Alert WT to any emergency
- H. Report any damage to building components or site items
- I. No gasoline-powered or carbon monoxide exhaust equipment can be used at any time in the building after it is enclosed, use propane instead. All equipment you plan to use must be reviewed with the WT Superintendent for safety concerns.

NOTE: THESE ABOVE SAFETY RULES ARE IN ADDITION TO OSHA REQUIREMENTS.

II. CONTRACTOR'S SAFETY PROGRAM

The Contractor will provide a competent safety person who will be responsible for administering the Contractor's safety program and enforcing the safety rules. The following are recommended suggestions for establishing an effective Contractor's safety program.

- A. Establish a schedule of safety meetings conducted by Contractor's foreman for discussing specific topics, such as safety rules, hazards or specific jobs, safe practices, etc.
- B. Establish a plan for Contractor's foreman to contact each employee under his supervision at least once per week on safety.
- C. Establish a procedure for the prompt investigation of all personal injuries and property damage by Contractor's management.
- D. Establish a schedule for periodic inspection by Contractor's management of "hazards" on job site.
- E. Establish a plan for the periodic inspection of tools and equipment by Contractor's management.
- F. Develop basic safety rules for job, instruct employees and enforced compliance.

III. INDEMNIFICATION (RELATED TO OSHA VIOLATIONS)

To the fullest extent permitted by law the Contractor shall indemnify and hold harmless Whiting-Turner, the Owner, and the Architect and their agents and employees from and against all claims, including citations and penalties imposed by the Occupational Safety and Health Administration, damages, losses, expenses and judgments including, but not limited to attorney's fees, arising out of or resulting from performance of the work in an area which is unsafe, harmful, dangerous, or hazardous and which is caused in whole or in part by any act of omission of the Contractor, anyone directly or indirectly employed by it, or any one for whose acts it may be liable, regardless of whether the claim, citation, penalty, damage, loss, expense or judgment results from unsafe, harmful, dangerous, hazardous or toxic materials or substances or whether from any other unsafe, harmful, dangerous or hazardous conditions.

IV. SEXUAL HARASSMENT POLICY

The Construction Manager and Owner will not accept any behavior deemed to be a form of sexual harassment and actively seeks to eliminate such behavior from the jobsite environment.

Definition of Sexual Harassment

The Construction Manager and Owner officially defines sexual harassment as "any unwelcome sexual advances or requests for sexual favors and other verbal or physical conduct of a sexual nature that has the effect or purpose of unreasonably interfering with an individual's work or academic environment, or of affecting an individual's employment or academic status." Sexual harassment is not only a clear violation, it is illegal and a form of discrimination, covered under Title VII of the Civil Rights Act of 1964.

Be Aware

Sexual harassment takes many forms, but includes any unwanted sexual attention such as:

- staring, leering, and ogling
- sexual teasing
- jokes and gestures
- repeatedly asking for dates after being refused
- lewd remarks
- whistles
- references to someone's anatomy
- inappropriate touching
- attempts to kiss or fondle
- coerced sexual intercourse

The sexual harassment policy will be strictly enforced. Any reported incident will be dealt with swiftly and severely. The offending party, if identified will be dismissed from the project and property and not allowed to return. Repeated incidents by employees of a particular firm can result in cancellation of that contract. The victim of the abuse retains the legal right to prosecute. All employees of these contracting firms should be apprised of this policy before working on this project.

END OF SECTION 013520

SECTION 014000 - QUALITY REQUIREMENTS

PART 1 - GENERAL

1.1 RELATED DOCUMENTS

- A. Drawings and general provisions of the Contract, including General and Supplementary Conditions and other Division 01 Specification Sections, apply to this Section.

1.2 SUMMARY

- A. Section includes administrative and procedural requirements for quality assurance and quality control.
- B. Testing and inspecting services are required to verify compliance with requirements specified or indicated. These services do not relieve Contractor of responsibility for compliance with the Contract Document requirements.
 - 1. Specific quality-assurance and -control requirements for individual construction activities are specified in the Sections that specify those activities. Requirements in those Sections may also cover production of standard products.
 - 2. Specified tests, inspections, and related actions do not limit Contractor's other quality-assurance and -control procedures that facilitate compliance with the Contract Document requirements.
 - 3. Requirements for Contractor to provide quality-assurance and -control services required by Architect, Owner, Commissioning Authority, or authorities having jurisdiction are not limited by provisions of this Section.
 - 4. Specific test and inspection requirements are not specified in this Section.
- C. Related Requirements:
 - 1. Section 012100 "Allowances" for testing and inspecting allowances.

1.3 DEFINITIONS

- A. Quality-Assurance Services: Activities, actions, and procedures performed before and during execution of the Work to guard against defects and deficiencies and substantiate that proposed construction will comply with requirements.
- B. Quality-Control Services: Tests, inspections, procedures, and related actions during and after execution of the Work to evaluate that actual products incorporated into the Work and completed construction comply with requirements. Services do not include contract enforcement activities performed by Architect.
- C. Mockups: Full-size physical assemblies that are constructed on-site. Mockups are constructed to verify selections made under Sample submittals; to demonstrate aesthetic effects and, where

indicated, qualities of materials and execution; to review coordination, testing, or operation; to show interface between dissimilar materials; and to demonstrate compliance with specified installation tolerances. Mockups are not Samples. Unless otherwise indicated, approved mockups establish the standard by which the Work will be judged.

- D. Preconstruction Testing: Tests and inspections performed specifically for Project before products and materials are incorporated into the Work, to verify performance or compliance with specified criteria.
- E. Product Testing: Tests and inspections that are performed by an NRTL, an NVLAP, or a testing agency qualified to conduct product testing and acceptable to authorities having jurisdiction, to establish product performance and compliance with specified requirements.
- F. Source Quality-Control Testing: Tests and inspections that are performed at the source, e.g., plant, mill, factory, or shop.
- G. Field Quality-Control Testing: Tests and inspections that are performed on-site for installation of the Work and for completed Work.
- H. Testing Agency: An entity engaged to perform specific tests, inspections, or both. Testing laboratory shall mean the same as testing agency.
- I. Installer/Applicator/Erector: Contractor or another entity engaged by Contractor as an employee, Subcontractor, or Sub-subcontractor, to perform a particular construction operation, including installation, erection, application, and similar operations.
 - 1. Use of trade-specific terminology in referring to a trade or entity does not require that certain construction activities be performed by accredited or unionized individuals, or that requirements specified apply exclusively to specific trade(s).
- J. Experienced: When used with an entity or individual, "experienced" means having successfully completed a minimum of five previous projects similar in nature, size, and extent to this Project; being familiar with special requirements indicated; and having complied with requirements of authorities having jurisdiction.

1.4 CONFLICTING REQUIREMENTS

- A. Referenced Standards: If compliance with two or more standards is specified and the standards establish different or conflicting requirements for minimum quantities or quality levels, comply with the most stringent requirement. Refer conflicting requirements that are different, but apparently equal, to Architect for a decision before proceeding.
- B. Minimum Quantity or Quality Levels: The quantity or quality level shown or specified shall be the minimum provided or performed. The actual installation may comply exactly with the minimum quantity or quality specified, or it may exceed the minimum within reasonable limits. To comply with these requirements, indicated numeric values are minimum or maximum, as appropriate, for the context of requirements. Refer uncertainties to Architect for a decision before proceeding.

1.5 INFORMATIONAL SUBMITTALS

- A. Contractor's Quality-Control Plan: For quality-assurance and quality-control activities and responsibilities.
- B. Qualification Data: For Contractor's quality-control personnel.
- C. Contractor's Statement of Responsibility: When required by authorities having jurisdiction, submit copy of written statement of responsibility sent to authorities having jurisdiction before starting work on the following systems:
 - 1. Seismic-force-resisting system, designated seismic system, or component listed in the designated seismic system quality-assurance plan prepared by Architect.
 - 2. Main wind-force-resisting system or a wind-resisting component listed in the wind-force-resisting system quality-assurance plan prepared by Architect.
- D. Testing Agency Qualifications: For testing agencies specified in "Quality Assurance" Article to demonstrate their capabilities and experience. Include proof of qualifications in the form of a recent report on the inspection of the testing agency by a recognized authority.
- E. Schedule of Tests and Inspections: Prepare in tabular form and include the following:
 - 1. Specification Section number and title.
 - 2. Entity responsible for performing tests and inspections.
 - 3. Description of test and inspection.
 - 4. Identification of applicable standards.
 - 5. Identification of test and inspection methods.
 - 6. Number of tests and inspections required.
 - 7. Time schedule or time span for tests and inspections.
 - 8. Requirements for obtaining samples.
 - 9. Unique characteristics of each quality-control service.

1.6 CONTRACTOR'S QUALITY-CONTROL PLAN

- A. Quality-Control Plan, General: Submit quality-control plan within 10 days of Notice to Proceed, and not less than five days prior to preconstruction conference. Submit in format acceptable to Architect. Identify personnel, procedures, controls, instructions, tests, records, and forms to be used to carry out Contractor's quality-assurance and quality-control responsibilities. Coordinate with Contractor's construction schedule.
- B. Quality-Control Personnel Qualifications: Engage qualified full-time personnel trained and experienced in managing and executing quality-assurance and quality-control procedures similar in nature and extent to those required for Project.
 - 1. Project quality-control manager may also serve as Project superintendent.
- C. Submittal Procedure: Describe procedures for ensuring compliance with requirements through review and management of submittal process. Indicate qualifications of personnel responsible for submittal review.

- D. **Testing and Inspection:** In quality-control plan, include a comprehensive schedule of Work requiring testing or inspection, including the following:
1. Contractor-performed tests and inspections including subcontractor-performed tests and inspections. Include required tests and inspections and Contractor-elected tests and inspections.
 2. Special inspections required by authorities having jurisdiction and indicated on the "Statement of Special Inspections."
- E. **Continuous Inspection of Workmanship:** Describe process for continuous inspection during construction to identify and correct deficiencies in workmanship in addition to testing and inspection specified. Indicate types of corrective actions to be required to bring work into compliance with standards of workmanship established by Contract requirements and approved mockups.
- F. **Monitoring and Documentation:** Maintain testing and inspection reports including log of approved and rejected results. Include work Architect has indicated as nonconforming or defective. Indicate corrective actions taken to bring nonconforming work into compliance with requirements. Comply with requirements of authorities having jurisdiction.

1.7 REPORTS AND DOCUMENTS

- A. **Test and Inspection Reports:** Prepare and submit certified written reports specified in other Sections. Include the following:
1. Date of issue.
 2. Project title and number.
 3. Name, address, and telephone number of testing agency.
 4. Dates and locations of samples and tests or inspections.
 5. Names of individuals making tests and inspections.
 6. Description of the Work and test and inspection method.
 7. Identification of product and Specification Section.
 8. Complete test or inspection data.
 9. Test and inspection results and an interpretation of test results.
 10. Record of temperature and weather conditions at time of sample taking and testing and inspecting.
 11. Comments or professional opinion on whether tested or inspected Work complies with the Contract Document requirements.
 12. Name and signature of laboratory inspector.
 13. Recommendations on retesting and reinspecting.
- B. **Manufacturer's Technical Representative's Field Reports:** Prepare written information documenting manufacturer's technical representative's tests and inspections specified in other Sections. Include the following:
1. Name, address, and telephone number of technical representative making report.
 2. Statement on condition of substrates and their acceptability for installation of product.
 3. Statement that products at Project site comply with requirements.

4. Summary of installation procedures being followed, whether they comply with requirements and, if not, what corrective action was taken.
 5. Results of operational and other tests and a statement of whether observed performance complies with requirements.
 6. Statement whether conditions, products, and installation will affect warranty.
 7. Other required items indicated in individual Specification Sections.
- C. Factory-Authorized Service Representative's Reports: Prepare written information documenting manufacturer's factory-authorized service representative's tests and inspections specified in other Sections. Include the following:
1. Name, address, and telephone number of factory-authorized service representative making report.
 2. Statement that equipment complies with requirements.
 3. Results of operational and other tests and a statement of whether observed performance complies with requirements.
 4. Statement whether conditions, products, and installation will affect warranty.
 5. Other required items indicated in individual Specification Sections.
- D. Permits, Licenses, and Certificates: For Owner's records, submit copies of permits, licenses, certifications, inspection reports, releases, jurisdictional settlements, notices, receipts for fee payments, judgments, correspondence, records, and similar documents, established for compliance with standards and regulations bearing on performance of the Work.

1.8 QUALITY ASSURANCE

- A. General: Qualifications paragraphs in this article establish the minimum qualification levels required; individual Specification Sections specify additional requirements.
- B. Manufacturer Qualifications: A firm experienced in manufacturing products or systems similar to those indicated for this Project and with a record of successful in-service performance, as well as sufficient production capacity to produce required units.
- C. Fabricator Qualifications: A firm experienced in producing products similar to those indicated for this Project and with a record of successful in-service performance, as well as sufficient production capacity to produce required units.
- D. Installer Qualifications: A firm or individual experienced in installing, erecting, or assembling work similar in material, design, and extent to that indicated for this Project, whose work has resulted in construction with a record of successful in-service performance.
- E. Professional Engineer Qualifications: A professional engineer who is legally qualified to practice in jurisdiction where Project is located and who is experienced in providing engineering services of the kind indicated. Engineering services are defined as those performed for installations of the system, assembly, or product that are similar in material, design, and extent to those indicated for this Project.

- F. Specialists: Certain Specification Sections require that specific construction activities shall be performed by entities who are recognized experts in those operations. Specialists shall satisfy qualification requirements indicated and shall be engaged for the activities indicated.
1. Requirements of authorities having jurisdiction shall supersede requirements for specialists.
- G. Testing Agency Qualifications: An NRTL, an NVLAP, or an independent agency with the experience and capability to conduct testing and inspecting indicated, as documented according to ASTM E 329; and with additional qualifications specified in individual Sections; and, where required by authorities having jurisdiction, that is acceptable to authorities.
1. NRTL: A nationally recognized testing laboratory according to 29 CFR 1910.7.
 2. NVLAP: A testing agency accredited according to NIST's National Voluntary Laboratory Accreditation Program.
- H. Manufacturer's Technical Representative Qualifications: An authorized representative of manufacturer who is trained and approved by manufacturer to observe and inspect installation of manufacturer's products that are similar in material, design, and extent to those indicated for this Project.
- I. Factory-Authorized Service Representative Qualifications: An authorized representative of manufacturer who is trained and approved by manufacturer to inspect installation of manufacturer's products that are similar in material, design, and extent to those indicated for this Project.
- J. Mockups: Before installing portions of the Work requiring mockups, build mockups for each form of construction and finish required to comply with the following requirements, using materials indicated for the completed Work:
1. Build mockups in location and of size indicated or, if not indicated, as directed by Architect.
 2. Notify Architect seven days in advance of dates and times when mockups will be constructed.
 3. Employ supervisory personnel who will oversee mockup construction. Employ workers that will be employed during the construction at Project.
 4. Demonstrate the proposed range of aesthetic effects and workmanship.
 5. Obtain Architect's approval of mockups before starting work, fabrication, or construction.
 - a. Allow seven days for initial review and each re-review of each mockup.
 6. Maintain mockups during construction in an undisturbed condition as a standard for judging the completed Work.
 7. Demolish and remove mockups when directed unless otherwise indicated.
- K. Integrated Exterior Mockups: Construct integrated exterior mockup as indicated on Drawings. Coordinate installation of exterior envelope materials and products for which mockups are required in individual Specification Sections, along with supporting materials.

1.9 QUALITY CONTROL

- A. **Owner Responsibilities:** Where quality-control services are indicated as Owner's responsibility, Owner will engage a qualified testing agency to perform these services.
1. Owner will furnish Contractor with names, addresses, and telephone numbers of testing agencies engaged and a description of types of testing and inspecting they are engaged to perform.
 2. Costs for retesting and reinspecting construction that replaces or is necessitated by work that failed to comply with the Contract Documents will be charged to Contractor, and the Contract Sum will be adjusted by Change Order.
- B. **Contractor Responsibilities:** Tests and inspections not explicitly assigned to Owner are Contractor's responsibility. Perform additional quality-control activities required to verify that the Work complies with requirements, whether specified or not.
1. Unless otherwise indicated, provide quality-control services specified and those required by authorities having jurisdiction. Perform quality-control services required of Contractor by authorities having jurisdiction, whether specified or not.
 2. Where services are indicated as Contractor's responsibility, engage a qualified testing agency to perform these quality-control services.
 - a. Contractor shall not employ same entity engaged by Owner, unless agreed to in writing by Owner.
 3. Notify testing agencies at least 24 hours in advance of time when Work that requires testing or inspecting will be performed.
 4. Where quality-control services are indicated as Contractor's responsibility, submit a certified written report, in duplicate, of each quality-control service.
 5. Testing and inspecting requested by Contractor and not required by the Contract Documents are Contractor's responsibility.
 6. Submit additional copies of each written report directly to authorities having jurisdiction, when they so direct.
- C. **Manufacturer's Field Services:** Where indicated, engage a factory-authorized service representative to inspect field-assembled components and equipment installation, including service connections. Report results in writing as specified in Section 013300 "Submittal Procedures."
- D. **Manufacturer's Technical Services:** Where indicated, engage a manufacturer's technical representative to observe and inspect the Work. Manufacturer's technical representative's services include participation in preinstallation conferences, examination of substrates and conditions, verification of materials, observation of Installer activities, inspection of completed portions of the Work, and submittal of written reports.
- E. **Retesting/Reinspecting:** Regardless of whether original tests or inspections were Contractor's responsibility, provide quality-control services, including retesting and reinspecting, for construction that replaced Work that failed to comply with the Contract Documents.

- F. Testing Agency Responsibilities: Cooperate with Architect, Commissioning Authority and Contractor in performance of duties. Provide qualified personnel to perform required tests and inspections.
1. Notify Architect, Commissioning Authority, and Contractor promptly of irregularities or deficiencies observed in the Work during performance of its services.
 2. Determine the location from which test samples will be taken and in which in-situ tests are conducted.
 3. Conduct and interpret tests and inspections and state in each report whether tested and inspected work complies with or deviates from requirements.
 4. Submit a certified written report, in duplicate, of each test, inspection, and similar quality-control service through Contractor.
 5. Do not release, revoke, alter, or increase the Contract Document requirements or approve or accept any portion of the Work.
 6. Do not perform any duties of Contractor.
- G. Associated Services: Cooperate with agencies performing required tests, inspections, and similar quality-control services, and provide reasonable auxiliary services as requested. Notify agency sufficiently in advance of operations to permit assignment of personnel. Provide the following:
1. Access to the Work.
 2. Incidental labor and facilities necessary to facilitate tests and inspections.
 3. Adequate quantities of representative samples of materials that require testing and inspecting. Assist agency in obtaining samples.
 4. Facilities for storage and field curing of test samples.
 5. Delivery of samples to testing agencies.
 6. Preliminary design mix proposed for use for material mixes that require control by testing agency.
 7. Security and protection for samples and for testing and inspecting equipment at Project site.
- H. Coordination: Coordinate sequence of activities to accommodate required quality-assurance and -control services with a minimum of delay and to avoid necessity of removing and replacing construction to accommodate testing and inspecting.
1. Schedule times for tests, inspections, obtaining samples, and similar activities.
- I. Schedule of Tests and Inspections: Prepare a schedule of tests, inspections, and similar quality-control services required by the Contract Documents as a component of Contractor's quality-control plan. Coordinate and submit concurrently with Contractor's construction schedule. Update as the Work progresses.
1. Distribution: Distribute schedule to Owner, Architect, Commissioning Authority, testing agencies, and each party involved in performance of portions of the Work where tests and inspections are required.

1.10 SPECIAL TESTS AND INSPECTIONS

- A. Special Tests and Inspections: Conducted by a qualified testing agency as required by authorities having jurisdiction, as indicated in individual Specification Sections, and as follows:
1. Verifying that manufacturer maintains detailed fabrication and quality-control procedures and reviews the completeness and adequacy of those procedures to perform the Work.
 2. Notifying Architect, Commissioning Authority, and Contractor promptly of irregularities and deficiencies observed in the Work during performance of its services.
 3. Submitting a certified written report of each test, inspection, and similar quality-control service to Architect and Commissioning Authority with copy to Contractor and to authorities having jurisdiction.
 4. Submitting a final report of special tests and inspections at Substantial Completion, which includes a list of unresolved deficiencies.
 5. Interpreting tests and inspections and stating in each report whether tested and inspected work complies with or deviates from the Contract Documents.
 6. Retesting and reinspecting corrected work.

PART 2 - PRODUCTS (Not Used)

PART 3 - EXECUTION

3.1 TEST AND INSPECTION LOG

- A. Test and Inspection Log: Prepare a record of tests and inspections. Include the following:
1. Date test or inspection was conducted.
 2. Description of the Work tested or inspected.
 3. Date test or inspection results were transmitted to Architect.
 4. Identification of testing agency or special inspector conducting test or inspection.
- B. Maintain log at Project site. Post changes and revisions as they occur. Provide access to test and inspection log for Architect's, Commissioning Authority's, reference during normal working hours.

3.2 REPAIR AND PROTECTION

- A. General: On completion of testing, inspecting, sample taking, and similar services, repair damaged construction and restore substrates and finishes.
1. Provide materials and comply with installation requirements specified in other Specification Sections or matching existing substrates and finishes. Restore patched areas and extend restoration into adjoining areas with durable seams that are as invisible as possible. Comply with the Contract Document requirements for cutting and patching in Section 017300 "Execution."
- B. Protect construction exposed by or for quality-control service activities.

- C. Repair and protection are Contractor's responsibility, regardless of the assignment of responsibility for quality-control services.

END OF SECTION 014000

SECTION 014200 - REFERENCES

PART 1 - GENERAL

1.1 RELATED DOCUMENTS

- A. Drawings and general provisions of the Contract, including General and Supplementary Conditions and other Division 01 Specification Sections, apply to this Section.

1.2 DEFINITIONS

- A. General: Basic Contract definitions are included in the Conditions of the Contract.
- B. "Approved": When used to convey Architect's action on Contractor's submittals, applications, and requests, "approved" is limited to Architect's duties and responsibilities as stated in the Conditions of the Contract.
- C. "Directed": A command or instruction by Architect. Other terms including "requested," "authorized," "selected," "required," and "permitted" have the same meaning as "directed."
- D. "Indicated": Requirements expressed by graphic representations or in written form on Drawings, in Specifications, and in other Contract Documents. Other terms including "shown," "noted," "scheduled," and "specified" have the same meaning as "indicated."
- E. "Regulations": Laws, ordinances, statutes, and lawful orders issued by authorities having jurisdiction, and rules, conventions, and agreements within the construction industry that control performance of the Work.
- F. "Furnish": Supply and deliver to Project site, ready for unloading, unpacking, assembly, installation, and similar operations.
- G. "Install": Unload, temporarily store, unpack, assemble, erect, place, anchor, apply, work to dimension, finish, cure, protect, clean, and similar operations at Project site.
- H. "Provide": Furnish and install, complete and ready for the intended use.
- I. "Project Site": Space available for performing construction activities. The extent of Project site is shown on Drawings and may or may not be identical with the description of the land on which Project is to be built.

1.3 INDUSTRY STANDARDS

- A. Applicability of Standards: Unless the Contract Documents include more stringent requirements, applicable construction industry standards have the same force and effect as if bound or copied directly into the Contract Documents to the extent referenced. Such standards are made a part of the Contract Documents by reference.

- B. Publication Dates: Comply with standards in effect as of date of the Contract Documents unless otherwise indicated.
- C. Copies of Standards: Each entity engaged in construction on Project should be familiar with industry standards applicable to its construction activity. Copies of applicable standards are not bound with the Contract Documents.
 - 1. Where copies of standards are needed to perform a required construction activity, obtain copies directly from publication source.

1.4 ABBREVIATIONS AND ACRONYMS

- A. Industry Organizations: Where abbreviations and acronyms are used in Specifications or other Contract Documents, they shall mean the recognized name of the entities indicated in Gale's "Encyclopedia of Associations: National Organizations of the U.S." or in Columbia Books' "National Trade & Professional Associations of the United States."
- B. Industry Organizations: Where abbreviations and acronyms are used in Specifications or other Contract Documents, they shall mean the recognized name of the entities in the following list. This information is subject to change and is believed to be accurate as of the date of the Contract Documents.
 - 1. AABC - Associated Air Balance Council; www.aabc.com.
 - 2. AAMA - American Architectural Manufacturers Association; www.aamanet.org.
 - 3. AAPFCO - Association of American Plant Food Control Officials; www.aapfco.org.
 - 4. AASHTO - American Association of State Highway and Transportation Officials; www.transportation.org.
 - 5. AATCC - American Association of Textile Chemists and Colorists; www.aatcc.org.
 - 6. ABMA - American Bearing Manufacturers Association; www.americanbearings.org.
 - 7. ACI - American Concrete Institute; (Formerly: ACI International); www.concrete.org.
 - 8. ACPA - American Concrete Pipe Association; www.concrete-pipe.org.
 - 9. AEIC - Association of Edison Illuminating Companies, Inc. (The); www.aeic.org.
 - 10. AF&PA - American Forest & Paper Association; www.afandpa.org.
 - 11. AGA - American Gas Association; www.aga.org.
 - 12. AHAM - Association of Home Appliance Manufacturers; www.aham.org.
 - 13. AHRI - Air-Conditioning, Heating, and Refrigeration Institute (The); www.ahrinet.org.
 - 14. AI - Asphalt Institute; www.asphaltinstitute.org.
 - 15. AIA - American Institute of Architects (The); www.aia.org.
 - 16. AISC - American Institute of Steel Construction; www.aisc.org.
 - 17. AISI - American Iron and Steel Institute; www.steel.org.
 - 18. AITC - American Institute of Timber Construction; www.aitc-glulam.org.
 - 19. AMCA - Air Movement and Control Association International, Inc.; www.amca.org.
 - 20. ANSI - American National Standards Institute; www.ansi.org.
 - 21. AOSA - Association of Official Seed Analysts, Inc.; www.aosaseed.com.
 - 22. APA - APA - The Engineered Wood Association; www.apawood.org.
 - 23. APA - Architectural Precast Association; www.archprecast.org.
 - 24. API - American Petroleum Institute; www.api.org.
 - 25. ARI - Air-Conditioning & Refrigeration Institute; (See AHRI).
 - 26. ARI - American Refrigeration Institute; (See AHRI).
 - 27. ARMA - Asphalt Roofing Manufacturers Association; www.asphaltroofing.org.

28. ASCE - American Society of Civil Engineers; www.asce.org.
29. ASCE/SEI - American Society of Civil Engineers/Structural Engineering Institute; (See ASCE).
30. ASHRAE - American Society of Heating, Refrigerating and Air-Conditioning Engineers; www.ashrae.org.
31. ASME - ASME International; (American Society of Mechanical Engineers); www.asme.org.
32. ASSE - American Society of Safety Engineers (The); www.asse.org.
33. ASSE - American Society of Sanitary Engineering; www.asse-plumbing.org.
34. ASTM - ASTM International; (American Society for Testing and Materials International); www.astm.org.
35. ATIS - Alliance for Telecommunications Industry Solutions; www.atis.org.
36. AWEA - American Wind Energy Association; www.awea.org.
37. AWI - Architectural Woodwork Institute; www.awinet.org.
38. AWMAC - Architectural Woodwork Manufacturers Association of Canada; www.awmac.com.
39. AWPA - American Wood Protection Association; (Formerly: American Wood-Preservers' Association); www.awpa.com.
40. AWS - American Welding Society; www.aws.org.
41. AWWA - American Water Works Association; www.awwa.org.
42. BHMA - Builders Hardware Manufacturers Association; www.buildershardware.com.
43. BIA - Brick Industry Association (The); www.gobrick.com.
44. BICSI - BICSI, Inc.; www.bicsi.org.
45. BIFMA - BIFMA International; (Business and Institutional Furniture Manufacturer's Association); www.bifma.com.
46. BISSC - Baking Industry Sanitation Standards Committee; www.bissc.org.
47. BOCA - BOCA; (Building Officials and Code Administrators International Inc.); (See ICC).
48. BWF - Badminton World Federation; (Formerly: International Badminton Federation); www.bwfbadminton.org.
49. CDA - Copper Development Association; www.copper.org.
50. CEA - Canadian Electricity Association; www.electricity.ca.
51. CEA - Consumer Electronics Association; www.ce.org.
52. CFFA - Chemical Fabrics & Film Association, Inc.; www.chemicalfabricsandfilm.com.
53. CFSEI - Cold-Formed Steel Engineers Institute; www.cfsei.org.
54. CGA - Compressed Gas Association; www.cganet.com.
55. CIMA - Cellulose Insulation Manufacturers Association; www.cellulose.org.
56. CISCA - Ceilings & Interior Systems Construction Association; www.cisca.org.
57. CISPI - Cast Iron Soil Pipe Institute; www.cispi.org.
58. CLFMI - Chain Link Fence Manufacturers Institute; www.chainlinkinfo.org.
59. CPA - Composite Panel Association; www.pbmdf.com.
60. CRI - Carpet and Rug Institute (The); www.carpet-rug.org.
61. CRRC - Cool Roof Rating Council; www.coolroofs.org.
62. CRSI - Concrete Reinforcing Steel Institute; www.crsi.org.
63. CSA - Canadian Standards Association; www.csa.ca.
64. CSA - CSA International; (Formerly: IAS - International Approval Services); www.csa-international.org.
65. CSI - Construction Specifications Institute (The); www.csinet.org.
66. CSSB - Cedar Shake & Shingle Bureau; www.cedarbureau.org.
67. CTI - Cooling Technology Institute; (Formerly: Cooling Tower Institute); www.cti.org.
68. CWC - Composite Wood Council; (See CPA).

69. DASMA - Door and Access Systems Manufacturers Association; www.dasma.com.
70. DHI - Door and Hardware Institute; www.dhi.org.
71. ECA - Electronic Components Association; www.ec-central.org.
72. ECAMA - Electronic Components Assemblies & Materials Association; (See ECA).
73. EIA - Electronic Industries Alliance; (See TIA).
74. EIMA - EIFS Industry Members Association; www.eima.com.
75. EJMA - Expansion Joint Manufacturers Association, Inc.; www.ejma.org.
76. ESD - ESD Association; (Electrostatic Discharge Association); www.esda.org.
77. ESTA - Entertainment Services and Technology Association; (See PLASA).
78. EVO - Efficiency Valuation Organization; www.evo-world.org.
79. FIBA - Federation Internationale de Basketball; (The International Basketball Federation); www.fiba.com.
80. FIVB - Federation Internationale de Volleyball; (The International Volleyball Federation); www.fivb.org.
81. FM Approvals - FM Approvals LLC; www.fmglobal.com.
82. FM Global - FM Global; (Formerly: FMG - FM Global); www.fmglobal.com.
83. FRSA - Florida Roofing, Sheet Metal & Air Conditioning Contractors Association, Inc.; www.floridarooft.com.
84. FSA - Fluid Sealing Association; www.fluidsealing.com.
85. FSC - Forest Stewardship Council U.S.; www.fscus.org.
86. GA - Gypsum Association; www.gypsum.org.
87. GANA - Glass Association of North America; www.glasswebsite.com.
88. GS - Green Seal; www.greenseal.org.
89. HI - Hydraulic Institute; www.pumps.org.
90. HI/GAMA - Hydronics Institute/Gas Appliance Manufacturers Association; (See AHRI).
91. HMMA - Hollow Metal Manufacturers Association; (See NAAMM).
92. HPVA - Hardwood Plywood & Veneer Association; www.hpva.org.
93. HPW - H. P. White Laboratory, Inc.; www.hpwhite.com.
94. IAPSC - International Association of Professional Security Consultants; www.iapsc.org.
95. IAS - International Approval Services; (See CSA).
96. ICBO - International Conference of Building Officials; (See ICC).
97. ICC - International Code Council; www.iccsafe.org.
98. ICEA - Insulated Cable Engineers Association, Inc.; www.icea.net.
99. ICPA - International Cast Polymer Alliance; www.icpa-hq.org.
100. ICRI - International Concrete Repair Institute, Inc.; www.icri.org.
101. IEC - International Electrotechnical Commission; www.iec.ch.
102. IEEE - Institute of Electrical and Electronics Engineers, Inc. (The); www.ieee.org.
103. IES - Illuminating Engineering Society; (Formerly: Illuminating Engineering Society of North America); www.ies.org.
104. IESNA - Illuminating Engineering Society of North America; (See IES).
105. IEST - Institute of Environmental Sciences and Technology; www.iest.org.
106. IGMA - Insulating Glass Manufacturers Alliance; www.igmaonline.org.
107. IGSHPA - International Ground Source Heat Pump Association; www.igshpa.okstate.edu.
108. ILI - Indiana Limestone Institute of America, Inc.; www.iliai.com.
109. Intertek - Intertek Group; (Formerly: ETL SEMCO; Intertek Testing Service NA); www.intertek.com.
110. ISA - International Society of Automation (The); (Formerly: Instrumentation, Systems, and Automation Society); www.isa.org.
111. ISAS - Instrumentation, Systems, and Automation Society (The); (See ISA).

112. ISFA - International Surface Fabricators Association; (Formerly: International Solid Surface Fabricators Association); www.isfanow.org.
113. ISO - International Organization for Standardization; www.iso.org.
114. ISSFA - International Solid Surface Fabricators Association; (See ISFA).
115. ITU - International Telecommunication Union; www.itu.int/home.
116. KCMA - Kitchen Cabinet Manufacturers Association; www.kcma.org.
117. LMA - Laminating Materials Association; (See CPA).
118. LPI - Lightning Protection Institute; www.lightning.org.
119. MBMA - Metal Building Manufacturers Association; www.mbma.com.
120. MCA - Metal Construction Association; www.metalconstruction.org.
121. MFMA - Maple Flooring Manufacturers Association, Inc.; www.maplefloor.org.
122. MFMA - Metal Framing Manufacturers Association, Inc.; www.metalframingmfg.org.
123. MHIA - Material Handling Industry of America; www.mhia.org.
124. MIA - Marble Institute of America; www.marble-institute.com.
125. MMPA - Moulding & Millwork Producers Association; (Formerly: Wood Moulding & Millwork Producers Association); www.wmmpa.com.
126. MPI - Master Painters Institute; www.paintinfo.com.
127. MSS - Manufacturers Standardization Society of The Valve and Fittings Industry Inc.; www.mss-hq.org.
128. NAAMM - National Association of Architectural Metal Manufacturers; www.naamm.org.
129. NACE - NACE International; (National Association of Corrosion Engineers International); www.nace.org.
130. NADCA - National Air Duct Cleaners Association; www.nadca.com.
131. NAIMA - North American Insulation Manufacturers Association; www.naima.org.
132. NBGQA - National Building Granite Quarries Association, Inc.; www.nbgqa.com.
133. NCAA - National Collegiate Athletic Association (The); www.ncaa.org.
134. NCMA - National Concrete Masonry Association; www.ncma.org.
135. NEBB - National Environmental Balancing Bureau; www.nebb.org.
136. NECA - National Electrical Contractors Association; www.necanet.org.
137. NeLMA - Northeastern Lumber Manufacturers Association; www.nelma.org.
138. NEMA - National Electrical Manufacturers Association; www.nema.org.
139. NETA - InterNational Electrical Testing Association; www.netaworld.org.
140. NFHS - National Federation of State High School Associations; www.nfhs.org.
141. NFPA - NFPA; (National Fire Protection Association); www.nfpa.org.
142. NFPA - NFPA International; (See NFPA).
143. NFRC - National Fenestration Rating Council; www.nfrc.org.
144. NHLA - National Hardwood Lumber Association; www.nhla.com.
145. NLGA - National Lumber Grades Authority; www.nlga.org.
146. NOFMA - National Oak Flooring Manufacturers Association; (See NWFA).
147. NOMMA - National Ornamental & Miscellaneous Metals Association; www.nomma.org.
148. NRCA - National Roofing Contractors Association; www.nrca.net.
149. NRMCA - National Ready Mixed Concrete Association; www.nrmca.org.
150. NSF - NSF International; (National Sanitation Foundation International); www.nsf.org.
151. NSPE - National Society of Professional Engineers; www.nspe.org.
152. NSSGA - National Stone, Sand & Gravel Association; www.nssga.org.
153. NTMA - National Terrazzo & Mosaic Association, Inc. (The); www.ntma.com.
154. NWFA - National Wood Flooring Association; www.nwfa.org.
155. PCI - Precast/Prestressed Concrete Institute; www.pci.org.
156. PDI - Plumbing & Drainage Institute; www.pdionline.org.

157. PLASA - PLASA; (Formerly: ESTA - Entertainment Services and Technology Association); www.plasa.org.
158. RCSC - Research Council on Structural Connections; www.boltcouncil.org.
159. RFCI - Resilient Floor Covering Institute; www.rfci.com.
160. RIS - Redwood Inspection Service; www.redwoodinspection.com.
161. SAE - SAE International; (Society of Automotive Engineers); www.sae.org.
162. SCTE - Society of Cable Telecommunications Engineers; www.scte.org.
163. SDI - Steel Deck Institute; www.sdi.org.
164. SDI - Steel Door Institute; www.steeldoor.org.
165. SEFA - Scientific Equipment and Furniture Association; www.sefalabs.com.
166. SEI/ASCE - Structural Engineering Institute/American Society of Civil Engineers; (See ASCE).
167. SIA - Security Industry Association; www.siaonline.org.
168. SJI - Steel Joist Institute; www.steeljoist.org.
169. SMA - Screen Manufacturers Association; www.smainfo.org.
170. SMACNA - Sheet Metal and Air Conditioning Contractors' National Association; www.smacna.org.
171. SMPTE - Society of Motion Picture and Television Engineers; www.smpte.org.
172. SPFA - Spray Polyurethane Foam Alliance; www.sprayfoam.org.
173. SPIB - Southern Pine Inspection Bureau; www.spib.org.
174. SPRI - Single Ply Roofing Industry; www.spri.org.
175. SRCC - Solar Rating and Certification Corporation; www.solar-rating.org.
176. SSINA - Specialty Steel Industry of North America; www.ssina.com.
177. SSPC - SSPC: The Society for Protective Coatings; www.sspc.org.
178. STI - Steel Tank Institute; www.steeltank.com.
179. SWI - Steel Window Institute; www.steelwindows.com.
180. SWPA - Submersible Wastewater Pump Association; www.swpa.org.
181. TCA - Tilt-Up Concrete Association; www.tilt-up.org.
182. TCNA - Tile Council of North America, Inc.; (Formerly: Tile Council of America); www.tileusa.com.
183. TEMA - Tubular Exchanger Manufacturers Association, Inc.; www.tema.org.
184. TIA - Telecommunications Industry Association; (Formerly: TIA/EIA - Telecommunications Industry Association/Electronic Industries Alliance); www.tiaonline.org.
185. TIA/EIA - Telecommunications Industry Association/Electronic Industries Alliance; (See TIA).
186. TMS - The Masonry Society; www.masonrysociety.org.
187. TPI - Truss Plate Institute; www.tpinst.org.
188. TPI - Turfgrass Producers International; www.turfgrasssod.org.
189. TRI - Tile Roofing Institute; www.tilerroofing.org.
190. UBC - Uniform Building Code; (See ICC).
191. UL - Underwriters Laboratories Inc.; www.ul.com.
192. UNI - Uni-Bell PVC Pipe Association; www.uni-bell.org.
193. USAV - USA Volleyball; www.usavolleyball.org.
194. USGBC - U.S. Green Building Council; www.usgbc.org.
195. USITT - United States Institute for Theatre Technology, Inc.; www.usitt.org.
196. WASTEC - Waste Equipment Technology Association; www.wastec.org.
197. WCLIB - West Coast Lumber Inspection Bureau; www.wclib.org.
198. WCMA - Window Covering Manufacturers Association; www.wcmanet.org.
199. WDMA - Window & Door Manufacturers Association; www.wdma.com.

200. WI - Woodwork Institute; (Formerly: WIC - Woodwork Institute of California); www.wicnet.org.
201. WMMPA - Wood Moulding & Millwork Producers Association; (See MMPA).
202. WSRCA - Western States Roofing Contractors Association; www.wsrca.com.
203. WPA - Western Wood Products Association; www.wwpa.org.

C. Code Agencies: Where abbreviations and acronyms are used in Specifications or other Contract Documents, they shall mean the recognized name of the entities in the following list. This information is believed to be accurate as of the date of the Contract Documents.

1. DIN - Deutsches Institut für Normung e.V.; www.din.de.
2. IAPMO - International Association of Plumbing and Mechanical Officials; www.iapmo.org.
3. ICC - International Code Council; www.iccsafe.org.
4. ICC-ES - ICC Evaluation Service, LLC; www.icc-es.org.

D. Federal Government Agencies: Where abbreviations and acronyms are used in Specifications or other Contract Documents, they shall mean the recognized name of the entities in the following list. Information is subject to change and is up-to-date as of the date of the Contract Documents.

1. COE - Army Corps of Engineers; www.usace.army.mil.
2. CPSC - Consumer Product Safety Commission; www.cpsc.gov.
3. DOC - Department of Commerce; National Institute of Standards and Technology; www.nist.gov.
4. DOD - Department of Defense; <http://dodssp.daps.dla.mil>.
5. DOE - Department of Energy; www.energy.gov.
6. EPA - Environmental Protection Agency; www.epa.gov.
7. FAA - Federal Aviation Administration; www.faa.gov.
8. FG - Federal Government Publications; www.gpo.gov.
9. GSA - General Services Administration; www.gsa.gov.
10. HUD - Department of Housing and Urban Development; www.hud.gov.
11. LBL - Lawrence Berkeley National Laboratory; Environmental Energy Technologies Division; <http://eetd.lbl.gov>.
12. OSHA - Occupational Safety & Health Administration; www.osha.gov.
13. SD - Department of State; www.state.gov.
14. TRB - Transportation Research Board; National Cooperative Highway Research Program; www.trb.org.
15. USDA - Department of Agriculture; Agriculture Research Service; U.S. Salinity Laboratory; www.ars.usda.gov.
16. USDA - Department of Agriculture; Rural Utilities Service; www.usda.gov.
17. USDJ - Department of Justice; Office of Justice Programs; National Institute of Justice; www.ojp.usdoj.gov.
18. USP - U.S. Pharmacopeia; www.usp.org.
19. USPS - United States Postal Service; www.usps.com.

E. Standards and Regulations: Where abbreviations and acronyms are used in Specifications or other Contract Documents, they shall mean the recognized name of the standards and regulations in the following list. This information is subject to change and is believed to be accurate as of the date of the Contract Documents.

1. CFR - Code of Federal Regulations; Available from Government Printing Office; www.gpo.gov/fdsys.
2. DOD - Department of Defense; Military Specifications and Standards; Available from Department of Defense Single Stock Point; <http://dodssp.daps.dla.mil>.
3. DSCC - Defense Supply Center Columbus; (See FS).
4. FED-STD - Federal Standard; (See FS).
5. FS - Federal Specification; Available from Department of Defense Single Stock Point; <http://dodssp.daps.dla.mil>.
 - a. Available from Defense Standardization Program; www.dsp.dla.mil.
 - b. Available from General Services Administration; www.gsa.gov.
 - c. Available from National Institute of Building Sciences/Whole Building Design Guide; www.wbdg.org/ccb.
6. MILSPEC - Military Specification and Standards; (See DOD).
7. USAB - United States Access Board; www.access-board.gov.
8. USATBCB - U.S. Architectural & Transportation Barriers Compliance Board; (See USAB).

F. State Government Agencies: Where abbreviations and acronyms are used in Specifications or other Contract Documents, they shall mean the recognized name of the entities in the following list. This information is subject to change and is believed to be accurate as of the date of the Contract Documents.

1. CBHF - State of California; Department of Consumer Affairs; Bureau of Electronic Appliance and Repair, Home Furnishings and Thermal Insulation; www.bearhfti.ca.gov.
2. CCR - California Code of Regulations; Office of Administrative Law; California Title 24 Energy Code; www.calregs.com.
3. CDHS - California Department of Health Services; (See CDPH).
4. CDPH - California Department of Public Health; Indoor Air Quality Program; www.cal-iaq.org.
5. CPUC - California Public Utilities Commission; www.cpuc.ca.gov.
6. SCAQMD - South Coast Air Quality Management District; www.aqmd.gov.
7. TFS - Texas Forest Service; Forest Resource Development and Sustainable Forestry; <http://txforests-service.tamu.edu>.

PART 2 - PRODUCTS (Not Used)

PART 3 - EXECUTION (Not Used)

END OF SECTION 014200

SECTION 015000 – TEMPORARY FACILITIES AND CONTROLS

Refer to the specific scopes of work for clarification of responsibility of the items specified herein.

PART 1 – GENERAL INFORMATION1.01 RELATED DOCUMENTS

Drawings and general provisions of the Contract, including General and Supplementary Conditions and other Division 0 and Division 1 Specification Sections, apply to this Section.

1.02 SUMMARY

This Section specifies requirements for temporary services and facilities, including utilities, construction and support facilities, security and protection, and shall be subject to the Construction Manager's approval.

A. Temporary utilities required include, but are not limited to:

- Water service and distribution
- Temporary electric power and light
- Telephone service
- Storm and sanitary sewer

B. Temporary construction and support facilities required include, but are not limited to:

- Dewatering facilities and drains
- Temporary heating, ventilating, humidification, and air conditioning
- Field offices and storage facilities
- Temporary roads and paving/construction parking/mud/snow and ice clean-up
- Sanitary facilities, including drinking water
- Temporary enclosures
- Hoists and temporary elevator use
- Temporary project identification signs and bulletin boards
- Waste disposal service and progress cleaning
- Construction aids and protection

C. Security and safety facilities required include, but are not limited to:

- Temporary fire protection
- Barricades, warning signs, lights
- Enclosure fence and security maintenance
- Environmental protection
- Safety requirements

D. Controls

Workday
 Lunch wagons
 Erosion control
 Excavation material
 Excavation training
 Material inventories
 Deliveries

1.03 QUALITY ASSURANCE

- A. Regulations: Comply with industry standards and applicable laws and regulations of authorities having jurisdiction, including but not limited to:

Municipal and Labor & Industry Building Code requirements
 Health and safety regulations
 Utility company regulations
 Police, Fire Department and Rescue Squad rules
 Environmental protection regulations

- B. Inspections: Arrange for authorities, having jurisdiction, to inspect and test each temporary utility before use. Obtain required certifications and permits.

1.04 PROJECT CONDITIONS

- A. Conditions of Use: Keep temporary services and facilities clean and neat in appearance. Operate in a safe and efficient manner. Take necessary fire prevention measures. Do not overload facilities, or permit them to interfere with progress. Do not allow hazardous, dangerous, or unsanitary conditions, or public nuisances to develop or persist on the site. They shall be removed, relocated as required by the progress of the work, or directed by the Construction Manager.

- B. Existing Utilities and Systems:

1. Existing systems shall be maintained at all times unless approved (48 hrs. notice of shutdown) by Owner. Permanent heating, plumbing and electrical systems shall be activated and maintained during owner occupancy of existing facilities. Facilities shall be maintained at 70°F.
2. Trade Contractors interrupting services due to their construction operations shall provide temporary utility lines, as required, to maintain services.

PART 2 - PRODUCTS2.01 MATERIALS

- A. General: Provide new materials; if acceptable to the Construction Manager, undamaged, previously used materials in serviceable condition may be used. Provide materials suitable for the use intended.

- B. Lumber and Plywood: Comply with requirements in Division-6 Section "Rough Carpentry."
- C. Tarpaulins: Provide waterproof, fire-resistant, UL-labeled tarpaulins with flame-spread rating of or less. For temporary enclosures, provide translucent, nylon-reinforced, laminated polyethylene or polyvinyl chloride fire retardant tarpaulins.
- D. Water: Provide potable water approved by local health authorities.
- E. Open-Mesh Fencing: Provide 11-gauge, galvanized two inch, chain link fabric fencing, six (6) feet high with galvanized steel pipe posts, 1-1/2" I.D. for line posts and 2-1/2" I.D. for corner posts.

2.02 EQUIPMENT

- A. General: Provide new equipment; if acceptable to the Construction Manager, undamaged, previously used equipment in serviceable condition may be used. Provide equipment suitable for use intended.
- B. Water Hoses: Provide 3/4" heavy-duty, abrasion-resistant, flexible rubber hoses 100 ft. long, with pressure rating greater than the maximum pressure of the water distribution system; provide adjustable shut-off nozzles at hose discharge.
- C. Electrical Outlets: Provide properly configured NEMA polarized outlets to prevent insertion of volt plugs into higher voltage outlets. Provide receptacle outlets equipped with ground-fault circuit interrupters, reset button, and pilot light, for connection of power tools, equipment, and GFI breakers.
- D. Electrical Power Cords: Provide grounded extension cords; use "hard-service" cords where exposed to abrasion and traffic. Provide waterproof connectors to connect separate lengths of electric cords if single lengths will not reach areas where construction activities are in progress.
- E. Electrical Welding Outlets: These will not be provided. Each Trade Contractor will be responsible for his own welding power.
- F. Lamps and Light Fixtures: Provide general service incandescent lamps of wattage required for adequate illumination. Provide guard cages or tempered glass enclosures where exposed to breakage. Provide exterior fixtures where exposed to moisture.
- G. Heating Units: Provide temporary heating units that have been tested and labeled by UL, FM or another recognized trade association related to the type of fuel being consumed.
- H. Temporary Offices: Provide prefabricated or mobile units or similar job-built construction with lockable entrances, operable windows and serviceable finishes. Provide heated and air-conditioned units on foundations adequate for normal loading.
- I. Temporary Toilet Units: Provide self-contained, single-occupant toilet units of the chemical, aerated recirculation, or combustions type, properly vented and fully enclosed with a glass fiber, reinforced polyester shell or similar nonabsorbent material.
- J. First Aid Supplies: Comply with governing regulations.

- K. Fire Extinguishers: Provide hand-carried, portable UL-rated, class "A" fire extinguishers for temporary offices and similar spaces. In other locations, provide hand-carried, portable, UL-rated, class "ABC" dry chemical extinguishers, or a combination of extinguishers of NFPA recommended classes for the exposures.

Comply with NFPA 10 classification, extinguishing agent and size required by location and class of fire exposure.

PART 3 - EXECUTION/SCOPE RESPONSIBILITIES

3.01 INSTALLATION (BY APPLICABLE TRADE CONTRACTORS)

- A. Use qualified personnel for installation of temporary facilities. Location facilities where they will serve the Project adequately and result in minimum interference with performance of the Work. Relocate and modify facilities as required.
- B. Provide each facility ready for use when needed to avoid delay. Maintain and modify as required. Do not remove until facilities are no longer needed, or are replaced by authorized use of completed permanent facilities.

3.02 TEMPORARY UTILITY INSTALLATION(BY APPLICABLE TRADE CONTRACTORS)

- A. General: Engage the appropriate local utility company to install temporary service or connect to existing service. Where the company provides only part of the service, provide the remainder with matching, compatible materials and equipment; comply with the company's recommendations.
1. Arrange with the company and existing users for a time when service can be interrupted, where necessary, to make connections for temporary services.
 2. Provide adequate capacity at each stage of construction. Prior to temporary utility availability, each Trade Contractor shall provide trucked-in services at their expense as required to complete their work.
 3. Obtain easements to bring temporary utilities to the site, where the Owner's easements cannot be used for that purpose.

Use Charges:

Cost or use charges for temporary facilities are to be paid by the Trade Contractor requiring or providing the temporary facility unless noted otherwise.

Owner will pay utility consumption costs during construction for construction activities only.

- B. Water Service: The Plumbing Contractor shall install water service and distribution piping of sizes and pressures adequate for construction. Provide 3/4" hose bib termination at each story of construction work, located so that any area of building construction can be reached with a 100 ft. length of hose. Water service may be run from a temporary or permanent source.

1. Sterilization: Sterilize temporary water piping prior to use.
2. Protect system from freezing.
3. Maintain 30 psig. water pressure with 5 gpm. flow rate.
4. Owner shall pay for cost of water consumed during construction. Trade Contractor shall take the necessary steps not to be wasteful.

C. Temporary Electricity Power Service:

1. After start of work at project site, when requested by the Construction Manager, the Electrical Contractor shall provide a temporary electrical power distribution system sufficient to accommodate temporary lighting and construction operations, including the use of power tools, and start-up of specified building equipment which must be tested, started or placed into use prior to completion of its permanent power connections. Provide 480 volts, 3 phase, 3 wires, 60 hertz and an equipment grounding conductor as well as 120 volts, 1 phase, 15 amperes, 60 hertz for lighting. Provide weatherproof, grounded wiring with overload protection; with direct wired connections, where feasible, and for voltages up to 220/208 volts. Locate multiple outlets for 120 volt power, not less than 4 gang, at each story of construction, spaced so that the entire area of construction can be reached by power tools on a single extension cord of 100' maximum length. Maximum 20 Amp circuit breaker, four (4) receptacles per circuit breaker.
2. The Owner will pay for cost of all electric energy used for construction activities.
3. The Electrical Trade Contractor shall provide and pay for maintenance, servicing, operation, and supervision of lines installed.
4. Provide service with ground fault circuit interrupter feature, as per NEC and OSHA requirements. The Electrical Trade Contractor shall have a cord inspection program in place. He shall maintain the inspection records on site.
5. As permanent power distribution system is accepted as substantially complete, either entire system or usable portions thereof, the Electrical Trade Contractor shall make suitable provisions for temporary use thereof, and remove unused portions of temporary system.
6. If required, provide meters for electrical power.
7. When temporary electrical lines are no longer required, they shall be removed by the Electrical Trade Contractor and any part, or parts, of the grounds or buildings disturbed or damaged shall be brought back to their original condition.
8. Electricity from existing lines may be used at no charge to the Trade Contractor. Each trade shall provide extension cords from the existing facilities, as required, for the execution of the Work. Electrical power for welding equipment will not be available.

9. The Electrical Trade Contractor shall maintain and operate permanent electrical supply and distribution system until time of final acceptance and transfer of operation to Owner's personnel.
10. The Electrical Trade Contractor shall install switching controls for all lighting which will enable turning off temporary lighting during off-construction hours.
11. Temporary power supplies to the Construction Manager's Office Conference/Office Complex shall be installed with service connection by the Electrical Trade Contractor.
12. The Electrical Trade Contractor will provide power for oil or gas fired temporary heaters, if required by the Construction Manager. It will be connected so that it can remain "live" when the lighting has been turned off.
13. The Electrical Trade Contractor will provide 24-hour temporary power to any heat tape (installed by others) on temporary water and/or fire lines. All temporary heat work will comply with existing OSHA requirements.
14. Construction circuits shall be separate and independent from temporary lighting.

- D. Temporary Lighting: Whenever overhead floor of roof deck has been installed, the Electrical Trade Contractor shall provide temporary lighting with local switching.

The Electrical Trade Contractor shall provide sufficient temporary lighting to ensure proper workmanship everywhere; by combined use of daylight and general lighting as stated below:

1. Provide uniformly spaced general lighting utilizing one (1) 150 watt incandescent lamp equivalent to 1.0 watts/sq. ft. of floor areas (minimum one (1) lamp per room), and one (1) 100 watt lamp per 50' of corridor or per flight of stairs.
2. Limit lighting installations to intensities which will accommodate normal access and workmanship requirements, recognizing that each entity performing work requiring higher intensity lighting will provide supplementary plug in temporary lighting and localized areas where such work is in progress.
3. As permanent lighting system is substantially complete for each story or usable portion thereof, the Electrical Trade Contractor shall make suitable provisions for temporary use thereof and remove unused portions of temporary lighting system.
4. The Electrical Trade Contractor shall maintain and operate permanent lighting system until the time of final acceptance and transfer of operation to Owner's personnel, including turning off lighting during off-construction hours.
5. The Electrical Trade Contractor shall replace bulbs that are burned out or substantially dimmed by substantial hours of use.
6. Special lighting required for construction activities shall be provided by contractor requiring it.

7. The Electrical Trade Contractor shall provide safety lighting in the stairways, hallways, and exterior security lighting (as required) on a 24-hour basis.
8. The Electrical Trade Contractor will provide a termination box in the Trade Contractor's office trailer area for hook-up of the Trade Contractor's trailers. Cost for individual Trade Contractor trailer hook-up will be born by the Trade Contractor requiring this service. Use of electric heaters in those trailers and shanties will not be permitted.

E. Temporary Telephones:

1. Each Trade Contractor shall be responsible for and provide for his own temporary telephone service.

F. Storm Sewers and Drainage:

1. If storm sewers are available, the Sitework Trade Contractor shall provide temporary connections to remove effluent that can be discharged lawfully. If sewers are not available, or cannot be used, Sitework Trade Contractor shall provide drainage ditches, dry wells, stabilization ponds and similar facilities. If neither sewers nor drainage facilities can be lawfully used for discharge of effluent, Sitework Trade Contractor provide containers to remove and dispose of effluent off the site in a lawful manner.
2. Filter out excessive amounts of soil, construction debris, chemicals, oils and similar contaminants that might clog sewers or pollute waterways before discharge.
3. Comply with the soil erosion and sedimentation control plan and local authorities having jurisdiction.

3.03 TEMPORARY CONSTRUCTION AND SUPPORT FACILITIES INSTALLATION
(BY APPLICABLE TRADE CONTRACTORS)

A. General:

1. Locate field offices, storage, sanitary facilities and other temporary construction and support facilities for easy access after approval from the Construction Manager.
2. Provide incombustible construction for offices, shops and sheds located within the construction area, or within 30 feet of building lines.

B. Dewatering Facilities and Drains:

1. For temporary drainage and dewatering facilities, and operations not directly associated with construction activities included under individual Sections, comply with dewatering requirements of applicable Division-2 Sections. Where feasible, utilize the same facilities.
2. The Sitework Trade Contractor shall be responsible to maintain the site, excavations and construction free of water. Review contract scopes for dewatering requirements for each Trade Contractor.

3. Plumbing Trade Contractor shall provide temporary storm water drainage from the building and the Sitework Trade Contractor shall control roof drainage from building on site.
4. Sitework Trade Contractor shall be responsible to drain or pump water and remove debris from the site so as not to delay his continuous work or progress. This shall include operating pumps during second shift in order to facilitate next-day continuation of work.
5. Sitework Trade Contractor shall excavate in a manner that prevents all surface water from flowing into the building area. Sitework Trade Contractor shall be responsible to remove any runoff water or debris which enters the building area.
6. Sitework Trade Contractor shall continue to drain site and remove debris until designed grades are obtained.
7. Upon completion of building foundations, each Trade Contractor shall be responsible to remove water and debris required to complete his work.

C. Temporary Heating, Ventilating & Air Conditioning:

1. Temporary heating shall be provided and maintained by the Trade Contractor performing the work if the outside temperature falls below 40°F at anytime during the day or night for all exterior work or work performed prior to the building being generally enclosed by walls and roof.
2. Each Trade Contractor shall furnish temporary heat by acceptable means to provide sufficient heat to maintain a temperature of 55°F, 24 hours a day throughout the entire area of the work for which the Trade Contractor is responsible.

Except where use of the permanent system is authorized, provide vented, self-contained LP gas or fuel oil heaters with individual space thermostatic control. Use of gasoline-burning space heaters, open flame, or salamander type heating units is prohibited. Temporary heating may not be provided using electrical heating equipment if using electrical power supplied by the Owner.

3. As soon as the building, or portions thereof, is generally enclosed with walls and roof and temporary heat is required for scheduled work, or required to facilitate proper workmanship, and permanent heating system is not yet operable or authorized for use, the Mechanical Trade Contractor shall provide temporary heat or air conditioning service for every entity authorized to do work at the project site. The Mechanical Trade Contractor shall maintain temperatures as indicated by other Specification Sections for each type of work to be performed. The Construction Manager shall be the sole arbiter of when the building is considered generally enclosed.
4. The Carpentry Trades shall install, maintain, and remove temporary enclosure of windows, doors and roof openings until the permanent materials are in place when such enclosures will result in the building being generally enclosed.

5. After the conditions of construction require continuous 24 hour heat in the building, as determined by the Construction Manager, the Mechanical Trade Contractor shall provide, operate, and maintain temporary radiation or unit heaters to provide required temperatures (minimum 55°F) for the conduct of the work. This service shall be continued until the permanent heating system has been completely installed and is in operation and the buildings of the project completed. The Mechanical Trade Contractor shall furnish and pay for all fuel as required for providing temporary heat and air conditioning after the building is generally enclosed. The Owner shall pay for all fuel costs incurred to operate the permanent HVAC systems for temporary purposes. As permanent heating/cooling system is substantially complete and operational for each story or usable portion thereof, the Mechanical Trade Contractor shall make suitable provisions for use thereof in temporary heating and cooling. The Mechanical Trade Contractor shall maintain and operate permanent system for temporary heating/cooling purposes, including service to occupied areas, if any, until time of final acceptance or transfer of operation to Owner's personnel, for major parts of system if not for entire heating system.
6. All permanent heating and air conditioning equipment used to supply temporary heat and air conditioning shall be completely cleaned and reconditioned by the Mechanical Trade Contractor prior to final acceptance. NOTE: All permanent equipment shall receive required scheduled maintenance while use for temporary service. Radiator traps and valves used in the heating system during the period of its operation to supply temporary heat shall not be reinstalled in the permanent system. Install new disposable filters and clean non-disposable filters prior to final acceptance. Replace significantly worn parts and parts that have been subject to unusual operating conditions.
7. The Mechanical Trade Contractor shall remove all soot, smudges, and other deposits from walls, ceilings, and all exposed surfaces which are the result of the use of any temporary heating equipment including the use of the permanent heating system for temporary heat purposes. Finish work shall not be done until all such surfaces are properly cleaned.
8. Temporary Ventilation: A Trade Contractor requiring ventilation for work shall provide fans or other necessary equipment to condition air, provided prior approval has been obtained from the Construction Manager.
9. Humidification: Where control of ambient humidity is required for proper performance of the work, or for curing/drying of installed work, or for protection of installed work from deterioration due to variations in ambient conditions, each Trade Contractor shall provide his own temporary humidification or dehumidification equipment to maintain the required conditions. Coordinate the use of the equipment with temporary heating to produce the required conditions with a minimum overall use of energy.
10. Permanent electrical power needed to operate permanent heating system must be provided by the Electrical Trade Contractor in conjunction with building enclosure, or the Electrical Trade Contractor shall furnish adequate temporary power to operate permanent heating system and bear all cost associated to provide that power.

D. Field Offices:

1. Trade Contractors shall provide offices for their own personnel. All type and location of jobsite offices and equipment will be approved by the Construction Manager. Trade Contractor's offices shall be a maximum of 40' in length.
2. Storage and Fabrication Sheds: Each Trade Contractor shall provide storage and fabrication sheds, sized, furnished and equipped to accommodate materials and equipment involved, including temporary utility service. Sheds may be open shelters or fully enclosed spaces. All steps and platforms connected to shelters must be per OSHA regulations.
3. All offices and sheds must have the Trade Contractor's identification on them.

E. Temporary Roads and Paving, Construction Parking:

1. Sitework Trade Contractor shall construct and maintain temporary roads, to adequately support the indicated loading and to withstand exposure to traffic during the construction period. Locate temporary paving for roads, storage areas and parking where the same permanent facilities will be located.
2. Snow removal will be performed by the Sitework Contractor for access roads and storage areas. Each Trade Contractor shall provide any additional snow removal required to maintain the schedule.

F. Sanitary Facilities:

1. The Construction Manager shall provide temporary toilets. Comply with regulations and health codes for the type, number, location, operation and maintenance of fixtures and facilities. Install where facilities will best serve the Project's needs.

Provide toilet tissue for each facility.

2. Toilets: Install self-contained toilet units. Shield toilets to ensure privacy. Use of pit type privies will not be permitted. Provide means of locking facilities when construction is not in progress.

Provide separate facilities for male and female personnel when both sexes are working in any capacity on project site.

Provide one unit for use of Owner representative's office/conference meeting complex.

3. Drinking Water Facilities: Each Trade Contractor shall provide containerized tap-dispenser bottled-water type drinking water units, including paper supply. Where power is accessible, provide electric water coolers to maintain dispensed water temperature at 45° to 55°F (7° to 13°C).

G. Temporary Enclosures:

1. All temporary enclosures required for protection of exterior construction in progress and completed from exposure, bad weather, other construction operations, and similar activities and to maintain the progress schedule, shall be provided by each contractor as necessary to protect their work.
2. Prior to the building being enclosed, all temporary enclosures required for protection of interior construction in progress and completed from exposure, bad weather, other construction operations, and similar activities and to maintain the progress schedule, shall be provided by each contractor as necessary to protect their work.
3. Where heat is needed and the permanent building enclosure is not complete (windows, doors, and roof openings not complete), the Carpentry Contractor shall provide temporary enclosures where there is no other provision for containment of heat. Coordinate enclosure with ventilating and material drying or curing requirements to avoid dangerous conditions and effects.
4. Install tarpaulins securely with noncombustible wood framing and other materials. Close openings of 25 sq. ft. or less with plywood or similar materials.
5. Each Trade Contractor is required to construct, maintain, and remove dust partitions required to prevent dust from entering adjacent areas.

H. Temporary Lifts and Hoists:

1. Each Trade Contractor shall be responsible for their own hoisting.
2. Existing Elevators:
 - A. N/A
3. New Elevators:
 - A. N/A

I. Project Identification and Temporary Signs

1. The Construction Manager shall prepare project identification and other signs, as approved by the Owner of the size indicated; install signs where indicated to inform the public and persons seeking entrance to the Project. Support on posts or framing of preservative treated wood or steel.
2. Provide on (1) sign erected on the site, where directed, to identify the project. Sign shall include Project name, Owner's name, Architect's name, and Construction Manager's name. Size shall be 4' x 8'; color and lettering style shall be as designed by the Architect.
3. Engage an experienced sign painter to apply graphics.

4. Temporary Signs: The Construction Manager shall prepare signs to provide directional information to construction personnel and visitors as required by the Construction Manager.
5. The Construction Manager shall erect weathertight bulletin boards adjacent to the office/conference complex. Size of the boards shall be equivalent to 32 sq. ft., visible area.

J. Waste Disposal Services:

1. The Construction Manager will provide trash collection containers for construction debris, exclusive of masonry, rock, earth, etc., and pay for all debris disposal costs for them. Each Trade Contractor on the project will be required to clean up, and deposit in the dumpster, all debris generated by his trade contract work on a daily basis. This requirement shall be enforced by the Construction Manager and will result in cost assessment against a Trade Contractor who fails to perform daily clean-up. Each Trade Contractor will be responsible for flattening or crushing all trash as necessary when placed into the dumpster. Hazardous material shall not be placed in the collection container.

K. Construction Aids, Protection and Facilities

1. The Carpentry Trades Contractor shall provide temporary ladders, ramps, and walkways required to access upper levels until permanent systems are installed. They shall be installed and maintained throughout the duration of the project and comply with all OSHA requirements. Removal of these shall be by the Carpentry Contractor when requested by the Construction Manager.
2. The Concrete Contractor shall be responsible for providing safety railings around basement area prior to completion of metal deck and slab. Concrete Contractor shall also provide railing around floor opening for floor hatch into basement once concrete has been poured.
3. Each Trade Contractor will be responsible for protecting any floor openings that have been opened for work under his trade.
4. Each Trade Contractor, upon working in any of the area named in the above paragraph, shall remove the safety covering and handrail to perform his work. Upon completion of his work for the day, lunch, or breaks, or any time when the individual Trade Contractor is not working in that opening, the safety covering and handrail must be replaced by the Trade Contractor removing it. At the end of each day, each Trade Contractor will inspect the site and install all safety coverings and handrails. IF coverings and handrails are not being reinstalled by Trade Contractors responsible for replacement, then Construction Manager will replace at Trade Contractor's expense. At the end of the project, or in order to install permanent construction, the Construction Manager shall remove all coverings and handrails.

5. The Carpentry Trades Contractor shall provide safe, temporary stairs, constructed of secure, dimensional lumber, with all railings and closures according to OSHA regulations, until permanent stairs are installed. Temporary stairs must be provided at the point when above grade floors are framed and decked, and require access by trades, in addition to the steel erection crews.
6. The Trade Contractors requiring access to above grade work are responsible for providing ladders, scaffolding and appropriate methods to access their work. Trade Contractors desiring use of in place above grade work platforms must arrange directly with the party that owns the equipment and make all rental and insurance arrangements directly with that party.
7. All work platforms, scaffolding, etc., on the project shall be available for access by the Owner, Architect, Municipal Authority, Test Agency and/or Construction Manager, and these parties shall be insured and held harmless when using these facilities by the Owner of the facility.
8. Each Trade Contractor shall be responsible for maintaining safe walkway and stair traffic areas, using anti-skid methods, routine sweeping, snow, mud and/or ice removal, and any other reasonable method for safe usage.

3.04 SECURITY AND SAFETY FACILITIES INSTALLATION

A. Temporary Fire Safety

1. Shall be maintained in place until permanent fire protection system is available for use. The Fire Protection Trade Contractor shall provide the permanent sprinkler fire protection system for use at the earliest possible date after building enclosure and 55°F temperatures are maintained to protect the building.
2. Until fire protection needs are supplied by permanent facilities, the Construction Manager shall install and maintain temporary fire protection facilities of the types needed to protect against reasonably predictable and controllable fire losses. Comply with NFPA 10 “Standard for Portable Fire Extinguishers.”
3. Locate fire extinguishers where convenient and effective for their intended purpose, but not less than one extinguisher on each floor at or near each usable stairwell.
4. Store combustible materials in containers in fire-safe locations.
5. Maintain unobstructed access to fire extinguishers, fire hydrants, temporary fire protection facilities, stairways and other access routes for fighting fires. Prohibit smoking in hazardous fire exposure areas. Prohibit smoking within the enclosure building.
6. Provide supervision of welding operations, combustion type temporary heating units, and similar sources of fire ignition.

- B. Barricades, Warning Signs and Lights: (Protection of Trade Contractors Work)
1. The responsible Trade Contractor shall comply with standards and code requirements for erection of structurally adequate barricades. Paint with appropriate colors, graphics, and warning signs to inform personnel and the public of the hazard being protected against.
- C. Building Security Enclosure and Lockup:
1. Each Trade Contractor shall be responsible for assisting the Construction Manager in maintaining a secure building at all times.
 2. Each Trade Contractor is responsible for the secure storage of their own material and equipment on and off the site.
- D. Environmental Protection:
1. To the fullest extent permitted by law, the Trade Contractor shall indemnify and hold harmless the Owner and Construction Manager, their employees and agents, from claims, losses, damage, and expenses including, but not limited to, attorney's fees arising out of performance of the work at it relates to any type of pollution related situations. This would apply to bodily injury, sickness, disease, or death, or to damages or destruction or contamination of tangible property arising out of the acts or omission of the Trade Contractor or the joint negligent acts of the Owner or Construction Manager, or anyone for whose acts the Trade Contractor may be liable.
 2. The Construction Manager will designate area available for construction storage.
 3. Each Trade Contractor shall provide protection, operate temporary facilities, and conduct construction in ways and methods that comply with all environmental regulations, and minimize the possibility that air, water, and soil become contaminated or polluted as a result of work or storage so supplies and materials, or equipment usage.
 4. Each Trade Contractor will designate and train a responsible employee in environmental contamination procedures, including, but not limited to, emergency responses, material and waste inventories, spills and leak precautions and responses, inspections, housekeeping, security, and external factors.
 5. Open burning will not be permitted.
- E. Safety Requirements
1. All work shall be performed in accordance with rules, regulations, procedures and safe practice and/or OSHA and all other Government agencies having jurisdiction over the project.

2. Safety precautions and programs:
 - a. Each container shall be responsible for initiating, maintaining and supervising safety precautions and programs in connection with the work. The name of the safety officer for each contractor shall be provided by the Construction Manager.
 - b. All Trade Contractors shall comply with the provisions of the “Specific Safety Requirements of the Construction Safety Act,” the “Occupational Safety and Health Act,” and Federal, State and local requirements.
 - c. If a contractor fails to maintain the safety precautions required by law or directed by the Construction Manager, the Construction Manager may take such action as necessary and charge the Trade Contractor for all incurred costs.
 - d. The failure of the Construction Manager to take any such action shall not relieve the Trade Contractor of his obligations.
 - e. The Trade Contractor individually shall be responsible for the safety, efficiency, and adequacy of his plant, appliances, and methods, and for any damage which may result from their failure or their improper construction, maintenance or operation.
 - f. Prior to mobilizing to the job, the Trade Contractor shall submit to the Construction Manager, in writing, a description of his safety program for review and comment. During the conduct of the work, the Trade Contractor shall immediately notify the Construction Manager, in writing, of all accidents and shall submit a written report describing in detail the circumstances of each accident within 24 hours of its occurrence.
 - g. All Trade Contractors shall notify the Construction Manager of any flammable, combustible and/or toxic materials intended for use on the project and shall furnish the Construction Manager with literature pertinent to the use and control of all materials, including, but limited to, MSDS sheets.
 - h. Each Trade Contractor shall delegate one representative who shall be responsible to maintain all safety requirements of the Trade Contractor, and shall attend all project safety meetings scheduled by the Construction Manager.
 - i. Each Trade Contractor shall conduct weekly safety discussions which shall be attended by all employees assigned to this project. A written safety given to the Construction Manager on a weekly basis.
3. Safety of persons and property:
 - a. The Trade Contractor shall take all reasonable precautions for the safety or, and shall provide all reasonable protection to prevent damage of loss to:
 1. All employees on the work site and all other persons may be affected thereby.

2. All the work and all materials and equipment to be incorporated therein, whether in storage on or off the site, under the care, custody, or control of the Trade Contractor or any of his Subcontractors or Sub-Contractors.
 3. Other property at the site or adjacent thereto, including, but not limited to, trees, shrubs, lawns, walks, pavements, roadways, structures and utilities not designated for removal, relocation or replacement in the course of construction and underground property.
- b. The Trade Contractor shall give all notices and comply with all applicable laws, ordinances, rules, regulations and lawful orders of any public authority, including the Owner's department of protective services, bearing on the safety of persons or property or their protection from damage, injury or loss.
 - c. The Trade Contractor shall erect and maintain, as required by existing conditions and progress of the work, all reasonable safeguards for safety and protection, from his work, including danger signs and other warnings against hazards. He shall comply with safety regulations and notify the Construction Manager of possible effects on adjacent facilities. If the Trade Contractor fails to so comply, he shall, at the direction of the Construction Manager, remove forces from the project without cost or loss to the Owner or Construction Manager, until he is in compliance.
 - d. The Trade Contractor shall promptly remedy all damage or loss to any property caused in whole or in part by the Trade Contractor, his subcontractors, his Sub-subcontractors, or anyone directly employed by any of them, or by anyone for whose acts any of them be liable.
 - e. The Trade Contractor shall not load or permit any part of the work to be loaded so as to endanger its integrity and safety.
 - f. The use of audio equipment and headsets will not be permitted on the construction site.
4. Emergencies:
 - a. In any emergency affecting the safety of persons or property, the Trade Contractor shall act, at his discretion, to prevent threatened damage, injury or loss and shall immediately notify the Construction Manager of such emergency conditions. Any claims made by the Trade Contractor for additional compensation or extension of time on account of emergency work shall be processed in accordance with the Contract Documents.
5. Indemnification:
 - a. The Trade Contractor shall indemnify and hold harmless the Owner, the Construction Manager, the Architect/Engineer, all municipal authorities, and their agents and employees, from and against all claims, damages, losses, and expenses including, but limited to, attorney's fees arising out of or resulting from the performance of the work, provided that any such claim, damage, loss or expense (1) is attributable to bodily injury, sickness, disease or death, or to

injury, sickness, disease or death, or to injury to or destruction of tangible property (other work than the work itself) including the loss of use resulting therefrom, and (2) is caused in whole or part by any negligent act or omission of the Trade Contractor, any Subcontractor, anyone directly or indirectly employed by any of them may be liable, regardless of whether or not it is caused in part by a party indemnified hereunder.

- b. In any and all claim against the Owner, the Construction Manager, the Architect/Engineer, or any of their agents or employees, by any employee of the Trade Contractor, and Sub-Contractor, anyone directly or indirectly employed by any of them may be liable, the indemnification obligation under this paragraph shall not be limited in any way by any limitation on the amount or type of damages, compensation or benefits payable by or for the type of damages, compensation or any Subcontractor under Worker's Compensation Acts, disability benefit acts or other employee benefit acts.
- c. The obligations of the Trade Contractor under this paragraph shall not extend to the liability of the Architect/Engineer or the Construction Manager, his agents or employees arising out of (1) the preparation of approval of maps, drawings, opinions, reports, surveys, design or specifications, or (2) the giving of or failure to give directions or instructions by the Architect/Engineer or the Construction Manager, their agents or employees provided such giving or failure to give is the primary cause of the injury or damage.
- d. No provision of this Subparagraph shall give rise to any duties on the part of the Architect or the Construction Manager not otherwise provided for by contract or by law.
- e. In the event that any party is requested but refuses to honor the indemnity obligations hereunder, then the party refusing to honor such requests shall, in addition to all other obligations, pay the cost of bringing any such action, including attorney's fees to the party requesting indemnity.

3.05 CONTROLS

A. Workday:

1. The workdays for the project are defined as 7:00 a.m. – 4:30 p.m., Monday through Friday, & 7-3:30 Saturday, with lunch period from 12:00 – 12:30 p.m. The progress schedule may require contractors to perform work other than the normal workday and in addition to the normal workday, to meet milestones in the progress schedule for the project, or to make up time previously lost to regain the progress schedule requirements or to prevent interruption of the Owner's ongoing operation.
2. Working times other than the normal workday or in addition to the normal work day, must be arranged in advance with the Construction Manager.
3. Trade Contractors who require additional workday hours to regain work time previously lost to meet the requirements of the project schedule shall be assessed for all costs including Construction Manager supervision and other Trade Contractor cost necessary for the performance of their work.

B. Lunch Wagons:

1. Lunch wagons, catered events of other non-construction related functions shall not be permitted on the project site, except by the written permission of the Owner and Construction Manager.
2. No alcoholic beverages or controlled substances shall be allowed on the project at any time.

C. Erosion Control:

1. The Sitework Trade Contractor shall employ all methods required to comply with Local, State, and Federal requirements to control erosion from the project site, including drainage control ditches, sediment basins, straw bale dykes and silt fencing.

D. Excavation Training:

1. Any Trade Contractor performing excavation shall have an OSHA trained person on site during all excavation operations. This person shall evaluate soil types and conditions to determine the required shoring and excavation methods.

E. Material Inventories:

1. Contractors shall coordinate the delivery and storage on the jobsite of all significant materials
2. Each Trade Contractor shall be responsible for the proper location, secure, and weather resistant storage as required of all materials. This includes placement of materials not to obstruct passage on site or within building structures or in any way which causes impediment or obstruction to other Trade Contractors.
3. All material inventories must be stored by the Trade Contractor to avoid excessive loads on building structure.
4. When directed by the Construction Manager, a Trade Contractor shall remove or relocate material inventories as required for the progress of the project.

F. Deliveries:

1. All contractors are required to properly instruct material suppliers and vendors to address deliveries to them specifically by named responsible party at the jobsite and require advance notice.
2. All deliveries addressed to the project in general, the Owner, Architect or Construction Manager, will be refused and returned to shipper.
3. The Owner will not be responsible for receipt, handing, or loss of any materials which are shipped to the Owner in error and received unknowing of relationship to the project.

4. Contractor receiving materials at the jobsite shall be responsible for prevention of any mud or other deposits on public roadways or other areas outside project limit lines, which may result due to methods of material delivery. Trade Contractor shall instruct delivery conveyor to take appropriate measures to prevent depositing mud or other construction deposits outside contract limit lines. Total responsibility of cleanup of mud or other construction deposit outside of contract limit lines will be the responsibility of the Trade Contractor receiving the delivery.

3.06 OPERATION, TERMINATION AND REMOVAL

- A. Supervision: Enforce strict discipline in use of temporary facilities. Limit availability of temporary facilities to essential and intended use to minimize waste and abuse.
- B. Maintenance: Maintain facilities in good operating condition until removal. Protect from damage by freezing temperatures and similar elements.
 1. Maintain operation of temporary enclosures, heating, cooling, humidity control, ventilation and similar facilities on a 24-hour day basis where required to achieve indicated results and to avoid possibility of damage.
 2. Protection: Prevent water filled piping from freezing. Maintain markers for underground lines. Protect from damage during excavation operations.
- C. Termination and Removal: Unless the Construction Manager requests that it be maintained longer, remove each temporary facility when the need has ended, or when replaced by authorized use of a permanent facility, or not later than Substantial Completion. Complete or, if necessary restore, permanent construction that may have been delayed because of interference with the temporary facility. Repair damaged work, clean exposed surfaces, and replace construction that cannot be satisfactorily repaired.
 1. Materials and facilities that constitute temporary facilities that constitute temporary facilities are property of the Trade Contractor. The Owner reserves the right to take possession of Project identification signs.
 2. The Sitework Trade Contractor shall remove temporary paving that is not intended for or acceptable for integration into permanent paving. Where the area is intended for landscape development, remove soil and aggregate fill that does not comply with requirements for fill or subsoil in the area. Remove materials contaminated with road oil, asphalt, and other petrochemical compounds, and other substance which might impair growth of plant materials or lawns. Repair or replace street paving, curbs and sidewalks at the temporary entrances, as required by the governing authority.

END OF SECTION 015000

SECTION 016000 - PRODUCT REQUIREMENTS

PART 1 - GENERAL

1.1 RELATED DOCUMENTS

- A. Drawings and general provisions of the Contract, including General and Supplementary Conditions and other Division 01 Specification Sections, apply to this Section.

1.2 SUMMARY

- A. Section includes administrative and procedural requirements for selection of products for use in Project; product delivery, storage, and handling; manufacturers' standard warranties on products; special warranties; and comparable products.
- B. Related Requirements:
 - 1. Section 012100 "Allowances" for products selected under an allowance.
 - 2. Section 012300 "Alternates" for products selected under an alternate.
 - 3. Section 012500 "Substitution Procedures" for requests for substitutions.
 - 4. Section 014200 "References" for applicable industry standards for products specified.

1.3 DEFINITIONS

- A. Products: Items obtained for incorporating into the Work, whether purchased for Project or taken from previously purchased stock. The term "product" includes the terms "material," "equipment," "system," and terms of similar intent.
 - 1. Named Products: Items identified by manufacturer's product name, including make or model number or other designation shown or listed in manufacturer's published product literature that is current as of date of the Contract Documents.
 - 2. New Products: Items that have not previously been incorporated into another project or facility. Products salvaged or recycled from other projects are not considered new products.
 - 3. Comparable Product: Product that is demonstrated and approved through submittal process to have the indicated qualities related to type, function, dimension, in-service performance, physical properties, appearance, and other characteristics that equal or exceed those of specified product.
- B. Basis-of-Design Product Specification: A specification in which a specific manufacturer's product is named and accompanied by the words "basis-of-design product," including make or model number or other designation, to establish the significant qualities related to type, function, dimension, in-service performance, physical properties, appearance, and other characteristics for purposes of evaluating comparable products of additional manufacturers named in the specification.

1.4 ACTION SUBMITTALS

- A. Comparable Product Requests: Submit request for consideration of each comparable product. Identify product or fabrication or installation method to be replaced. Include Specification Section number and title and Drawing numbers and titles.
 - 1. Include data to indicate compliance with the requirements specified in "Comparable Products" Article.
 - 2. Architect's Action: If necessary, Architect will request additional information or documentation for evaluation within one week of receipt of a comparable product request. Architect will notify Contractor of approval or rejection of proposed comparable product request within 15 days of receipt of request, or seven days of receipt of additional information or documentation, whichever is later.
 - a. Form of Approval: As specified in Section 013300 "Submittal Procedures."
 - b. Use product specified if Architect does not issue a decision on use of a comparable product request within time allocated.
- B. Basis-of-Design Product Specification Submittal: Comply with requirements in Section 013300 "Submittal Procedures." Show compliance with requirements.

1.5 QUALITY ASSURANCE

- A. Compatibility of Options: If Contractor is given option of selecting between two or more products for use on Project, select product compatible with products previously selected, even if previously selected products were also options.

1.6 PRODUCT DELIVERY, STORAGE, AND HANDLING

- A. Deliver, store, and handle products using means and methods that will prevent damage, deterioration, and loss, including theft and vandalism. Comply with manufacturer's written instructions.
- B. Delivery and Handling:
 - 1. Schedule delivery to minimize long-term storage at Project site and to prevent overcrowding of construction spaces.
 - 2. Coordinate delivery with installation time to ensure minimum holding time for items that are flammable, hazardous, easily damaged, or sensitive to deterioration, theft, and other losses.
 - 3. Deliver products to Project site in an undamaged condition in manufacturer's original sealed container or other packaging system, complete with labels and instructions for handling, storing, unpacking, protecting, and installing.
 - 4. Inspect products on delivery to determine compliance with the Contract Documents and to determine that products are undamaged and properly protected.
- C. Storage:
 - 1. Store products to allow for inspection and measurement of quantity or counting of units.

2. Store materials in a manner that will not endanger Project structure.
3. Store products that are subject to damage by the elements, under cover in a weathertight enclosure above ground, with ventilation adequate to prevent condensation.
4. Protect foam plastic from exposure to sunlight, except to extent necessary for period of installation and concealment.
5. Comply with product manufacturer's written instructions for temperature, humidity, ventilation, and weather-protection requirements for storage.
6. Protect stored products from damage and liquids from freezing.

1.7 PRODUCT WARRANTIES

- A. Warranties specified in other Sections shall be in addition to, and run concurrent with, other warranties required by the Contract Documents. Manufacturer's disclaimers and limitations on product warranties do not relieve Contractor of obligations under requirements of the Contract Documents.
 1. Manufacturer's Warranty: Written warranty furnished by individual manufacturer for a particular product and specifically endorsed by manufacturer to Owner.
 2. Special Warranty: Written warranty required by the Contract Documents to provide specific rights for Owner.
- B. Special Warranties: Prepare a written document that contains appropriate terms and identification, ready for execution.
 1. Manufacturer's Standard Form: Modified to include Project-specific information and properly executed.
 2. Specified Form: When specified forms are included with the Specifications, prepare a written document using indicated form properly executed.
 3. See other Sections for specific content requirements and particular requirements for submitting special warranties.
- C. Submittal Time: Comply with requirements in Section 017700 "Closeout Procedures."

PART 2 - PRODUCTS

2.1 PRODUCT SELECTION PROCEDURES

- A. General Product Requirements: Provide products that comply with the Contract Documents, are undamaged and, unless otherwise indicated, are new at time of installation.
 1. Provide products complete with accessories, trim, finish, fasteners, and other items needed for a complete installation and indicated use and effect.
 2. Standard Products: If available, and unless custom products or nonstandard options are specified, provide standard products of types that have been produced and used successfully in similar situations on other projects.
 3. Owner reserves the right to limit selection to products with warranties not in conflict with requirements of the Contract Documents.

4. Where products are accompanied by the term "as selected," Architect will make selection.
5. Descriptive, performance, and reference standard requirements in the Specifications establish salient characteristics of products.
6. Or Equal: For products specified by name and accompanied by the term "or equal," or "or approved equal," or "or approved," comply with requirements in "Comparable Products" Article to obtain approval for use of an unnamed product.

B. Product Selection Procedures:

1. Product: Where Specifications name a single manufacturer and product, provide the named product that complies with requirements. Comparable products or substitutions for Contractor's convenience will not be considered.
2. Manufacturer/Source: Where Specifications name a single manufacturer or source, provide a product by the named manufacturer or source that complies with requirements. Comparable products or substitutions for Contractor's convenience will not be considered.
3. Products:
 - a. Restricted List: Where Specifications include a list of names of both manufacturers and products, provide one of the products listed that complies with requirements. Comparable products or substitutions for Contractor's convenience will not be considered.
4. Manufacturers:
 - a. Restricted List: Where Specifications include a list of manufacturers' names, provide a product by one of the manufacturers listed that complies with requirements. Comparable products or substitutions for Contractor's convenience will not be considered.
5. Basis-of-Design Product: Where Specifications name a product, or refer to a product indicated on Drawings, and include a list of manufacturers, provide the specified or indicated product or a comparable product by one of the other named manufacturers. Drawings and Specifications indicate sizes, profiles, dimensions, and other characteristics that are based on the product named. Comply with requirements in "Comparable Products" Article for consideration of an unnamed product by one of the other named manufacturers.

C. Visual Matching Specification: Where Specifications require "match Architect's sample", provide a product that complies with requirements and matches Architect's sample. Architect's decision will be final on whether a proposed product matches.

1. If no product available within specified category matches and complies with other specified requirements, comply with requirements in Section 012500 "Substitution Procedures" for proposal of product.

D. Visual Selection Specification: Where Specifications include the phrase "as selected by Architect from manufacturer's full range" or similar phrase, select a product that complies with requirements. Architect will select color, gloss, pattern, density, or texture from manufacturer's product line that includes both standard and premium items.

2.2 COMPARABLE PRODUCTS

- A. Conditions for Consideration: Architect may consider Contractor's request for comparable product when the following conditions are satisfied. The Architect is the sole determiner whether a proposed product is comparable or a substitution. If a product submitted is determined to be a substitution, Contractor shall provide documentation as required by Section 012500 "Substitution Procedures." If the following conditions are not satisfied, Architect may return requests without action, except to record noncompliance with these requirements:
1. Evidence that the proposed product does not require revisions to the Contract Documents, that it is consistent with the Contract Documents and will produce the indicated results, and that it is compatible with other portions of the Work.
 2. Detailed comparison of significant qualities of proposed product with those named in the Specifications. Significant qualities include attributes such as performance, weight, size, durability, visual effect, and specific features and requirements indicated.
 3. Evidence that proposed product provides specified warranty.
 4. List of similar installations for completed projects with project names and addresses and names and addresses of architects and owners, if requested.
 5. Samples, if requested.
- B. Timing: Requests for substitution for convenience shall be submitted not less than 10 days prior to bid. Request for substitution received after Bid will not be reviewed.

PART 3 - EXECUTION (Not Used)

END OF SECTION 016000

SECTION 017300 - EXECUTION

PART 1 - GENERAL

1.1 RELATED DOCUMENTS

- A. Drawings and general provisions of the Contract, including General and Supplementary Conditions and other Division 01 Specification Sections, apply to this Section.

1.2 SUMMARY

- A. Section includes general administrative and procedural requirements governing execution of the Work including, but not limited to, the following:

1. Construction layout.
2. Field engineering and surveying.
3. Installation of the Work.
4. Cutting and patching.
5. Coordination of Owner-installed products.
6. Progress cleaning.
7. Starting and adjusting.
8. Protection of installed construction.

- B. Related Requirements:

1. Section 011000 "Summary" for limits on use of Project site.
2. Section 013300 "Submittal Procedures" for submitting surveys.
3. Section 017700 "Closeout Procedures" for submitting final property survey with Project Record Documents, recording of Owner-accepted deviations from indicated lines and levels, and final cleaning.
4. Section 078413 "Penetration Firestopping" for patching penetrations in fire-rated construction.

1.3 DEFINITIONS

- A. Cutting: Removal of in-place construction necessary to permit installation or performance of other work.
- B. Patching: Fitting and repair work required to restore construction to original conditions after installation of other work.

1.4 INFORMATIONAL SUBMITTALS

1.5 QUALITY ASSURANCE

- A. Land Surveyor Qualifications: A professional land surveyor who is legally qualified to practice in jurisdiction where Project is located and who is experienced in providing land-surveying services of the kind indicated.
- B. Cutting and Patching: Comply with requirements for and limitations on cutting and patching of construction elements.
 - 1. Structural Elements: When cutting and patching structural elements, notify Architect of locations and details of cutting and await directions from Architect before proceeding. Shore, brace, and support structural elements during cutting and patching. Do not cut and patch structural elements in a manner that could change their load-carrying capacity or increase deflection
 - 2. Operational Elements: Do not cut and patch operating elements and related components in a manner that results in reducing their capacity to perform as intended or that results in increased maintenance or decreased operational life or safety.
 - a. Primary operational systems and equipment.
 - b. Fire separation assemblies.
 - c. Air or smoke barriers.
 - d. Fire-suppression systems.
 - e. Mechanical systems piping and ducts.
 - f. Control systems.
 - g. Communication systems.
 - h. Fire-detection and -alarm systems.
 - i. Electrical wiring systems.
 - j. Operating systems of special construction.
 - 3. Other Construction Elements: Do not cut and patch other construction elements or components in a manner that could change their load-carrying capacity, that results in reducing their capacity to perform as intended, or that results in increased maintenance or decreased operational life or safety.
 - a. Water, moisture, or vapor barriers.
 - b. Membranes and flashings.
 - c. Exterior curtain-wall construction.
 - d. Equipment supports.
 - e. Piping, ductwork, vessels, and equipment.
 - f. Noise- and vibration-control elements and systems.
 - 4. Visual Elements: Do not cut and patch construction in a manner that results in visual evidence of cutting and patching. Do not cut and patch exposed construction in a manner that would, in Architect's opinion, reduce the building's aesthetic qualities. Remove and replace construction that has been cut and patched in a visually unsatisfactory manner.

- C. Manufacturer's Installation Instructions: Obtain and maintain on-site manufacturer's written recommendations and instructions for installation of products and equipment.

PART 2 - PRODUCTS

PART 3 - EXECUTION

3.1 EXAMINATION

- A. Existing Conditions: The existence and location of underground and other utilities and construction indicated as existing are not guaranteed. Before beginning sitework, investigate and verify the existence and location of underground utilities, mechanical and electrical systems, and other construction affecting the Work.
 - 1. Before construction, verify the location and invert elevation at points of connection of sanitary sewer, storm sewer, and water-service piping; underground electrical services, and other utilities.
 - 2. Furnish location data for work related to Project that must be performed by public utilities serving Project site.
- B. Examination and Acceptance of Conditions: Before proceeding with each component of the Work, examine substrates, areas, and conditions, with Installer or Applicator present where indicated, for compliance with requirements for installation tolerances and other conditions affecting performance. Record observations.
 - 1. Examine roughing-in for mechanical and electrical systems to verify actual locations of connections before equipment and fixture installation.
 - 2. Examine walls, floors, and roofs for suitable conditions where products and systems are to be installed.
 - 3. Verify compatibility with and suitability of substrates, including compatibility with existing finishes or primers.
- C. Written Report: Where a written report listing conditions detrimental to performance of the Work is required by other Sections, include the following:
 - 1. Description of the Work.
 - 2. List of detrimental conditions, including substrates.
 - 3. List of unacceptable installation tolerances.
 - 4. Recommended corrections.
- D. Proceed with installation only after unsatisfactory conditions have been corrected. Proceeding with the Work indicates acceptance of surfaces and conditions.

3.2 PREPARATION

- A. Existing Utility Information: Furnish information to local utility and Owner that is necessary to adjust, move, or relocate existing utility structures, utility poles, lines, services, or other utility appurtenances located in or affected by construction. Coordinate with authorities having jurisdiction.
- B. Field Measurements: Take field measurements as required to fit the Work properly. Recheck measurements before installing each product. Where portions of the Work are indicated to fit to other construction, verify dimensions of other construction by field measurements before fabrication. Coordinate fabrication schedule with construction progress to avoid delaying the Work.
- C. Space Requirements: Verify space requirements and dimensions of items shown diagrammatically on Drawings.
- D. Review of Contract Documents and Field Conditions: Immediately on discovery of the need for clarification of the Contract Documents caused by differing field conditions outside the control of Contractor, submit a request for information to Architect according to requirements in Section 013100 "Project Management and Coordination."

3.3 CONSTRUCTION LAYOUT

- A. Verification: Before proceeding to lay out the Work, verify layout information shown on Drawings, in relation to the property survey and existing benchmarks. If discrepancies are discovered, notify Architect promptly.
- B. General: Engage a land surveyor to lay out the Work using accepted surveying practices.
 - 1. Establish benchmarks and control points to set lines and levels at each story of construction and elsewhere as needed to locate each element of Project.
 - 2. Establish limits on use of Project site.
 - 3. Establish dimensions within tolerances indicated. Do not scale Drawings to obtain required dimensions.
 - 4. Inform installers of lines and levels to which they must comply.
 - 5. Check the location, level and plumb, of every major element as the Work progresses.
 - 6. Notify Architect when deviations from required lines and levels exceed allowable tolerances.
 - 7. Close site surveys with an error of closure equal to or less than the standard established by authorities having jurisdiction.
- C. Site Improvements: Locate and lay out site improvements, including pavements, grading, fill and topsoil placement, utility slopes, and rim and invert elevations.
- D. Building Lines and Levels: Locate and lay out control lines and levels for structures, building foundations, column grids, and floor levels, including those required for mechanical and electrical work. Transfer survey markings and elevations for use with control lines and levels. Level foundations and piers from two or more locations.

- E. Record Log: Maintain a log of layout control work. Record deviations from required lines and levels. Include beginning and ending dates and times of surveys, weather conditions, name and duty of each survey party member, and types of instruments and tapes used. Make the log available for reference by Architect.

3.4 FIELD ENGINEERING

- A. Reference Points: Locate existing permanent benchmarks, control points, and similar reference points before beginning the Work. Preserve and protect permanent benchmarks and control points during construction operations.
 - 1. Do not change or relocate existing benchmarks or control points without prior written approval of Architect. Report lost or destroyed permanent benchmarks or control points promptly. Report the need to relocate permanent benchmarks or control points to Architect before proceeding.
 - 2. Replace lost or destroyed permanent benchmarks and control points promptly. Base replacements on the original survey control points.
- B. Benchmarks: Establish and maintain a minimum of two permanent benchmarks on Project site, referenced to data established by survey control points. Comply with authorities having jurisdiction for type and size of benchmark.
 - 1. Record benchmark locations, with horizontal and vertical data, on Project Record Documents.
 - 2. Where the actual location or elevation of layout points cannot be marked, provide temporary reference points sufficient to locate the Work.
 - 3. Remove temporary reference points when no longer needed. Restore marked construction to its original condition.

3.5 INSTALLATION

- A. General: Locate the Work and components of the Work accurately, in correct alignment and elevation, as indicated.
 - 1. Make vertical work plumb and make horizontal work level.
 - 2. Where space is limited, install components to maximize space available for maintenance and ease of removal for replacement.
 - 3. Conceal pipes, ducts, and wiring in finished areas unless otherwise indicated.
 - 4. Maintain minimum headroom clearance of 96 inches (2440 mm) in occupied spaces and 90 inches (2300 mm) in unoccupied spaces.
- B. Comply with manufacturer's written instructions and recommendations for installing products in applications indicated.
- C. Install products at the time and under conditions that will ensure the best possible results. Maintain conditions required for product performance until Substantial Completion.
- D. Conduct construction operations so no part of the Work is subjected to damaging operations or loading in excess of that expected during normal conditions of occupancy.

- E. Sequence the Work and allow adequate clearances to accommodate movement of construction items on site and placement in permanent locations.
- F. Tools and Equipment: Do not use tools or equipment that produce harmful noise levels.
- G. Templates: Obtain and distribute to the parties involved templates for work specified to be factory prepared and field installed. Check Shop Drawings of other work to confirm that adequate provisions are made for locating and installing products to comply with indicated requirements.
- H. Attachment: Provide blocking and attachment plates and anchors and fasteners of adequate size and number to securely anchor each component in place, accurately located and aligned with other portions of the Work. Where size and type of attachments are not indicated, verify size and type required for load conditions.
 - 1. Mounting Heights: Where mounting heights are not indicated, mount components at heights directed by Architect.
 - 2. Allow for building movement, including thermal expansion and contraction.
 - 3. Coordinate installation of anchorages. Furnish setting drawings, templates, and directions for installing anchorages, including sleeves, concrete inserts, anchor bolts, and items with integral anchors, that are to be embedded in concrete or masonry. Deliver such items to Project site in time for installation.
- I. Joints: Make joints of uniform width. Where joint locations in exposed work are not indicated, arrange joints for the best visual effect. Fit exposed connections together to form hairline joints.
- J. Hazardous Materials: Use products, cleaners, and installation materials that are not considered hazardous.

3.6 CUTTING AND PATCHING

- A. Cutting and Patching, General: Employ skilled workers to perform cutting and patching. Proceed with cutting and patching at the earliest feasible time, and complete without delay.
 - 1. Cut in-place construction to provide for installation of other components or performance of other construction, and subsequently patch as required to restore surfaces to their original condition.
- B. Existing Warranties: Remove, replace, patch, and repair materials and surfaces cut or damaged during installation or cutting and patching operations, by methods and with materials so as not to void existing warranties.
- C. Temporary Support: Provide temporary support of work to be cut.
- D. Protection: Protect in-place construction during cutting and patching to prevent damage. Provide protection from adverse weather conditions for portions of Project that might be exposed during cutting and patching operations.

- E. Adjacent Occupied Areas: Where interference with use of adjoining areas or interruption of free passage to adjoining areas is unavoidable, coordinate cutting and patching according to requirements in Section 011000 "Summary."
- F. Cutting: Cut in-place construction by sawing, drilling, breaking, chipping, grinding, and similar operations, including excavation, using methods least likely to damage elements retained or adjoining construction. If possible, review proposed procedures with original Installer; comply with original Installer's written recommendations.
1. In general, use hand or small power tools designed for sawing and grinding, not hammering and chopping. Cut holes and slots neatly to minimum size required, and with minimum disturbance of adjacent surfaces. Temporarily cover openings when not in use.
 2. Finished Surfaces: Cut or drill from the exposed or finished side into concealed surfaces.
 3. Concrete and Masonry: Cut using a cutting machine, such as an abrasive saw or a diamond-core drill.
 4. Excavating and Backfilling: Comply with requirements in applicable Sections where required by cutting and patching operations.
 5. Mechanical and Electrical Services: Cut off pipe or conduit in walls or partitions to be removed. Cap, valve, or plug and seal remaining portion of pipe or conduit to prevent entrance of moisture or other foreign matter after cutting.
 6. Proceed with patching after construction operations requiring cutting are complete.
- G. Patching: Patch construction by filling, repairing, refinishing, closing up, and similar operations following performance of other work. Patch with durable seams that are as invisible as practicable. Provide materials and comply with installation requirements specified in other Sections, where applicable.
1. Inspection: Where feasible, test and inspect patched areas after completion to demonstrate physical integrity of installation.
 2. Exposed Finishes: Restore exposed finishes of patched areas and extend finish restoration into retained adjoining construction in a manner that will minimize evidence of patching and refinishing.
 - a. Clean piping, conduit, and similar features before applying paint or other finishing materials.
 - b. Restore damaged pipe covering to its original condition.
 3. Floors and Walls: Where walls or partitions that are removed extend one finished area into another, patch and repair floor and wall surfaces in the new space. Provide an even surface of uniform finish, color, texture, and appearance. Remove in-place floor and wall coverings and replace with new materials, if necessary, to achieve uniform color and appearance.
 - a. Where patching occurs in a painted surface, prepare substrate and apply primer and intermediate paint coats appropriate for substrate over the patch, and apply final paint coat over entire unbroken surface containing the patch. Provide additional coats until patch blends with adjacent surfaces.
 4. Ceilings: Patch, repair, or rehang in-place ceilings as necessary to provide an even-plane surface of uniform appearance.

5. Exterior Building Enclosure: Patch components in a manner that restores enclosure to a weathertight condition and ensures thermal and moisture integrity of building enclosure.

H. Cleaning: Clean areas and spaces where cutting and patching are performed. Remove paint, mortar, oils, putty, and similar materials from adjacent finished surfaces.

3.7 OWNER-INSTALLED PRODUCTS

A. Site Access: Provide access to Project site for Owner's construction personnel.

B. Coordination: Coordinate construction and operations of the Work with work performed by Owner's construction personnel.

1. Construction Schedule: Inform Owner of Contractor's preferred construction schedule for Owner's portion of the Work. Adjust construction schedule based on a mutually agreeable timetable. Notify Owner if changes to schedule are required due to differences in actual construction progress.

3.8 PROGRESS CLEANING

A. General: Clean Project site and work areas daily, including common areas. Enforce requirements strictly. Dispose of materials lawfully.

1. Comply with requirements in NFPA 241 for removal of combustible waste materials and debris.

2. Do not hold waste materials more than seven days during normal weather or three days if the temperature is expected to rise above 80 deg F (27 deg C).

3. Containerize hazardous and unsanitary waste materials separately from other waste. Mark containers appropriately and dispose of legally, according to regulations.

a. Use containers intended for holding waste materials of type to be stored.

B. Site: Maintain Project site free of waste materials and debris.

C. Work Areas: Clean areas where work is in progress to the level of cleanliness necessary for proper execution of the Work.

1. Remove liquid spills promptly.

2. Where dust would impair proper execution of the Work, broom-clean or vacuum the entire work area, as appropriate.

D. Installed Work: Keep installed work clean. Clean installed surfaces according to written instructions of manufacturer or fabricator of product installed, using only cleaning materials specifically recommended. If specific cleaning materials are not recommended, use cleaning materials that are not hazardous to health or property and that will not damage exposed surfaces.

E. Concealed Spaces: Remove debris from concealed spaces before enclosing the space.

F. Exposed Surfaces in Finished Areas: Clean exposed surfaces and protect as necessary to ensure freedom from damage and deterioration at time of Substantial Completion.

- G. Waste Disposal: Do not bury or burn waste materials on-site. Do not wash waste materials down sewers or into waterways. Comply with waste disposal requirements in Section 017419 "Construction Waste Management and Disposal."
- H. During handling and installation, clean and protect construction in progress and adjoining materials already in place. Apply protective covering where required to ensure protection from damage or deterioration at Substantial Completion.
- I. Clean and provide maintenance on completed construction as frequently as necessary through the remainder of the construction period. Adjust and lubricate operable components to ensure operability without damaging effects.
- J. Limiting Exposures: Supervise construction operations to assure that no part of the construction, completed or in progress, is subject to harmful, dangerous, damaging, or otherwise deleterious exposure during the construction period.

3.9 STARTING AND ADJUSTING

- A. Coordinate startup and adjusting of equipment and operating components with requirements in Section 019113 "General Commissioning Requirements."
- B. Start equipment and operating components to confirm proper operation. Remove malfunctioning units, replace with new units, and retest.
- C. Adjust equipment for proper operation. Adjust operating components for proper operation without binding.
- D. Test each piece of equipment to verify proper operation. Test and adjust controls and safeties. Replace damaged and malfunctioning controls and equipment.
- E. Manufacturer's Field Service: Comply with qualification requirements in Section 014000 "Quality Requirements."

3.10 PROTECTION OF INSTALLED CONSTRUCTION

- A. Provide final protection and maintain conditions that ensure installed Work is without damage or deterioration at time of Substantial Completion.
- B. Comply with manufacturer's written instructions for temperature and relative humidity.

END OF SECTION 017300

SECTION 017700 – CLOSEOUT PROCEDURES

PART 1 - GENERAL

1.1 SUMMARY

- A. This Section includes administrative and procedural requirements for contract closeout, including, but not limited to, the following:
 - 1. Inspection procedures.
 - 2. Warranties.
 - 3. Final cleaning.
- B. See Volume I "Payment Procedures" for requirements for Applications for Payment for Substantial and Final Completion.
- C. See Division 1 Section "Project Record Documents" for submitting Record Drawings, Record Specifications, and Record Product Data.
- D. See Division 1 Section "Operation and Maintenance Data" for operation and maintenance manual requirements.
- E. See Division 1 Section "Demonstration and Training" for requirements for instructing Owner's personnel.
- F. See Divisions 2 through 16 Sections for specific closeout and special cleaning requirements for the Work in those Sections.

1.2 SUBSTANTIAL COMPLETION

- A. Preliminary Procedures: Before requesting inspection for determining date of Substantial Completion, complete the following. List items below that are incomplete in request.
 - 1. Prepare a list of items to be completed and corrected (punch list), the value of items on the list, and reasons why the Work is not complete.
 - 2. Advise Owner of pending insurance changeover requirements.
 - 3. Submit specific warranties, workmanship bonds, maintenance service agreements, final certifications, and similar documents.
 - 4. Obtain and submit releases permitting Owner unrestricted use of the Work and access to services and utilities. Include occupancy permits, operating certificates, and similar releases.
 - 5. Prepare and submit Project Record Documents, operation and maintenance manuals, Final Completion construction photographs, damage or settlement surveys, property surveys, and similar final record information.
 - 6. Deliver tools, spare parts, extra materials, and similar items to location designated by Owner. Label with manufacturer's name and model number where applicable.
 - 7. Make final changeover of permanent locks. Advise Owner's personnel of changeover in security provisions.
 - 8. Complete startup testing of systems.
 - 9. Submit test/adjust/balance records.

10. Terminate and remove temporary facilities from Project site, along with mockups, construction tools, and similar elements.
 11. Advise Owner of changeover in heat and other utilities.
 12. Submit changeover information related to Owner's occupancy, use, operation, and maintenance.
 13. Complete final cleaning requirements, including touchup painting.
 14. Touch up and otherwise repair and restore marred exposed finishes to eliminate visual defects.
- B. Inspection: Submit a written request for inspection for Substantial Completion. On receipt of request, Construction Manager and Architect will either proceed with inspection or notify Contractor of unfulfilled requirements. Architect will prepare the Certificate of Substantial Completion after inspection or will notify Contractor of items, either on Contractor's list or additional items identified by Architect, that must be completed or corrected before certificate will be issued.
1. Reinspection: Request reinspection when the Work identified in previous inspections as incomplete is completed or corrected.
 2. Results of completed inspection will form the basis of requirements for Final Completion.

1.3 FINAL COMPLETION

- A. Preliminary Procedures: Before requesting final inspection for determining date of Final Completion, complete the following:
1. Submit a final Application for Payment according to Division 1 Section "Payment Procedures."
 2. Submit certified copy of Architect's Substantial Completion inspection list of items to be completed or corrected (punch list), endorsed and dated by Architect. The certified copy of the list shall state that each item has been completed or otherwise resolved for acceptance.
 3. Submit evidence of final, continuing insurance coverage complying with insurance requirements.
 4. Submit pest-control final inspection report and warranty.
 5. Instruct Owner's personnel in operation, adjustment, and maintenance of products, equipment, and systems.
- B. Inspection: Submit a written request for final inspection for acceptance. On receipt of request, Architect will either proceed with inspection or notify Contractor of unfulfilled requirements. Architect will prepare a final Certificate for Payment after inspection or will notify Contractor of construction that must be completed or corrected before certificate will be issued.
1. Re-inspection: Request re-inspection when the Work identified in previous inspections as incomplete is completed or corrected.

1.4 LIST OF INCOMPLETE ITEMS (PUNCH LIST)

- A. Preparation: Submit three copies of list. Include name and identification of each space and area affected by construction operations for incomplete items and items needing correction including, if necessary, areas disturbed by Contractor that are outside the limits of construction. Use CSI Form 14.1A or approved comparable form.

1. Organize list of spaces in sequential order, starting with exterior areas first and proceeding from lowest floor to highest floor.
2. Organize items applying to each space by major element, including categories for ceiling, individual walls, floors, equipment, and building systems.

1.5 WARRANTIES

- A. Submittal Time: Submit written warranties on request of Architect for designated portions of the Work where commencement of warranties other than date of Substantial Completion is indicated.
- B. Organize warranty documents into an orderly sequence based on the table of contents of the Project Manual.
 1. Bind warranties and bonds in heavy-duty, 3-ring, vinyl-covered, loose-leaf binders, thickness as necessary to accommodate contents, and sized to receive 8-1/2-by-11-inch paper.
 2. Provide heavy paper dividers with plastic-covered tabs for each separate warranty. Mark tab to identify the product or installation. Provide a typed description of the product or installation, including the name of the product and the name, address, and telephone number of Installer.
 3. Identify each binder on the front and spine with the typed or printed title "WARRANTIES," Project name, and name of Contractor.
- C. Provide additional copies of each warranty to include in operation and maintenance manuals.

PART 2 - PRODUCTS

2.1 MATERIALS

- A. Cleaning Agents: Use cleaning materials and agents recommended by manufacturer or fabricator of the surface to be cleaned. Do not use cleaning agents that are potentially hazardous to health or property or that might damage finished surfaces.

PART 3 - EXECUTION

3.1 FINAL CLEANING

- A. General: Provide final cleaning. Conduct cleaning and waste-removal operations to comply with local laws and ordinances and Federal and local environmental and antipollution regulations.
- B. Cleaning: Employ experienced workers or professional cleaners for final cleaning. Clean each surface or unit to condition expected in an average commercial building cleaning and maintenance program. Comply with manufacturer's written instructions.
 1. Complete the following cleaning operations before requesting inspection for certification of Substantial Completion for entire Project or for a portion of Project:

- a. Clean Project site, yard, and grounds, in areas disturbed by construction activities, including landscape development areas, of rubbish, waste material, litter, and other foreign substances.
 - b. Sweep paved areas broom clean. Remove petrochemical spills, stains, and other foreign deposits.
 - c. Rake grounds that are neither planted nor paved to a smooth, even-textured surface.
 - d. Remove tools, construction equipment, machinery, and surplus material from Project site.
 - e. Remove snow and ice to provide safe access to building.
 - f. Clean exposed exterior and interior hard-surfaced finishes to a dirt-free condition, free of stains, films, and similar foreign substances. Avoid disturbing natural weathering of exterior surfaces. Restore reflective surfaces to their original condition.
 - g. Remove debris and surface dust from limited access spaces, including roofs, plenums, shafts, trenches, equipment vaults, manholes, attics, and similar spaces.
 - h. Sweep concrete floors broom clean in unoccupied spaces.
 - i. Vacuum carpet and similar soft surfaces, removing debris and excess nap; shampoo if visible soil or stains remain.
 - j. Clean transparent materials, including mirrors and glass in doors and windows. Remove glazing compounds and other noticeable, vision-obscuring materials. Replace chipped or broken glass and other damaged transparent materials. Polish mirrors and glass, taking care not to scratch surfaces.
 - k. Remove labels that are not permanent.
 - l. Touch up and otherwise repair and restore marred, exposed finishes and surfaces. Replace finishes and surfaces that cannot be satisfactorily repaired or restored or that already show evidence of repair or restoration.
 - 1) Do not paint over "UL" and similar labels, including mechanical and electrical nameplates.
 - m. Wipe surfaces of mechanical and electrical equipment, elevator equipment, and similar equipment. Remove excess lubrication, paint and mortar droppings, and other foreign substances.
 - n. Clean plumbing fixtures to a sanitary condition, free of stains, including stains resulting from water exposure.
 - o. Replace disposable air filters and clean permanent air filters. Clean exposed surfaces of diffusers, registers, and grills.
 - p. Clean light fixtures, lamps, globes, and reflectors to function with full efficiency. Replace burned-out bulbs, and those noticeably dimmed by hours of use, and defective and noisy starters in fluorescent and mercury vapor fixtures to comply with requirements for new fixtures.
 - q. Leave Project clean and ready for occupancy.
- C. Pest Control: Engage an experienced, licensed exterminator to make a final inspection and rid Project of rodents, insects, and other pests. Prepare a report.
- D. Comply with safety standards for cleaning. Do not burn waste materials. Do not bury debris or excess materials on Owner's property. Do not discharge volatile, harmful, or dangerous materials into drainage systems. Remove waste materials from Project site and dispose of lawfully.

END OF SECTION 017700

SECTION 017750 – CLOSEOUT REQUIREMENTS

1. The following documents are included in this section:
 - A. Trade Contractors Partial Release of Lien (to be submitted with each invoice)
 - B. Partial Release of Lien – 2nd tier subcontractors and suppliers (to be submitted by every subcontractor and supplier when the contract is 50% billed)
 - C. Trade Contractors Final Release of Lien (to be submitted with final invoice)
 - D. Final Release of Lien – 2nd tier subcontractors and suppliers (to be submitted by every subcontractor and supplier prior to or with final invoice)
 - E. Affidavit Taxes have been paid. (to be submitted prior to or with final invoice)
 - F. Guarantee and Warranty (to be submitted prior to or with final invoice)
 - G. AIA Document G706, Contractors Affidavit of Payment of Debts and Claims (to be submitted prior to or with final invoice)
 - H. AIA Document G706A, Contractors Affidavit of Release of Liens (to be submitted prior to or with final invoice)
 - I. AIA Document G707, Consent of Surety to Final Payment (to be submitted prior to or with final invoice)

END OF SECTION 017750
(ATTACHMENTS FOLLOW)

**TRADE CONTRACTOR'S PARTIAL RELEASE,
WAIVER OF LIEN AND AFFIDAVIT**

TO: Red Clay Consolidated School District
1502 Spruce Avenue
Wilmington, DE 19805

RE: Red Clay School District Contract No.:
CM: Whiting-Turner Contracting Company
PROJECT: William F. Cooke Elementary School
CURRENT INVOICE NO.: _____
FOR THE PERIOD ENDING: _____

The undersigned Contractor, in consideration of the payments previously made and payment for the period covered by the current invoice set forth above, hereby waives and releases all mechanic's, materialman's or other liens and, to the fullest extent permitted by law, all rights to file any such liens in the future, and all claims and demands against Owner, Construction Manager, and the real property on which the project is located, in any manner arising out of work, labor, services, equipment or materials, performed or furnished by Contractor, its subcontractors and suppliers, in connection with the Project and trade contract, through the period covered by the current invoice and all previous invoices. The release does not apply to retention, nor to extra work which Contractor has been authorized to proceed with by the Construction Manager, but for which payment has not yet been approved.

Except as noted below, Contractor acknowledges and represents that for the period and work covered by all previous invoices for which Contractor has received payment:

1. Contractor has paid in full all amounts for subcontracts, labor, materials and rented equipment.
2. Contractor has properly applied previous payments to pay all outstanding invoices related to the Project.
3. Contractor is aware of no claims nor any circumstances that could give rise to any future claims against Owner, Construction Manager, Architect or other Trade Contractor on the Project.
4. All payroll, withholding, sales and other taxes, union benefits, insurance premiums and any other amount required by law, regulation or agreement to be paid in connection with labor, materials, and equipment for the Project have been paid in full.

List exceptions, if any:

Contractor represents that the amounts set forth below are correct and that the amount of the current payment due will be applied promptly to full payment of all outstanding amounts due from Contractor to others in connection with the Project.

Contract Sum to Date	\$ _____
Total Completed and Stored to Date	\$ _____
Total Retention to Date	\$ _____
Total Earned Less Retention	\$ _____
Less Previous Payments	\$ _____
Current Payment Due	\$ _____

BY: _____
(Name of Subcontractor)

BY: _____
(Signature, Printed Name and Title), Duly Authorized Agent of Subcontractor

STATE OF _____)
(CITY)(COUNTY)OF _____) to wit:

On this _____ day of _____, 20____, appeared before me _____ and he/she made oath in due form of law that the facts, information and representations set forth in the foregoing Trade Contractor's Partial Release, Waiver of lien and Affidavit, are true and accurate to the best of his/her knowledge, information and belief.

Notary Public My commission expires: _____

**PARTIAL WAIVER AND RELEASE
FOR SECOND TIER SUBCONTRACTORS AND SUPPLIERS**

TO: Red Clay Consolidated School District(Owner)

DATE: _____

CONSTRUCTION MANAGER: The Whiting-Turner Contracting Co.

PROJECT: William F. Cooke Elementary School

CONTRACTOR: _____

The undersigned Company, a subcontractor or supplier to the Trade Contractor named above, and hereinafter referred to as the "Company", in consideration of payments previously received and in consideration of payment for work performed through the current date set forth below, hereby waives and releases all mechanics', materialman's, or other liens and, to the fullest extent permitted by law, all rights to file any such liens in the future, and all claims and demands against the Owner, the Construction Manager and the real property on which the Project is located, and any claims arising out of work, labor, services, equipment or materials, performed or furnished by the Company, its subcontractors and suppliers, in connection with the Project, through the period covered by the current invoice.

Except as noted below, the Company further acknowledges and represents that all persons and entities which have provided labor or material, or rented equipment, for or through the Company in connection with the project have been paid in full, for the periods covered by previous payments, that previous payments to the Company have been properly applied to pay all outstanding invoices relating to the Project, that the Company is not aware of any claims, or circumstances which could give rise to future claims, against the Owner, the Construction Manager or the Project, and that all payroll, withholding and other taxes, union benefits, insurance premiums or other amounts required by law, regulation or agreement to be paid in connection with labor for the project have been paid in full through the last date of work covered by the current invoice.

List exceptions, if any:

Last date of work period covered by current Invoice: _____

(Name of Company)

BY: _____
Signature, Duly Authorized Agent of Company

Address: _____

Printed Name and Title

STATE OF _____)
(CITY)(COUNTY)OF _____)

)to wit:

On this _____ day of _____, _____, appeared before me _____ and he/she made oath in due form of law that the facts, information and representations set forth in the foregoing Company's Partial Waiver and Release, are true and accurate to the best of his/her knowledge, information and belief.

Notary Public

My commission expires: _____

TRADE CONTRACTOR'S FINAL RELEASE AND AFFIDAVIT

TO: Red Clay Consolidated School District(OWNER) DATE:
1502 Spruce Avenue
Wilmington, DE 19805

FROM: (Trade Contractor)

RE: DATED:

CONSTRUCTION MANAGER: The Whiting-Turner Contracting Company

PROJECT: William F. Cooke Elementary School

The undersigned Trade Contractor, in consideration of final payment as set forth herein, hereby waives all mechanic's liens and rights to file mechanic's liens and generally releases, and agrees to indemnify and save harmless, the above Owner, the construction manager, their successors and assigns, from all causes of action, suits, debts, contracts, damages, judgments, decrees, claims, demands, liens, rights to assert liens, awards and expenses, including attorneys' fees, in law, equity or otherwise, which Trade Contractor, its subcontractors and suppliers, their successors and assigns and any persons claiming through them or based upon their acts or omissions ever had, now have or hereafter may have against the above Owner, the construction manager, and any real property or improvements of Owner, from the beginning of the world to the date of this Release, in any manner relating to or arising in connection with the above referenced contract or project.

Trade Contractor represents that the amounts set forth below are correct and that the amount of the current payment due will promptly be applied to full payment of all outstanding amounts due from Trade Contractor to others in connection with the Project.

Table with 2 columns: Description and Amount. Rows include Final Contract Amount, Less Previous Payments, and Final Payment Due.

I hereby certify, under penalties of perjury, that the information and representations set forth above are true and accurate to the best of my knowledge, information and belief.

Trade Contractor
BY: Address:

Signature, Duly Authorized Agent of Trade Contractor

Printed Name and Title

STATE OF)
(CITY)(COUNTY)OF) to wit:

On this ___ day of ___, 20___, appeared before me ___ and he/she made oath in due form of law that the facts, information and representations set forth in the foregoing Trade Contractor's Final Release and Affidavit, are true and accurate to the best of his/her knowledge, information and belief.

(Notary Public) My commission expires:

**FINAL WAIVER AND RELEASE
FOR SECOND TIER SUBCONTRACTORS AND SUPPLIERS**

OWNER: Red Clay Consolidated School District

DATE: _____

CONSTRUCTION MANAGER: The Whiting-Turner Contracting Co.

PROJECT: William F, Cooke Elementary School

CONTRACTOR: _____

The undersigned Company, a subcontractor or supplier to the contractor named above, and hereinafter referred to as the "Company", in consideration of payments previously received and in consideration of final payment set forth below, hereby waives and releases all mechanics', materialman's, or other liens and, to the fullest extent permitted by law, all rights to file any such liens in the future, and all claims and demands against the Owner, the Construction Manager and the real property on which the Project is located, and any claims arising out of work, labor, services, equipment or materials, performed or furnished by the Company, its subcontractors and suppliers, in connection with the Project, from the beginning of the world to the date of this Waiver and Release.

Except as noted below, the Company further acknowledges and represents that all persons and entities which have provided labor or material, or rented equipment, for or through the Company in connection with the project have been paid in full, that previous payments to the Company have been properly applied to pay all outstanding invoices relating to the project, that the Company is not aware of any claims, or circumstances which could give rise to future claims, against the Owner, the Construction Manager or the Project, and that all payroll, withholding and other taxes, union benefits, insurance premiums or other amounts required by law, regulation or agreement to be paid in connection with labor for the project have been paid in full.

Final Payment Due: \$ _____

(Name of Company)

BY: _____
Signature, Duly Authorized Agent of Company

Address: _____

Printed Name and Title

STATE OF _____)
(CITY)(COUNTY)OF _____)

)to wit:

On this _____ day of _____, _____, appeared before me _____ and he/she made oath in due form of law that the facts, information and representations set forth in the foregoing Company's Final Waiver and Release, are true and accurate to the best of his/her knowledge, information and belief.

(Notary Public)

My commission expires: _____

AFFIDAVIT THAT ALL TAXES HAVE BEEN PAID

RE: William F. Cooke Elementary School

Date: _____

TO: RED CLAY CONSOLIDATED SCHOOL DISTRICT
1502 SPRUCE AVENUE
WILMINGTON, DE 19805

The undersigned certifies that all federal, state and local taxes (including sales, consumer, use and excise taxes) applicable to the work and services performed and materials and equipment incorporated into the work, in each case pursuant to the contract referred to above, have been paid in full.

SUPPLIER/CONTRACTOR: _____

By: _____

Date: _____

Title: _____

STATE OF _____)

COUNTY OF _____)

On this ____ day of _____, _____, before me personally came _____
_____, to me known who, being by me duly sworn, did depose and say that
he resides at _____ that
he is _____ of _____
the corporation that executed the foregoing instrument and that he signed his name thereto by order of the Board of
Directors of said corporation.

Notary Public

My Commission Expires: _____

GUARANTEE AND WARRANTY

WHEREAS, _____, hereinafter called the "Guarantor," entered into a contract dated _____, hereinafter called the "Contract," with the Christina School District, hereinafter called the Owner, for the construction of the William F. Cooke Elementary School (hereinafter referred to as the "Work"), located at 2025 Graves Road, Hockessin, Delaware 19707.

WHEREAS, the Owner has performed, kept, observed and fulfilled each and every one of the obligations, promises, stipulated, terms and conditions on its part, and

WHEREAS, by the terms of the Contract, one of the conditions precedent to the making of final payment is the execution and delivery by the Grantor of this guarantee and warranty; and

WHEREAS, the Guarantor is now desirous of obtaining payment pursuant to the terms of said Contract and as a condition precedent to such payment, furnishes this separate guarantee and warranty for all work and material included in said Contract,

NOW THEREFORE, in consideration of the premises and of the payments made to the Guarantor under said Contract and in further consideration of final payment, the Guarantor does hereby for itself and its successors, heirs and assigns, guarantee and warrant to the Owner, its successors and assigns, that the Guarantor has performed all the work required by said Contract in accordance with the terms thereof including but not limited to satisfactory operation of all equipment by means or acceptance tests, correction of items on punchlists prepared by the Architect, and that all portions of the work completed under the Contract are perfect as to materials and workmanship and will so remain from _____ for a period of one (1) year; and

The Guarantor does hereby further guarantee and warrant that the Guarantor will make good and replace at its own cost and expense all defects in material and workmanship appearing during the period aforesaid and the Guarantor will be responsible for all damage caused to the Owner by such defects or by the work required to remedy such defects. All corrections to material and workmanship shall be made at the convenience of the Owner and shall be performed in a good workmanlike manner.

The Guarantor does hereby warrant and represent that it has obtained warranties and guarantees from its material and equipment suppliers and from its subcontractors to the fullest extent possible and as customary in the various trades and has delivered all assignable warranties and guarantees to the Owner.

It is understood that this guarantee shall in no way be construed to limit in any manner any of the provisions of the Contract or to modify or limit any of the obligations, liabilities and duties of the Guarantor thereunder.

It is further understood that his guarantee shall remain binding and irrevocable during the above stated period and that the Guarantor shall not contest the validity of, or in any way attempt to revoke or withdraw from, this guarantee for any cause whatsoever, whatever arising before or after the execution of the Contract or this guarantee.

IN WITNESS WHEREOF, the Guarantor has caused this instrument to be signed and executed this _____ day of _____, 20____.

(GUARANTOR)

WITNESS:

BY: _____

TITLE: _____

STATE OF _____)
COUNTY OF _____)

On this _____ day of _____, 20____, before me personally came _____, to me known who, being by me duly sworn, did depose and say that he resides at _____, that he is _____ of _____, the corporation that executed the foregoing instrument and that he signed his name thereto by order of the Board of Directors of said corporation.

NOTARY PUBLIC

My Commission Expires: _____

DRAFT AIA[®] Document G706[™] - 1994

Contractor's Affidavit of Payment of Debts and Claims

PROJECT: *(Name and address)*

ARCHITECT'S PROJECT NUMBER:

TO OWNER: *(Name and address)*

CONTRACT FOR: General Construction

CONTRACT DATED:

OWNER:
ARCHITECT:
CONTRACTOR:
SURETY:
OTHER:

STATE OF:
COUNTY OF:

The undersigned hereby certifies that, except as listed below, payment has been made in full and all obligations have otherwise been satisfied for all materials and equipment furnished, for all work, labor, and services performed, and for all known indebtedness and claims against the Contractor for damages arising in any manner in connection with the performance of the Contract referenced above for which the Owner or Owner's property might in any way be held responsible or encumbered.

EXCEPTIONS:

SUPPORTING DOCUMENTS ATTACHED HERETO:

1. Consent of Surety to Final Payment. Whenever Surety is involved, Consent of Surety is required. AIA Document G707, Consent of Surety, may be used for this purpose

Indicate Attachment Yes No

The following supporting documents should be attached hereto if required by the Owner:

1. Contractor's Release or Waiver of Liens, conditional upon receipt of final payment.
2. Separate Releases or Waivers of Liens from Subcontractors and material and equipment suppliers, to the extent required by the Owner, accompanied by a list thereof.
3. Contractor's Affidavit of Release of Liens (AIA Document G706A).

CONTRACTOR: *(Name and address)*

BY: _____

(Signature of authorized representative)

(Printed name and title)

Subscribed and sworn to before me on this date:

Notary Public:

My Commission Expires:

DRAFT AIA[®] Document G706A[™] - 1994

Contractor's Affidavit of Release of Liens

PROJECT: *(Name and address)*

ARCHITECT'S PROJECT NUMBER:

CONTRACT FOR: General
Construction

CONTRACT DATED:

TO OWNER: *(Name and address)*

OWNER:

ARCHITECT:

CONTRACTOR:

SURETY:

OTHER:

STATE OF:
COUNTY OF:

The undersigned hereby certifies that to the best of the undersigned's knowledge, information and belief, except as listed below, the Releases or Waivers of Lien attached hereto include the Contractor, all Subcontractors, all suppliers of materials and equipment, and all performers of Work, labor or services who have or may have liens or encumbrances or the right to assert liens or encumbrances against any property of the Owner arising in any manner out of the performance of the Contract referenced above.

EXCEPTIONS:

SUPPORTING DOCUMENTS ATTACHED HERETO:

1. Contractor's Release or Waiver of Liens, conditional upon receipt of final payment.
2. Separate Releases or Waivers of Liens from Subcontractors and material and equipment suppliers, to the extent required by the Owner, accompanied by a list thereof.

CONTRACTOR: *(Name and address)*

BY:

(Signature of authorized representative)

(Printed name and title)

Subscribed and sworn to before me on this date:

Notary Public:

My Commission Expires:

DRAFT AIA[®] Document G707[™] - 1994

Consent Of Surety to Final Payment

PROJECT: *(Name and address)*

ARCHITECT'S PROJECT NUMBER:

OWNER:

CONTRACT FOR: General Construction

ARCHITECT:

TO OWNER: *(Name and address)*

CONTRACT DATED:

CONTRACTOR:

SURETY:

OTHER:

In accordance with the provisions of the Contract between the Owner and the Contractor as indicated above, the
(Insert name and address of Surety)

, SURETY,

on bond of
(Insert name and address of Contractor)

, CONTRACTOR,

hereby approves of the final payment to the Contractor, and agrees that final payment to the Contractor shall not relieve the
Surety of any of its obligations to
(Insert name and address of Owner)

, OWNER,

as set forth in said Surety's bond.

IN WITNESS WHEREOF, the Surety has hereunto set its hand on this date:
(Insert in writing the month followed by the numeric date and year.)

(Surety)

(Signature of authorized representative)

Attest:
(Seal):

(Printed name and title)

SECTION 017823 - OPERATION AND MAINTENANCE DATA

PART 1 - GENERAL

1.1 RELATED DOCUMENTS

- A. Drawings and general provisions of the Contract, including General and Supplementary Conditions and other Division 01 Specification Sections, apply to this Section.

1.2 SUMMARY

- A. Section includes administrative and procedural requirements for preparing operation and maintenance manuals, including the following:
 - 1. Operation and maintenance documentation directory.
 - 2. Emergency manuals.
 - 3. Operation manuals for systems, subsystems, and equipment.
 - 4. Product maintenance manuals.
 - 5. Systems and equipment maintenance manuals.
- B. Related Requirements:
 - 1. Section 013300 "Submittal Procedures" for submitting copies of submittals for operation and maintenance manuals.
 - 2. Section 019113 "General Commissioning Requirements" for verification and compilation of data into operation and maintenance manuals.

1.3 DEFINITIONS

- A. System: An organized collection of parts, equipment, or subsystems united by regular interaction.
- B. Subsystem: A portion of a system with characteristics similar to a system.

1.4 CLOSEOUT SUBMITTALS

- A. Manual Content: Operations and maintenance manual content is specified in individual Specification Sections to be reviewed at the time of Section submittals. Submit reviewed manual content formatted and organized as required by this Section.
 - 1. Architect will comment on whether content of operations and maintenance submittals are acceptable.
 - 2. Where applicable, clarify and update reviewed manual content to correspond to revisions and field conditions.

- B. Initial Manual Submittal: Submit draft copy of each manual at least 30 days before commencing demonstration and training. Architect and Engineer will comment on whether general scope and content of manual are acceptable.
1. PDF electronic file. Assemble each manual into a composite electronically indexed file. Submit on digital media acceptable to Architect.
 - a. Name each indexed document file in composite electronic index with applicable item name. Include a complete electronically linked operation and maintenance directory.
 - b. Enable inserted reviewer comments on draft submittals.
 2. One paper copy. Include a complete operation and maintenance directory. Enclose title pages and directories in clear plastic sleeves. Architect will return copy to contractor.
- C. Final Manual Submittal: Submit each manual in final form prior to requesting inspection for Substantial Completion and at least 15 days before commencing demonstration and training.
1. Three paper copies. Include a complete operation and maintenance directory. Enclose title pages and directories in clear plastic sleeves. Architect will return copies to contractor.
 2. Electronic copy, PDF file format.
 - 1) Provide 3 copies of manual on DVD / CD organized in binder w/ digital media file sheets.

PART 2 - PRODUCTS

2.1 OPERATION AND MAINTENANCE DOCUMENTATION DIRECTORY

- A. Directory: Prepare a single, comprehensive directory of emergency, operation, and maintenance data and materials, listing items and their location to facilitate ready access to desired information. Include a section in the directory for each of the following:
1. List of documents.
 2. List of systems.
 3. List of equipment.
 4. Table of contents.
- B. List of Systems and Subsystems: List systems alphabetically. Include references to operation and maintenance manuals that contain information about each system.
- C. List of Equipment: List equipment for each system, organized alphabetically by system. For pieces of equipment not part of system, list alphabetically in separate list.
- D. Tables of Contents: Include a table of contents for each emergency, operation, and maintenance manual.

- E. Identification: In the documentation directory and in each operation and maintenance manual, identify each system, subsystem, and piece of equipment with same designation used in the Contract Documents. If no designation exists, assign a designation according to ASHRAE Guideline 4, "Preparation of Operating and Maintenance Documentation for Building Systems."

2.2 REQUIREMENTS FOR EMERGENCY, OPERATION, AND MAINTENANCE MANUALS

- A. Organization: Unless otherwise indicated, organize each manual into a separate section for each system and subsystem, and a separate section for each piece of equipment not part of a system. Each manual shall contain the following materials, in the order listed:
 - 1. Title page.
 - 2. Table of contents.
 - 3. Manual contents.
- B. Title Page: Include the following information:
 - 1. Subject matter included in manual.
 - 2. Name and address of Project.
 - 3. Name and address of Owner.
 - 4. Date of submittal.
 - 5. Name and contact information for Contractor.
 - 6. Name and contact information for Construction Manager.
 - 7. Name and contact information for Architect.
 - 8. Name and contact information for Commissioning Authority.
 - 9. Names and contact information for major consultants to the Architect that designed the systems contained in the manuals.
 - 10. Cross-reference to related systems in other operation and maintenance manuals.
- C. Table of Contents: List each product included in manual, identified by product name, indexed to the content of the volume, and cross-referenced to Specification Section number in Project Manual.
 - 1. If operation or maintenance documentation requires more than one volume to accommodate data, include comprehensive table of contents for all volumes in each volume of the set.
- D. Manual Contents: Organize into sets of manageable size. Arrange contents alphabetically by system, subsystem, and equipment. If possible, assemble instructions for subsystems, equipment, and components of one system into a single binder.
- E. Manuals, Electronic Files: Submit manuals in the form of a multiple file composite electronic PDF file for each manual type required.
 - 1. Electronic Files: Use electronic files prepared by manufacturer where available. Where scanning of paper documents is required, configure scanned file for minimum readable file size.
 - 2. File Names and Bookmarks: Enable bookmarking of individual documents based on file names. Name document files to correspond to system, subsystem, and equipment names

used in manual directory and table of contents. Group documents for each system and subsystem into individual composite bookmarked files, then create composite manual, so that resulting bookmarks reflect the system, subsystem, and equipment names in a readily navigated file tree. Configure electronic manual to display bookmark panel on opening file.

- F. Manuals, Paper Copy: Submit manuals in the form of hard copy, bound and labeled volumes.
1. Binders: Heavy-duty, three-ring, vinyl-covered, post-type binders, in thickness necessary to accommodate contents, sized to hold 8-1/2-by-11-inch (215-by-280-mm) paper; with clear plastic sleeve on spine to hold label describing contents and with pockets inside covers to hold folded oversize sheets.
 - a. If two or more binders are necessary to accommodate data of a system, organize data in each binder into groupings by subsystem and related components. Cross-reference other binders if necessary to provide essential information for proper operation or maintenance of equipment or system.
 - b. Identify each binder on front and spine, with printed title "OPERATION AND MAINTENANCE MANUAL," Project title or name, subject matter of contents, and indicate Specification Section number on bottom of spine. Indicate volume number for multiple-volume sets.
 2. Dividers: Heavy-paper dividers with plastic-covered tabs for each section of the manual. Mark each tab to indicate contents. Include typed list of products and major components of equipment included in the section on each divider, cross-referenced to Specification Section number and title of Project Manual.
 3. Protective Plastic Sleeves: Transparent plastic sleeves designed to enclose diagnostic software storage media for computerized electronic equipment.
 4. Supplementary Text: Prepared on 8-1/2-by-11-inch (215-by-280-mm) white bond paper.
 5. Drawings: Attach reinforced, punched binder tabs on drawings and bind with text.
 - a. If oversize drawings are necessary, fold drawings to same size as text pages and use as foldouts.
 - b. If drawings are too large to be used as foldouts, fold and place drawings in labeled envelopes and bind envelopes in rear of manual. At appropriate locations in manual, insert typewritten pages indicating drawing titles, descriptions of contents, and drawing locations.

2.3 EMERGENCY MANUALS

- A. Content: Organize manual into a separate section for each of the following:
1. Type of emergency.
 2. Emergency instructions.
 3. Emergency procedures.
- B. Type of Emergency: Where applicable for each type of emergency indicated below, include instructions and procedures for each system, subsystem, piece of equipment, and component:
1. Fire.

2. Flood.
 3. Gas leak.
 4. Water leak.
 5. Power failure.
 6. Water outage.
 7. System, subsystem, or equipment failure.
 8. Chemical release or spill.
- C. Emergency Instructions: Describe and explain warnings, trouble indications, error messages, and similar codes and signals. Include responsibilities of Owner's operating personnel for notification of Installer, supplier, and manufacturer to maintain warranties.
- D. Emergency Procedures: Include the following, as applicable:
1. Instructions on stopping.
 2. Shutdown instructions for each type of emergency.
 3. Operating instructions for conditions outside normal operating limits.
 4. Required sequences for electric or electronic systems.
 5. Special operating instructions and procedures.

2.4 OPERATION MANUALS

- A. Content: In addition to requirements in this Section, include operation data required in individual Specification Sections and the following information:
1. System, subsystem, and equipment descriptions. Use designations for systems and equipment indicated on Contract Documents.
 2. Performance and design criteria if Contractor has delegated design responsibility.
 3. Operating standards.
 4. Operating procedures.
 5. Operating logs.
 6. Wiring diagrams.
 7. Control diagrams.
 8. Piped system diagrams.
 9. Precautions against improper use.
 10. License requirements including inspection and renewal dates.
- B. Descriptions: Include the following:
1. Product name and model number. Use designations for products indicated on Contract Documents.
 2. Manufacturer's name.
 3. Equipment identification with serial number of each component.
 4. Equipment function.
 5. Operating characteristics.
 6. Limiting conditions.
 7. Performance curves.
 8. Engineering data and tests.
 9. Complete nomenclature and number of replacement parts.

- C. Operating Procedures: Include the following, as applicable:
 - 1. Startup procedures.
 - 2. Equipment or system break-in procedures.
 - 3. Routine and normal operating instructions.
 - 4. Regulation and control procedures.
 - 5. Instructions on stopping.
 - 6. Normal shutdown instructions.
 - 7. Seasonal and weekend operating instructions.
 - 8. Required sequences for electric or electronic systems.
 - 9. Special operating instructions and procedures.
- D. Systems and Equipment Controls: Describe the sequence of operation, and diagram controls as installed.
- E. Piped Systems: Diagram piping as installed, and identify color-coding where required for identification.

2.5 PRODUCT MAINTENANCE MANUALS

- A. Content: Organize manual into a separate section for each product, material, and finish. Include source information, product information, maintenance procedures, repair materials and sources, and warranties and bonds, as described below.
- B. Source Information: List each product included in manual, identified by product name and arranged to match manual's table of contents. For each product, list name, address, and telephone number of Installer or supplier and maintenance service agent, and cross-reference Specification Section number and title in Project Manual and drawing or schedule designation or identifier where applicable.
- C. Product Information: Include the following, as applicable:
 - 1. Product name and model number.
 - 2. Manufacturer's name.
 - 3. Color, pattern, and texture.
 - 4. Material and chemical composition.
 - 5. Reordering information for specially manufactured products.
- D. Maintenance Procedures: Include manufacturer's written recommendations and the following:
 - 1. Inspection procedures.
 - 2. Types of cleaning agents to be used and methods of cleaning.
 - 3. List of cleaning agents and methods of cleaning detrimental to product.
 - 4. Schedule for routine cleaning and maintenance.
 - 5. Repair instructions.
- E. Repair Materials and Sources: Include lists of materials and local sources of materials and related services.

- F. Warranties and Bonds: Include copies of warranties and bonds and lists of circumstances and conditions that would affect validity of warranties or bonds.
 - 1. Include procedures to follow and required notifications for warranty claims.

2.6 SYSTEMS AND EQUIPMENT MAINTENANCE MANUALS

- A. Content: For each system, subsystem, and piece of equipment not part of a system, include source information, manufacturers' maintenance documentation, maintenance procedures, maintenance and service schedules, spare parts list and source information, maintenance service contracts, and warranty and bond information, as described below.
- B. Source Information: List each system, subsystem, and piece of equipment included in manual, identified by product name and arranged to match manual's table of contents. For each product, list name, address, and telephone number of Installer or supplier and maintenance service agent, and cross-reference Specification Section number and title in Project Manual and drawing or schedule designation or identifier where applicable.
- C. Manufacturers' Maintenance Documentation: Manufacturers' maintenance documentation including the following information for each component part or piece of equipment:
 - 1. Standard maintenance instructions and bulletins.
 - 2. Drawings, diagrams, and instructions required for maintenance, including disassembly and component removal, replacement, and assembly.
 - 3. Identification and nomenclature of parts and components.
 - 4. List of items recommended to be stocked as spare parts.
- D. Maintenance Procedures: Include the following information and items that detail essential maintenance procedures:
 - 1. Test and inspection instructions.
 - 2. Troubleshooting guide.
 - 3. Precautions against improper maintenance.
 - 4. Disassembly; component removal, repair, and replacement; and reassembly instructions.
 - 5. Aligning, adjusting, and checking instructions.
 - 6. Demonstration and training video recording, if available.
- E. Maintenance and Service Schedules: Include service and lubrication requirements, list of required lubricants for equipment, and separate schedules for preventive and routine maintenance and service with standard time allotment.
 - 1. Scheduled Maintenance and Service: Tabulate actions for daily, weekly, monthly, quarterly, semiannual, and annual frequencies.
 - 2. Maintenance and Service Record: Include manufacturers' forms for recording maintenance.
- F. Spare Parts List and Source Information: Include lists of replacement and repair parts, with parts identified and cross-referenced to manufacturers' maintenance documentation and local sources of maintenance materials and related services.

- G. Maintenance Service Contracts: Include copies of maintenance agreements with name and telephone number of service agent.
- H. Warranties and Bonds: Include copies of warranties and bonds and lists of circumstances and conditions that would affect validity of warranties or bonds.
 - 1. Include procedures to follow and required notifications for warranty claims.

PART 3 - EXECUTION

3.1 MANUAL PREPARATION

- A. Operation and Maintenance Documentation Directory: Prepare a separate manual that provides an organized reference to emergency, operation, and maintenance manuals.
- B. Emergency Manual: Assemble a complete set of emergency information indicating procedures for use by emergency personnel and by Owner's operating personnel for types of emergencies indicated.
- C. Product Maintenance Manual: Assemble a complete set of maintenance data indicating care and maintenance of each product, material, and finish incorporated into the Work.
- D. Operation and Maintenance Manuals: Assemble a complete set of operation and maintenance data indicating operation and maintenance of each system, subsystem, and piece of equipment not part of a system.
 - 1. Engage a factory-authorized service representative to assemble and prepare information for each system, subsystem, and piece of equipment not part of a system.
 - 2. Prepare a separate manual for each system and subsystem, in the form of an instructional manual for use by Owner's operating personnel.
- E. Manufacturers' Data: Where manuals contain manufacturers' standard printed data, include only sheets pertinent to product or component installed. Mark each sheet to identify each product or component incorporated into the Work. If data include more than one item in a tabular format, identify each item using appropriate references from the Contract Documents. Identify data applicable to the Work and delete references to information not applicable.
 - 1. Prepare supplementary text if manufacturers' standard printed data are not available and where the information is necessary for proper operation and maintenance of equipment or systems.
- F. Drawings: Prepare drawings supplementing manufacturers' printed data to illustrate the relationship of component parts of equipment and systems and to illustrate control sequence and flow diagrams. Coordinate these drawings with information contained in record Drawings to ensure correct illustration of completed installation.
 - 1. Do not use original project record documents as part of operation and maintenance manuals.

2. Comply with requirements of newly prepared record Drawings in Section 017839 "Project Record Documents."
- G. Comply with Section 017700 "Closeout Procedures" for schedule for submitting operation and maintenance documentation.

END OF SECTION 017823

SECTION 017839 - PROJECT RECORD DOCUMENTS

PART 1 - GENERAL

1.1 RELATED DOCUMENTS

- A. Drawings and general provisions of the Contract, including General and Supplementary Conditions and other Division 01 Specification Sections, apply to this Section.

1.2 SUMMARY

- A. Section includes administrative and procedural requirements for project record documents, including the following:
 - 1. Record Drawings.
 - 2. Record Specifications.
 - 3. Record Product Data.
 - 4. Miscellaneous record submittals.
- B. Related Requirements:
 - 1. Section 017300 "Execution" for final property survey.
 - 2. Section 017700 "Closeout Procedures" for general closeout procedures.
 - 3. Section 017823 "Operation and Maintenance Data" for operation and maintenance manual requirements.

1.3 CLOSEOUT SUBMITTALS

- A. Record Drawings: Comply with the following:
 - 1. Number of Copies: Submit copies of record Drawings as follows:
 - a. Initial Submittal:
 - 1) Submit PDF electronic files of scanned record prints and of file prints.
 - 2) Architect will indicate whether general scope of changes, additional information recorded, and quality of drafting are acceptable.
 - b. Final Submittal:
 - 1) Submit PDF electronic files of scanned record prints and three set(s) of prints.
 - 2) Print each drawing, whether or not changes and additional information were recorded.

- B. Miscellaneous Record Submittals: See other Specification Sections for miscellaneous record-keeping requirements and submittals in connection with various construction activities. Submit annotated PDF electronic files and directories of each submittal.
- C. Reports: Submit written report monthly indicating items incorporated into project record documents concurrent with progress of the Work, including revisions, concealed conditions, field changes, product selections, and other notations incorporated.

PART 2 - PRODUCTS

2.1 RECORD DRAWINGS

- A. Record Prints: Maintain one set of marked-up paper copies of the Contract Drawings and Shop Drawings, incorporating new and revised drawings as modifications are issued.
 - 1. Preparation: Mark record prints to show the actual installation where installation varies from that shown originally. Require individual or entity who obtained record data, whether individual or entity is Installer, subcontractor, or similar entity, to provide information for preparation of corresponding marked-up record prints.
 - a. Give particular attention to information on concealed elements that would be difficult to identify or measure and record later.
 - b. Accurately record information in an acceptable drawing technique.
 - c. Record data as soon as possible after obtaining it.
 - d. Record and check the markup before enclosing concealed installations.
 - 2. Content: Types of items requiring marking include, but are not limited to, the following:
 - a. Dimensional changes to Drawings.
 - b. Revisions to details shown on Drawings.
 - c. Depths of foundations below first floor.
 - d. Locations and depths of underground utilities.
 - e. Revisions to routing of piping and conduits.
 - f. Revisions to electrical circuitry.
 - g. Actual equipment locations.
 - h. Duct size and routing.
 - i. Locations of concealed internal utilities.
 - j. Changes made by Change Order or Construction Change Directive.
 - k. Changes made following Architect's written orders.
 - l. Details not on the original Contract Drawings.
 - m. Field records for variable and concealed conditions.
 - n. Record information on the Work that is shown only schematically.
 - 3. Mark the Contract Drawings and Shop Drawings completely and accurately. Use personnel proficient at recording graphic information in production of marked-up record prints.
 - 4. Mark record sets with erasable, red-colored pencil. Use other colors to distinguish between changes for different categories of the Work at same location.

5. Mark important additional information that was either shown schematically or omitted from original Drawings.
 6. Note Construction Change Directive numbers, alternate numbers, Change Order numbers, and similar identification, where applicable.
- B. Format: Identify and date each record Drawing; include the designation "PROJECT RECORD DRAWING" in a prominent location.
1. Record Prints: Organize record prints and newly prepared record Drawings into manageable sets. Bind each set with durable paper cover sheets. Include identification on cover sheets.
 2. Format: Annotated PDF electronic file.
 3. Identification: As follows:
 - a. Project name.
 - b. Date.
 - c. Designation "PROJECT RECORD DRAWINGS."
 - d. Name of Architect.
 - e. Name of Contractor.

2.2 MISCELLANEOUS RECORD SUBMITTALS

- A. Assemble miscellaneous records required by other Specification Sections for miscellaneous record keeping and submittal in connection with actual performance of the Work. Bind or file miscellaneous records and identify each, ready for continued use and reference.
- B. Format: Submit miscellaneous record submittals as PDF electronic file.
1. Include miscellaneous record submittals directory organized by Specification Section number and title, electronically linked to each item of miscellaneous record submittals.

PART 3 - EXECUTION

3.1 RECORDING AND MAINTENANCE

- A. Recording: Maintain one copy of each submittal during the construction period for project record document purposes. Post changes and revisions to project record documents as they occur; do not wait until end of Project.
- B. Maintenance of Record Documents and Samples: Store record documents and Samples in the field office apart from the Contract Documents used for construction. Do not use project record documents for construction purposes. Maintain record documents in good order and in a clean, dry, legible condition, protected from deterioration and loss. Provide access to project record documents for Architect's reference during normal working hours.

END OF SECTION 017839

SECTION 017900 - DEMONSTRATION AND TRAINING

PART 1 - GENERAL

1.1 RELATED DOCUMENTS

- A. Drawings and general provisions of the Contract, including General and Supplementary Conditions and other Division 01 Specification Sections, apply to this Section.

1.2 SUMMARY

- A. Section includes administrative and procedural requirements for instructing Owner's personnel, including the following:
 - 1. Demonstration of operation of systems, subsystems, and equipment.
 - 2. Training in operation and maintenance of systems, subsystems, and equipment.
 - 3. Demonstration and training video recordings.

1.3 INFORMATIONAL SUBMITTALS

- A. Instruction Program: Submit outline of instructional program for demonstration and training, including a list of training modules and a schedule of proposed dates, times, length of instruction time, and instructors' names for each training module. Include learning objective and outline for each training module.
 - 1. Indicate proposed training modules using manufacturer-produced demonstration and training video recordings for systems, equipment, and products in lieu of video recording of live instructional module.

1.4 CLOSEOUT SUBMITTALS

- A. Demonstration and Training Video Recordings: Submit two copies within seven days of end of each training module.
 - 1. Identification: On each copy, provide an applied label with the following information:
 - a. Name of Project.
 - b. Name and address of videographer.
 - c. Name of Architect.
 - d. Name of Construction Manager.
 - e. Name of Contractor.
 - f. Date of video recording.
 - 2. Transcript: Prepared and bound in format matching operation and maintenance manuals. Mark appropriate identification on front and spine of each binder. Include a cover sheet

with same label information as the corresponding video recording. Include name of Project and date of video recording on each page.

3. Transcript: Prepared in PDF electronic format. Include a cover sheet with same label information as the corresponding video recording and a table of contents with links to corresponding training components. Include name of Project and date of video recording on each page.
4. At completion of training, submit complete training manual(s) for Owner's use prepared and bound in format matching operation and maintenance manuals and in PDF electronic file format on compact disc.

1.5 QUALITY ASSURANCE

- A. Facilitator Qualifications: A firm or individual experienced in training or educating maintenance personnel in a training program similar in content and extent to that indicated for this Project, and whose work has resulted in training or education with a record of successful learning performance.
- B. Instructor Qualifications: A factory-authorized service representative, complying with requirements in Section 014000 "Quality Requirements," experienced in operation and maintenance procedures and training.
- C. Videographer Qualifications: A professional videographer who is experienced photographing demonstration and training events similar to those required.
- D. Preinstruction Conference: Conduct conference at Project site to comply with requirements in Section 013100 "Project Management and Coordination." Review methods and procedures related to demonstration and training including, but not limited to, the following:
 1. Inspect and discuss locations and other facilities required for instruction.
 2. Review and finalize instruction schedule and verify availability of educational materials, instructors' personnel, audiovisual equipment, and facilities needed to avoid delays.
 3. Review required content of instruction.
 4. For instruction that must occur outside, review weather and forecasted weather conditions and procedures to follow if conditions are unfavorable.

1.6 COORDINATION

- A. Coordinate instruction schedule with Owner's operations. Adjust schedule as required to minimize disrupting Owner's operations and to ensure availability of Owner's personnel.
- B. Coordinate instructors, including providing notification of dates, times, length of instruction time, and course content.
- C. Coordinate content of training modules with content of approved emergency, operation, and maintenance manuals. Do not submit instruction program until operation and maintenance data has been reviewed and approved by Architect.

PART 2 - PRODUCTS

2.1 INSTRUCTION PROGRAM

- A. Program Structure: Develop an instruction program that includes individual training modules for each system and for equipment not part of a system, as required by individual Specification Sections.
- B. Training Modules: Develop a learning objective and teaching outline for each module. Include a description of specific skills and knowledge that participant is expected to master. For each module, include instruction for the following as applicable to the system, equipment, or component:
 - 1. Basis of System Design, Operational Requirements, and Criteria: Include the following:
 - a. System, subsystem, and equipment descriptions.
 - b. Performance and design criteria if Contractor is delegated design responsibility.
 - c. Operating standards.
 - d. Regulatory requirements.
 - e. Equipment function.
 - f. Operating characteristics.
 - g. Limiting conditions.
 - h. Performance curves.
 - 2. Documentation: Review the following items in detail:
 - a. Emergency manuals.
 - b. Operations manuals.
 - c. Maintenance manuals.
 - d. Project record documents.
 - e. Identification systems.
 - f. Warranties and bonds.
 - g. Maintenance service agreements and similar continuing commitments.
 - 3. Emergencies: Include the following, as applicable:
 - a. Instructions on meaning of warnings, trouble indications, and error messages.
 - b. Instructions on stopping.
 - c. Shutdown instructions for each type of emergency.
 - d. Operating instructions for conditions outside of normal operating limits.
 - e. Sequences for electric or electronic systems.
 - f. Special operating instructions and procedures.
 - 4. Operations: Include the following, as applicable:
 - a. Startup procedures.
 - b. Equipment or system break-in procedures.
 - c. Routine and normal operating instructions.
 - d. Regulation and control procedures.
 - e. Control sequences.

- f. Safety procedures.
 - g. Instructions on stopping.
 - h. Normal shutdown instructions.
 - i. Operating procedures for emergencies.
 - j. Operating procedures for system, subsystem, or equipment failure.
 - k. Seasonal and weekend operating instructions.
 - l. Required sequences for electric or electronic systems.
 - m. Special operating instructions and procedures.
5. Adjustments: Include the following:
- a. Alignments.
 - b. Checking adjustments.
 - c. Noise and vibration adjustments.
 - d. Economy and efficiency adjustments.
6. Troubleshooting: Include the following:
- a. Diagnostic instructions.
 - b. Test and inspection procedures.
7. Maintenance: Include the following:
- a. Inspection procedures.
 - b. Types of cleaning agents to be used and methods of cleaning.
 - c. List of cleaning agents and methods of cleaning detrimental to product.
 - d. Procedures for routine cleaning
 - e. Procedures for preventive maintenance.
 - f. Procedures for routine maintenance.
 - g. Instruction on use of special tools.
8. Repairs: Include the following:
- a. Diagnosis instructions.
 - b. Repair instructions.
 - c. Disassembly; component removal, repair, and replacement; and reassembly instructions.
 - d. Instructions for identifying parts and components.
 - e. Review of spare parts needed for operation and maintenance.

PART 3 - EXECUTION

3.1 PREPARATION

- A. Assemble educational materials necessary for instruction, including documentation and training module. Assemble training modules into a training manual organized in coordination with requirements in Section 017823 "Operation and Maintenance Data."
- B. Set up instructional equipment at instruction location.

3.2 INSTRUCTION

- A. Facilitator: Engage a qualified facilitator to prepare instruction program and training modules, to coordinate instructors, and to coordinate between Contractor and Owner for number of participants, instruction times, and location.
- B. Engage qualified instructors to instruct Owner's personnel to adjust, operate, and maintain systems, subsystems, and equipment not part of a system.
 - 1. Architect will furnish an instructor to describe basis of system design, operational requirements, criteria, and regulatory requirements.
 - 2. Owner will furnish an instructor to describe Owner's operational philosophy.
 - 3. Owner will furnish Contractor with names and positions of participants.
- C. Scheduling: Provide instruction at mutually agreed on times. For equipment that requires seasonal operation, provide similar instruction at start of each season.
 - 1. Schedule training with Owner with at least seven days' advance notice.
- D. Training Location and Reference Material: Conduct training on-site in the completed and fully operational facility using the actual equipment in-place. Conduct training using final operation and maintenance data submittals.
- E. Cleanup: Collect used and leftover educational materials and give to Owner. Remove instructional equipment. Restore systems and equipment to condition existing before initial training use.

3.3 DEMONSTRATION AND TRAINING VIDEO RECORDINGS

- A. General: Engage a qualified commercial videographer to record demonstration and training video recordings. Record each training module separately. Include classroom instructions and demonstrations, board diagrams, and other visual aids, but not student practice.
 - 1. At beginning of each training module, record each chart containing learning objective and lesson outline.
- B. Video: Provide minimum 640 x 480 video resolution converted to format file type acceptable to Owner, on electronic media.
 - 1. Electronic Media: Read-only format compact disc acceptable to Owner, with commercial-grade graphic label.
 - 2. File Hierarchy: Organize folder structure and file locations according to project manual table of contents. Provide complete screen-based menu.
 - 3. File Names: Utilize file names based upon name of equipment generally described in video segment, as identified in Project specifications.
 - 4. Contractor and Installer Contact File: Using appropriate software, create a file for inclusion on the Equipment Demonstration and Training DVD that describes the following for each Contractor involved on the Project, arranged according to Project table of contents:

- a. Name of Contractor/Installer.
 - b. Business address.
 - c. Business phone number.
 - d. Point of contact.
 - e. E-mail address.
- C. Recording: Mount camera on tripod before starting recording, unless otherwise necessary to adequately cover area of demonstration and training. Display continuous running time.
1. Film training session(s) in segments not to exceed 15 minutes.
 - a. Produce segments to present a single significant piece of equipment per segment.
 - b. Organize segments with multiple pieces of equipment to follow order of Project Manual table of contents.
 - c. Where a training session on a particular piece of equipment exceeds 15 minutes, stop filming and pause training session. Begin training session again upon commencement of new filming segment.
- D. Light Levels: Verify light levels are adequate to properly light equipment. Verify equipment markings are clearly visible prior to recording.
1. Furnish additional portable lighting as required.
- E. Narration: Describe scenes on video recording by dubbing audio narration off-site after video recording is recorded. Include description of items being viewed.
- F. Transcript: Provide a transcript of the narration. Display images and running time captured from videotape opposite the corresponding narration segment.
- G. Preproduced Video Recordings: Provide video recordings used as a component of training modules in same format as recordings of live training.

END OF SECTION 017900



ARCHITECTURE
PLANNING

Date:

William F. Cooke, Jr. Elementary School
New Castle County, Delaware
2012080.00

Release for use of Digital Media

Revised to include Building Information Modeling

Pursuant to your request, the Digital Media being provided is forwarded in accordance with the following terms.

Definitions:

- a. The Work: the instrument of professional services of the Firm including but not limited to the design drawings, sketches, renderings, photographs, models, specifications.
- b. Digital Media: the electronic, electromagnetic and/or optical storage media, (i.e. physical media) on which the Work is stored.
- c. Digital Information: the information stored on Digital Media or sent via an electronic exchange method (email and FTP) known as the Work of the contracted design professional, Becker Morgan Group, Inc. and their consultants, herein after referred to as the Firm.
- d. Digital Documents: the collective Digital Information that constitutes equivalent physical documents or Work of the Firm. Digital Documents may include one or more electronic files produced by Computer Aided Design (CAD) software applications.

Terms:

1. In accepting and utilizing Digital Information on any form of Digital Media generated and provided by the Firm, the Recipient covenants and agrees that all such Digital Information are instruments of service of the Firm prepared solely for use in connection with the single project for which they were prepared, who shall be deemed the author of the Digital Information, and shall retain all common law, statutory law and other rights, including copyrights.
2. The Digital Documents are provided as a convenience to the Recipient for informational purposes only in connection with the Recipient's performance of its responsibilities and obligations relating to the Project. The Digital Documents do not replace or supplement the printed copies of the Drawings and Specifications that are, and remain, the Contract Documents for the Project.
3. The Digital Information is provided only as a design record prior to construction and for reference to the Recipient. The information in no way shall be used for "as-built" or record purposes.
4. The Recipient agrees not to use this Digital Information, in whole or in part for any purpose or project other than the specific project for which the Recipient and the Firm have a prior Professional Services Agreement. It is further understood and agreed that only printed copies of the Instruments of Services shall be signed and sealed by Architect or its sub-consultants in accordance with the laws of the state in which the project is built.

5. The Work cannot be distributed, altered, reused, sold, leased, printed, plotted, or duplicated without the expressed written consent of the Firm.
6. For Shop Drawings - Where the Recipient has received specific permission to use the Digital Documents in connection with Recipient's obligation to prepare certain documents for the Project, Recipient shall, in addition to the other obligations set forth herein, be obligated to remove Architect's or Architect's Consultant's title block from the copy of the Digital Documents used by Recipient. It is understood and agreed that the Digital Documents are not to be used by any contractor or any of its subcontractors of any tier or any material supplier or vendor as a shop drawing or any other type of submittal or as the basis for preparing such shop drawing or submittal. The sole exception to this prohibition shall be that the Recipient may use the Digital Documents as backgrounds upon which to prepare its shop drawing or other submittal when it is specifically permitted in technical section of project specification. When these digital documents are used as backgrounds in the preparation of shop drawings or other submittals, the Recipient agrees to confirm the accuracy of the digital documents before using them, Recipient agrees to accept all responsibility for any errors or inaccuracies and to release the Architect and its sub-consultants from any liability or claims for recovery of damages or expenses arising as the result of such errors or inaccuracies.
7. Under no circumstances shall transfer of the Digital Information for use by the Recipient be deemed a sale by the Firm. The parties agree that the Digital Documents are not, nor shall they be construed to be, a product. The Firm makes no warranties, either express or implied, of the Digital Media or the Digital Information as to merchantability or fitness for any particular purpose the Recipient may need.
8. The Digital Information submitted by the Firm to the Recipient is submitted for an acceptance period of sixty days. Any defects the Recipient discovers during this period shall be reported to the Firm and may be corrected as part of the Firm's Basic Scope of Services. Correction of defects detected and reported after the acceptance period will be compensated for as Additional Services.
9. The Digital Information is not guaranteed as to accuracy and completeness of all dimensions and details. Information contained in the signed and sealed printed documents should be deemed to be correct and superior to digital information.
10. The Digital Information is not guaranteed as to compatibility, in so far as incompatibilities may be present now or in the future with the Recipient's computers, storage devices, software, and output systems.
11. The Digital Media on which the Digital Information is provided cannot be guaranteed as to its durability, completeness or usability, in so far as instabilities may be present in the Digital Media, and in the transferring, archiving, recording or translating systems now and in the future. The Firm is not liable in any way for the perpetuation of this Digital Information on released digital media or on digital media retained by the Firm for its archives. Recipient agrees to accept all responsibility for any errors or inaccuracies and to release Architect and its sub-consultants from any liability or claims for recovery of damages or expenses arising as the result of such errors or inaccuracies.
12. Provision of the Information to the Recipient in no way limits the Firm to the further use of the Digital Information for the Firm's benefit.
13. Recipient agrees to waive any and all claims and liability against Architect and its sub-consultants resulting in any way from any failure by Recipient to comply with the requirements of this Agreement for the Delivery of Documents in Digital Format. The Recipient agrees, to the fullest extent permitted by law, to indemnify and hold the Firm harmless from any damage, liability or cost, including reasonable attorney's fees and costs of defense, arising from any changes made by anyone other than the Firm or from any reuse of the Digital Information without the prior written consent of the Firm. Recipient further agrees to indemnify and save harmless the Owner, Architect and its sub-consultants and each of their partners, officers, shareholders, directors and employees from any and all claims, judgments, suits, liabilities, damages, costs or expenses (including reasonable defense and attorney's fees) arising as the result of either: 1) Recipient's failure to comply with any of the requirements of this Agreement for the Delivery of Documents in Digital Format; or 2) a defect, error or omission in the Digital Documents or the information contained therein, which defect, error or omission was not contained in the Contract Documents

as defined in Paragraph 2 or where the use of such Contract Documents would have prevented the claim, judgment, suit, liability, damage, cost or expense.

The Recipient agrees to a \$200 charge per each of the following drawing sheets listed below, created within a CAD digital file, payable to this office prior to release of any Digital Information. NOTE: All sheets are available for release.

List Requested Drawing Sheets:

The Recipient agrees to a \$500 charge per each of the following groups of CAD digital files or RVT models checked below, payable to this office prior to release of any Digital Information. NOTE: Only those file groups listed below are available for release.

Check Requested Files:

- S101-series, S102-series, and S103-series (DWG)
- A101-series, A102-series, A103, A104, A106-series, A107D, A110, A111 (DWG)
- P101-series, P102, P103, P201-P207 (DWG)
- M101-series, M102D, MP101-series, MP102D (DWG)
- EP101-series, EP102D, EL101-series, EL102D EMP101-series, EMP102D, EFA101-series, EFA102 (DWG)
- T101-series, T102D (DWG)
- Structural model (RVT)
- Architectural model (RVT)
- Mechanical, Plumbing, Electrical model (RVT)

Please sign and return one copy of any release forms required by Consultants.

Please sign below and return one copy of this form with a check for the total payment made out to Becker Morgan Group.

Recipient sign here>

Accepted - signature

Date

Name/Title – printed

Company

BMG Principal - signature

Date

BMG Principal – printed

Prepared by – printed