



ARCHITECTURE
ENGINEERING

ADDENDUM TO CONTRACT DOCUMENTS

Date: April 27, 2017

To: Bidders

From: Wayne J. Sharp, AIA

Copies: All Attending Pre-Bid Meeting, see attached sign-in sheet
Marcin Michalski, Supervisor of Facilities and maintenance
Emily Ryan, Data Service Center

Project: **McKean High School Athletic Field Renovations**
Wilmington, Delaware

Project Number: BMG Project No. 2015145.01

Contract No.: 2-17-34

Subject: **ADDENDUM NO. 02**

NOTICE: Attention is called to the following item(s), effective as of the date above, which shall be added to, deleted from, or changed in the contract documents dated February 22, 2017, and any previously issued addenda, thereby incorporating these items into the contract.

RFI's

(Italicized questions still pending)

(Shaded questions answered in previous Addenda)

MCE RFI 1	
Item	Description
1	Q: Is it possible for the project schedule to allow the successful contractor to start work mid summer of 2017 and complete the project sometime in the Fall of 2017? We only ask because our Summer schedule is pretty full and we may not be able to bid the project. A: The field hockey field must be completed by August 15 th . The soccer and softball fields need to be completed (grass planted) by end of October.
EASTERN STATES RFI 1	
Item	Description
1	Q: Is the contractor required to paint the striping for each field? A: Yes. Once 85% field cover is established, field striping is required.
2	Q: Is epoxy resin necessary for the parking lot and driveway striping or will you allow standard parking lot paint? A: No, see project drawing changes items 1 & 2 below.
3	Q: Can you provide a detail on the irrigation valve and box for each field? A: A detail will not be provided. See 328400 Sports Field Irrigation Specification.
4	Q: How many aluminum benches are needed for the softball field? A: Contract includes four (4) aluminum benches total. Two (2) are required for the softball field. See Spec 321817 – Exterior Athletic Equipment.

PROJECT MANUAL CHANGES:

Item	Description
1	Section 321817 – Exterior Athletic Equipment A. Part 2.2 Softball Diamond Equipment - Aluminum Bleachers. Delete “4 Row Low Rise Bleachers,” Substitute “40 Seat Row Low Rise Bleachers, Add “Quantity – Four (4). Locations to be determined by owner. B. Part 2.2 Softball Diamond Equipment - Helmet & Bat Storage. Add “Quantity – One (1) per dugout.
2	Section 328400 - Sports Field Irrigation: A. Add Section 328400 Sports Field Irrigation, dated 04/21/17.

DRAWING CHANGES:

Item	Description
1	Sheet C-401 – Grading & Utility Plan: A. Striping & Signage Construction Notes T-1 & T-2. Delete “Epoxy Resin”, Substitute “Regular-Dry water based paint.” B. Striping & Signage Construction Note T-5. Delete “Painted” Substitute “Regular-Dry water based paint.”
2	Sheet C-402 – Grading & Utility Plan: A. Striping & Signage Construction Notes T-1 & T-2. Delete “Epoxy Resin”, Substitute “Regular-Dry water based paint.” B. Striping & Signage Construction Note T-5. Delete “Painted” Substitute “Regular-Dry water based paint.”

LIST OF ATTACHMENTS

Item	Description	
1	Specification Section 328400 Sports Field Irrigation	04/21/17

END OF ADDENDUM # 02

201514501_Addn02.doc