SECTION 087100 – DOOR HARDWARE

PART 1 - GENERAL

1.1 RELATED DOCUMENTS

A. Drawings and general provisions of the Contract, including General and Supplementary Conditions and Division 01 Specification Sections, apply to this Section.

1.2 SUMMARY

A. Section includes:

1. Mechanical and electrified door hardware for:

   a. Swinging doors.
   b. Sliding doors.
   c. Gates.

2. Field verification, preparation and modification of existing doors and frames to receive new door hardware.
3. Lead-lining door hardware items required for radiation protection at door openings.

B. Exclusions: Unless specifically listed in hardware sets, hardware is not specified in this section for:

1. Windows
2. Cabinets (casework), including locks in cabinets
3. Signage
4. Toilet accessories
5. Overhead doors

C. Related Sections:

1. Division 01 Section "Alternates" for alternates affecting this section.
2. Division 07 Section "Joint Sealants" for sealant requirements applicable to threshold installation specified in this section.
3. Division 09 sections for touchup finishing or refinishing of existing openings modified by this section.
4. Division 13 Section "Radiation Protection" for requirements for lead-lining for door hardware at openings indicated to receive radiation protection.
5. Division 26 sections for connections to electrical power system and for low-voltage wiring.
6. Division 28 sections for coordination with other components of electronic access control system.

1.3 REFERENCES

A. Fire/Life Safety

1. NFPA - National Fire Protection Association

   a. NFPA 70 – National Electric Code
   b. NFPA 80 - Standard for Fire Doors and Fire Windows
   c. NFPA 101 - Life Safety Code

d. NFPA 105 - Smoke and Draft Control Door Assemblies

2. State Fire Safety Code.

B. UL - Underwriters Laboratories

1. UL 10B - Fire Test of Door Assemblies
2. UL 10C - Positive Pressure Test of Fire Door Assemblies
3. UL 1784 - Air Leakage Tests of Door Assemblies
4. UL 305 - Panic Hardware

C. Accessibility

1. ADA - Americans with Disabilities Act.
2. ANSI A117.1 - Accessible and Usable Buildings and Facilities.

D. DHI - Door and Hardware Institute

1. Sequence and Format for the Hardware Schedule
2. Recommended Locations for Builders Hardware
3. Key Systems and Nomenclature

E. ANSI - American National Standards Institute

1. ANSI/BHMA A156.1 - A156.29, and ANSI A156.31 - Standards for Hardware and Specialties

1.4 SUBMITTALS

A. General:

1. Submit in accordance with Conditions of Contract and Division 01 requirements.
2. Highlight, encircle, or otherwise specifically identify on submittals deviations from Contract Documents, issues of incompatibility or other issues which may detrimentally affect the Work.
3. Prior to forwarding submittal, comply with procedures for verifying existing door and frame compatibility for new hardware, as specified in PART 3, "EXAMINATION" article, herein.

B. Action Submittals:

1. Product Data: Product data including manufacturers' technical product data for each item of door hardware, installation instructions, maintenance of operating parts and finish, and other information necessary to show compliance with requirements.
2. Riser and Wiring Diagrams: After final approval of hardware schedule, submit details of electrified door hardware, indicating:

   a. Wiring Diagrams: For power, signal, and control wiring and including:
      1) Details of interface of electrified door hardware and building safety and security systems.
      2) Schematic diagram of systems that interface with electrified door hardware.
      3) Point-to-point wiring.
      4) Risers.

3. Samples for Verification: If requested by Architect, submit production sample or sample installations of each type of exposed hardware unit in finish indicated, and tagged with full description for coordination with schedule.

a. Samples will be returned to supplier in like-new condition. Units that are acceptable to Architect may, after final check of operations, be incorporated into Work, within limitations of key coordination requirements.

4. Door Hardware Schedule: Submit schedule with hardware sets in vertical format as illustrated by Sequence of Format for the Hardware Schedule as published by the Door and Hardware Institute. Indicate complete designations of each item required for each door or opening, include:

   a. Door Index; include door number, heading number, and Architects hardware set number.
   b. Opening Lock Function Spreadsheet: List locking device and function for each opening.
   c. Type, style, function, size, and finish of each hardware item.
   d. Name and manufacturer of each item.
   e. Fastenings and other pertinent information.
   f. Location of each hardware set cross-referenced to indications on Drawings.
   g. Explanation of all abbreviations, symbols, and codes contained in schedule.
   h. Mounting locations for hardware.
   i. Door and frame sizes and materials.
   j. Name and phone number for local manufacturer's representative for each product.
   k. Operational Description of openings with any electrified hardware (locks, exits, electromagnetic locks, electric strikes, automatic operators, door position switches, magnetic holders or closer/holder units, and access control components). Operational description should include how door will operate on egress, ingress, and fire and smoke alarm connection.
      1) Submittal Sequence: Submit door hardware schedule concurrent with submissions of Product Data, Samples, and Shop Drawings. Coordinate submission of door hardware schedule with scheduling requirements of other work to facilitate fabrication of other work that is critical in Project construction schedule.

5. Key Schedule:

   a. After Keying Conference, provide keying schedule listing levels of keying as well as explanation of key system's function, key symbols used and door numbers controlled.
   b. Use ANSI A156.28 "Recommended Practices for Keying Systems" as guideline for nomenclature, definitions, and approach for selecting optimal keying system.
   c. Provide 3 copies of keying schedule for review prepared and detailed in accordance with referenced DHI publication. Include schematic keying diagram and index each key to unique door designations.
   d. Index keying schedule by door number, keyset, hardware heading number, cross keying instructions, and special key stamping instructions.
   e. Provide one complete bitting list of key cuts and one key system schematic illustrating system usage and expansion.
      1) Forward bitting list, key cuts and key system schematic directly to Owner, by means as directed by Owner.

   f. Prepare key schedule by or under supervision of supplier, detailing Owner's final keying instructions for locks.

6. Templates: After final approval of hardware schedule, provide templates for doors, frames and other work specified to be factory prepared for door hardware installation.

C. Informational Submittals:

1. Qualification Data: For Supplier, Installer and Architectural Hardware Consultant.
2. Product Certificates for electrified door hardware, signed by manufacturer:

   a. Certify that door hardware approved for use on types and sizes of labeled fire-rated doors complies with listed fire-rated door assemblies.

3. Certificates of Compliance:

   a. Certificates of compliance for fire-rated hardware and installation instructions if requested by Architect or Authority Having Jurisdiction.
   b. Installer Training Meeting Certification: Letter of compliance, signed by Contractor, attesting to completion of installer training meeting specified in "QUALITY ASSURANCE" article, herein.
   c. Electrified Hardware Coordination Conference Certification: Letter of compliance, signed by Contractor, attesting to completion of electrified hardware coordination conference, specified in "QUALITY ASSURANCE" article, herein.

4. Product Test Reports: For compliance with accessibility requirements, based on evaluation of comprehensive tests performed by manufacturer and witnessed by qualified testing agency, for door hardware on doors located in accessible routes.
5. Warranty: Special warranty specified in this Section.

D. Closeout Submittals:

1. Operations and Maintenance Data : Provide in accordance with Division 01 and include:

   a. Complete information on care, maintenance, and adjustment; data on repair and replacement parts, and information on preservation of finishes.
   b. Catalog pages for each product.
   c. Name, address, and phone number of local representative for each manufacturer.
   d. Parts list for each product.
   e. Final approved hardware schedule, edited to reflect conditions as-installed.
   f. Final keying schedule
   g. Copies of floor plans with keying nomenclature
   h. As-installed wiring diagrams for each opening connected to power, both low voltage and 110 volts.
   i. Copy of warranties including appropriate reference numbers for manufacturers to identify project.

1.5 QUALITY ASSURANCE

A. Product Substitutions: Comply with product requirements stated in Division 01 and as specified herein.

1. Where specific manufacturer's product is named and accompanied by "No Substitute," including make or model number or other designation, provide product specified. (Note: Certain products have been selected for their unique characteristics and particular project suitability.)

   a. Where no additional products or manufacturers are listed in product category, requirements for "No Substitute" govern product selection.

2. Where products indicate "acceptable substitute" or "acceptable manufacturer", provide product from specified manufacturers, subject to compliance with specified requirements and "Single Source Responsibility" requirements stated herein.

B. Supplier Qualifications and Responsibilities: Recognized architectural hardware supplier with record of successful in-service performance for supplying door hardware similar in quantity, type, and quality to that indicated for this Project and that provides certified Architectural Hardware Consultant (AHC) available to Owner, Architect, and Contractor, at reasonable times during the Work for consultation.

1. Warehousing Facilities: In Project's vicinity.
2. Scheduling Responsibility: Preparation of door hardware and keying schedules.

3. Engineering Responsibility: Preparation of data for electrified door hardware, including Shop Drawings, based on testing and engineering analysis of manufacturer's standard units in assemblies similar to those indicated for this Project.
4. Coordination Responsibility: Coordinate installation of electronic security hardware with Architect and electrical engineers and provide installation and technical data to Architect and other related subcontractors.

    a. Upon completion of electronic security hardware installation, inspect and verify that all components are working properly.

C. Installer Qualifications: Qualified tradesmen, skilled in application of commercial grade hardware with record of successful in-service performance for installing door hardware similar in quantity, type, and quality to that indicated for this Project.

D. Architectural Hardware Consultant Qualifications: Person who is experienced in providing consulting services for door hardware installations that are comparable in material, design, and extent to that indicated for this Project and meets these requirements:

1. For door hardware, DHI-certified, Architectural Hardware Consultant (AHC).
2. Can provide installation and technical data to Architect and other related subcontractors.
3. Can inspect and verify components are in working order upon completion of installation.
4. Capable of producing wiring diagrams.
5. Capable of coordinating installation of electrified hardware with Architect and electrical engineers.

E. Single Source Responsibility: Obtain each type of door hardware from single manufacturer.

1. Provide electrified door hardware from same manufacturer as mechanical door hardware, unless otherwise indicated.
2. Manufacturers that perform electrical modifications and that are listed by testing and inspecting agency acceptable to authorities having jurisdiction are acceptable.

F. Fire-Rated Door Openings: Provide door hardware for fire-rated openings that complies with NFPA 80 and requirements of authorities having jurisdiction. Provide only items of door hardware that are listed and are identical to products tested by Underwriters Laboratories, Intertek Testing Services, or other testing and inspecting organizations acceptable to authorities having jurisdiction for use on types and sizes of doors indicated, based on testing at positive pressure and according to NFPA 252 or UL 10C and in compliance with requirements of fire-rated door and door frame labels.

G. Smoke- and Draft-Control Door Assemblies: Where smoke- and draft-control door assemblies are required, provide door hardware that meets requirements of assemblies tested according to UL 1784 and installed in compliance with NFPA 105.

1. Air Leakage Rate: Maximum air leakage of 0.3 cfm/sq. ft. (3 cu. m per minute/sq. m) at tested pressure differential of 0.3-inch wg (75 Pa) of water.

H. Electrified Door Hardware: Listed and labeled as defined in NFPA 70, Article 100, by testing agency acceptable to authorities having jurisdiction.

I. Means of Egress Doors: Latches do not require more than 15 lbf (67 N) to release latch. Locks do not require use of key, tool, or special knowledge for operation.

J. Accessibility Requirements: For door hardware on doors in an accessible route, comply with governing accessibility regulations cited in "REFERENCES" article, herein.

1. Provide operating devices that do not require tight grasping, pinching, or twisting of wrist and that operate with force of not more than 5 lbf (22.2 N).
2. Maximum opening-force requirements:

    a. Interior, Non-Fire-Rated Hinged Doors: 5 lbf (22.2 N) applied perpendicular to door.
    b. Sliding or Folding Doors: 5 lbf (22.2 N) applied parallel to door at latch.
    c. Fire Doors: Minimum opening force allowable by authorities having jurisdiction.

3. Bevel raised thresholds with slope of not more than 1:2. Provide thresholds not more than 1/2 inch (13 mm) high.
4. Adjust door closer sweep periods so that, from open position of 70 degrees, door will take at least 3 seconds to move to 3 inches (75 mm) from latch, measured to leading edge of door.

K. Keying Conference: Conduct conference at Project site to comply with requirements in Division 01.

1. Attendees: Owner, Contractor, Architect, Installer,Owner's security consultant, and Supplier's Architectural Hardware Consultant.
2. Incorporate keying conference decisions into final keying schedule after reviewing door hardware keying system including:

    a. Function of building, flow of traffic, purpose of each area, degree of security required, and plans for future expansion.
    b. Preliminary key system schematic diagram.
    c. Requirements for key control system.
    d. Requirements for access control.
    e. Address for delivery of keys.

L. Pre-installation Conference: Conduct conference at Project site

1. Review and finalize construction schedule and verify availability of materials, Installer's personnel, equipment, and facilities needed to make progress and avoid delays.
2. Inspect and discuss preparatory work performed by other trades.
3. Inspect and discuss electrical roughing-in for electrified door hardware.
4. Review sequence of operation for each type of electrified door hardware.
5. Review required testing, inspecting, and certifying procedures.

M. Coordination Conferences:

1. Installation Coordination Conference: Prior to hardware installation, schedule and hold meeting to review questions or concerns related to proper installation and adjustment of door hardware.

    a. Attendees: Door hardware supplier, door hardware installer, Contractor.
    b. After meeting, provide letter of compliance to Architect, indicating when meeting was held and who was in attendance.

2. Electrified Hardware Coordination Conference: Prior to ordering electrified hardware, schedule and hold meeting to coordinate door hardware with security, electrical, doors and frames, and other related suppliers.

    a. Attendees: electrified door hardware supplier, doors and frames supplier, electrified door hardware installer, electrical subcontractor, Owner, Owner's security consultant, Architect and Contractor.
    b. After meeting, provide letter of compliance to Architect, indicating when coordination conference was held and who was in attendance.

1.6 DELIVERY, STORAGE, AND HANDLING

A. Inventory door hardware on receipt and provide secure lock-up for hardware delivered to Project site.

B. Tag each item or package separately with identification coordinated with final door hardware schedule, and include installation instructions, templates, and necessary fasteners with each item or package.

1. Deliver each article of hardware in manufacturer's original packaging.

C. Project Conditions:

1. Maintain manufacturer-recommended environmental conditions throughout storage and installation periods.
2. Provide secure lock-up for door hardware delivered to Project, but not yet installed. Control handling and installation of hardware items so that completion of Work will not be delayed by hardware losses both before and after installation.

D. Protection and Damage:

1. Promptly replace products damaged during shipping.
2. Handle hardware in manner to avoid damage, marring, or scratching. Correct, replace or repair products damaged during Work.
3. Protect products against malfunction due to paint, solvent, cleanser, or any chemical agent.

E. Deliver keys to manufacturer of key control system for subsequent delivery to Owner.

F. Deliver keys and permanent cores to Owner by registered mail or overnight package service.

1.7 COORDINATION

A. Coordinate layout and installation of floor-recessed door hardware with floor construction. Cast anchoring inserts into concrete. Concrete, reinforcement, and formwork requirements are specified in Division 03.

B. Installation Templates: Distribute for doors, frames, and other work specified to be factory prepared. Check Shop Drawings of other work to confirm that adequate provisions are made for locating and installing door hardware to comply with indicated requirements.

C. Security: Coordinate installation of door hardware, keying, and access control with Owner's security consultant.

D. Electrical System Roughing-In: Coordinate layout and installation of electrified door hardware with connections to power supplies and building safety and security systems.

E. Existing Openings: Where hardware components are scheduled for application to existing construction or where modifications to existing door hardware are required, field verify existing conditions and coordinate installation of door hardware to suit opening conditions and to provide proper door operation.

F. Direct shipments not permitted, unless approved by Contractor.

1.8 WARRANTY

A. Special Warranty: Manufacturer's standard form in which manufacturer agrees to repair or replace components of door hardware that fail in materials or workmanship within specified warranty period.

1. Warranty Period: Years from date of Substantial Completion, for durations indicated.

a. Closers:
1) Mechanical: 10 years.
2) Electrified: 2 years.

b. Exit Devices:
1) Mechanical: 3 years.
2) Electrified: 1 year.

c. Locksets:
1) Mechanical: 3 years.
2) Electrified: 1 year.

d. Continuous Hinges: Lifetime warranty.
e. Key Blanks: Lifetime

2. Warranty does not cover damage or faulty operation due to improper installation, improper use or abuse.

1.9 MAINTENANCE

A. Extra Materials:

1. Furnish extra materials that match products installed and that are packaged with protective covering for storage and identified with labels describing contents.

a. Door Hardware: <Insert detailed descriptions and specific numbers of units>.
b. Electrical Parts: <Insert detailed descriptions and specific numbers of units>.

B. Maintenance Tools:

1. Furnish complete set of special tools required for maintenance and adjustment of hardware, including changing of cylinders.

PART 2 - PRODUCTS

2.1 MANUFACTURERS

A. The Owner requires use of certain products for their unique characteristics and particular project suitability to insure continuity of existing and future performance and maintenance standards. After investigating available product offerings Awarding Authority has elected to prepare proprietary specifications. These products are specified with the notation: "No Substitute."

1. Where "No Substitute" is noted, submittals and substitution requests for other products will not be considered.

B. Approval of manufacturers other than those listed shall be in accordance with QUALITY ASSURANCE article, herein.

C. Approval of products from manufacturers indicated as "Acceptable Manufacturer" is contingent upon those products providing all functions and features and meeting all requirements of scheduled manufacturer's product.

Item	Scheduled Manufacturer	Acceptable Manufacturer
Hinges	Ives (IVE)	Hager, McKinney, Stanley
Continuous Hinges	Ives (IVE)	Markar, Stanley
Electric Power Transfer	Von Duprin (VON)	ABH, Falcon
Floor Closers	Rixson (RIX)	Dorma, Jackson
Flush Bolts & Coordinators	Ives (IVE)	Burns, Rockwood
Locksets & Deadlocks	Schlage (SCH)	None
Padlocks	Schlage (SCH)	Best, Sargent
Exit Devices & Mullions	Von Duprin (VON)	None
Electric Strikes	Von Duprin (VON)	None
Power Supplies	Schlage Electronics (SCE)	Precision, Sargent, Falcon
Roller Latches	Ives (IVE)	Burns, Rockwood
Cylinders & Keying	Schlage (SCH)	Best, Corbin-Russwin, Sargent, Falcon
Door Closers	LCN (LCN)	None
Electro-Hydraulic Automatic Operators	LCN (LCN)	Besam, Norton
Electro-Mechanical Automatic Operators	LCN (LCN)	Besam, Horton
Door Trim	Ives (IVE)	Burns, Rockwood
Protection Plates	Ives (IVE)	Burns, Rockwood
Overhead Stops	Glynn-Johnson (GLY)	Rixson, Sargent
Stops & Holders	Ives (IVE)	Burns, Rockwood
Thresholds & Weatherstrip	Reese (REE)	Pemko, Zero
Silencers	Ives (IVE)	Burns, Rockwood
Magnetic Holders	LCN (LCN)	Rixson, Sargent
Door Position Switches	Schlage Electronics (SCE)	GE, Sargent
Door Viewer	Ives (IVE)	Burns, Rockwood
Latch Protector	Ives (IVE)	Burns, Rockwood
Key Cabinets	Telkee (TEL)	HPC, Lund

D. Hand of Door: Drawings show direction of slide, swing, or hand of each door leaf. Furnish each item of hardware for proper installation and operation of door movement as shown.

E. Where specified hardware is not adaptable to finished shape or size of members requiring hardware, furnish suitable types having same operation and quality as type specified, subject to Architect's approval.

2.2 MATERIALS

A. Fasteners

1. Provide hardware manufactured to conform to published templates, generally prepared for machine screw installation.
2. Furnish screws for installation with each hardware item. Finish exposed (exposed under any condition) screws to match hardware finish, or, if exposed in surfaces of other work, to match finish of this other work including prepared for paint surfaces to receive painted finish.

3. Provide concealed fasteners for hardware units exposed when door is closed except when no standard units of type specified are available with concealed fasteners. Do not use thru-bolts for installation where bolt head or nut on opposite face is exposed in other work unless thru-bolts are required to fasten hardware securely. Review door specification and advise Architect if thru-bolts are required.
4. Install hardware with fasteners provided by hardware manufacturer.

B. Provide screws, bolts, expansion shields, drop plates and other devices necessary for hardware installation.

1. Where fasteners are exposed to view: Finish to match adjacent door hardware material.

2.3 HINGES

A. Provide five-knuckle, ball bearing hinges.

1. Manufacturers and Products:

a. Scheduled Manufacturer and Product: Ives 5BB series.
b. Acceptable Manufacturers and Products: Hager BB series, McKinney TA/T4A series, Stanley FBB Series.

B. Requirements:

1. 1-3/4 inch (44 mm) thick doors, up to and including 36 inches (914 mm) wide:

a. Exterior: Standard weight, bronze or stainless steel, 4-1/2 inches (114 mm) high
b. Interior: Standard weight, steel, 4-1/2 inches (114 mm) high

2. 1-3/4 inch (44 mm) thick doors over 36 inches (914 mm) wide:

a. Exterior: Heavy weight, bronze/stainless steel, 5 inches (127 mm) high
b. Interior: Heavy weight, steel, 5 inches (127 mm) high

3. 2 inches or thicker doors:

a. Exterior: Heavy weight, bronze or stainless steel, 5 inches (127 mm) high
b. Interior: Heavy weight, steel, 5 inches (127 mm) high

4. Provide three hinges per door leaf for doors 90 inches (2286 mm) or less in height, and one additional hinge for each 30 inches (762 mm) of additional door height.
5. Where new hinges are specified for existing doors or existing frames, provide new hinges of identical size to hinge preparation present in existing door or existing frame.
6. Hinge Pins: Except as otherwise indicated, provide hinge pins as follows:

a. Steel Hinges: Steel pins
b. Non-Ferrous Hinges: Stainless steel pins
c. Out-Swinging Exterior Doors: Non-removable pins
d. Out-Swinging Interior Lockable Doors: Non-removable pins
e. Interior Non-lockable Doors: Non-rising pins

7. Width of hinges: 4-1/2 inches (114 mm) at 1-3/4 inch (44 mm) thick doors, and 5 inches (127 mm) at 2 inches (51 mm) or thicker doors. Adjust hinge width as required for door, frame, and wall conditions to allow proper degree of opening.

8. Doors 36 inches (914 mm) wide or less furnish hinges 4 ½ inches (114 mm) high; doors greater than 36 inches (914 mm) wide furnish hinges 5 inches (127 mm) high, heavy weight or standard weight as specified.
9. Provide hinges with electrified option where specified. Provide with sufficient number and gage of concealed wires to accommodate electric function of specified hardware. Locate electric hinge at second hinge from bottom or nearest to electrified locking component.
10. Provide mortar guard for each electrified hinge specified, unless specified in hollow metal frame specification.
11. Provide spring hinges where specified. Provide two spring hinges and one bearing hinge per door leaf for doors 90 inches (2286 mm) or less in height. Provide one additional bearing hinge for each 30 inches (762 mm) of additional door height.

2.4 CONTINUOUS HINGES

A. Stainless Steel

1. Manufacturers:

   a. Scheduled Manufacturer: Ives
   b. Acceptable Manufacturers: Markar, Stanley

2. Requirements:

   a. Provide pin and barrel continuous hinges conforming to ANSI A156.26, Grade 2.
   b. Provide pin and barrel continuous hinges fabricated from 14 gauge, type 304 stainless steel.
   c. Provide twin self-lubricated nylon bearings at each hinge knuckle, with 0.25-inch (6 mm) diameter stainless steel pin.
   d. Provide hinges capable of supporting door weights up to 600 pounds, and successfully tested for 1,500,000 cycles.
   e. On fire-rated doors, provide pin and barrel continuous hinges that are classified for use on rated doors by testing agency acceptable to authority having jurisdiction.
   f. Provide pin and barrel continuous hinges with electrified option where specified. Provide with sufficient number and gage of concealed wires to accommodate electric function of specified hardware.
   g. Install hinges with fasteners supplied by manufacturer.
   h. Provide hinges with symmetrical hole pattern.

B. Aluminum Geared

1. Manufacturers:

   a. Scheduled Manufacturer: Ives.
   b. Acceptable Manufacturers: Markar, Stanley.

2. Requirements:

   a. Provide aluminum geared continuous hinges conforming to ANSI A156.25, Grade 2.
   b. Provide aluminum geared continuous hinges, where specified in the hardware sets, fabricated from 6063-T6 aluminum, with 0.25-inch (6 mm) diameter Teflon coated stainless steel hinge pin.
   c. Provide split nylon bearings at each hinge knuckle for quiet, smooth, self-lubricating operation.
   d. Provide hinges capable of supporting door weights up to 450 pounds, and successfully tested for 1,500,000 cycles.
   e. On fire-rated doors, provide aluminum geared continuous hinges that are classified for use on rated doors by testing agency acceptable to authority having jurisdiction.

f. Provide aluminum geared continuous hinges with electrified option where specified. Provide with sufficient number and gage of concealed wires to accommodate electric function of specified hardware.
g. Install hinges with fasteners supplied by manufacturer.
h. Provide hinges with symmetrical hole pattern.

2.5 ELECTRIC POWER TRANSFER

A. Manufacturers:

a. Scheduled Manufacturer: Von Duprin
b. Acceptable Manufacturers: Falcon, ABH

B. Provide power transfer with number and gage of wires sufficient to accommodate electric function of specified hardware.

C. Locate electric power transfer per manufacturer's template and UL requirements, unless interference with operation of door or other hardware items.

2.6 PIVOT SETS

A. Manufacturers:

1. Scheduled Manufacturer: Ives
2. Acceptable Manufacturers: Dorma, Rixson

B. Requirements:

1. Provide pivot sets complete with oil-impregnated top pivot, unless indicated otherwise.
2. Where offset pivots are specified, Provide one intermediate pivot for doors less than 91 inches (2311 mm) high and one additional intermediate pivot per leaf for each additional 30 inches (762 mm) in height or fraction thereof. Intermediate pivots spaced equally not less than 25 inches (635 mm) or not more than 35 inches (889 mm) on center, for doors over 121 inches (3073 mm) high.
3. Provide appropriate model where pivot sets are specified at fire rated openings.
4. Provide lead-lined model where pivot sets are specified at lead-lined doors.
5. Provide electric pivot, located nearest to electrified locking component, with sufficient number and gage of concealed wires to accommodate electric function of specified hardware. If manufacturer of electrified locking component requires another device for power transfer then provide recommended power transfer device and appropriate quantity of pivots.
6. Provide mortar guard for each electric pivot specified, unless specified in hollow metal frame specification.

2.7 FLUSH BOLTS

A. Manufacturers:

1. Scheduled Manufacturer: Ives
2. Acceptable Manufacturers: Burns, Rockwood

B. Requirements:

1. Provide automatic, constant latching, and manual flush bolts with forged bronze or stainless steel face plates, extruded brass levers, and with wrought brass guides and strikes. Provide 12 inch

(305 mm) steel or brass rods at doors up to 90 inches (2286 mm) in height. For doors over 90 inches (2286 mm) in height increase top rods by 6 inches (152 mm) for each additional 6 inches (152 mm) of door height. Provide dust-proof strikes at each bottom flush bolt.

2.8 COORDINATORS

A. Manufacturers:

1. Scheduled Manufacturer: Ives
2. Acceptable Manufacturers: Burns, Rockwood

B. Requirements:

1. Where pairs of doors are equipped with automatic flush bolts, an astragal, or other hardware that requires synchronized closing of the doors, provide bar-type coordinating device, surface applied to underside of stop at frame head.
2. Provide filler bar of correct length for unit to span entire width of opening, and appropriate brackets for parallel arm door closers and surface vertical rod exit device strikes. Factory-prep coordinators for vertical rod devices if required.

2.9 MORTISE LOCKS

A. Manufacturers and Products:

1. Scheduled Manufacturer and Product: Schlage L9000 series
2. Acceptable Manufacturers and Products: None

B. Requirements:

1. Provide mortise locks certified as ANSI A156.13, Grade 1 Operational, Grade 1 Security, and manufactured from heavy gauge steel, containing components of steel with a zinc dichromate plating for corrosion resistance. Provide lock case that is multi-function and field reversible for handing without opening case. Cylinders: Refer to "KEYING" article, herein.
2. Provide locks with standard 2-3/4 inches (70 mm) backset with full 3/4 inch (19 mm) throw stainless steel mechanical anti-friction latchbolt. Provide deadbolt with full 1 inch (25 mm) throw, constructed of stainless steel.
3. Provide standard ASA strikes unless extended lip strikes are necessary to protect trim.
4. Provide electrical options as scheduled. Provide electrified locksets with micro switch (RX) option that monitors retractor crank, and is actuated when rotation of inside or outside lever rotates retractor hub. Provide normally closed contacts or normally open contacts as required by security system.
5. Lever Trim: Solid brass, bronze, or stainless steel, cast or forged in design specified, with wrought roses and external lever spring cages. Provide thru-bolted levers with 2-piece spindles.

   a. Lever Design: Schlage 17A.

2.10 CYLINDRICAL LOCKS – GRADE 1

A. Manufacturers and Products:

1. Scheduled Manufacturer and Product: Schlage ND Series
2. Acceptable Manufacturers and Products: None.

B. Requirements:

1. Provide cylindrical locks conforming to ANSI A156.2 Series 4000, Grade 1. Cylinders: Refer to "KEYING" article, herein.
2. Provide locksets able to withstand 1500 inch pounds of torque applied to locked outside lever without gaining access per ANSI A156.2 Abusive Locked Lever Torque Test and cycle tested to 3 million cycles per ANSI A156.2 Cycle Test.
3. Provide solid steel rotational stops to control excessive rotation of lever.
4. Provide completely refunctionable lockset that allows lock function to be changed to over twenty other common functions by swapping easily accessible parts.
5. Provide locks with standard 2-3/4 inches (70 mm) backset, unless noted otherwise, with 1/2 inch latch throw. Provide proper latch throw for UL listing at pairs.
6. Provide locksets with separate anti-rotation thru-bolts, and no exposed screws.
7. Provide independently operating levers with two external return spring cassettes mounted under roses to prevent lever sag.
8. Provide standard ASA strikes unless extended lip strikes are necessary to protect trim.
9. Provide electrical options as scheduled.
10. Lever Trim: Solid cast levers without plastic inserts, and wrought roses on both sides.

    a. Lever Design: Schlage Sparta.

2.11 AUXILIARY LOCKS

A. Deadlocks:

1. Manufacturers and Products:

    a. Scheduled Manufacturer and Product: Schlage L400 series
    b. Acceptable Manufacturers and Products: None.

2. Requirements:

    a. Provide mortise deadlock series conforming to ANSI A156 and function as specified. Cylinders: Refer to "KEYING" article, herein.
    b. Provide deadlocks with standard 2-3/4 inches (70 mm) backset. Provide deadbolt with full 1 inch (25 mm) throw, constructed of stainless steel.
    c. Provide manufacturer's standard strike.

B. Padlocks:

1. Manufacturers and Products:

    a. Scheduled Manufacturer and Product: Schlage KS series
    b. Acceptable Manufacturers and Products: Best 11B series, Sargent 758 series

2. Requirements:

    a. Provide padlocks with 1 inch (25 mm) shackle height, unless noted otherwise, as specified. Cylinders: Refer to "KEYING" article, herein.

2.12 EXIT DEVICES

A. Manufacturer and Product:

1. Von Duprin 98/35 series, No Substitute

2. Acceptable Manufacturers and Products: None.

B. Requirements:

1. Provide exit devices tested to ANSI/BHMA A156.3 Grade 1, and UL listed for Panic Exit or Fire Exit Hardware. Cylinders: Refer to "KEYING" article, herein.
2. Provide touchpad type exit devices, fabricated of brass, bronze, stainless steel, or aluminum, plated to standard architectural finishes to match balance of door hardware.
3. Quiet Operation: Incorporate fluid damper or other device that eliminates noise of exit device operation.
4. Touchpad: Extend minimum of one half of door width, but not the full length of exit device rail. Provide end-cap with two-point attachment to door. Match exit device finish, stainless steel for US26, US26D, US28, US32, and US32D finishes; and for all other finishes, provide compatible finish to exit device. Provide compression springs in devices, latches, and outside trims or controls; tension springs prohibited.
5. Provide exit devices with deadlatching feature for security and for future addition of alarm kits and/or other electrical requirements.
6. Concealed Vertical Cable Exit Devices: Cable-actuated concealed vertical latch system in two-point and less bottom latch (LBL) configurations. Vertical rods not permitted.

    a. Cable: Stainless steel core wire in stainless steel with polytetrafluoroethylene (Teflon®) liner color-coded to latches and center slides. Conduit and core wire ends snap into latch and center slides without use of tools.
    b. Latchbolts and Blocking Cams: Manufactured from sintered metal low carbon copper-infiltrated steel, with molybdenum disulfide low friction coating.
    c. Top Latchbolt: Minimum 0.382 inch (10 mm) and greater than 90 degree engagement with strike to prevent door and frame separation under high static load.
    d. Bottom Latchbolt: Minimum of 0.44 inch (11 mm) engagement with strike.
    e. Product Cycle Life: 1,000,000 cycles.
    f. Latch Operation: Top and bottom latch operate independently of each other. Top latch fully engages top strike even when bottom latch is compromised. Separate trigger mechanisms not permitted.
    g. Latch release does not require separate trigger mechanism.
    h. Cable and latching system characteristics:
        1) Assembled prior to being installed in door.
        2) Installed in door as complete assembly.
        3) Installed independently of exit device installation, and capable of functioning on door prior to device and trim installation.
        4) Connected to exit device at single attachment point.
        5) Bottom latch height adjusted from single point, after system is installed and connected to exit device, while door is hanging
        6) Latch position altered up and down 2 inches (51 mm) without additional adjustment.
        7) System may be removed while door is hanging.
        8) Configure latchbolt mounting: double or single tab mount for steel doors, and wood doors, face mount for aluminum doors, eliminating requirement of tabs.
        9) Provide adjustable exit device to latch center line adjustment. Ensures double tab mounting option for top latch, regardless of exit device centerline.

7. Provide exit devices with manufacturer's approved strikes.
8. Provide exit devices cut to door width and height. Locate exit devices at height recommended by exit device manufacturer, allowable by governing building codes, and approved by Architect.
9. Mount mechanism case flush on face of doors, or provide spacers to fill gaps behind devices. Where glass trim or molding projects off face of door, provide glass bead kits.
10. Provide cylinder dogging at non-fire-rated exit devices, unless specified less dogging.

11. Removable Mullions: 2 inches (51 mm) x 3 inches (76 mm) steel tube. Where scheduled as keyed removable mullion that is removed by use of a keyed cylinder, which is self-locking when re-installed.
12. Where lever handles are specified as outside trim for exit devices, provide heavy-duty lever trims with forged or cast escutcheon plates. Provide vandal-resistant levers that will travel to 90-degree down position when more than 35 pounds of torque are applied, and which can easily be re-set.

    a. Lever Style: Match lever style of locksets.
    b. Tactile Warning (Knurling): Where required by authority having jurisdiction. Provide on levers on exterior (secure side) of doors serving rooms considered to be hazardous.

13. Provide UL labeled fire exit hardware for fire rated openings.
14. Provide factory drilled weep holes for exit devices used in full exterior application, highly corrosive areas, and where noted in hardware sets.
15. Provide electrical options as scheduled.

2.13 ELECTRIC STRIKES

A. Manufacturers and Products:

1. Scheduled Manufacturer and Product: Von Duprin 6000 series
2. Acceptable Manufacturers and Products: Folger Adam 300 series, HES 1006 series

B. Requirements:

1. Provide electric strikes designed for use with type of locks shown at each opening.
2. Provide electric strikes UL Listed as burglary-resistant.
3. Where required, provide electric strikes UL Listed for fire doors and frames.
4. Provide fail-secure type electric strikes, unless specified otherwise.
5. Coordinate voltage and provide transformers and rectifiers for each strike as required.

2.14 POWER SUPPLIES

A. Manufacturers and Products:

1. Scheduled Manufacturer and Product: Schlage Electronics or Von Duprin PS900 series
2. Acceptable Manufacturers and Products: None

B. Requirements:

1. Provide power supplies, recommended and approved by manufacturer of electrified locking component, for operation of electrified locks, electrified exit devices, magnetic locks, electric strikes, and other components requiring power supply.
2. Provide appropriate quantity of power supplies necessary for proper operation of electrified locking components as recommended by manufacturer of electrified locking components with consideration for each electrified component using power supply, location of power supply, and approved wiring diagrams. Locate power supplies as directed by Architect.
3. Provide regulated and filtered 24 VDC power supply , and UL class 2 listed.
4. Options:

    a. Provide power supply, where specified, with internal capability of charging sealed backup batteries 24 VDC, in addition to operating DC load.
    b. Provide sealed batteries for battery back-up at each power supply where specified.
    c. Provide keyed power supply cabinet.

5. Provide power supply in an enclosure, complete, and requiring 120VAC to fused input.
6. Provide power supply with emergency release terminals, where specified, that allow release of all devices upon activation of fire alarm system complete with fire alarm input for initiating "no delay" exiting mode.

2.15 CYLINDERS

A. Manufacturer:

1. Scheduled Manufacturer: Schlage
2. Acceptable Manufacturers and Products: None.

B. Requirements: Provide cylinders/cores complying with the following requirements.

1. Furnished by same manufacturer as locks.
2. Cylinders/cores compliant with ANSI/BHMA A156.5; latest revision, Section 12, Grade 1; permanent cylinders; cylinder face finished to match lockset, manufacturer's series as indicated.

C. Full-sized cylinders in the below-listed configuration(s), distributed throughout the Project as indicated.

1. Keying:

D. . [Manufacturer-keyed permanent cylinders/cores, configured into existing keying system per "KEYING" article herein.]

E. . [Locksmith-keyed permanent cylinders/cores, configured into existing keying system per "KEYING" article herein.]

1. . <provide contact information if the Owner or Owners representative are to provide the permanent cylinders and/or cores>
2. Features: Cylinders/cores shall incorporate the following features.

F. Nickel silver bottom pins.

1. Identification:

G. Mark permanent cylinders/cores and keys with applicable blind code per DHI publication "Keying Systems and Nomenclature" for identification. Blind code marks shall not include actual key cuts.

H. Identification stamping provisions must be approved by the Architect and Owner.

I. Failure to comply with stamping requirements shall be cause for replacement of cylinders/cores involved at no additional cost to Owner.

1. Forward cylinders/cores to Owner, separately from keys, by means as directed by Owner.

J. Construction Keying System.

K. 3 construction control keys and extractor tool, if required.

L. 12 construction change (day) keys.

1. Owner or Owner's Representative will void operation of temporary construction keys.

M. Replaceable Construction Cores.

1. Provide temporary construction cores replaceable by permanent cores, furnished in accordance with the following requirements.

N. 12 construction change (day) keys.

1. Owner or Owner's Representative will replace temporary construction cores with permanent cores.

2.16 KEYING

A. Keying System: Factory registered, complying with guidelines in ANSI/BHMA A156.28, incorporating decisions made at keying conference.

B. Keying System: Existing Schlage system maintained by Owner or Owners representative, incorporating decisions made at keying conference.

1. . <provide contact information if the Owner or Owners representative are to perform the keying>

C. Keying Requirements – General

1. Permanent cylinders/cores keyed by the manufacturer according to the following key system.

D. Keying system tied into existing system as directed by the Owner.

1. Forward bitting list and keys separately from cylinders, by means as directed by Owner. Failure to comply with forwarding requirements shall be cause for replacement of cylinders/cores involved at no additional cost to Owner.

E. Key Features: Provide keys with the following features.

1. . [Patent Protection: Keys and blanks protected by one or more utility patent(s).]

F. One allocation within postal zip codes with the same first 2 digits.

G. One allocation per time zone.

H. One allocation per Country.

I. Keys

1. Material: Nickel silver; minimum thickness of .092-inch (2.3mm)
2. Identification:

J. Coordinate with cylinder/core and key identification requirements above.

K. Stamp keys with Owner's unique key system facility code as established by the manufacturer; key symbol and embossed or stamped with "DO NOT DUPLICATE" along with the "PATENTED" or patent number to enforce the patent protection.

L. Failure to comply with stamping requirements shall be cause for replacement of keys involved at no additional cost to Owner.

1. Quantity: Furnish in the following quantities.

M. Change (Day) Keys: 3 per cylinder/core.

N. Permanent Control Keys: 3.

O. Master Keys: 6.

P. Unused balance of key blanks shall be furnished to Owner with the cut keys.

Q. Extra Keys:

1. <insert quantity> Presentation Keys
2. <insert quantity> Construction Keys

2.17 KEY CONTROL SYSTEM

A. Key Control System Manufacturers:

1. Scheduled Manufacturer: Telkee
2. Acceptable Manufacturers: HPC, Lund

B. Requirements:

1. Provide key control system, including envelopes, labels, tags with self-locking key clips, receipt forms, 3-way visible card index, temporary markers, permanent markers, and standard metal cabinet, all as recommended by system manufacturer, with capacity for 150% of number of locks required for Project.

   a. Provide complete cross index system set up by hardware supplier, and place keys on markers and hooks in cabinet as determined by final key schedule.
   b. Provide hinged-panel type cabinet for wall mounting.

C. Key Management Software Manufacturers and Products:

1. Scheduled Manufacturer and Product: Schlage SITEMASTER 200
2. Acceptable Manufacturers and Products: Best Keystone 600N, Corbin-Russwin KeyWizard, Medeco KeyWizard, Sargent KeyWizard, Yale KeyWizard.

D. Key Management Software Requirements:

1. Software: Provide tracking, issuing, collecting and transferring information regarding keys. Provide customized query, reporting, searching capability, comprehensive location hardware listings, display key holder photos and signature for verification, and provide automatic reminders for maintenance, back-ups and overdue keys.
2. Provide training for Owner's personnel on proper operation and application of key management software.

2.18 DOOR CLOSERS OPTION: when required to specify LCN 4010/4110 in an NO-SUBSTITUTION specification

A. Manufacturer and Product: LCN 4010/4110 series. No Substitute

B. Requirements:

1. Provide door closers certified to ANSI/BHMA A156.4 Grade 1 requirements by BHMA certified independent testing laboratory. [Certify surface mounted mechanical closers to exceed ten million (10,000,000) full load cycles]. ISO 9000 certify closers. Stamp units with date of manufacture code.
2. Provide door closers with fully hydraulic, full rack and pinion action with high strength cast iron cylinder, and full complement bearings at shaft.
3. Cylinder Body: 1-1/2 inch (38 mm) diameter with 11/16 inch (17 mm) diameter double heat-treated pinion journal.
4. Hydraulic Fluid: Fireproof, passing requirements of UL10C, and requiring no seasonal closer adjustment for temperatures ranging from 120 degrees F to -30 degrees F.
5. Spring Power: Continuously adjustable over full range of closer sizes, and providing reduced opening force as required by accessibility codes and standards.
6. Hydraulic Regulation: By tamper-proof, non-critical valves, with separate adjustment for latch speed, general speed, and backcheck.
7. Provide closers with solid forged steel main arms and factory assembled heavy-duty forged forearms for parallel arm closers. When closers are parallel arm mounted, provide closers which mount within 6-inch (152 mm) top rail without use of mounting plate so that closer is not visible through vision panel from pull side.
8. Pressure Relief Valve (PRV) Technology: Not permitted.
9. Finish for Closer Cylinders, Arms, Adapter Plates, and Metal Covers: Powder coating finish which has been certified to exceed 100 hours salt spray testing as described in ANSI Standard A156.4 and ASTM B117, or has special rust inhibitor (SRI).
10. Provide special templates, drop plates, mounting brackets, or adapters for arms as required for details, overhead stops, and other door hardware items interfering with closer mounting.

2.19 DOOR CLOSERS

A. Manufacturers and Products:

1. Scheduled Manufacturer and Product: LCN 4040XP series
2. Acceptable Manufacturers and Products: None.

B. Requirements:

1. Provide door closers certified to ANSI/BHMA A156.4 Grade 1 requirements by BHMA certified independent testing laboratory. ISO 9000 certify closers. Stamp units with date of manufacture code.
2. Provide door closers with fully hydraulic, full rack and pinion action with high strength cast iron cylinder, and full complement bearings at shaft.
3. Cylinder Body: 1-1/2 inch (38 mm) diameter, with 11/16 inch (17 mm) diameter double heat-treated pinion journal.
4. Hydraulic Fluid: Fireproof, passing requirements of UL10C, and requiring no seasonal closer adjustment for temperatures ranging from 120 degrees F to -30 degrees F.
5. Spring Power: Continuously adjustable over full range of closer sizes, and provideing reduced opening force as required by accessibility codes and standards.
6. Hydraulic Regulation: By tamper-proof, non-critical valves with separate adjustment for latch speed, general speed, and backcheck.
7. Provide closers with a solid forged steel main arms and factory assembled heavy-duty forged forearms for parallel arm closers.
8. Pressure Relief Valve (PRV) Technology: Not permitted.
9. Finish for Closer Cylinders, Arms, Adapter Plates, and Metal Covers: Powder coating finish which has been certified to exceed 100 hours salt spray testing as described in ANSI Standard A156.4 and ASTM B117, or has special rust inhibitor (SRI).
10. Provide special templates, drop plates, mounting brackets, or adapters for arms as required for details, overhead stops, and other door hardware items interfering with closer mounting.

2.20 DOOR TRIM

A. Manufacturers:

1. Scheduled Manufacturer: Ives.
2. Acceptable Manufacturers: Burns, Rockwood.

B. Requirements:

1. Provide push plates 4 inches (102 mm) wide by 16 inches (406 mm) high by 0.050 inch (1 mm) thick and beveled 4 edges. Where width of door stile prevents use of 4 inches (102 mm) wide plate, adjust width to fit.
2. Provide push bars of solid bar stock, diameter and length as scheduled. Provide push bars of sufficient length to span from center to center of each stile. Where required, mount back to back with pull.
3. Provide offset pulls of solid bar stock, diameter and length as scheduled. Where required, mount back to back with push bar.
4. Provide flush pulls as specified. Where required, provide back-to-back mounted model.
5. Provide pulls of solid bar stock, diameter and length as scheduled. Where required, mount back to back with push bar.
6. Provide pull plates 4 inches (102 mm) wide by 16 inches (406 mm) high by 0.050 inch (1 mm) thick, beveled 4 edges, and prepped for pull. Where width of door stile prevents use of 4 inches (102 mm) wide plate, adjust width to fit.
7. Provide wire pulls of solid bar stock, diameter and length as scheduled.

2.21 PROTECTION PLATES

A. Manufacturers:

1. Scheduled Manufacturer: Ives.
2. Acceptable Manufacturers: Burns, Rockwood.

B. Requirements:

1. Provide kick plates, mop plates, and armor plates minimum of 0.050 inch (1 mm) thick as scheduled. Furnish with sheet metal or wood screws, finished to match plates.
2. Sizes of plates:

   a. Kick Plates: 10 inches (254 mm) high by 2 inches (51 mm) less width of door on single doors, 1 inch (25 mm) less width of door on pairs
   b. Mop Plates: 4 inches (102 mm) high by 2 inches (51 mm) less width of door on single doors, 1 inch (25 mm) less width of door on pairs
   c. Armor Plates: 36 inches (914 mm) high by 2 inches (51 mm) less width of door on single doors, 1 inch (25 mm) less width of door on pairs

2.22 OVERHEAD STOPS AND OVERHEAD STOP/HOLDERS

A. Manufacturers:

1. Scheduled Manufacturers: Glynn-Johnson
2. Acceptable Manufacturers: Rixson, Sargent

B. Requirements:

1. Provide heavy duty concealed mounted overhead stop or holder as specified for exterior and interior vestibule single acting doors.
2. Provide heavy duty concealed mounted overhead stop or holder as specified for double acting doors.
3. Provide heavy or medium duty and concealed or surface mounted overhead stop or holder for interior doors as specified. Provide medium duty surface mounted overhead stop for interior doors and at any door that swings more than 140 degrees before striking wall, open against equipment, casework, sidelights, and where conditions do not allow wall stop or floor stop presents tripping hazard.
4. Where overhead holders are specified provide friction type at doors without closer and positive type at doors with closer.

2.23 DOOR STOPS AND HOLDERS

A. Manufacturers:

1. Scheduled Manufacturer: Ives.
2. Acceptable Manufacturers: Burns, Rockwood.

B. Provide door stops at each door leaf:

1. Provide wall stops wherever possible. Provide convex type where mortise type locks are used and concave type where cylindrical type locks are used.
2. Where a wall stop cannot be used, provide universal floor stops for low or high rise options.
3. Where wall or floor stop cannot be used, provide medium duty surface mounted overhead stop.

2.24 THRESHOLDS, SEALS, DOOR SWEEPS, AUTOMATIC DOOR BOTTOMS, AND GASKETING

A. Manufacturers:

1. Scheduled Manufacturer: National Guard.
2. Acceptable Manufacturers: Pemko, Zero.

B. Requirements:

1. Provide thresholds, weatherstripping (including door sweeps, seals, astragals) and gasketing systems (including smoke, sound, and light) as specified and per architectural details. Match finish of other items.
2. Size of thresholds::

   a. Saddle Thresholds: 1/2 inch (13 mm) high by jamb width by door width
   b. Bumper Seal Thresholds: 1/2 inch (13 mm) high by 5 inches (127 mm) wide by door width

3. Provide door sweeps, seals, astragals, and auto door bottoms only of type where resilient or flexible seal strip is easily replaceable and readily available.

2.25 SILENCERS

A. Manufacturers:

1. Scheduled Manufacturer: Ives.
2. Acceptable Manufacturers: Burns, Rockwood.

B. Requirements:

1. Provide "push-in" type silencers for hollow metal or wood frames.
2. Provide one silencer per 30 inches (762 mm) of height on each single frame, and two for each pair frame.
3. Omit where gasketing is specified.

2.26 MAGNETIC HOLDERS

A. Manufacturers:

1. Scheduled Manufacturer: LCN.
2. Acceptable Manufacturers: Rixson, Sargent.

B. Requirements:

1. Provide wall or floor mounted electromagnetic door release as specified with minimum of 25 pounds of holding force. Coordination projection of holder and armature with other hardware and wall conditions to ensure that door sits parallel to wall when fully open. Wire magnetic holders on fire-rated doors into the fire control panel for fail-safe operation.

2.27 DOOR POSITION SWITCHES

A. Manufacturers:

1. Scheduled Manufacturer: Schlage Electronics.
2. Acceptable Manufacturers: GE-Interlogix, Sargent.

B. Requirements:

1. Provide recessed or surface mounted type door position switches as specified.
2. Coordinate door and frame preparations with door and frame suppliers. If switches are being used with magnetic locking device, provide minimum of 4 inches (102 mm) between switch and magnetic locking device.

2.28 LATCH PROTECTORS

A. Manufacturers:

1. Scheduled Manufacturer: Ives.
2. Acceptable Manufacturers: Burns, Rockwood.

B. Provide latch protectors of type required to function with specified lock.

2.29 FINSHES

A. Finish: BHMA 626/652 (US26D); except:

1. Hinges at Exterior Doors: BHMA 630 (US32D)
2. Continuous Hinges: BHMA 630 (US32D)
3. Push Plates, Pulls, and Push Bars: BHMA 630 (US32D)
4. Protection Plates: BHMA 630 (US32D)

5. Overhead Stops and Holders: BHMA 630 (US32D)
6. Door Closers: Powder Coat to Match
7. Wall Stops: BHMA 630 (US32D)
8. Latch Protectors: BHMA 630 (US32D)
9. Weatherstripping: Clear Anodized Aluminum
10. Thresholds: Mill Finish Aluminum

PART 3 - EXECUTION

3.1 EXAMINATION

A. Prior to installation of hardware, examine doors and frames, with Installer present, for compliance with requirements for installation tolerances, labeled fire-rated door assembly construction, wall and floor construction, and other conditions affecting performance.

B. Existing Door and Frame Compatibility: Field verify existing doors and frames receiving new hardware and existing conditions receiving new openings. Verify that new hardware is compatible with existing door and frame preparation and existing conditions.

C. Examine roughing-in for electrical power systems to verify actual locations of wiring connections before electrified door hardware installation.

D. Proceed with installation only after unsatisfactory conditions have been corrected.

3.2 PREPARATION

A. Where on-site modification of doors and frames is required:

1. Remove existing hardware being replaced, tag, and store according to contract documents.
2. Field modify and prepare existing door and frame for new hardware being installed.
3. When modifications are exposed to view, use concealed fasteners, when possible.
4. Prepare hardware locations in accordance with:

   a. Steel Doors and Frames: For surface applied door hardware, drill and tap doors and frames according to ANSI/SDI A250.6.
   b. Wood Doors: DHI WDHS.5 "Recommended Hardware Reinforcement Locations for Mineral Core Wood Flush Doors."
   c. Doors in rated assemblies: NFPA 80 for restrictions on on-site door hardware preparation.

3.3 INSTALLATION

A. Mounting Heights: Mount door hardware units at heights to comply with the following, unless otherwise indicated or required to comply with governing regulations.

1. Standard Steel Doors and Frames: ANSI/SDI A250.8.
2. Custom Steel Doors and Frames: HMMA 831.
3. Wood Doors: DHI WDHS.3, "Recommended Locations for Architectural Hardware for Wood Flush Doors."

B. Install each hardware item in compliance with manufacturer's instructions and recommendations, using only fasteners provided by manufacturer.

C. Do not install surface mounted items until finishes have been completed on substrate. Protect all installed hardware during painting.

D. Set units level, plumb and true to line and location. Adjust and reinforce attachment substrate as necessary for proper installation and operation.

E. Drill and countersink units that are not factory prepared for anchorage fasteners. Space fasteners and anchors according to industry standards.

F. Install operating parts so they move freely and smoothly without binding, sticking, or excessive clearance.

G. Hinges: Install types and in quantities indicated in door hardware schedule but not fewer than quantity recommended by manufacturer for application indicated or one hinge for every 30 inches (750 mm) of door height, whichever is more stringent, unless other equivalent means of support for door, such as spring hinges or pivots, are provided.

H. Intermediate Offset Pivots: Where offset pivots are indicated, provide intermediate offset pivots in quantities indicated in door hardware schedule but not fewer than one intermediate offset pivot per door and one additional intermediate offset pivot for every 30 inches (750 mm) of door height greater than 90 inches (2286 mm).

I. Lock Cylinders: Install construction cores to secure building and areas during construction period.

1. Replace construction cores with permanent cores as indicated in keying section.
2. . OPTION: Furnish permanent cores to Owner for installation.

J. Lead Protection: Lead wrap hardware penetrating lead-lined doors. Levers and roses to be lead lined. Apply kick and armor plates on lead-lined doors with adhesive as recommended by manufacturer.

K. Wiring: Coordinate with Division 26, ELECTRICAL sections for:

1. Conduit, junction boxes and wire pulls.
2. Connections to and from power supplies to electrified hardware.
3. Connections to fire/smoke alarm system and smoke evacuation system.
4. Connection of wire to door position switches and wire runs to central room or area, as directed by Architect.
5. Testing and labeling wires with Architect's opening number.

L. Key Control System: Tag keys and place them on markers and hooks in key control system cabinet, as determined by final keying schedule.

M. Door Closers: Mount closers on room side of corridor doors, inside of exterior doors, and stair side of stairway doors from corridors. Closers shall not be visible in corridors, lobbies and other public spaces unless approved by Architect.

N. Closer/Holders: Mount closer/holders on room side of corridor doors, inside of exterior doors, and stair side of stairway doors.

O. Power Supplies: Locate power supplies as indicated or, if not indicated, above accessible ceilings or in equipment room, or alternate location as directed by Architect.

1. Configuration: Provide [one power supply for each door opening][least number of power supplies required to adequately serve doors] with electrified door hardware.

P. Thresholds: Set thresholds in full bed of sealant complying with requirements specified in Division 07 Section "Joint Sealants."

Q. Stops: Provide floor stops for doors unless wall or other type stops are indicated in door hardware schedule. Do not mount floor stops where they may impede traffic or present tripping hazard.

R. Perimeter Gasketing: Apply to head and jamb, forming seal between door and frame.

S. Meeting Stile Gasketing: Fasten to meeting stiles, forming seal when doors are closed.

T. Door Bottoms: Apply to bottom of door, forming seal with threshold when door is closed.

3.4 FIELD QUALITY CONTROL

A. Architectural Hardware Consultant: Engage qualified independent Architectural Hardware Consultant to perform inspections and to prepare inspection reports.

1. Architectural Hardware Consultant will inspect door hardware and state in each report whether installed work complies with or deviates from requirements, including whether door hardware is properly installed and adjusted.

3.5 ADJUSTING

A. Initial Adjustment: Adjust and check each operating item of door hardware and each door to ensure proper operation or function of every unit. Replace units that cannot be adjusted to operate as intended. Adjust door control devices to compensate for final operation of heating and ventilating equipment and to comply with referenced accessibility requirements.

1. Spring Hinges: Adjust to achieve positive latching when door is allowed to close freely from an open position of 30 degrees.
2. Electric Strikes: Adjust horizontal and vertical alignment of keeper to properly engage lock bolt.
3. Door Closers: Adjust sweep period to comply with accessibility requirements and requirements of authorities having jurisdiction.

B. Occupancy Adjustment: Approximately three[six] <Insert number> months after date of Substantial Completion, Installer's Architectural Hardware Consultant shall examine and readjust each item of door hardware, including adjusting operating forces, as necessary to ensure function of doors, door hardware, and electrified door hardware.

3.6 CLEANING AND PROTECTION

A. Clean adjacent surfaces soiled by door hardware installation.

B. Clean operating items as necessary to restore proper function and finish.

C. Provide final protection and maintain conditions that ensure door hardware is without damage or deterioration at time of Substantial Completion.

3.7 DEMONSTRATION

A. Provide training for Owner's maintenance personnel to adjust, operate, and maintain door hardware and door hardware finishes. Refer to Division 01 Section "Demonstration and Training."

3.8 DOOR HARDWARE SCHEDULE

A. Locksets, exit devices, and other hardware items are referenced in the following hardware sets for series, type and function. Refer to the above-specifications for special features, options, cylinders/keying, and other requirements.

B. Hardware Sets:

End Of Section

Hardware Set No. 100

For use on door #(s):
A114A/1 A114B/1

Provide each PR door(s) with the following:

Qty		Description	Catalog Number	Finish	Mfr
2	EA	CONT. HINGE	224HD EPT	628	IVE
2	EA	POWER TRANSFER	EPT10	689	VON
1	EA	KEYED REMOVABLE MULLION	KR4954-STAB	689	VON
1	EA	ELEC PANIC HARDWARE	RX-QEL+-98-NL-OP-110	626	VON
1	EA	ELEC PANIC HARDWARE	RX-QEL+-SD-98-EO	626	VON
1	EA	RIM CYLINDER	20-057-ICX	626	SCH
3	EA	MORTISE CYLINDER	20-061-ICX	626	SCH
4	EA	FSIC CORE	23-030	626	SCH
2	EA	90 DEG OFFSET PULL	8190 18" O	630	IVE
2	EA	OH STOP	100S	630	GLY
2	EA	SURFACE CLOSER	4040XP EDA TBSRT	689	LCN
2	EA	CUSH SHOE SUPPORT	4040-30	689	LCN
2	EA	BLADE STOP SPACER	4040-61	689	LCN
1	EA	MULLION SEAL	5100	BLK	NGP
1	EA	THRESHOLD	896S	AL	NGP
2	EA	DOOR CONTACT	679-05HM	BLK	SCE
1	EA	POWER SUPPLY	PS902 900-2RS KL900	LGR	VON

DOOR OPERATION: Door normally closed and secure. Entry from secure side by valid credential or key override which will unlock electrified door. Free egress from inside at all times. Door position switch and request to exit connected to access control system for monitoring.

Hardware Set No. 101

For use on door #(s):
A114A/2 A114B/2

Provide each PR door(s) with the following:

Qty		Description	Catalog Number	Finish	Mfr
2	EA	CONT. HINGE	224HD EPT	628	IVE
1	EA	KEYED REMOVABLE MULLION	KR4954-STAB	689	VON
2	EA	ELEC PANIC HARDWARE	RX-QEL+-SD-98-EO	626	VON
3	EA	MORTISE CYLINDER	20-061-ICX	626	SCH
3	EA	FSIC CORE	23-030	626	SCH
2	EA	90 DEG OFFSET PULL	8190 18" O	630	IVE
2	EA	OH STOP	100S	630	GLY
2	EA	SURFACE CLOSER	4040XP EDA TBSRT	689	LCN
2	EA	CUSH SHOE SUPPORT	4040-30	689	LCN
2	EA	BLADE STOP SPACER	4040-61	689	LCN
1	EA	MULLION SEAL	5100	BLK	NGP
1	EA	THRESHOLD	896S	AL	NGP
2	EA	DOOR CONTACT	679-05HM	BLK	SCE
1	EA	POWER SUPPLY	PS902 900-2RS KL900	LGR	VON

DOOR OPERATION: Door normally closed and secure. Entry from secure side by valid credential or key override which will unlock electrified door. Free egress from inside at all times. Door position switch and request to exit connected to access control system for monitoring.

Hardware Set No. 102

For use on door #(s):
A114A/3

Provide each PR door(s) with the following:

Qty		Description	Catalog Number	Finish	Mfr
2	EA	CONT. HINGE	224HD EPT	628	IVE
2	EA	POWER TRANSFER	EPT10	689	VON
1	EA	KEYED REMOVABLE MULLION	KR4954-STAB	689	VON
1	EA	ELEC PANIC HARDWARE	RX-QEL+-98-NL-OP-110	626	VON
1	EA	ELEC PANIC HARDWARE	RX-QEL+-SD-98-EO	626	VON
1	EA	RIM CYLINDER	20-057-ICX	626	SCH
3	EA	MORTISE CYLINDER	20-061-ICX	626	SCH
4	EA	FSIC CORE	23-030	626	SCH
2	EA	90 DEG OFFSET PULL	8190 18" O	630	IVE
2	EA	OH STOP	100S	630	GLY
2	EA	SURFACE CLOSER	4040XP EDA TBSRT	689	LCN
2	EA	CUSH SHOE SUPPORT	4040-30	689	LCN
2	EA	BLADE STOP SPACER	4040-61	689	LCN
2	EA	DOOR CONTACT	679-05HM	BLK	SCE
1	EA	POWER SUPPLY	PS902 900-2RS KL900	LGR	VON

DOOR OPERATION: Door normally closed and secure. Entry from secure side by valid credential or key override which will unlock electrified door. Free egress from inside at all times. Door position switch and request to exit connected to access control system for monitoring.

Hardware Set No. 103

For use on door #(s):
A114A/4

Provide each PR door(s) with the following:

Qty		Description	Catalog Number	Finish	Mfr
2	EA	CONT. HINGE	224HD EPT	628	IVE
1	EA	KEYED REMOVABLE MULLION	KR4954-STAB	689	VON
2	EA	ELEC PANIC HARDWARE	RX-QEL+-SD-98-EO	626	VON
3	EA	MORTISE CYLINDER	20-061-ICX	626	SCH
3	EA	FSIC CORE	23-030	626	SCH
2	EA	90 DEG OFFSET PULL	8190 18" O	630	IVE
2	EA	OH STOP	100S	630	GLY
2	EA	SURFACE CLOSER	4040XP EDA TBSRT	689	LCN
2	EA	CUSH SHOE SUPPORT	4040-30	689	LCN
2	EA	BLADE STOP SPACER	4040-61	689	LCN
2	EA	DOOR CONTACT	679-05HM	BLK	SCE
1	EA	POWER SUPPLY	PS902 900-2RS KL900	LGR	VON

DOOR OPERATION: Door normally closed and secure. Entry from secure side by valid credential or key override which will unlock electrified door. Free egress from inside at all times. Door position switch and request to exit connected to access control system for monitoring.

Hardware Set No. 104

For use on door #(s):
A101/2

Provide each PR door(s) with the following:

Qty		Description	Catalog Number	Finish	Mfr
1	EA	CONT. HINGE	224HD	628	IVE
1	EA	CONT. HINGE	224HD EPT	628	IVE
1	EA	POWER TRANSFER	EPT10	689	VON
2	EA	MANUAL FLUSH BOLT	FB458	626	IVE
1	EA	DUST PROOF STRIKE	DP2	626	IVE
1	EA	EU STOREROOM LOCK	RX-L9080TEU 17A	626	SCH
1	EA	FSIC CORE	23-030	626	SCH
2	EA	OH STOP	100S	630	GLY
2	EA	SURFACE CLOSER	4040XP EDA TBSRT	689	LCN
2	EA	DOOR CONTACT	679-05HM	BLK	SCE
1	EA	POWER SUPPLY	PS902 KL900	LGR	SCE
			CARD READER BY OTHERS		

DOOR OPERATION: Door normally closed and secure. Entry from secure side by valid credential or key override which will unlock electrified door. Free egress from inside at all times. Door position switch and request to exit connected to access control system for monitoring.

Hardware Set No. 105

For use on door #(s):
A114B/3 C100C/2 C100F/3 C100F/4

Provide each PR door(s) with the following:

Qty		Description	Catalog Number	Finish	Mfr
2	EA	CONT. HINGE	224HD	628	IVE
1	EA	DUMMY PUSH BAR	350-EO	626	VON
2	EA	90 DEG OFFSET PULL	8190 18" O	630	IVE
2	EA	OH STOP	100S	630	GLY
2	EA	SURFACE CLOSER	4040XP EDA TBSRT	689	LCN

Hardware Set No. 106

For use on door #(s):
A100/1 C100A/1 C101/2 D114/2

Provide each PR door(s) with the following:

Qty		Description	Catalog Number	Finish	Mfr
2	EA	CONT. HINGE	224HD	628	IVE
1	EA	KEYED REMOVABLE MULLION	KR4954-STAB	689	VON
2	EA	PANIC HARDWARE	CD-98-EO	626	VON
3	EA	MORTISE CYLINDER	20-061-ICX	626	SCH
3	EA	FSIC CORE	23-030	626	SCH
2	EA	OH STOP	100S	630	GLY
2	EA	SURFACE CLOSER	4040XP EDA TBSRT	689	LCN
2	EA	CUSH SHOE SUPPORT	4040-30	689	LCN
2	EA	BLADE STOP SPACER	4040-61	689	LCN
1	EA	MULLION SEAL	5100	BLK	NGP
1	EA	THRESHOLD	896S	AL	NGP
2	EA	DOOR CONTACT	679-05HM	BLK	SCE

DOOR OPERATION: Door position switch to be connected to access control system for monitoring.

Hardware Set No. 107

For use on door #(s):
C101/1

Provide each SGL door(s) with the following:

Qty		Description	Catalog Number	Finish	Mfr
1	EA	CONT. HINGE	224HD	628	IVE
1	EA	STOREROOM LOCK	LV9080T 17A	626	SCH
1	EA	FSIC CORE	23-030	626	SCH
1	EA	SURFACE CLOSER	4040XP SCUSH TBSRT	689	LCN
1	EA	KICK PLATE	8400 10" X 2" LDW B4E	630	IVE
1	EA	DRIP CAP	17	AL	NGP
1	SET	SEALS	5050B	BRN	NGP
1	EA	THRESHOLD	896S	AL	NGP

1	EA	DOOR CONTACT	679-05HM	BLK	SCE

DOOR OPERATION: Door position switch to be connected to access control system for monitoring.

Hardware Set No. 108

For use on door #(s):
B100A/1 C100C/1 C100F/1

Provide each PR door(s) with the following:

Qty		Description	Catalog Number	Finish	Mfr
2	EA	CONT. HINGE	224HD EPT	628	IVE
2	EA	POWER TRANSFER	EPT10	689	VON
1	EA	KEYED REMOVABLE MULLION	KR4954-STAB	689	VON
1	EA	ELEC PANIC HARDWARE	RX-CD-98-EO	626	VON
1	EA	ELEC PANIC HARDWARE	RX-QEL+-SD-98-NL-OP-110	626	VON
1	EA	RIM CYLINDER	20-057-ICX	626	SCH
3	EA	MORTISE CYLINDER	20-061-ICX	626	SCH
4	EA	FSIC CORE	23-030	626	SCH
2	EA	90 DEG OFFSET PULL	8190 18" O	630	IVE
2	EA	OH STOP	100S	630	GLY
2	EA	SURFACE CLOSER	4040XP EDA TBSRT	689	LCN
2	EA	CUSH SHOE SUPPORT	4040-30	689	LCN
2	EA	BLADE STOP SPACER	4040-61	689	LCN
1	EA	MULLION SEAL	5100	BLK	NGP
1	EA	THRESHOLD	896S	AL	NGP
2	EA	DOOR CONTACT	679-05HM	BLK	SCE
1	EA	POWER SUPPLY	PS902 900-2RS KL900	LGR	VON

DOOR OPERATION: Door normally closed and secure. Entry from secure side by valid credential or key override which will unlock electrified door. Free egress from inside at all times. Door position switch and request to exit connected to access control system for monitoring.

Hardware Set No. 109

For use on door #(s):
C110/1

Provide each PR door(s) with the following:

Qty		Description	Catalog Number	Finish	Mfr
2	EA	CONT. HINGE	224HD	628	IVE
1	EA	KEYED REMOVABLE MULLION	KR4954-STAB	689	VON
1	EA	PANIC HARDWARE	98-EO	626	VON
1	EA	PANIC HARDWARE	98-NL-OP-110	626	VON
1	EA	RIM CYLINDER	20-057-ICX	626	SCH
1	EA	FSIC CORE	23-030	626	SCH
1	EA	DOOR PULL	VR910 NL	630	IVE
2	EA	SURFACE CLOSER	4040XP SCUSH TBSRT	689	LCN
2	EA	KICK PLATE	8400 10" X 2" LDW B4E	630	IVE

1	SET	SEALS	5050B	BRN	NGP
1	SET	ASTRAGAL	140PA	CL	NGP
1	EA	MULLION SEAL	5100	BLK	NGP
2	EA	DOOR SWEEP	C627A	CL	NGP
1	EA	THRESHOLD	896S	AL	NGP
2	EA	DOOR CONTACT	679-05HM	BLK	SCE

DOOR OPERATION: Door position switch to be connected to access control system for monitoring.

Hardware Set No. 110

For use on door #(s):
C107/2 C120/1

Provide each PR door(s) with the following:

Qty		Description	Catalog Number	Finish	Mfr
2	EA	CONT. HINGE	224HD	628	IVE
2	EA	MANUAL FLUSH BOLT	FB458	626	IVE
1	EA	STOREROOM LOCK	LV9080T 17A	626	SCH
1	EA	FSIC CORE	23-030	626	SCH
2	EA	OH STOP & HOLDER	90H	630	GLY
2	EA	SURFACE CLOSER	4040XP EDA TBSRT x ST2731	689	LCN
2	EA	KICK PLATE	8400 10" X 1" LDW B4E	630	IVE
1	SET	SEALS	5050B	BRN	NGP
1	SET	ASTRAGAL	140PA	CL	NGP
2	EA	DOOR SWEEP	C627A	CL	NGP
1	EA	THRESHOLD	896S	AL	NGP
2	EA	DOOR CONTACT	679-05HM	BLK	SCE

DOOR OPERATION: Door position switch to be connected to access control system for monitoring.

Hardware Set No. 111

For use on door #(s):
C128/1

Provide each SGL door(s) with the following:

Qty		Description	Catalog Number	Finish	Mfr
1	EA	CONT. HINGE	112HD EPT	628	IVE
1	EA	ELEC PANIC HARDWARE	RX-98-L-E996-17-FSE	626	VON
1	EA	FSIC CORE	23-030	626	SCH
1	EA	KICK PLATE	8400 10" X 2" LDW B4E	630	IVE
1	EA	DRIP CAP	17	AL	NGP
1	SET	SEALS	5050B	BRN	NGP
1	EA	THRESHOLD	896S	AL	NGP
1	EA	DOOR CONTACT	679-05HM	BLK	SCE
			CARD READER BY OTHERS		

DOOR OPERATION: Door normally closed and secure. Entry from secure side by valid credential or key override which will unlock electrified door. Free egress from inside at all times. Door position switch and request to exit connected to access control system for monitoring.

Hardware Set No. 112

For use on door #(s):
C105/1 C106/2

Provide each PR door(s) with the following:

Qty		Description	Catalog Number	Finish	Mfr
2	EA	CONT. HINGE	224HD	628	IVE
1	EA	KEYED REMOVABLE MULLION	KR4954-STAB	689	VON
1	EA	PANIC HARDWARE	CD-98-EO	626	VON
3	EA	MORTISE CYLINDER	20-061-ICX	626	SCH
3	EA	FSIC CORE	23-030	626	SCH
2	EA	OH STOP	90S	630	GLY
2	EA	SURFACE CLOSER	4040XP EDA TBSRT x ST2731	689	LCN
2	EA	KICK PLATE	8400 10" X 2" LDW B4E	630	IVE
1	EA	DRIP CAP	17	AL	NGP
1	SET	SEALS	5050B	BRN	NGP
1	EA	MULLION SEAL	5100	BLK	NGP
2	EA	DOOR SWEEP	C627A	CL	NGP
1	EA	THRESHOLD	896S	AL	NGP
2	EA	DOOR CONTACT	679-05HM	BLK	SCE

DOOR OPERATION: Door position switch to be connected to access control system for monitoring.

Hardware Set No. 113

For use on door #(s):
C124/1

Provide each SGL door(s) with the following:

Qty		Description	Catalog Number	Finish	Mfr
1	EA	CONT. HINGE	224HD	628	IVE
1	EA	PRIVACY W/DB & IND	LV9496T 17A L583-363	626	SCH
1	EA	FSIC CORE	23-030	626	SCH
1	EA	OH STOP	90S	630	GLY
1	EA	SURFACE CLOSER	4040XP EDA TBSRT	689	LCN
1	EA	KICK PLATE	8400 10" X 2" LDW B4E	630	IVE
1	EA	DRIP CAP	17	AL	NGP
1	SET	SEALS	5050B	BRN	NGP
1	EA	DOOR SWEEP	C627A	CL	NGP
1	EA	THRESHOLD	896S	AL	NGP

Hardware Set No. 114

For use on door #(s):
C100F/2

Provide each PR door(s) with the following:

Qty	Description	Catalog Number	Finish	Mfr

2	EA	CONT. HINGE	224HD	628	IVE
1	EA	KEYED REMOVABLE MULLION	KR4954-STAB	689	VON
2	EA	PANIC HARDWARE	CD-98-EO	626	VON
3	EA	MORTISE CYLINDER	20-061-ICX	626	SCH
3	EA	FSIC CORE	23-030	626	SCH
2	EA	90 DEG OFFSET PULL	8190 18" O	630	IVE
2	EA	OH STOP	100S	630	GLY
2	EA	SURFACE CLOSER	4040XP EDA TBSRT	689	LCN
1	EA	MULLION SEAL	5100	BLK	NGP
1	EA	THRESHOLD	896S	AL	NGP
2	EA	DOOR CONTACT	679-05HM	BLK	SCE

DOOR OPERATION: Door position switch to be connected to access control system for monitoring.

Hardware Set No. 200

For use on door #(s):

C100A/2 D114/1 D114/3 D201A/1

Provide each PR door(s) with the following:

Qty		Description	Catalog Number	Finish	Mfr
2	EA	CONT. HINGE	715	630	IVE
2	EA	FIRE EXIT HARDWARE	9849-L-BE-F-996-17-LBL	626	VON
2	EA	SURFACE CLOSER	4040XP EDA TBSRT	689	LCN
2	EA	KICK PLATE	8400 10" X 1" LDW B4E	630	IVE
2	EA	FIRE/LIFE WALL MAG	SEM1980	689	LCN
1	SET	SEALS	5020B	BRN	NGP
1	SET	SEALS	5060B	BRN	NGP

Door held open by wall magnets connected to fire alarm system.

Hardware Set No. 300 Classrooms

For use on door #(s):

B101/1	B102/1	B103/1	B104/1	B105A/1	B105D/1
B105E/1	B106/1	B107/1	B108/1	B109/1	B110/1
B112/1	C125/1	D101/1	D102/1	D103/1	D104/1
D105/1	D107/1	D107B/2	D109/1	D110/1	D111/1
D112/1	D113/1	D200C/1	D201/1	D203/1	D204/1.D202/1
D205/1	D207/1	D207C/1	D207E/1	D209/1	D210/1
D211/1	D212/1	D213/1			

Provide each SGL door(s) with the following:

Qty		Description	Catalog Number	Finish	Mfr
3	EA	HW HINGE	5BB1HW 4.5 X 4.5 NRP	652	IVE
1	EA	CLASSROOM SECURITY	L9071T 17A	626	SCH
2	EA	FSIC CORE	23-030	626	SCH
1	EA	SURFACE CLOSER	4040XP EDA TBSRT	689	LCN
1	EA	KICK PLATE	8400 10" X 2" LDW B4E	630	IVE
1	EA	WALL STOP/HOLDER	FS495	626	IVE
3	EA	SILENCER	SR64	GRY	IVE

Hardware Set No. 301

For use on door #(s):
A101/1

Provide each SGL door(s) with the following:

Qty		Description	Catalog Number	Finish	Mfr
3	EA	HW HINGE	5BB1HW 4.5 X 4.5 NRP	652	IVE
1	EA	CLASSROOM X STORERM	ND70X80TD SPA	626	SCH
2	EA	FSIC CORE	23-030	626	SCH
1	EA	SURFACE CLOSER	4040XP EDA TBSRT	689	LCN
1	EA	KICK PLATE	8400 10" X 2" LDW B4E	630	IVE
1	EA	WALL STOP	WS406CCV	630	IVE
3	EA	SILENCER	SR64	GRY	IVE

DOOR OPERATION: Door normally closed and secure from the waiting room. Entry from waiting room into corridor by valid credential or key override which will unlock electrified door. Free egress from inside at all times. Door position switch and request to exit connected to access control system for monitoring. Corridor side of lock is equipped with a classroom function and can be unlocked during the day for entry into the waiting area.

Hardware Set No. 302

For use on door #(s):
A102/1 A105/1 A106/1 A107/1 A109/1 A110/1
C108/1

Provide each SGL door(s) with the following:

Qty		Description	Catalog Number	Finish	Mfr
3	EA	HINGE	5BB1 4.5 X 4.5	652	IVE
1	EA	OFFICE/ENTRY LOCK	L9050T 17A	626	SCH
1	EA	FSIC CORE	23-030	626	SCH
1	EA	WALL STOP	WS406CCV	630	IVE
3	EA	SILENCER	SR64	GRY	IVE

Hardware Set No. 303

For use on door #(s):
A111/1

Provide each SGL door(s) with the following:

Qty		Description	Catalog Number	Finish	Mfr
3	EA	HINGE	5BB1 4.5 X 4.5	652	IVE
1	EA	OFFICE/ENTRY LOCK	L9050T 17A	626	SCH
1	EA	FSIC CORE	23-030	626	SCH
1	EA	SURFACE CLOSER	4040XP TBSRT	689	LCN
1	EA	KICK PLATE	8400 10" X 2" LDW B4E	630	IVE
1	EA	WALL STOP/HOLDER	FS495	626	IVE
1	SET	SEALS	5020B	BRN	NGP

Hardware Set No. 304

For use on door #(s):
A101A/1

Provide each SGL door(s) with the following:

Qty		Description	Catalog Number	Finish	Mfr
3	EA	HW HINGE	5BB1HW 4.5 X 4.5 NRP	652	IVE
1	EA	CLASSROOM SECURITY	L9071T 17A	626	SCH
2	EA	FSIC CORE	23-030	626	SCH
1	EA	SURFACE CLOSER	4040XP EDA TBSRT	689	LCN
1	EA	KICK PLATE	8400 10" X 2" LDW B4E	630	IVE
3	EA	SILENCER	SR64	GRY	IVE

Hardware Set No. 305

For use on door #(s):
A112/2

Provide each SGL door(s) with the following:

Qty		Description	Catalog Number	Finish	Mfr
3	EA	HINGE	5BB1 4.5 X 4.5 NRP	652	IVE
1	EA	CLASSROOM LOCK	L9070T 17A	626	SCH
1	EA	FSIC CORE	23-030	626	SCH
1	EA	WALL STOP	WS406CCV	630	IVE
3	EA	SILENCER	SR64	GRY	IVE

Hardware Set No. 306

For use on door #(s):
A112/1

Provide each SGL door(s) with the following:

Qty		Description	Catalog Number	Finish	Mfr
3	EA	HW HINGE	5BB1HW 4.5 X 4.5	652	IVE
1	EA	CLASSROOM SECURITY	L9071T 17A	626	SCH
2	EA	FSIC CORE	23-030	626	SCH
1	EA	SURFACE CLOSER	4040XP TBSRT	689	LCN
1	EA	KICK PLATE	8400 10" X 2" LDW B4E	630	IVE
1	EA	WALL STOP	WS406CCV	630	IVE
3	EA	SILENCER	SR64	GRY	IVE

Hardware Set No. 307

For use on door #(s):
A100D/1 B100B/1 D100A/1 D200A/1

Provide each PR door(s) with the following:

Qty		Description	Catalog Number	Finish	Mfr
6	EA	HINGE	5BB1 4.5 X 4.5 NRP	652	IVE
1	SET	AUTO FLUSH BOLT	FB41P	630	IVE

1	EA	DUST PROOF STRIKE	DP2	626	IVE
1	EA	STOREROOM LOCK	L9080T 17A	626	SCH
1	EA	FSIC CORE	23-030	626	SCH
1	EA	COORDINATOR	COR X FL	628	IVE
2	EA	MOUNTING BRACKET	MB	689	IVE
2	EA	SURFACE CLOSER	4040XP EDA TBSRT	689	LCN
2	EA	KICK PLATE	8400 10" X 1" LDW B4E	630	IVE
1	SET	SEALS	5020B	BRN	NGP
1	SET	SEALS	5060B	BRN	NGP

Hardware Set No. 308

For use on door #(s):
A113/1

Provide each SGL door(s) with the following:

Qty		Description	Catalog Number	Finish	Mfr
3	EA	HW HINGE	5BB1HW 4.5 X 4.5	652	IVE
1	EA	CLASSROOM SECURITY	L9071T 17A	626	SCH
2	EA	FSIC CORE	23-030	626	SCH
1	EA	SURFACE CLOSER	4040XP TBSRT	689	LCN
1	EA	KICK PLATE	8400 10" X 2" LDW B4E	630	IVE
1	EA	WALL STOP/HOLDER	FS495	626	IVE
3	EA	SILENCER	SR64	GRY	IVE

Hardware Set No. 309

For use on door #(s):
A113C/1

Provide each SGL door(s) with the following:

Qty		Description	Catalog Number	Finish	Mfr
3	EA	HINGE	5BB1 4.5 X 4.5	652	IVE
1	EA	PASSAGE SET	L9010 17A	626	SCH
1	EA	MOP PLATE	8400 4" X 1" LDW B4E	630	IVE
1	EA	WALL STOP	WS406CCV	630	IVE
3	EA	SILENCER	SR64	GRY	IVE

Hardware Set No. 310

For use on door #(s):
A113A/1

Provide each SGL door(s) with the following:

Qty		Description	Catalog Number	Finish	Mfr
3	EA	HINGE	5BB1 4.5 X 4.5	652	IVE
1	EA	STOREROOM LOCK	L9080T 17A	626	SCH
1	EA	FSIC CORE	23-030	626	SCH
1	EA	OH STOP	90S J	630	GLY
3	EA	SILENCER	SR64	GRY	IVE

Hardware Set No. 311

For use on door #(s):
A104/1 A117/1 A120A/1 B105G/1 D107D/1 D207G/1

Provide each SGL door(s) with the following:

Qty		Description	Catalog Number	Finish	Mfr
3	EA	HW HINGE	5BB1HW 4.5 X 4.5	652	IVE
1	EA	PRIVACY W/DB & IND	L9496T OCCUPIED/VACANT 17A	626	SCH
1	EA	FSIC CORE	23-030	626	SCH
1	EA	SURFACE CLOSER	4040XP EDA TBSRT	689	LCN
1	EA	KICK PLATE	8400 10" X 2" LDW B4E	630	IVE
1	EA	WALL STOP	WS406CCV	630	IVE
1	SET	SEALS	5020B	BRN	NGP

Hardware Set No. 312

For use on door #(s):
A113B/1

Provide each SGL door(s) with the following:

Qty		Description	Catalog Number	Finish	Mfr
3	EA	HINGE	5BB1 4.5 X 4.5	652	IVE
1	EA	PRIVACY LOCK	L9040 17A	626	SCH
1	EA	WALL STOP	WS406CCV	630	IVE
3	EA	SILENCER	SR64	GRY	IVE

Hardware Set No. 313

For use on door #(s):
C110/2

Provide each SGL door(s) with the following:

Qty		Description	Catalog Number	Finish	Mfr
3	EA	HW HINGE	5BB1HW 4.5 X 4.5 NRP	652	IVE
1	EA	FIRE EXIT HARDWARE	98-L-NL-F-996-17	626	VON
1	EA	RIM CYLINDER	20-057-ICX	626	SCH
1	EA	FSIC CORE	23-030	626	SCH
1	EA	SURFACE CLOSER	4040XP CUSH	689	LCN
1	EA	KICK PLATE	8400 10" X 2" LDW B4E	630	IVE
1	SET	SEALS	5020B	BRN	NGP

Hardware Set No. 314

For use on door #(s):
C109/1 D107C/1

Provide each SGL door(s) with the following:

Qty	Description	Catalog Number	Finish	Mfr

3	EA	HINGE	5BB1 4.5 X 4.5 NRP	652	IVE
1	EA	STOREROOM LOCK	L9080T 17A	626	SCH
1	EA	FSIC CORE	23-030	626	SCH
1	EA	OH STOP	90S	630	GLY
3	EA	SILENCER	SR64	GRY	IVE

Hardware Set No. 315

For use on door #(s):
C100E/1 C107/1 D100B/1 D200B/1

Provide each SGL door(s) with the following:

Qty		Description	Catalog Number	Finish	Mfr
3	EA	HW HINGE	5BB1HW 4.5 X 4.5 NRP	652	IVE
1	EA	STOREROOM LOCK	L9080T 17A	626	SCH
1	EA	FSIC CORE	23-030	626	SCH
1	EA	SURFACE CLOSER	4040XP EDA TBSRT	689	LCN
1	EA	KICK PLATE	8400 10" X 2" LDW B4E	630	IVE
1	EA	WALL STOP	WS406CCV	630	IVE
1	SET	SEALS	5020B	BRN	NGP

Hardware Set No. 316

For use on door #(s):
C104/1 C106/1

Provide each SGL door(s) with the following:

Qty		Description	Catalog Number	Finish	Mfr
3	EA	HW HINGE	5BB1HW 4.5 X 4.5 NRP	652	IVE
1	EA	CLASSROOM SECURITY	L9071T 17A	626	SCH
2	EA	FSIC CORE	23-030	626	SCH
1	EA	SURFACE CLOSER	4040XP CUSH	689	LCN
1	EA	KICK PLATE	8400 10" X 2" LDW B4E	630	IVE
3	EA	SILENCER	SR64	GRY	IVE

Hardware Set No. 317 MDF

For use on door #(s):
A116/1 B105F/1 C100G/1 D107B/1 D207F/1

Provide each SGL door(s) with the following:

Qty		Description	Catalog Number	Finish	Mfr
3	EA	HINGE	5BB1 4.5 X 4.5 NRP	652	IVE
1	EA	STOREROOM LOCK	L9080T 17A	626	SCH
1	EA	FSIC CORE	23-030	626	SCH
1	EA	ELECTRIC STRIKE	6211 FSE DS	630	VON
1	EA	SURFACE CLOSER	4040XP CUSH	689	LCN
1	EA	KICK PLATE	8400 10" X 2" LDW B4E	630	IVE
3	EA	SILENCER	SR64	GRY	IVE
1	EA	DOOR CONTACT	679-05HM	BLK	SCE
1	EA	POWER SUPPLY	PS902 KL900	LGR	SCE
			CARD READER BY OTHERS		

DOOR OPERATION: Door normally closed and secure. Entry from secure side by valid credential or key override which will unlock electrified door. Free egress from inside at all times. Door position switch and request to exit connected to access control system for monitoring.

Hardware Set No. 318

For use on door #(s):
A118/1 A119/1

Provide each SGL door(s) with the following:

Qty		Description	Catalog Number	Finish	Mfr
3	EA	HINGE	5BB1 4.5 X 4.5	652	IVE
1	EA	OFFICE/ENTRY LOCK	L9050T 17A	626	SCH
1	EA	FSIC CORE	23-030	626	SCH
1	EA	OH STOP	90S J	630	GLY
3	EA	SILENCER	SR64	GRY	IVE

Hardware Set No. 319

For use on door #(s):
A115/1

Provide each PR door(s) with the following:

Qty		Description	Catalog Number	Finish	Mfr
2	EA	CONT. HINGE	224HD	628	IVE
1	EA	PANIC HARDWARE	CD-9849-EO-LBL	626	VON
1	EA	PANIC HARDWARE	CD-9849-NL-OP-110-LBL	626	VON
1	EA	RIM CYLINDER	20-057-ICX	626	SCH
2	EA	MORTISE CYLINDER	20-061-ICX	626	SCH
3	EA	FSIC CORE	23-030	626	SCH
2	EA	90 DEG OFFSET PULL	8190 10" O	630	IVE
2	EA	SURFACE CLOSER	4040XP HCUSH TBSRT	689	LCN

Hardware Set No. 320

For use on door #(s):
C114/1 C114/2 C121/1

Provide each PR door(s) with the following:

Qty		Description	Catalog Number	Finish	Mfr
2	EA	CONT. HINGE	224HD	628	IVE
1	EA	KEYED FIRE RATED REMOVABLE MULLION	KR9954-STAB	689	VON
2	EA	FIRE EXIT HARDWARE	98-L-F-2-996-17	626	VON
4	EA	RIM CYLINDER	20-057-ICX	626	SCH
1	EA	MORTISE CYLINDER	20-061-ICX	626	SCH
5	EA	FSIC CORE	23-030	626	SCH
2	EA	SURFACE CLOSER	4040XP CUSH	689	LCN
2	EA	KICK PLATE	8400 10" X 2" LDW B4E	630	IVE
1	SET	SEALS	5020B	BRN	NGP
1	SET	SEALS	5060B	BRN	NGP

1	EA	MULLION SEAL	5100	BLK	NGP

Hardware Set No. 321

For use on door #(s):
C123/1

Provide each SGL door(s) with the following:

Qty		Description	Catalog Number	Finish	Mfr
3	EA	HW HINGE	5BB1HW 4.5 X 4.5 NRP	652	IVE
1	EA	CLASSROOM SECURITY	L9071T 17A	626	SCH
2	EA	FSIC CORE	23-030	626	SCH
1	EA	MOUNTING BRACKET	MB	689	IVE
1	EA	SURFACE CLOSER	4040XP EDA TBSRT	689	LCN
1	EA	KICK PLATE	8400 10" X 2" LDW B4E	630	IVE
1	EA	WALL STOP/HOLDER	FS495	626	IVE
1	SET	SEALS	107NA	CL	NGP
1	EA	DOOR BOTTOM	522N	AL	NGP

INSTALLATION NOTE: Mount 107NA sound seal and MB mounting bracket prior to installing door closer. Note closer is lower on the door to accommodate sound seal.

Hardware Set No. 322

For use on door #(s):
C123A/1 C123A/2

Provide each SGL door(s) with the following:

Qty		Description	Catalog Number	Finish	Mfr
3	EA	HINGE	5BB1 4.5 X 4.5 NRP	652	IVE
1	EA	CLASSROOM LOCK	L9070T 17A	626	SCH
1	EA	FSIC CORE	23-030	626	SCH
1	EA	SURFACE CLOSER	4041 DEL CUSH	689	LCN
1	EA	KICK PLATE	8400 10" X 2" LDW B4E	630	IVE
1	SET	SEALS	5020B	BRN	NGP

Hardware Set No. 323

For use on door #(s):
C125A/1 C125B/1

Provide each SGL door(s) with the following:

Qty		Description	Catalog Number	Finish	Mfr
3	EA	HINGE	5BB1 4.5 X 4.5 NRP	652	IVE
1	EA	CLASSROOM LOCK	L9070T 17A	626	SCH
1	EA	FSIC CORE	23-030	626	SCH
1	EA	OH STOP	90S	630	GLY
3	EA	SILENCER	SR64	GRY	IVE

Hardware Set No. 324

For use on door #(s):
C118/1

Provide each SGL door(s) with the following:

Qty		Description	Catalog Number	Finish	Mfr
3	EA	HINGE	5BB1 4.5 X 4.5 NRP	652	IVE
1	EA	OFFICE/ENTRY LOCK	L9050T 17A	626	SCH
1	EA	FSIC CORE	23-030	626	SCH
1	EA	SURFACE CLOSER	4040XP CUSH	689	LCN
1	EA	KICK PLATE	8400 10" X 2" LDW B4E	630	IVE
1	SET	SEALS	5020B	BRN	NGP

Hardware Set No. 325

For use on door #(s):
C115/1 C117/1

Provide each PR door(s) with the following:

Qty		Description	Catalog Number	Finish	Mfr
6	EA	HW HINGE	5BB1HW 4.5 X 4.5 NRP	652	IVE
1	SET	AUTO FLUSH BOLT	FB31P	630	IVE
1	EA	DUST PROOF STRIKE	DP2	626	IVE
1	EA	STOREROOM LOCK	L9080T 17A	626	SCH
1	EA	FSIC CORE	23-030	626	SCH
1	EA	COORDINATOR	COR X FL	628	IVE
2	EA	MOUNTING BRACKET	MB	689	IVE
2	EA	SURFACE CLOSER	4041 DEL CUSH	689	LCN
2	EA	KICK PLATE	8400 16" X 1" LDW B4E	630	IVE
1	SET	SEALS	5020B	BRN	NGP
1	SET	SEALS	5060B	BRN	NGP

Hardware Set No. 326

For use on door #(s):
C122/1

Provide each PR door(s) with the following:

Qty		Description	Catalog Number	Finish	Mfr
2	EA	CONT. HINGE	715	630	IVE
1	SET	AUTO FLUSH BOLT	FB31P	630	IVE
1	EA	DUST PROOF STRIKE	DP2	626	IVE
1	EA	CLASSROOM LOCK	L9070T 17A	626	SCH
1	EA	FSIC CORE	23-030	626	SCH
1	EA	COORDINATOR	COR X FL	628	IVE
2	EA	MOUNTING BRACKET	MB	689	IVE
2	EA	SURFACE CLOSER	4041 DEL CUSH	689	LCN
2	EA	KICK PLATE	8400 16" X 1" LDW B4E	630	IVE
1	SET	SEALS	5020B	BRN	NGP
1	SET	SEALS	5060B	BRN	NGP

Hardware Set No. 327

For use on door #(s):
C111A/1

Provide each SGL door(s) with the following:

Qty		Description	Catalog Number	Finish	Mfr
3	EA	HW HINGE	5BB1HW 4.5 X 4.5 NRP	652	IVE
1	EA	STOREROOM LOCK	L9080T 17A	626	SCH
1	EA	FSIC CORE	23-030	626	SCH
1	EA	SURFACE CLOSER	4041 DEL CUSH	689	LCN
1	EA	KICK PLATE	8400 16" X 1" LDW B4E	630	IVE
1	SET	SEALS	5020B	BRN	NGP

Hardware Set No. 328

For use on door #(s):
C126/1 C126/2

Provide each SGL door(s) with the following:

Qty		Description	Catalog Number	Finish	Mfr
3	EA	HW HINGE	5BB1HW 4.5 X 4.5 NRP	652	IVE
1	EA	CLASSROOM DEAD LOCK	L463T	626	SCH
1	EA	FSIC CORE	23-030	626	SCH
1	EA	PUSH PLATE	8200 4" X 16"	630	IVE
1	EA	PULL PLATE	8303 10" 4" X 16"	630	IVE
1	EA	SURFACE CLOSER	4040XP EDA TBSRT	689	LCN
1	EA	KICK PLATE	8400 10" X 2" LDW B4E	630	IVE
1	EA	MOP PLATE	8400 4" X 1" LDW B4E	630	IVE
1	EA	WALL STOP/HOLDER	FS495	626	IVE
3	EA	SILENCER	SR64	GRY	IVE

Hardware Set No. 329

For use on door #(s):
C112/1

Provide each SGL door(s) with the following:

Qty		Description	Catalog Number	Finish	Mfr
1	EA	CONT. HINGE	224HD	628	IVE
1	EA	CLASSROOM SECURITY	L9071T 17A	626	SCH
2	EA	FSIC CORE	23-030	626	SCH
1	EA	SURFACE CLOSER	4040XP HCUSH TBSRT	689	LCN

Hardware Set No. 330

For use on door #(s):

C127/1

Provide each SGL door(s) with the following:

Qty		Description	Catalog Number	Finish	Mfr
3	EA	HINGE	5BB1 4.5 X 4.5 NRP	652	IVE
1	EA	OFFICE/ENTRY LOCK	L9050T 17A	626	SCH
1	EA	FSIC CORE	23-030	626	SCH
1	EA	MOP PLATE	8400 4" X 1" LDW B4E	630	IVE
1	EA	KICK PLATE	8400 4" X 2" LDW B4E	630	IVE
1	EA	WALL STOP	WS406CCV	630	IVE

Hardware Set No. 331

For use on door #(s):
C132/1

Provide each SGL door(s) with the following:

Qty		Description	Catalog Number	Finish	Mfr
3	EA	HW HINGE	5BB1HW 4.5 X 4.5	652	IVE
1	EA	PUSH PLATE	8200 4" X 16"	630	IVE
1	EA	PULL PLATE	8303 10" 4" X 16"	630	IVE
1	EA	SURFACE CLOSER	4040XP EDA TBSRT	689	LCN
1	EA	KICK PLATE	8400 10" X 2" LDW B4E	630	IVE
1	EA	MOP PLATE	8400 4" X 1" LDW B4E	630	IVE
1	EA	KICK PLATE	8400 4" X 2" LDW B4E	630	IVE
1	EA	WALL STOP	WS406CCV	630	IVE
3	EA	SILENCER	SR64	GRY	IVE

Hardware Set No. 332

For use on door #(s):
C133/1

Provide each SGL door(s) with the following:

Qty		Description	Catalog Number	Finish	Mfr
3	EA	HW HINGE	5BB1HW 4.5 X 4.5	652	IVE
1	EA	PRIVACY W/DB & IND	LV9496T 17A L583-363	626	SCH
1	EA	FSIC CORE	23-030	626	SCH
1	EA	SURFACE CLOSER	4040XP TBSRT	689	LCN
1	EA	KICK PLATE	8400 10" X 2" LDW B4E	630	IVE
1	EA	MOP PLATE	8400 4" X 1" LDW B4E	630	IVE
1	EA	WALL STOP	WS406CCV	630	IVE
3	EA	SILENCER	SR64	GRY	IVE

Hardware Set No. 333

For use on door #(s):
C131/1

Provide each SGL door(s) with the following:

Qty	Description	Catalog Number	Finish	Mfr

3	EA	HW HINGE	5BB1HW 4.5 X 4.5	652	IVE
1	EA	CLASSROOM LOCK	L9070T 17A	626	SCH
1	EA	FSIC CORE	23-030	626	SCH
1	EA	OH STOP	90S	630	GLY
1	EA	KICK PLATE	8400 10" X 2" LDW B4E	630	IVE
1	EA	MOP PLATE	8400 4" X 1" LDW B4E	630	IVE
3	EA	SILENCER	SR64	GRY	IVE

Hardware Set No. 334

For use on door #(s):
C114A/1 C201/1

Provide each SGL door(s) with the following:

Qty		Description	Catalog Number	Finish	Mfr
3	EA	HW HINGE	5BB1HW 4.5 X 4.5	652	IVE
1	EA	STOREROOM LOCK	L9080T 17A	626	SCH
1	EA	FSIC CORE	23-030	626	SCH
1	EA	SURFACE CLOSER	4041 DEL	689	LCN
1	EA	KICK PLATE	8400 10" X 2" LDW B4E	630	IVE
1	EA	MOP PLATE	8400 4" X 1" LDW B4E	630	IVE
1	EA	WALL STOP	WS406CCV	630	IVE
1	SET	SEALS	5020B	BRN	NGP

Hardware Set No. 335

For use on door #(s):
B105C/1 D207D/1

Provide each SGL door(s) with the following:

Qty		Description	Catalog Number	Finish	Mfr
3	EA	HINGE	5BB1 4.5 X 4.5	652	IVE
1	EA	CLASSROOM LOCK	L9070T 17A	626	SCH
1	EA	FSIC CORE	23-030	626	SCH
1	EA	WALL STOP	WS406CCV	630	IVE
3	EA	SILENCER	SR64	GRY	IVE

Hardware Set No. 336

For use on door #(s):
B105B/1 D207B/1

Provide each PR door(s) with the following:

Qty		Description	Catalog Number	Finish	Mfr
6	EA	HINGE	5BB1 4.5 X 4.5 NRP	652	IVE
2	EA	MANUAL FLUSH BOLT	FB458	626	IVE
1	EA	DUST PROOF STRIKE	DP2	626	IVE
1	EA	STOREROOM LOCK	L9080T 17A	626	SCH
1	EA	FSIC CORE	23-030	626	SCH
2	EA	OH STOP	90S	630	GLY
2	EA	SILENCER	SR64	GRY	IVE

Hardware Set No. 337

For use on door #(s):

B101A/1	B102A/1	B103A/1	B104A/1	B106A/1	B107A/1
B108A/1	B109A/1	B110A/1	B112A/1		

Provide each DD door(s) with the following:

Qty		Description	Catalog Number	Finish	Mfr
4	EA	HW HINGE	5BB1HW 4.5 X 4.5	652	IVE
1	EA	DUTCH DOOR BOLT	054	626	IVE
1	EA	PASSAGE SET	L9010 17A	626	SCH
1	EA	FSIC CORE	23-030	626	SCH
1	EA	WALL STOP	WS406CCV	630	IVE
4	EA	SILENCER	SR64	GRY	IVE

Hardware Set No. 338

For use on door #(s):

A120/1

Provide each SGL door(s) with the following:

Qty		Description	Catalog Number	Finish	Mfr
3	EA	HW HINGE	5BB1HW 4.5 X 4.5	652	IVE
1	EA	CLASSROOM SECURITY	L9071T 17A	626	SCH
2	EA	FSIC CORE	23-030	626	SCH
1	EA	SURFACE CLOSER	4040XP TBSRT	689	LCN
1	EA	KICK PLATE	8400 10" X 2" LDW B4E	630	IVE
1	EA	WALL STOP/HOLDER	FS495	626	IVE
3	EA	SILENCER	SR64	GRY	IVE

End Of Section