

ADDENDUM NO. 1 (6-27-13)
CAESAR RODNEY TENNIS COURT RENOVATIONS
CONTRACT # 95-10-2013-01

Front End Specifications

1. The attached list of attendees at the pre-bid meeting held on June 25, 2013 are the eligible bidders for this project.
2. The bid form has been revised per the attached. The bid due date, unit prices and subcontractor categories have been added.
3. The bids are due on July 11, 2013 by 2:00 P.M. at the Caesar Rodney District office at 7 Front Street in Wyoming, Delaware. The bids will be publically opened at the deadline time.
4. Bond forms are to be included with the bids.
5. In order to perform work on the project, the Contractor must have a business license from the State of Delaware and the Town of Camden.
6. All substitution requests are due by July 1, 2013.
7. A two (2) year warranty is required on the proposed construction.
8. An insurance certificate is required upon execution of the Contract.
9. 5% retainage will be held on all monthly invoices.

Site Plans

10. Portable bathrooms are to be provided by the Contractor.
11. The school district will provide compaction testing review.
12. The Contractor does not need to provide any nets. The school district will provide the nets to be installed by the Contractor.
13. DelDOT approved truncated domes will need to be installed at a location to be specified by the Owner.
14. A minimum of three inches (3) of new graded aggregate type B shall be placed at the top of the base layer throughout the entire proposed tennis court section. A mixture of the existing millings and base materials can be used in the base layer below the top three (3) inches. A minimum 6" total base thickness is required for the entire proposed court section.

15. The base bid is to include all graded aggregate, excavation and fill necessary to obtain the proposed grades. The unit prices are only applicable if the existing stone base thicknesses specified on the Existing Conditions – Demolition Plan are inaccurate or the existing soil subgrade needs to be removed because it is structurally inadequate. A representative from the school district or the Engineer will need to verify the inaccuracy of the stone base thickness or the existing subgrade unsuitability.

TENNIS COURT RENOVATIONS
CAESAR RODNEY HIGH SCHOOL
CONTRACT # 95-10-2013-01

BID FORM

UNIT PRICES

Unit prices conform to applicable project specification section. Refer to the specifications for a complete description of the following Unit Prices:

	<u>ADD</u>	<u>DEDUCT</u>
UNIT PRICE No. 1: <u>Graded Aggregate Base Course Type B (cy)</u>	\$ _____	\$ _____
UNIT PRICE No. 2: <u>Subgrade Excavation and disposal (cy)</u>	\$ _____	\$ _____
UNIT PRICE No. 3: <u>Select Borrow Fill Type G (cy)</u>	\$ _____	\$ _____

The base bid is to include all graded aggregate, excavation and fill necessary to obtain the proposed grades. The unit prices are only applicable if the existing stone base material thicknesses specified on the Existing Conditions – Demolition Plan are inaccurate or the existing soil subgrade needs to be removed because it is structurally inadequate. A representative from the school district or the Engineer will need to verify the inaccuracy of the stone base thickness or the existing subgrade unsuitability.