

**Addendum  
No. 3**

Date: April 3, 2018

Project: CRSD Charlton School Renovations Phase 2  
Secured Entry & HVAC Renovations  
SRS-18005-ChRen2

---

The work herein shall be considered part of the bid documents for the referenced project and carried out in accordance with the following supplemental instructions issued in accordance with the Contract Documents without change in Contract Sum or Contract Time. Acknowledge receipt of addendum on the bid form as indicated.

---

**RFI Responses**

1. **Question:** Please verify the following:
  - a. All new HVAC systems serving Allen Frear ES are to be an extension of the existing Johnson Controls Metasys (by MCI) building automation system located in Allen Frear ES.
  - b. All new HVAC systems serving John S. Charlton School are to be an extension of the existing Johnson Controls FX (by MCI) building automation system located in John S. Charlton School.

**Answer:** Correct. The units located over Allen Frear should be tied into the existing JCI Metasys system, while the units located over the Charlton School should be tied into the recently installed JACE.

2. **Question:** Please verify that Spec 23 09 23 Note "Replacement of the existing DDC system is to be included in Alternate #1. Base scope of work shall include integration of new HVAC equipment into existing building

**Clarifications**

1. Flooring Color

**Changes to Drawings**

1. A3.3 – CORRIDOR AND CAFETERIA FLOOR REPLACEMENT  
Add scope to demolish existing recessed walk-off matts, infill floor and install new modular entrance floor system.  
See attached revised drawing A3.3.

**End**