

**SUSSEX TECHNICAL SCHOOL DISTRICT  
Sussex Technical High School – Bleacher Replacement  
Bid Number SUS-18-001-STHS Bleacher Replacement**

ADDENDUM NO. 2                      14 February 2018

Sussex Technical School District  
Sussex Technical High School  
17099 County Seat Highway  
Georgetown, DE 19947

Fearn-Clendaniel Architects, Inc.  
6 Larch Avenue Suite 398  
Wilmington, Delaware, 19804  
Phone: (302) 998-7615

BIDS DUE:                              **3:00 p.m. on February 20, 2018**

LOCATION:                                **Sussex Technical School District Administrative Offices  
17099 County Seat Highway, Georgetown, DE 19947**

ARCHITECT'S PROJECT NO: 17111

**1.0 NOTICE TO ALL BIDDERS:**

- 1.1. Bidders are hereby notified that this Addendum shall be and hereby becomes part of their Contract Documents, and shall be attached to the Project Manual for this project.
- 1.2. The following items are intended to revise and clarify the Contract Documents, and shall be included by the Bidder in their proposal.
- 1.3. Bidders shall verify that their sub-bidders are in full receipt of the information contained herein.

**2.0 QUESTIONS:**

2.1 **Q:** Section 126600, paragraph 1.8.C specifies a comprehensive analysis by a qualified engineer. Can you confirm if the shop drawings will need to be stamped by a Delaware PE?

**A:** the qualified engineer analysis does not need to be a Delaware licensed Professional Engineer.

2.2 **Q:** Section 126600, paragraph 2.3.C specifies the decking be ¾" thick, all manufacturers use 5/8" as their standard. Can you confirm that ¾" thick plywood will be required?

**A:** 5/8" thick plywood is acceptable.

Addendum No. 2

Page 2 of 2

2.3 **Q:** Section 126600, paragraph 2.4.C.4 custom logo graphics on front face of benches and end panels. The front face graphics are clear and shown on the drawings. Can you confirm that the end panel logos are the CourtSide XC10 graphic logos or equal?

**A:** Disregard logo graphics on 'end panels' of benches in section 126600, paragraph 2.4.C.4. Logos will be provided on front face of benches as indicated on drawings. End panel logos will be provided on the end-closure curtains as indicated on drawings.

2.4 **Q:** Can you confirm if a media platform rail sleeve should be provided?

**A:** Yes, please provide and install manufacture's heavy weight vinyl fabric detachable rail sleeve to cover the front face of the Announcer / Video observation platform railing. Rail sleeve to provide School Logo and School Name.

END OF ADDENDUM NO. 2