



240 Continental Drive
Suite 200
Newark, Delaware 19713
Tel. (302) 738-7551
Fax (302) 454-5980

Addendum No. 7

OWNER: Delaware Army National Guard (DEARNG)

PROJECT: **DESIGN-BUILD PROJCT – BETHANY BEACH TRAINING SITE (BBTS)
TRANSIENT TRAINING OFFICER QUARTERS**

LOCATION: Bethany Beach, Delaware

DEARNG Contract No.: 2020-16

National Guard PN No: 100103

Tt Project No. 213-76984-22001

Addendum No. 07
to
RFP Bridging Documents
November 6, 2023

To: ALL BIDDERS

This ADDENDUM forms a part of the BIDDING AND CONTRACT DOCUMENTS and modifies the following documents:

Original RFP DRAWINGS dated June 20, 2023

RFP MANUAL dated June 20, 2023

Acknowledge receipt of the ADDENDUM in the space provided on the FORM OF PROPOSAL.

This ADDENDUM consists of two (2) pages and the following:

7.1 GENERAL

- A. All questions and to purchase the RFP package, please email Tabi Heath at Tetra Tech tabi.heath@tetrattech.com. Please also copy the following addresses: michael.berninger@tetrattech.com, chuck.dobbs@tetrattech.com, ier.deng@tetrattech.com.
- B. Critical Dates:
1. **Bid Due Date: CHANGED Tuesday, January 16, 2024 @1:00pm.**
 2. **CORRECTED DATE** Cut off for questions and clarifications: **Wednesday, January 3, 2024, by COB (EST).**

7.2 REQUEST FOR PROPOSAL (RFP) & SCOPE OF WORK (SOW) MODIFICATIONS – N/A

7.3 DRAWING MODIFICATIONS - N/A

7.4 QUESTIONS/CLARIFICATIONS

Question No.1: Is the medium voltage transformer to be New or can it be Refurbished?

Response: **DEARNG recognizes the supply delay with new transformers, so they are willing to accept a refurbished unit from Delmarva Power for this project.**

Question No.2: Can the primary building shell framing for these buildings be wood?

Response: **All building shell framing can be wood. Note: Regarding the foundation system, as stated in Addendum 4, UFC 3-301-01 prohibits the use of wood for foundations.**

ATTACHMENTS - NA

END OF ADDENDUM No. 6

CC: all plan holders

O:\Projects\CBI\76984\213-76984-22001\Construction\BidSupport\23-05-25 Barrack Bid DB\Addendum #06\213-76984-22001- Addendum 6.doc