

Addendum #2

Addendum Date: July 30, 2026

Project: ARNG23006-SRCREFURB – Scannell Refurbishment

DEARNG Contract No. 2023-06 / StudioJAED Project No. 25068

The work herein shall be considered part of the bid documents for the referenced project and carried out in accordance with the following supplemental instructions issued in accordance with the Contract Documents without change in Contract Sum or Contract Time. Acknowledge receipt of addendum on the bid form as indicated.

RFIs & Responses:

1. 08 11 13 – Please provide a hardware schedule and lock requirements for door number 109.

Response: See Door Hardware Set on sheet A-601.

2. What is the existing fire alarm system?

Response: Notifier by Honeywell NFS-640.

3. Does DEARNG have a required/preferred vendor for the fire alarm upgrades/replacement?

Response: The work may be performed by any State Approved Vendor for fire alarm systems.

4. Drawing E-101 shows (8) new Wall Packs. The fixture schedule does not include a type/manufacturer. Please Clarify

Response: Added appropriate selection on sheet E-000**Changes to Drawings:****Electrical*****1. Drawing E-000***

- a. Added a wall pack selection in the lighting fixture schedule.

2. Drawing ED101

- a. Added existing exterior lights.

3. Drawing ED102

- a. Added existing exterior lights.

4. Drawing ED201

- a. Removed horn-strobe on exterior for replacement.

5. Drawing ED202

- a. Removed horn-strobe on exterior for replacement.

6. *Drawing E-102*
 - a. Added new wall pack lighting fixture.
7. *Drawing E-201*
 - a. Added horn-strobe on exterior.
8. *Drawing E-202*
 - a. Added horn-strobe on exterior.

END