

TERRY OFFICE OF THE PRESIDENT

DOVER, DELAWARE

APRIL 2025

ARCHITECT

BSA+A

95 JUSTISON STREET

WILMINGTON, DELAWARE 19801

302-658-9300

PROJECT NO 23.003

DTCC C9004060001

CONSTRUCTION MANAGER

RICHARD Y. JOHNSON & SON, INC.

18404 JOHNSON ROAD

P.O. BOX 105

LINCOLN, DELAWARE

302-422-3732

Title Page/Consultants Directory

By

Project Contacts

Owner's Representative

Delaware Technical Community College
100 Campus Drive
Dover, Delaware 19904

Architects

BSA+A
954 Justison Street
Wilmington, Delaware 19801
302-658-9300

Construction Manager

Richard Y. Johnson & Son
18404 Johnson Road
PO Box 105
Lincoln, Delaware 19960
302-422-3732/302-422-4696 fax

NOT FOR BIDDING

SECTION 000101 - TABLE OF CONTENTS

VOLUME I

DIVISION 00 – PROCUREMENT AND CONTRACTING REQUIREMENTS

000101	PROJECT CONTACTS
000111	TABLE OF CONTENTS
000115	LIST OF DRAWINGS
000113	ADVERTISEMNET FOR BIDS
002113	INSTRUCTIONS TO BIDDERS
004126	BID FORMS INCLUDING: BID FORM SUB LISTING NON-COLLUSION STATEMENT AFFIDAVIT OF EMPLOYEE DRUG TESTING PROGRAM AFFIDAVIT OF CONTRACTOR QUALIFICATIONS
004313	STATE OF DELAWARE BID BOND

CONTRACTING INFORMATION

005226	AGREEMENT INCLUDING STANDARD FORM OF AGREEMENT BETWEEN OWNER AND CONTRACTOR (AIA A132 – 2019)
005313	AMENDMENT TO CONTRACT FOR CONSTRUCTION BETWEEN DELAWARE TECHNICAL AND COMMUNITY COLLEGE AND CONTRACTOR
006113.13	STATE OF DELAWARE PERFORMANCE BOND FORM
006113.16	STATE OF DELAWARE PAYMENT BOND FORM
006276	MONTHLY REQUISITION & CONTINUATION SHEET (AIA G732-2019 & G703-2021)
006300	STANDARD FORMS CERTIFICATES AND MODIFICATION FORMS
007226	GENERAL CONDITIONS OF THE CONTRACT FOR CONSTRUCTION (AIA A232-2019)
007300	SUPPLEMENTARY GENERAL CONDITIONS A232-2019 INCLUDING ATTACHMENT “A” CONSTRUCTION MANAGER GENERAL CONDITIONS
007316	INSURANCE INCLUDING SAMPLE CERTIFICATE OF INSURANCE
007346	DELAWARE PREVAILING WAGE RATES
008013	GENERAL REQUIREMENTS
008114	DRUG TESTING FORMS
009300	RECORD CLARIFICATION AND PROPOSALS PAYROLL REPORT FORM

DIVISION 01 – GENERAL REQUIREMENTS

011100	SUMMARY OF WORK
011200	MULTIPLE CONTRACT SUMMARY
011216	WORK SEQUENCE
011400	WORK RESTRICTIONS
012000	PRICE AND PAYMENT PROCEDURES
012100	ALLOWANCES
012116	CONTINGENCY ALLOWANCES
012200	UNIT PRICES
012300	ALTERNATES
012500	SUBSTITUTION PROCEDURES
012500A	SUBSTITUTION REQUEST FORM
012600	CONTRACT MODIFICATION PROCEDURES

012900	PAYMENT PROCEDURES
012973	SCHEDULE OF VALUES
013100	PROJECT MANAGEMENT AND COORDINATION
013113	PROJECT COORDINATION
013216	CONSTRUCTION SCHEDULE
013233	CONSTRUCTION PROGRESS DOCUMENTATION
013300	SAFETY
013319	FIELD ENGINEERING
013500	SAFETY
014000	QUALITY REQUIREMENTS
014200	REFERENCES
015000	TEMPORARY CONSTRUCTION UTILITIES, FACILITIES & CONTROLS
016000	MATERIALS AND EQUIPMENT PRODUCT REQUIREMENTS
017000	CONTRACT CLOSEOUT
017329	CUTTING AND PATCHING
017419	CONSTRUCTION WASTE MANAGEMENT
017700	CLOSEOUT PROCEDURES
017836	WARRANTIES

TECHNICAL SPECIFICATIONS

DIVISION 2 – EXISTING CONDITIONS

02 41 13	SELECTIVE SITE DEMOLITION
02 41 19	SELECTIVE DEMOLITION

DIVISION 3 - CONCRETE

03 30 00	CAST-IN-PLACE CONCRETE

DIVISION 04 - MASONRY

04 20 00	UNIT MASONRY ASSEMBLIES

DIVISION 05 – METALS

05 40 00	COLD-FORMED METAL FRAMING
05 50 00	METAL FABRICATIONS

DIVISION 6 – WOOD, PLASTICS AND COMPOSITES

06 10 53	MISCELLANEOUS CARPENTRY
06 16 00	SHEATHING
06 40 23	INTERIOR ARCHITECTURAL WOODWORK

DIVISION 7 - THERMAL AND MOISTURE PROTECTION

07 21 00	THERMAL INSULATION
07 25 00	WEATHER BARRIERS
07 62 00	SHEET METAL FLASHING & TRIM
07 84 00	FIRESTOPPING

07 92 00 JOINT SEALANTS

DIVISION 8 - OPENINGS

08 11 13 HOLLOW METAL DOORS & FRAMES
08 14 16 FLUSH WOOD DOORS
08 41 13 ALUMINUM FRAMED ENTRANCES, STOREFRONTS & DOORS
08 71 00 DOOR HARDWARE
08 80 00 GLAZING

DIVISION 9 - FINISHES

09 22 16 NON-STRUCTURAL METAL FRAMING
09 29 00 GYPSUM BOARD
09 51 13 ACOUSTICAL PANEL CEILINGS
09 65 13 RESILIENT BASE & ACCESSORIES
09 68 13 CARPET TILE
09 91 00 PAINTING

DIVISION 10 - SPECIALTIES

10 44 00 FIRE-PROTECTION SPECIALTIES

DIVISION 11 – EQUIPMENT

NOT USED

DIVISION 12 – FURNISHINGS

NOT USED

DIVISION 21 – FIRE SUPPRESSION

21 05 00 COMMON WORK RESULTS FOR FIRE SUPPRESSION
21 05 23 GENERAL-DUTY VALVES FOR WATER BASED FIRE SUPPRESSION PIPING
21 05 48 VIBRATION AND SEISMIC CONTROLS FOR FIRE SUPPRESSION PIPING AND EQUIP

21 05 53 IDENTIFICATION FOR FIRE SUPPRESSION PIPING AND EQUIPMENT
21 13 00 FIRE-SUPPRESSION SPRINKLER SYSTEMS

DIVISION 22 - PLUMBING

NOT USED

DIVISION 23 – HEATING VENTILATING & AIR CONDITIONING

23 01 30.51 HVAC AIR DISTRIBUTION SYSTEM CLEANING
23 05 17 SLEEVES AND SLEEVE SEALS FOR HVAC PIPING
23 05 23 GENERAL-DUTY VALVES FOR HVAC PIPING
23 05 29 HANGERS AND SUPPORTS FOR HVAC PIPING AND EQUIPMENT
23 05 48 VIBRATION AND SEISMIC CONTROLS FOR HVAC
23 05 53 IDENTIFICATION FOR HVAC PIPING AND EQUIPMENT
23 05 93 TESTING, ADJUSTING, AND BALANCING FOR HVAC
23 07 13 DUCT INSULATION

23 09 13	INSTRUMENTATION AND CONTROL DEVICES FOR HVAC
23 09 23	DIRECT DIGITAL CONTROLLERS FOR HVAC
23 09 34	VARIABLE FREQUENCY MOTOR CONTROLLERS FOR HVAC
23 21 13	HYDRONIC PIPING
23 21 14	HYDRONIC SPECIALTIES
23 21 23	HYDRONIC PUMPS
23 23 00	REFRIGERANT PIPING
23 31 00	HVAC DUCTS AND CASINGS
23 33 00	AIR DUCT ACCESSORIES
23 37 00	AIR OUTLETS AND INLETS
23 72 00	AIR-TO-AIR ENERGY RECOVERY EQUIPMENT
23 81 26.13	SMALL CAPACITY SPLIT-SYSTEM AIR CONDITIONERS
23 81 29	VARIABLE REFRIGERANT FLOW HVAC SYSTEM
23 81 46	WATER SOURCE UNITARY HEAT PUMPS

DIVISION 26 – ELECTRICAL

26 05 05	SELECTIVE DEMOLITION FOR ELECTRICAL
26 05 19	LOW-VOLTAGE ELECTRICAL POWER CONDUCTORS AND CABLES (600V AND LESS)
26 05 26	GROUNDING AND BONDING FOR ELECTRICAL SYSTEMS
26 05 29	HANGERS AND SUPPORTS FOR ELECTRICAL SYSTEMS
26 05 33.13	CONDUIT FOR ELECTRICAL SYSTEMS
26 05 53	IDENTIFICATION FOR ELECTRICAL SYSTEMS
26 05 83	WIRING CONNECTIONS
26 09 23	LIGHTING CONTROL DEVICES
26 24 16	PANELBOARDS
26 27 26	WIRING DEVICES
26 28 13	FUSES
26 51 00	INTERIOR LIGHTING

DIVISION 27 – COMMUNICATIONS

27 10 00	STRUCTURED CABLING

DIVISION 28 – ELECTRONIC SAFETY AND SECURITY

28 46 00	FIRE DETECTION AND ALARM

DIVISION 31– EARTHWORK

31 10 00	SITE CLEARING

DIVISION 32– EXTERIOR IMPROVEMENTS

NOT USED

DIVISION 33– UTILITY

NOT USED

END TABLE OF CONTENTS

DOCUMENT 000115 - LIST OF DRAWING SHEETS

1.1 LIST OF DRAWINGS

GENERAL

A001 ACCESSIBILITY DETAILS
A002 LIFE SAFETY PLANS
A004 PARTITION TYPES & NOTES

CIVIL

CC-01 INDEX PLAN
CC-02 EXISTING CONDITIONS AND DEMOLITION PLAN
CC-03 PROPOSED CONDITIONS AND GRADING PLAN
CC-04 EROSION AND SEDIMENT CONTROL PLAN
CC-05 SITE CONSTRUCTION DETAILS

STRUCTURAL

S001 STRUCTURAL NOTES
S002 SPECIAL INSPECTION NOTES
S101 FOUNDATION AND ROOF FRAMING PLANS
S201 SECTIONS & DETAILS
S301 TYPICAL SECTIONS & DETAILS

ARCHITECTURAL

A100 EXISTING SITE PLAN
A101 EXISTING FLOOR PLAN
A102 DEMOLITION PLAN
A103 ENLARGED DEMOLITION PLAN
A104 REFLECTED CEILING DEMOLITION PLAN
A106 PROPOSED SITE PLAN
A111 FLOOR PLAN
A112 ENLARGED FLOOR PLANS
A121 REFLECTED CEILING PLAN
A122 ENLARGED REFLECTED CEILING PLANS
A123 MECHANICAL ACCESS PLATFORM
A131 ROOF PLAN
A141 FINISH PLANS
A151 FURNITURE PLANS
A201 EXTERIOR BUILDING ELEVATIONS
A301 BUILDING SECTIONS
A311 WALL SECTIONS
A451 CASEWORK
A501 PLAN DETAILS
A511 CEILING DETAILS
A521 ROOF DETAILS

A522 EXTERIOR DETAILS
A601 DOORS
A611 STOREFRONTS

FIRE PROTECTION

F000 FIRE PROTECTION - GENERAL NOTES
F101 FIRE PROTECTION FLOOR PLAN - NEW WORK
F102 FIRE PROTECTION ATTIC PLAN - NEW WORK

MECHANICAL

M000 MECHANICAL TITLE SHEET
M101 MECHANICAL DUCTWORK FLOOR PLAN - NEW WORK
M102 MECHANICAL DUCTWORK ATTIC PLAN - NEW WORK
M111 MECHANICAL PIPING FLOOR PLAN - NEW WORK
M501 MECHANICAL DETAILS
M601 MECHANICAL SCHEDULES
M701 MECHANICAL CONTROL DIAGRAMS
MD101 MECHANICAL FLOOR PLAN - DEMOLITION
MD111 MECHANICAL PIPING FLOOR PLAN - DEMOLITION

PLUMBING

P101 PLUMBING - FIRST FLOOR SANITARY PLAN - NEW WORK

ELECTRICAL

E000 ELECTRICAL SYMBOLS AND ABBREVIATIONS
E101 ELECTRICAL-SITE NEW WORK PLAN
E201 ELECTRICAL-LIGHTING NEW WORK PLAN
E301 ELECTRICAL-POWER NEW WORK PLAN
E501 ELECTRICAL DETAILS
ED100 ELECTRICAL-SITE DEMOLITION PLAN
ED101 ELECTRICAL-DEMOLITION PLAN

END OF DOCUMENT 000115

SECTION 001113 – ADVERTISEMENT FOR BID

Public notice is hereby given that sealed bids for Project No. 23.003, DTCC DC9004060001 will be received by the State of Delaware, Delaware Technical Community College at **DTCC Terry Campus located at 100 Campus Drive Dover DE 19904 in the Downs Lecture Hall in Building 100 until 11:00AM local time on June 4, 2025**, at which time they will be publicly opened and read aloud in the conference room. Bidder bears the risk of late delivery. Any bids received after the stated time will be returned unopened.

Project involves the interior renovation and addition to the existing Office of the President located at the DTCC Terry Campus with associated site improvements. This is a construction management project. Bids are to be for the following contracts:

A-1:	Site Work	A-9:	Drywall/Metal Stud
A-2:	Concrete Work	A-10:	Acoustical Work
A-3:	Masonry Work	A-11:	Floor Covering Work
A-4:	Steel Work	A-12:	Caulking/Painting
A-5:	Carpentry & General Work	A-13:	Mechanical
A-6:	Roofing Work	A-14:	Sprinkler System
A-7:	Furnish Hollow Metal/Doors/Hardware	A-15:	Electrical
A-8:	Aluminum Storefront/Windows/ Glass & Glazing		

Attention is called to construction schedule as detailed in the Bid Documents.

A **NON-MANDATORY** Pre-Bid Meeting will be held on May 13, 2025, at 1:00pm at **DTCC Terry Campus located at 100 Campus Drive Dover DE 19904 in the Downs Lecture Hall in Building 100** for the purpose of establishing the listing of subcontractors and to answer questions. Following the meeting, the building will be available for contractors to view the building jobsite. All representatives must be employed by the company you are representing. Representatives of each party to any Joint Venture must attend this meeting. **ATTENDANCE OF THIS MEETING IS NOT A PREREQUISITE FOR BIDDING ON THIS CONTRACT.**

Sealed bids shall be addressed to DTCC Terry Campus, Attn: Mark Devore P.E. – Collegewide Director of Facilities. The outer envelope should clearly indicate: **TERRY OFFICE OF THE PRESIDENT Project No. 23.003, DTCC DC9004060001, Company Name, Contract you are bidding, SEALED BID - DO NOT OPEN."**

Construction documents will be available for review at the following locations: Richard Y Johnson & Son Inc., and Delaware Contractors Association. Contract documents may be purchased at DiCarlo Printers, located at 2006 Northwood Drive, Salisbury MD, 21801 or RCI Printing and Graphics located at 298 Churchmans Road, New Castle DE, 19720. Electronic documents will be available on Richard Y. Johnson & Son, Inc's website www.rjyson.com under plan room. It is the responsibility of each bidder to review and coordinate all project documents. This includes plans, specifications and addendums. All documents will be available on the day of the pre-bid.

Questions should be directed to the Construction Manager, Richard Y. Johnson & Son, Inc. in writing only. The fax number is (302) 422-4696. Email questions too Attn: Jesse Dixon (jdixon@rjyson.com).

A bid security in the amount of 10% of the bid must accompany each bid. Bid Security shall specify the Owner as the obligee. Owner: DTCC Terry Campus 100 Campus Drive Dover, Delaware 19904.

Minority Business Enterprises (MBE), Disadvantaged Business Enterprises (DBE) and Women-Owned Business Enterprises (WBE) will be afforded full opportunity to submit bids on this contract and will not be subject to discrimination on the basis of race, color, national origin or sex in consideration of this award. The successful bidder must post a performance bond and payment bond in a sum equal to 100 percent of the contract price upon execution of the contract. The Owner reserves the right to reject any or all bids and to waive any informalities therein. The Owner may extend the time and place for the opening of the

bids from that described in the advertisement, with not less than two calendar days notice by certified delivery, facsimile machine or other electronic means to those bidders who have received plans.

NOT FOR BIDDING

INSTRUCTIONS TO BIDDERS

TABLE OF ARTICLES

1. DEFINITIONS
2. BIDDER'S REPRESENTATION
3. BIDDING DOCUMENTS
4. BIDDING PROCEDURES
5. CONSIDERATION OF BIDS
6. POST-BID INFORMATION
7. PERFORMANCE BOND AND PAYMENT BOND
8. FORM OF AGREEMENT BETWEEN OWNER AND CONTRACTOR

ARTICLE 1: GENERAL

1.1 DEFINITIONS

1.1.1 Whenever the following terms are used, their intent and meaning shall be interpreted as follows:

1.2 STATE: The State of Delaware.

1.3 AGENCY: Delaware Technical and Community College ("Delaware Technical Community College" or "DTCC")

1.4 DESIGNATED OFFICIAL: The agent authorized to act for the Agency.

1.5 BIDDING DOCUMENTS: Bidding Documents include the Bidding Requirements and the proposed Contract Documents. The Bidding Requirements consist of the Advertisement for Bid, Invitation to Bid, Instructions to Bidders, Supplementary Instructions to Bidders (if any), General Conditions, Supplementary General Conditions, General Requirements, Special Provisions (if any), the Bid Form (including the Non-collision Statement), and other sample bidding and contract forms. The proposed Contract Documents consist of the form of Agreement between the Owner and Contractor, as well as the Drawings, Specifications (Project Manual) and all Addenda issued prior to execution of the Contract.

1.6 CONTRACT DOCUMENTS: The Contract Documents consist of the, Instructions to Bidders, Supplementary Instructions to Bidders (if any), General Conditions, Supplementary General Conditions, General Requirements, Special Provisions (if any), the form of agreement between the Owner and the Contractor, Drawings (if any), Specifications (Project Manual), and all addenda.

1.7 AGREEMENT: The form of the Agreement shall be AIA Document A101, Standard Form of Agreement between Owner and Contractor where the basis of payment is a STIPULATED SUM, as modified by the State of Delaware's Supplement to Agreement Between Owner and Contractor A132-2019, and the Agency's Amendment to Contract for Construction Between Delaware Technical Community College and Contractor. In the case of conflict between the instructions contained in the AIA Document A132 Contract form and the General Requirements herein, these General Requirements shall prevail.

1.8 GENERAL REQUIREMENTS (or CONDITIONS): General Requirements (or conditions) are instructions pertaining to the Bidding Documents and to contracts in general. They contain, in summary, requirements of laws of the State; policies of the Agency and instructions to bidders.

1.9 SPECIAL PROVISIONS: Special Provisions are specific conditions or requirements peculiar to the bidding documents and to the contract under consideration and are supplemental to the General Requirements. Should the Special Provisions conflict with the General Requirements, the Special Provisions shall prevail.

1.10 ADDENDA: Written or graphic instruments issued by the Owner/Architect prior to the execution of the contract which modify or interpret the Bidding Documents by additions, deletions, clarifications or corrections.

1.11 BIDDER OR VENDOR: A person or entity who formally submits a Bid for the material or Work contemplated, acting directly or through a duly authorized representative who meets the requirements set forth in the Bidding Documents.

- 1.12 SUB-BIDDER: A person or entity who submits a Bid to a Bidder for materials or labor, or both for a portion of the Work.
- 1.13 BID: A complete and properly executed proposal to do the Work for the sums stipulated therein, submitted in accordance with the Bidding Documents.
- 1.14 BASE BID: The sum stated in the Bid for which the Bidder offers to perform the Work described in the Bidding Documents as the base, to which Work may be added or from which Work may be deleted for sums stated in Alternate Bids (if any are required to be stated in the bid).
- 1.15 ALTERNATE BID (or ALTERNATE): An amount stated in the Bid, where applicable, to be added to or deducted from the amount of the Base Bid if the corresponding change in the Work, as described in the Bidding Documents is accepted.
- 1.16 UNIT PRICE: An amount stated in the Bid, where applicable, as a price per unit of measurement for materials, equipment or services or a portion of the Work as described in the Bidding Documents.
- 1.17 SURETY: The corporate body which is bound with and for the Contract, or which is liable, and which engages to be responsible for the Contractor's payments of all debts pertaining to and for his acceptable performance of the Work for which he has contracted.
- 1.18 BIDDER'S DEPOSIT: The security designated in the Bid to be furnished by the Bidder as a guaranty of good faith to enter into a contract with the Agency if the Work to be performed or the material or equipment to be furnished is awarded to him.
- 1.19 CONTRACT: The written agreement covering the furnishing and delivery of material or work to be performed.
- 1.20 CONTRACTOR: Any individual, firm or corporation with whom a contract is made by the Agency.
- 1.21 SUBCONTRACTOR: An individual, partnership or corporation which has a direct contract with a contractor to furnish labor and materials at the job site, or to perform construction labor and furnish material in connection with such labor at the job site.
- 1.22 CONTRACT BOND: The approved form of security furnished by the contractor and his surety as a guaranty of good faith on the part of the contractor to execute the work in accordance with the terms of the contract.

ARTICLE 2: BIDDER'S REPRESENTATIONS

- 2.1 PRE-BID MEETING
- 2.1.1 A pre-bid meeting for this project will be held at the time and place designated. Attendance at this meeting is a pre-requisite for submitting a Bid, unless this requirement is specifically waived elsewhere in the Bid Documents.
- 2.2 By submitting a Bid, the Bidder represents that:
- 2.2.1 The Bidder has read and understands the Bidding Documents and that the Bid is made in accordance therewith.

2.2.2 The Bidder has visited the site, become familiar with existing conditions under which the Work is to be performed, and has correlated the Bidder's his personal observations with the requirements of the proposed Contract Documents.

2.2.3 The Bid is based upon the materials, equipment, and systems required by the Bidding Documents without exception.

2.3 JOINT VENTURE REQUIREMENTS

2.3.1 For Public Works Contracts, each Joint Venturer shall be qualified and capable to complete the Work with their own forces.

2.3.2 Included with the Bid submission, and as a requirement to bid, a copy of the executed Joint Venture Agreement shall be submitted and signed by all Joint Venturers involved.

2.3.3 All required Bid Bonds, Performance Bonds, Material and Labor Payment Bonds must be executed by both Joint Venturers and be placed in both of their names.

2.3.4 All required insurance certificates shall name both Joint Venturers.

2.3.5 Both Joint Venturers shall sign the Bid Form and shall submit a valid Delaware Business License Number with their Bid or shall state that the process of application for a Delaware Business License has been initiated.

2.3.6 Both Joint Venturers shall include their Federal E.I. Number with the Bid.

2.3.7 In the event of a mandatory Pre bid Meeting, each Joint Venturer shall have a representative in attendance.

2.3.8 Due to exceptional circumstances and for good cause shown, one or more of these provisions may be waived at the discretion of the State.

2.4 ASSIGNMENT OF ANTITRUST CLAIMS

2.4.1 As consideration for the award and execution by the Owner of this contract, the Contractor hereby grants, conveys, sells, assigns and transfers to the State of Delaware all of its right, title and interests in and to all known or unknown causes of action it presently has or may now or hereafter acquire under the antitrust laws of the United States and the State of Delaware, relating to the particular goods or services purchased or acquired by the Owner pursuant to this contract.

ARTICLE 3: BIDDING DOCUMENTS

3.1 COPIES OF BID DOCUMENTS

3.1.1 Bidders may obtain complete sets of the Bidding Documents from the Architectural/Engineering firm designated in the Advertisement or Invitation to Bid in the number and for the deposit sum, if any, stated therein.

3.1.2 Bidders shall use complete sets of Bidding Documents for preparation of Bids. The issuing Agency nor the Architect assumes no responsibility for errors or misinterpretations resulting from the use of incomplete sets of Bidding Documents.

- 3.1.3 Any errors, inconsistencies or omissions discovered shall be reported to the Architect immediately.
- 3.1.4 The Agency and Architect may make copies of the Bidding Documents available on the above terms for the purpose of obtaining Bids on the Work. No license or grant of use is conferred by issuance of copies of the Bidding Documents.
- 3.2 INTERPRETATION OR CORRECTION OF BIDDING DOCUMENTS
- 3.2.1 The Bidder shall carefully study and compare the Bidding Documents with each other, and with other work being bid concurrently or presently under construction to the extent that it relates to the Work for which the Bid is submitted, shall examine the site and local conditions, and shall report any errors, inconsistencies, or ambiguities discovered to the Architect.
- 3.2.2 Bidders or Sub-bidders requiring clarification or interpretation of the Bidding Documents shall make a written request to the Architect at least seven days prior to the date for receipt of Bids. Interpretations, corrections and changes to the Bidding Documents will be made by written Addendum. Interpretations, corrections, or changes to the Bidding Documents made in any other manner shall not be binding.
- 3.2.3 The apparent silence of the specifications as to any detail, or the apparent omission from it of detailed description concerning any point, shall be regarded as meaning that only the best commercial practice is to prevail and only material and workmanship of the first quality are to be used. Proof of specification compliance will be the responsibility of the Bidder.
- 3.2.4 Unless otherwise provided in the Contract Documents, the Contractor shall provide and pay for all permits, labor, materials, equipment, tools, construction equipment and machinery, water, heat, utilities, transportation, and other facilities and services necessary for the proper execution and completion of the Work.
- 3.2.5 The Owner will bear the costs for all impact and user fees associated with the project.
- 3.3 SUBSTITUTIONS
- 3.3.1 The materials, products and equipment described in the Bidding Documents establish a standard of quality, required function, dimension, and appearance to be met by any proposed substitution. The specification of a particular manufacturer or model number is not intended to be proprietary in any way. Substitutions of products for those named will be considered, providing that the Vendor certifies that the function, quality, and performance characteristics of the material offered is equal or superior to that specified. It shall be the Bidder's responsibility to assure that the proposed substitution will not affect the intent of the design, and to make any installation modifications required to accommodate the substitution.
- 3.3.2 Requests for substitutions shall be made in writing to the Architect at least ten days prior to the date of the Bid Opening. Such requests shall include a complete description of the proposed substitution, drawings, performance and test data, explanation of required installation modifications due the substitution, and any other information necessary for an evaluation. The burden of proof of the merit of the proposed substitution is upon the proposer. The Architect's decision of approval or disapproval shall be final. The Architect is to notify Owner prior to any approvals.

- 3.3.3 If the Architect approves a substitution prior to the receipt of Bids, such approval shall be set forth in an Addendum. Approvals made in any other manner shall not be binding.
- 3.3.4 The Architect shall have no obligation to consider any substitutions after the Contract award.
- 3.4 **ADDENDA**
- 3.4.1 Addenda will be mailed or delivered to all who are known by the Architect to have received a complete set of the Bidding Documents.
- 3.4.2 Copies of Addenda will be made available for inspection wherever Bidding Documents are on file for that purpose.
- 3.4.3 No Addenda will be issued later than 4 days prior to the date for receipt of Bids except an Addendum withdrawing the request for Bids or one which extends the time or changes the location for the opening of bids.
- 3.4.4 Each bidder shall ascertain prior to submitting his Bid that they have received all Addenda issued, and shall acknowledge their receipt in their Bid in the appropriate space. Not acknowledging an issued Addenda could be grounds for determining a bid to be non-responsive.

ARTICLE 4: BIDDING PROCEDURES

- 4.1 **PREPARATION OF BIDS**
- 4.1.1 Submit the bids on the Bid Forms included with the Bidding Documents.
- 4.1.2 Submit the original Bid Form for each bid. Bid Forms may be removed from the project manual for this purpose.
- 4.1.3 Execute all blanks on the Bid Form in a non-erasable medium (typewriter or manually in ink).
- 4.1.4 Where so indicated by the makeup on the Bid Form, express sums in both words and figures, in case of discrepancy between the two, the written amount shall govern.
- 4.1.5 Interlineations, alterations or erasures must be initialed by the signer of the Bid.
- 4.1.6 **BID ALL REQUESTED ALTERNATES AND UNIT PRICES, IF ANY.** If there is no change in the Base Bid for an Alternate, enter "No Change". The Contractor is responsible for verifying that they have received all addenda issued during the bidding period. Work required by Addenda shall automatically become part of the Contract.
- 4.1.7 Make no additional stipulations on the Bid Form and do not qualify the Bid in any other manner.
- 4.1.8 Each copy of the Bid shall include the legal name of the Bidder and a statement whether the Bidder is a sole proprietor, a partnership, a corporation, or any legal entity, and each copy shall be signed by the person or persons legally authorized to bind the Bidder to a contract. A Bid by a corporation shall further give the state of incorporation and have the corporate seal affixed. A Bid submitted by an agent shall have a current Power of Attorney attached, certifying agent's authority to bind the Bidder.

- 4.1.9 Bidder shall complete the Non-Collusion Statement form included with the Bid Forms and include it with their Bid.
- 4.1.10 In the construction of all Public Works projects for the State of Delaware or any agency thereof, preference in employment of laborers, workers or mechanics shall be given to bona fide legal citizens of the State who have established citizenship by residence of at least 90 days in the State.
- 4.1.11 Each bidder shall include in their bid a copy of a valid Delaware Business License.
- 4.1.12 Each bidder shall include signed Affidavit(s) for the bidder and each listed Subcontractor certifying compliance with OMB Regulation 4104 "Regulations for the Drug Testing of Contractor and Subcontractor Employees Working on " Large Public Works Projects" "large Public Works" is based upon the current threshold required for bidding Public Works as set by the Purchasing and Contracting Advisory Council.
- 4.2 **BID SECURITY**
- 4.2.1 All bids shall be accompanied by a deposit of either a good and sufficient bond to the agency for the benefit of the agency, with corporate surety authorized to do business in this State, the form of the bond and the surety to be approved by the agency, or a security of the bidder assigned to the agency, for a sum equal to at least 10% of the bid plus all add alternates, or in lieu of the bid bond a security deposit in the form of a certified check, bank treasurer's check, cashier's check, money order, or other prior approved secured deposit assigned to the State. The bid bond need not be for a specific sum, but may be stated to be for a sum equal to 10% of the bid plus all add alternates to which it relates and not to exceed a certain stated sum, if said sum is equal to at least 10% of the bid. The Bid Bond form used shall be the standard OMB form (attached).
- 4.2.2 The Agency has the right to retain the bid security of Bidders to whom an award is being considered until either a formal contract has been executed and bonds have been furnished or the specified time has elapsed so the Bids may be withdrawn or all Bids have been rejected.
- 4.2.3 In the event of any successful Bidder refusing or neglecting to execute a formal contract and bond within 20 days of the awarding of the contract, the bid bond or security deposited by the successful bidder shall be forfeited.
- 4.3 **SUBCONTRACTOR LIST**
- 4.3.1 As required by Delaware Code, Title 29, section 6962(d)(10)b, each Bidder shall submit with their Bid a completed List of Sub-Contractors included with the Bid Form. **NAME ONLY ONE SUBCONTRACTOR FOR EACH TRADE.** A Bid will be considered non-responsive unless the completed list is included.
- 4.3.2 Provide the Name and Address for each listed subcontractor. Addresses by City, Town or Locality, plus State, will be acceptable.
- 4.3.3 It is the responsibility of the Contractor to ensure that their Subcontractors are in compliance with the provisions of this law. Also, if a Contractor elects to list themselves as a Subcontractor for any category, they must specifically name themselves on the Bid Form and be able to document their capability to act as Subcontractor in that category in accordance with this law.

4.4 EQUALITY OF EMPLOYMENT OPPORTUNITY ON PUBLIC WORKS

4.4.1 During the performance of this contract, the contractor agrees as follows:

- A. The Contractor will not discriminate against any employee or applicant for employment because of race, creed, color, sex or national origin. The Contractor will take affirmative action to ensure the applicants are employed, and that employees are treated during employment, without regard to their race, creed, color, sex or national origin. Such action shall include, but not be limited to, the following: Employment, upgrading, demotion or transfer; recruitment or recruitment advertising; layoff or termination; rates of pay or other forms of compensation; and selection for training, including apprenticeship. The Contractor agrees to post in conspicuous places available to employees and applicants for employment notices to be provided by the contracting agency setting forth this nondiscrimination clause.
- B. The Contractor will, in all solicitations or advertisements for employees placed by or on behalf of the Contractor, state that all qualified applicants will receive consideration for employment without regard to race, creed, color, sex or national origin."

4.5 PREVAILING WAGE REQUIREMENT

4.5.1 Wage Provisions: In accordance with Delaware Code, Title 29, Section 6960, renovation projects whose total cost shall exceed \$45,000, and \$500,000 for new construction, the minimum wage rates for various classes of laborers and mechanics shall be as determined by the Department of Labor, Division of Industrial Affairs of the State of Delaware.

4.5.2 The prevailing wage shall be the wage paid to a majority of employees performing similar work as reported in the Department's annual prevailing wage survey or in the absence of a majority, the average paid to all employees reported.

4.5.3 The employer shall pay all mechanics and labors employed directly upon the site of work, unconditionally and not less often than once a week and without subsequent deduction or rebate on any account, the full amounts accrued at time of payment, computed at wage rates not less than those stated in the specifications, regardless of any contractual relationship which may be alleged to exist between the employer and such laborers and mechanics.

4.5.4 The scale of the wages to be paid shall be posted by the employer in a prominent and easily accessible place at the site of the work.

4.5.5 Every contract based upon these specifications shall contain a stipulation that sworn payroll information, as required by the Department of Labor, be furnished weekly. The Department of Labor shall keep and maintain the sworn payroll information for a period of 6 months from the last day of the work week covered by the payroll.

4.6 SUBMISSION OF BIDS

4.6.1 Enclose the Bid, the Bid Security, and any other documents required to be submitted with the Bid in a sealed opaque envelope. Address the envelope to the party receiving the Bids. Identify with the project name, project number, and the Bidder's name and address. If the

Bid is sent by mail, enclose the sealed envelope in a separate mailing envelope with the notation "BID ENCLOSED" on the face thereof. The State is not responsible for the opening of bids prior to bid opening date and time that are not properly marked.

4.6.2 Deposit Bids at the designated location prior to the time and date for receipt of bids indicated in the Advertisement for Bids. Bids received after the time and date for receipt of bids will be marked "LATE BID" and returned.

4.6.3 Bidder assumes full responsibility for timely delivery at location designated for receipt of bids.

4.6.4 Oral, telephonic or telegraphic bids are invalid and will not receive consideration.

4.6.5 Withdrawn Bids may be resubmitted up to the date and time designated for the receipt of Bids, provided that they are then fully in compliance with these Instructions to Bidders.

4.7 MODIFICATION OR WITHDRAW OF BIDS

4.7.1 Prior to the closing date for receipt of Bids, a Bidder may withdraw a Bid by personal request and by showing proper identification to the Architect. A request for withdraw by letter or fax, if the Architect is notified in writing prior to receipt of fax, is acceptable. A fax directing a modification in the bid price will render the Bid informal, causing it to be ineligible for consideration of award. Telephone directives for modification of the bid price shall not be permitted and will have no bearing on the submitted proposal in any manner.

4.7.2 Bidders submitting Bids that are late shall be notified as soon as practicable and the bid shall be returned.

4.7.3 A Bid may not be modified, withdrawn or canceled by the Bidder during a thirty (30) day period following the time and date designated for the receipt and opening of Bids, and Bidder so agrees in submitting their Bid. Bids shall be binding for 30 days after the date of the Bid opening.

ARTICLE 5: CONSIDERATION OF BIDS

5.1 OPENING/REJECTION OF BIDS

5.1.1 Unless otherwise stated, Bids received on time will be publicly opened and will be read aloud. An abstract of the Bids will be made available to Bidders.

5.1.2 The Agency shall have the right to reject any and all Bids. A Bid not accompanied by a required Bid Security or by other data required by the Bidding Documents, or a Bid which is in any way incomplete or irregular is subject to rejection.

5.1.3 If the Bids are rejected, it will be done within thirty (30) calendar day of the Bid opening.

5.2 COMPARISON OF BIDS

5.2.1 After the Bids have been opened and read, the bid prices will be compared and the result of such comparisons will be made available to the public. Comparisons of the Bids may be based on the Base Bid plus desired Alternates. The Agency shall have the right to accept Alternates in any order or combination.

- 5.2.2 The Agency reserves the right to waive technicalities, to reject any or all Bids, or any portion thereof, to advertise for new Bids, to proceed to do the Work otherwise, or to abandon the Work, if in the judgment of the Agency or its agent(s), it is in the best interest of the State.
- 5.2.3 An increase or decrease in the quantity for any item is not sufficient grounds for an increase or decrease in the Unit Price.
- 5.2.4 The prices quoted are to be those for which the material will be furnished F.O.B. Job Site and include all charges that may be imposed during the period of the Contract.
- 5.2.5 No qualifying letter or statements in or attached to the Bid, or separate discounts will be considered in determining the low Bid except as may be otherwise herein noted. Cash or separate discounts should be computed and incorporated into Unit Bid Price(s).
- 5.3 DISQUALIFICATION OF BIDDERS
- 5.3.1 An agency shall determine that each Bidder on any Public Works Contract is responsible before awarding the Contract. Factors to be considered in determining the responsibility of a Bidder include:
- A. The Bidder's financial, physical, personnel or other resources including Subcontracts;
 - B. The Bidder's record of performance on past public or private construction projects, including, but not limited to, defaults and/or final adjudication or admission of violations of the Prevailing Wage Laws in Delaware or any other state;
 - C. The Bidder's written safety plan;
 - D. Whether the Bidder is qualified legally to contract with the State;
 - E. Whether the Bidder supplied all necessary information concerning its responsibility; and,
 - F. Any other specific criteria for a particular procurement, which an agency may establish; provided however, that, the criteria be set forth in the Invitation to Bid and is otherwise in conformity with State and/or Federal law.
- 5.3.2 If an agency determines that a Bidder is nonresponsive and/or nonresponsible, the determination shall be in writing and set forth the basis for the determination. A copy of the determination shall be sent to the affected Bidder within five (5) working days of said determination.
- 5.3.3 In addition, any one or more of the following causes may be considered as sufficient for the disqualification of a Bidder and the rejection of their Bid or Bids.
- 5.3.3.1 More than one Bid for the same Contract from an individual, firm or corporation under the same or different names.
- 5.3.3.2 Evidence of collusion among Bidders.
- 5.3.3.3 Unsatisfactory performance record as evidenced by past experience.

- 5.3.3.4 If the Unit Prices are obviously unbalanced either in excess or below reasonable cost analysis values.
- 5.3.3.5 If there are any unauthorized additions, interlineation, conditional or alternate bids or irregularities of any kind which may tend to make the Bid incomplete, indefinite or ambiguous as to its meaning.
- 5.3.3.6 If the Bid is not accompanied by the required Bid Security and other data required by the Bidding Documents.
- 5.3.3.7 If any exceptions or qualifications of the Bid are noted on the Bid Form.
- 5.4 ACCEPTANCE OF BID AND AWARD OF CONTRACT
- 5.4.1 A formal Contract shall be executed with the successful Bidder within twenty (20) calendar days after the award of the Contract.
- 5.4.2 Per Section 6962(d)(13) a., Title 29, Delaware Code, "The contracting agency shall award any public works contract within thirty (30) days of the bid opening to the lowest responsive and responsible Bidder, unless the Agency elects to award on the basis of best value, in which case the election to award on the basis of best value shall be stated in the Invitation To Bid."
- 5.4.3 Each Bid on any Public Works Contract must be deemed responsive by the Agency to be considered for award. A responsive Bid shall conform in all material respects to the requirements and criteria set forth in the Contract Documents and specifications.
- 5.4.4 The Agency shall have the right to accept Alternates in any order or combination, and to determine the low Bidder on the basis of the sum of the Base Bid, plus accepted Alternates.
- 5.4.5 The successful Bidder shall execute a formal contract, submit the required Insurance Certificate, and furnish good and sufficient bonds, unless specifically waived in the General Requirements, in accordance with the General Requirement, within twenty (20) days of official notice of contract award. Bonds shall be for the benefit of the Agency with surety in the amount of 100% of the total contract award. Said Bonds shall be conditioned upon the faithful performance of the contract. Bonds shall remain in affect for period of one year after the date of substantial completion.
- 5.4.6 If the successful Bidder fails to execute the required Contract and Bond, as aforesaid, within twenty (20) calendar days after the date of official Notice of the Award of the Contract, their Bid guaranty shall immediately be taken and become the property of the State for the benefit of the Agency as liquidated damages, and not as a forfeiture or as a penalty. Award will then be made to the next lowest qualified Bidder of the Work or readvertised, as the Agency may decide.
- 5.4.7 Each bidder shall supply with its bid its taxpayer identification number (i.e., federal employer identification number or social security number) and a copy of its Delaware business license, and should the vendor be awarded a contract, such vendor shall provide to the agency the taxpayer identification license numbers of such subcontractors. Such numbers shall be provided on the later of the date on which such subcontractor is required to be identified or the time the contract is executed. The successful Bidder shall provide to the agency to which it is contracting, within 30 days of entering into such public

works contract, copies of all Delaware Business licenses of subcontractors and/or independent contractors that will perform work for such public works contract. However, if a subcontractor or independent contractor is hired or contracted more than 20 days after the Bidder entered the public works contract the Delaware Business license of such subcontractor or independent contractor shall be provided to the agency within 10 days of being contracted or hired.

- 5.4.8 The Bid Security shall be returned to the successful Bidder upon the execution of the formal contract. The Bid Securities of unsuccessful bidders shall be returned within thirty (30) calendar days after the opening of the Bids.

ARTICLE 6: POST-BID INFORMATION

6.1 CONTRACTOR'S QUALIFICATION STATEMENT

- 6.1.1 Bidders to whom award of a Contract is under consideration shall, if requested by the Agency, submit a properly executed AIA Document A305, Contractor's Qualification Statement, unless such a statement has been previously required and submitted.

6.2 BUSINESS DESIGNATION FORM

- 6.2.1 Successful bidder shall be required to accurately complete an Office of Management and Budget Business Designation Form for Subcontractors.

ARTICLE 7: PERFORMANCE BOND AND PAYMENT BOND

7.1 BOND REQUIREMENTS

- 7.1.1 The cost of furnishing the required Bonds, that are stipulated in the Bidding Documents, shall be included in the Bid.
- 7.1.2 If the Bidder is required by the Agency to secure a bond from other than the Bidder's usual sources, changes in cost will be adjusted as provide in the Contract Documents.
- 7.1.3 The Performance and Payment Bond forms used shall be the standard OMB forms (attached).

7.2 TIME OF DELIVERY AND FORM OF BONDS

- 7.2.1 The bonds shall be dated on or after the date of the Contract.
- 7.2.2 The Bidder shall require the attorney-in-fact who executes the required bonds on behalf of the surety to affix a certified and current copy of the power of attorney.

ARTICLE 8: FORM OF AGREEMENT BETWEEN AGENCY AND CONTRACTOR

- 8.1 Unless otherwise required in the Bidding Documents, the Agreement for the Work will be written on AIA Document A101, Standard Form of Agreement Between Owner and Contractor Where the Basis of Payment is a Stipulated Sum, as modified by the State of Delaware's Supplement to Agreement Between Owner and Contractor A132-2019, and the Agency's Amendment to Contract for Construction Between Delaware Technical Community College and Contractor.

END OF INSTRUCTIONS TO BIDDER

BID FORM

To: Delaware Technical Community College
Attn: Mark Devore P.E.
Collegewide Director of Facilities

Clearly Mark Contract you are bidding (Only 1 contract per bid form)

For Bid Package AB:

Contract #1	Site Work
Contract #2	Concrete Work
Contract #3	Masonry Work
Contract #4	Steel Work
Contract #5	Carpentry & General Work
Contract #6	Roofing Work
Contract #7	Furnish Hollow Metal/Doors/Hardware
Contract #8	Aluminum Storefront/Windows/Glass & Glazing
Contract #9	Drywall/Metal Studs
Contract #10	Acoustical Work
Contract #11	Floor Covering Work
Contract #12	Caulking/Painting
Contract #13	Mechanical
Contract #14	Sprinkler System
Contract #15	Electrical

Name of Bidder: _____

Delaware Business License No.: _____ **Taxpayer ID No.:** _____

(Other License Nos.): _____

Phone No.: () _____ - _____ **Fax No.:** () _____ - _____

The undersigned, representing that he has read and understands the Bidding Documents and that this bid is made in accordance therewith, that he has visited the site and has familiarized himself with the local conditions under which the Work is to be performed, and that his bid is based upon the materials, systems and equipment described in the Bidding Documents without exception, hereby proposes and agrees to provide all labor, materials, plant, equipment, supplies, transport and other facilities required to execute the work described by the aforesaid documents for the lump sum itemized below:

\$()

BID FORM

ALTERNATES

Alternate prices conform to applicable project specification section. Refer to specifications for a complete description of the following Alternates. An "ADD" or "DEDUCT" amount is indicated by the crossed out part that does not apply.

ADD. Alternate No. One – Flooring Work (Contracts A-11 & A-12)

1. Base Bid Item: No Additional Flooring, base or Paint.
2. Alternate Item: Provide additional flooring, base, and paint as indicated. Work includes removal of existing carpet and base and patching of subfloor if necessary, and patch/repair of drywall as necessary prior to painting. Work is to be coordinated with phased heat pump work throughout the existing building. Contractors are responsible to move and protect furniture as required to complete the work and place furniture back in its original location.

Add/Delete: _____
(\$ _____)

ALLOWANCES

Contract No. 2 Concrete Work

1 – Include the lump sum of the following amount **\$10,000** in the contract for cold weather protection of concrete work. See Section 012100 Allowances.

Contract No. 3 Masonry Work

2 – Include the lump sum of the following amount **\$10,000** in the contract for cold weather protection of masonry work. See Section 012100 Allowances.

Contract No. 5 Carpentry & General Works

3 – Include the lump sum of the following amount **\$25,000** in the contract for unforeseen conditions that may arise during construction to be used at the discretion of the Construction Manager. See Section 012100 Allowances.

Contract No. 3 Carpentry & General Works

4 – Include the lump sum of the following amount **\$25,000** in the contract for temporary closures during construction for the exterior wall construction. See Section 012100 Allowances.

Contract No. 13 Mechanical

5 – Include the lump sum of the following amount **\$10,000** in the contract for the temp heat fuel cost. Cost of work to be determined by fuel company receipts with the amount of fuel and cost per gallon. All equipment and labor for temp heat is part of the contract. This allowance is for fuel cost only. See Section 012100 Allowances.

Contract No. 15 Electrical

6 – Include the lump sum of the following amount **\$10,000** in the contract for short circuit analysis gear revisions. See Section 012100 Allowances.

Contract No. 15 Electrical

7 – Include the lump sum of the following amount **\$20,000** in the contract for selective demolition of existing offices. See Section 012100 Allowances.

UNIT PRICES

NOT USED

Terry Office of the President
Delaware Technical and Community College
100 Campus Drive, Dover, Delaware 19904
Project No. 23.003

BID FORM

I/We acknowledge Addendums numbered _____ and the price(s) submitted include any cost/schedule impact they may have.

This bid shall remain valid and cannot be withdrawn for thirty (30) days from the date of opening of bids (60 days for School Districts and Department of Education), and the undersigned shall abide by the Bid Security forfeiture provisions. Bid Security is attached to this Bid.

The Owner shall have the right to reject any or all bids, and to waive any informality or irregularity in any bid received.

This bid is based upon work being accomplished by the Sub-Contractors named on the list attached to this bid.

Should I/We be awarded this contract, I/We pledge to achieve substantial completion of all the work within _____ calendar days of the Notice to Proceed.

The undersigned represents and warrants that he has complied and shall comply with all requirements of local, state, and national laws; that no legal requirement has been or shall be violated in making or accepting this bid, in awarding the contract to him or in the prosecution of the work required; that the bid is legal and firm; that he has not, directly or indirectly, entered into any agreement, participated in any collusion, or otherwise taken action in restraint of free competitive bidding.

Upon receipt of written notice of the acceptance of this Bid, the Bidder shall, within twenty (20) calendar days, execute the agreement in the required form and deliver the Contract Bonds, and Insurance Certificates, required by the Contract Documents.

I am / We are an Individual / a Partnership / a Corporation

By _____ Trading as _____
(Individual's / General Partner's / Corporate Name)

(State of Corporation)

Business Address: _____

Witness: _____ By: _____
(SEAL) (Authorized Signature)

(Title)
Date: _____

ATTACHMENTS

Sub-Contractor List
Non-Collusion Statement
Affidavit of Employee Drug Testing Program
Affidavit of Contractor Qualifications
Bid Security
(Others as Required by Project Manuals)

BID FORM

SUBCONTRACTOR LIST

In accordance with Title 29, Chapter 69, Section 6962(d)(10)b of the Delaware Code, the following subcontractor listing must accompany any bid submittal. The bidder must list **in each category** the full name and address (City & State) of the sub-contractor that the bidder will be using to perform the work and provide material for that subcontractor category. Should the bidder's listed subcontractor intend to provide any of their subcontractor category of work through a third-tier contractor, the bidder shall list that third-tier contractor's full name and address (City & State). **If the bidder intends to perform any category of work itself, it must list its full name and address.** For clarification, if the bidder intends to perform the work themselves, the bidder **may not** insert "not applicable", "N/A", "self" or anything other than its own full name and address (City & State). To do so shall cause the bid to be rejected. In addition, the failure to produce a completed subcontractor list with the bid submittal shall cause the bid to be rejected. If you have more than three (3) third-tier contractors to report in any subcontractor category, print out additional page(s) containing the appropriate category, complete the rest of your list of third-tier contractors for that category, notate the addition in parentheses as (CONTINUATION) next to the subcontractor category and an asterisk (*) next to any additional third-tier contractors, and submit it with your bid.

<u>Subcontractor Category</u>	<u>Subcontractor</u>	<u>Address (City & State)</u>	<u>Subcontractors tax-payer ID # or Delaware Business license #</u>
1.			
A.			
B.			
C.			
2.			
A.			
B.			
C.			

Terry Office of the President
Delaware Technical and Community College
100 Campus Drive, Dover, Delaware 19904
Project No. 23.003

BID FORM

3.			
A.			
B.			
C.			
4.			
A.			
B.			
C.			
5.			
A.			
B.			
C.			

BID FORM

NON-COLLUSION STATEMENT

This is to certify that the undersigned bidder has neither directly nor indirectly, entered into any agreement, participated in any collusion or otherwise taken any action in restraint of free competitive bidding in connection with this proposal submitted this date to Delaware Technical and Community College.

All the terms and conditions of Project No. 19.021, Contract #: DTCC22C900406SSC-A have been thoroughly examined and are understood.

NAME OF BIDDER:

**AUTHORIZED REPRESENTATIVE
(TYPED):**

**AUTHORIZED REPRESENTATIVE
(SIGNATURE):**

TITLE:

ADDRESS OF BIDDER:

E-MAIL:

PHONE NUMBER:

Sworn to and Subscribed before me this _____ day of _____ 20____.

My Commission expires _____. NOTARY PUBLIC _____.

THIS PAGE MUST BE SIGNED AND NOTARIZED FOR YOUR BID TO BE CONSIDERED.

BID FORM

**AFFIDAVIT
OF
EMPLOYEE DRUG TESTING PROGRAM**

4104 Regulations for the Drug Testing of Contractor and Subcontractor Employees Working on Large Public Works Projects requires that Contractors and Subcontractors implement a program of mandatory drug testing for Employees who work on Large Public Works Contracts funded all or in part with public funds.

We hereby certify that we have in place or will implement during the entire term of the contract a Mandatory Drug Testing Program for our employees on the jobsite, including subcontractors, that complies with this regulation:

Contractor/Subcontractor Name: _____

Contractor/Subcontractor Address: _____

Authorized Representative (typed or printed): _____

Authorized Representative (signature): _____

Title: _____

Sworn to and Subscribed before me this _____ day of _____ 20____.

My Commission expires _____. NOTARY PUBLIC _____.

THIS PAGE MUST BE SIGNED AND NOTARIZED FOR YOUR BID TO BE CONSIDERED.

Terry Office of the President
Delaware Technical and Community College
100 Campus Drive, Dover, Delaware 19904
Project No. 23.003

BID FORM

**AFFIDAVIT
OF
CONTRACTOR QUALIFICATIONS**

We hereby certify that we will abide by the contractor's qualifications outlined in the construction bid specifications for the duration of the contract term.

In accordance with Title 29, Chapter 69, Section 6962(d)(10)b.3 of the Delaware Code, after a contract has been awarded the successful bidder shall not substitute another subcontractor whose name was submitted on the Subcontractor Form except for the reasons in the statute and not without written consent from the awarding agency. Failure to utilize the subcontractors on the list will subject the successful bidder to penalties as outlined in the General Requirements Section 5.2 of the contract.

Contractor Name:

Contractor Address:

Authorized Representative (typed or printed):

Authorized Representative (signature):

Title:

Sworn to and Subscribed before me this _____ day of _____, 20____.

My Commission expires _____. NOTARY PUBLIC _____.

THIS PAGE MUST BE SIGNED AND NOTARIZED FOR YOUR BID TO BE CONSIDERED.

**AFFIDAVIT OF
CRAFT TRAINING COMPLIANCE**

We, the contractor, hereby certify that we and all applicable subcontractors will abide by the contractor and subcontractor craft training requirements outlined below for the duration of the contract. Craft training must be provided by a contractor and/or subcontractor for each craft on a project for which there are Delaware Department of Labor approved and registered training programs. A list of crafts for which there are approved and registered training programs is maintained by the Delaware Department of Labor and can be found at

<https://laborfiles.delaware.gov/main/det/apprenticeship/DE%20Craft%20Training%20Occupation%20List%20Effective%20March%201%202022.pdf>. If you have questions regarding craft training programs, please submit them in writing to the Delaware Department of Labor at: apprenticeship@delaware.gov. The Craft Training Compliance Affidavit must be submitted prior to contract execution.

In accordance with Title 29, Chapter 69, Section 6962(c)(13) of the Delaware Code, contractors and subcontractors must provide craft training for journeyman and apprentice levels if all of the following apply:

- A. A project meets the prevailing wage requirement under Title 29, Chapter 69, Section 6960 of the Delaware Code.
- B. The contractor employs 10 or more total employees.
- C. The project is not a federal highway project

Failure to provide required craft training on the project may subject the successful contractor and/or subcontractor(s) to penalties as outlined in Title 29, Chapter 69, Section 6962(c)(13) of the Delaware Code.

Craft(s)

Contractor Name:

Contractor Address:

Contractor Program

Registration Number(s)

On this line also indicate whether DE, Other State (identify) or US Registration Number

Or

☐ **Craft Training requirements are not applicable because:**

Authorized Representative (typed or printed):

Authorized Representative (signature):

Title:

Sworn to and Subscribed before me this _____ day of _____, 20____.

My Commission expires _____. NOTARY PUBLIC _____.

THIS PAGE MUST BE SIGNED AND NOTARIZED TO BE CONSIDERED.

BID BOND

TO ACCOMPANY PROPOSAL
(Not necessary if security is used)

KNOW ALL MEN BY THESE PRESENTS That: _____
_____ of _____ in the County of _____
_____ and State of _____ as **Principal**, and _____
_____ of _____ in the County of _____
and State of _____ as **Surety**, legally authorized to do business in the State of Delaware
("State"), are held and firmly unto the **State** in the sum of _____
_____ Dollars (\$ _____), or _____ percent not to exceed _____
_____ Dollars (\$ _____)
of amount of bid on Contract No. _____, to be paid to the **State** for the use and
benefit of _____ (*insert State agency name*) for which payment
well and truly to be made, we do bind ourselves, our and each of our heirs, executors, administrators, and
successors, jointly and severally for and in the whole firmly by these presents.

NOW THE CONDITION OF THIS OBLIGATION IS SUCH That if the above bonded **Principal**
who has submitted to the _____ (*insert State agency name*) a
certain proposal to enter into this contract for the furnishing of certain material and/or services within the
State, shall be awarded this Contract, and if said **Principal** shall well and truly enter into and execute this
Contract as may be required by the terms of this Contract and approved by the _____
_____ (*insert State agency name*) this Contract to be entered into within twenty days after
the date of official notice of the award thereof in accordance with the terms of said proposal, then this
obligation shall be void or else to be and remain in full force and virtue.

Sealed with _____ seal and dated this _____ day of _____ in the year of our Lord two
thousand and _____ (20____).

SEALED, AND DELIVERED IN THE
Presence of

Corporate
Seal

By:

Name of Bidder (Organization)

Authorized Signature

Attest _____

Title

Witness: _____

By:

Name of Surety

AIA[®] Document A132[™] – 2019

Standard Form of Agreement Between Owner and Contractor, Construction Manager as Adviser Edition

AGREEMENT made as of the day of in the year
(In words, indicate day, month, and year.)

BETWEEN the Owner:
(Name, legal status, address, and other information)

and the Contractor:
(Name, legal status, address, and other information)

for the following Project:
(Name, location, and detailed description)

The Construction Manager:
(Name, legal status, address, and other information)

The Architect:
(Name, legal status, address, and other information)

The Owner and Contractor agree as follows.

ADDITIONS AND DELETIONS:

The author of this document has added information needed for its completion. The author may also have revised the text of the original AIA standard form. An *Additions and Deletions Report* that notes added information as well as revisions to the standard form text is available from the author and should be reviewed. A vertical line in the left margin of this document indicates where the author has added necessary information and where the author has added to or deleted from the original AIA text.

This document has important legal consequences. Consultation with an attorney is encouraged with respect to its completion or modification.

This document is intended to be used in conjunction with AIA Documents A232[™]–2019, General Conditions of the Contract for Construction, Construction Manager as Adviser Edition; B132[™]–2019, Standard Form of Agreement Between Owner and Architect, Construction Manager as Adviser Edition; and C132[™]–2019, Standard Form of Agreement Between Owner and Construction Manager as Adviser. AIA Document A232[™]–2019 is adopted in this document by reference. Do not use with other general conditions unless this document is modified.

Init.

TABLE OF ARTICLES

- 1 THE CONTRACT DOCUMENTS
- 2 THE WORK OF THIS CONTRACT
- 3 DATE OF COMMENCEMENT AND DATES OF SUBSTANTIAL COMPLETION
- 4 CONTRACT SUM
- 5 PAYMENTS
- 6 DISPUTE RESOLUTION
- 7 TERMINATION OR SUSPENSION
- 8 MISCELLANEOUS PROVISIONS
- 9 ENUMERATION OF CONTRACT DOCUMENTS

EXHIBIT A INSURANCE AND BONDS

EXHIBIT B DETERMINATION OF THE COST OF THE WORK

ARTICLE 1 THE CONTRACT DOCUMENTS

The Contract Documents consist of this Agreement, Conditions of the Contract (General, Supplementary, and other Conditions), Drawings, Specifications, Addenda issued prior to execution of this Agreement, other documents listed in this Agreement, and Modifications issued after execution of this Agreement, all of which form the Contract, and are as fully a part of the Contract as if attached to this Agreement or repeated herein. The Contract represents the entire and integrated agreement between the parties herein and supersedes prior negotiations, representations, or agreements, either written or oral. An enumeration of the Contract Documents, other than Modifications, appears in Article 9.

ARTICLE 2 THE WORK OF THIS CONTRACT

The Contractor shall fully execute the Work described in the Contract Documents, except as specifically indicated in the Contract Documents to be the responsibility of others.

ARTICLE 3 DATE OF COMMENCEMENT AND DATES OF SUBSTANTIAL COMPLETION

§ 3.1 The date of commencement of the Work shall be:

(Check one of the following boxes.)

☐ The date of this Agreement.

☐ A date set forth in a notice to proceed issued by the Owner.

☐ Established as follows:

(Insert a date or a means to determine the date of commencement of the Work.)

If a date of commencement of the Work is not selected, then the date of commencement shall be the date of this Agreement.

§ 3.2 The Contract Time shall be measured from the date of commencement of the Work.

Init.

§ 3.3 Substantial Completion of the Project or Portions Thereof

§ 3.3.1 Subject to adjustments of the Contract Time as provided in the Contract Documents, the date of Substantial Completion of the Work of all of the Contractors for the Project will be:
(Insert the date of Substantial Completion of the Work of all Contractors for the Project.)

§ 3.3.2 Subject to adjustments of the Contract Time as provided in the Contract Documents, if portions of the Work of all of the Contractors for the Project are to be completed prior to Substantial Completion of the entire Work of all of the Contractors for the Project, the Contractors shall achieve Substantial Completion of such portions by the following dates:

Portion of Work	Substantial Completion Date

§ 3.4 When the Work of this Contract, or any Portion Thereof, is Substantially Complete

§ 3.4.1 Subject to adjustments of the Contract Time as provided in the Contract Documents, the Contractor shall substantially complete the entire Work of this Contract:
(Check one of the following boxes and complete the necessary information.)

- ☐ Not later than () calendar days from the date of commencement of the Work.
- ☐ By the following date:

§ 3.4.2 Subject to adjustments of the Contract Time as provided in the Contract Documents, if portions of the Work of this Contract are to be substantially complete prior to when the entire Work of this Contract shall be substantially complete, the Contractor shall substantially complete such portions by the following dates:

Portion of Work	Date to be substantially complete

§ 3.4.3 If the Contractor fails to substantially complete the Work of this Contract, or portions thereof, as provided in this Section 3.4, liquidated damages, if any, shall be assessed as set forth in Section 4.5.

ARTICLE 4 CONTRACT SUM

§ 4.1 The Owner shall pay the Contractor the Contract Sum in current funds for the Contractor's performance of the Contract. The Contract Sum shall be one of the following:
(Check the appropriate box.)

- ☐ Stipulated Sum, in accordance with Section 4.2 below
- ☐ Cost of the Work plus the Contractor's Fee, in accordance with Section 4.3 below
- ☐ Cost of the Work plus the Contractor's Fee with a Guaranteed Maximum Price, in accordance with Section 4.4 below

(Based on the selection above, complete Section 4.2, 4.3 or 4.4 below.)

§ 4.2 Stipulated Sum

§ 4.2.1 The Contract Sum shall be (\$), subject to additions and deductions as provided in the Contract Documents.

§ 4.2.2 Alternates

§ 4.2.2.1 Alternates, if any, included in the Contract Sum:

Item	Price

§ 4.2.2.2 Subject to the conditions noted below, the following alternates may be accepted by the Owner following execution of this Agreement. Upon acceptance, the Owner shall issue a Modification to this Agreement.
(Insert below each alternate and the conditions that must be met for the Owner to accept the alternate.)

Item	Price	Conditions for Acceptance

§ 4.2.3 Allowances, if any, included in the Contract Sum:
(Identify each allowance.)

Item	Price

§ 4.2.4 Unit prices, if any:
(Identify the item and state the unit price, and quantity limitations, if any, to which the unit price will be applicable.)

Item	Units and Limitations	Price per Unit (\$0.00)

§ 4.3 Cost of the Work Plus Contractor's Fee without a Guaranteed Maximum Price

§ 4.3.1 The Cost of the Work is as defined in Exhibit B, Determination of the Cost of the Work.

§ 4.3.2 The Contractor's Fee:

(State a lump sum, percentage of Cost of the Work or other provision for determining the Contractor's Fee.)

§ 4.3.3 The method of adjustment of the Contractor's Fee for changes in the Work:

§ 4.3.4 Limitations, if any, on a Subcontractor's overhead and profit for increases in the cost of its portion of the Work:

§ 4.3.5 Rental rates for Contractor-owned equipment shall not exceed percent (%) of the standard rental rate paid at the place of the Project.

§ 4.3.6 Unit prices, if any:

(Identify the item and state the unit price and quantity limitations, if any, to which the unit price will be applicable.)

Item	Units and Limitations	Price per Unit (\$0.00)

§ 4.3.7 The Contractor shall prepare and submit to the Construction Manager, within 14 days of executing this Agreement, a written Control Estimate for the Owner's review and approval. The Control Estimate shall include the items in Section B.1 of Exhibit B, Determination of the Cost of the Work.

§ 4.4 Cost of the Work Plus Contractor's Fee with a Guaranteed Maximum Price

§ 4.4.1 The Cost of the Work is as defined in Exhibit B, Determination of the Cost of the Work.

§ 4.4.2 The Contractor's Fee:

(State a lump sum, percentage of Cost of the Work or other provision for determining the Contractor's Fee.)

§ 4.4.3 The method of adjustment of the Contractor's Fee for changes in the Work:

§ 4.4.4 Limitations, if any, on a Subcontractor's overhead and profit for increases in the cost of its portion of the Work:

§ 4.4.5 Rental rates for Contractor-owned equipment shall not exceed percent (%) of the standard rental rate paid at the place of the Project.

§ 4.4.6 Unit Prices, if any:
(Identify the item and state the unit price and quantity limitations, if any, to which the unit price will be applicable.)

Item	Units and Limitations	Price per Unit (\$0.00)

§ 4.4.7 Guaranteed Maximum Price

§ 4.4.7.1 The Contract Sum is guaranteed by the Contractor not to exceed (\$), subject to additions and deductions by Change Order as provided in the Contract Documents. This maximum sum is referred to in the Contract Documents as the Guaranteed Maximum Price. Costs which would cause the Guaranteed Maximum Price to be exceeded shall be paid by the Contractor without reimbursement by the Owner.

§ 4.4.7.2 Alternates

§ 4.4.7.2.1 Alternates, if any, included in the Guaranteed Maximum Price:

Item	Price

§ 4.4.7.2.2 Subject to the conditions noted below, the following alternates may be accepted by the Owner following execution of this Agreement. Upon acceptance, the Owner shall issue a Modification to this Agreement.
(Insert below each alternate and the conditions that must be met for the Owner to accept the alternate.)

Item	Price	Conditions for Acceptance

§ 4.4.7.3 Allowances, if any, included in the Guaranteed Maximum Price:
(Identify each allowance.)

Item	Price

§ 4.4.7.4 Assumptions, if any, upon which the Guaranteed Maximum Price is based:
(Identify each assumption.)

§ 4.4.8 To the extent that the Contract Documents are anticipated to require further development, the Guaranteed Maximum Price includes the costs attributable to such further development consistent with the Contract Documents and reasonably inferable therefrom. Such further development does not include changes in scope, systems, kinds and quality of materials, finishes, or equipment, all of which, if required, shall be incorporated by Change Order.

§ 4.4.9 The Owner shall authorize preparation of revisions to the Contract Documents that incorporate the agreed-upon assumptions contained in Section 4.4.7.4. The Owner shall promptly furnish such revised Contract Documents

Init.

to the Contractor. The Contractor shall notify the Owner and Architect of any inconsistencies between the agreed-upon assumptions contained in Section 4.4.7.4 and the revised Contract Documents.

§ 4.5 Liquidated damages, if any:

(Insert terms and conditions for liquidated damages, if any, to be assessed in accordance with Section 3.4.)

§ 4.6 Other:

(Insert provisions for bonus, cost savings or other incentives, if any, that might result in a change to the Contract Sum.)

ARTICLE 5 PAYMENTS

§ 5.1 Progress Payments

§ 5.1.1 Based upon Applications for Payment submitted to the Construction Manager by the Contractor, and Certificates for Payment issued by the Construction Manager and Architect, the Owner shall make progress payments on account of the Contract Sum, to the Contractor, as provided below and elsewhere in the Contract Documents.

§ 5.1.2 The period covered by each Application for Payment shall be one calendar month ending on the last day of the month, or as follows:

§ 5.1.3 Provided that an Application for Payment is received by the Construction Manager not later than the day of a month, the Owner shall make payment of the amount certified to the Contractor not later than the day of the month. If an Application for Payment is received by the Construction Manager after the application date fixed above, payment of the amount certified shall be made by the Owner not later than () days after the Construction Manager receives the Application for Payment.

(Federal, state or local laws may require payment within a certain period of time.)

§ 5.1.4 Progress Payments Where the Contract Sum is Based on a Stipulated Sum

§ 5.1.4.1 Each Application for Payment shall be based on the most recent schedule of values submitted by the Contractor in accordance with the Contract Documents. The schedule of values shall allocate the entire Contract Sum among the various portions of the Work. The schedule of values shall be prepared in such form, and supported by such data to substantiate its accuracy, as the Construction Manager and Architect may require. This schedule of values shall be used as a basis for reviewing the Contractor's Applications for Payment.

§ 5.1.4.2 Applications for Payment shall show the percentage of completion of each portion of the Work as of the end of the period covered by the Application for Payment.

§ 5.1.4.3 In accordance with AIA Document A232™-2019, General Conditions of the Contract for Construction, Construction Manager as Adviser Edition, and subject to other provisions of the Contract Documents, the amount of each progress payment shall be computed as follows:

§ 5.1.4.3.1 The amount of each progress payment shall first include:

- .1 That portion of the Contract Sum properly allocable to completed Work;
- .2 That portion of the Contract Sum properly allocable to materials and equipment delivered and suitably stored at the site for subsequent incorporation in the completed construction, or, if approved in advance by the Owner, suitably stored off the site at a location agreed upon in writing; and
- .3 That portion of Construction Change Directives that the Architect determines, in the Architect's professional judgment, to be reasonably justified.

§ 5.1.4.3.2 The amount of each progress payment shall then be reduced by:

- .1 The aggregate of any amounts previously paid by the Owner;

Init.

- .2 The amount, if any, for Work that remains uncorrected and for which the Architect has previously withheld a Certificate for Payment as provided in Article 9 of AIA Document A232-2019;
- .3 Any amount for which the Contractor does not intend to pay a Subcontractor or material supplier, unless the Work has been performed by others the Contractor intends to pay;
- .4 For Work performed or defects discovered since the last payment application, any amount for which the Architect may withhold payment, or nullify a Certificate of Payment in whole or in part, as provided in Article 9 of AIA Document A232-2019; and
- .5 Retainage withheld pursuant to Section 5.1.7.

§ 5.1.5 Progress Payments Where the Contract Sum is Based on the Cost of the Work without a Guaranteed Maximum Price

§ 5.1.5.1 With each Application for Payment, the Contractor shall submit the cost control information required in Exhibit B, Determination of the Cost of the Work, along with payrolls, petty cash accounts, receipted invoices, or invoices with check vouchers attached, and any other evidence required by the Owner, Construction Manager or Architect to demonstrate that payments already made by the Contractor on account of the Cost of the Work equal or exceed progress payments already received by the Contractor, plus payrolls for the period covered by the present Application for Payment, less that portion of the payments attributable to the Contractor's Fee.

§ 5.1.5.2 Applications for Payment shall show the Cost of the Work actually incurred by the Contractor through the end of the period covered by the Application for Payment and for which the Contractor has made or intends to make actual payment prior to the next Application for Payment.

§ 5.1.5.3 In accordance with AIA Document A232-2019 and subject to other provisions of the Contract Documents, the amount of each progress payment shall be computed as follows:

§ 5.1.5.3.1 The amount of each progress payment shall first include:

- .1 The Cost of the Work as described in Exhibit B, Determination of the Cost of the Work;
- .2 That portion of Construction Change Directives that the Architect determines, in the Architect's professional judgment, to be reasonably justified; and
- .3 The Contractor's Fee computed upon the Cost of the Work described in the preceding Section 5.1.5.3.1.1 at the rate stated in Section 4.3.2; or if the Contractor's Fee is stated as a fixed sum in Section 4.3.2 an amount which bears the same ratio to that fixed-sum Fee as the Cost of the Work included in Section 5.1.5.3.1.1 bears to a reasonable estimate of the probable Cost of the Work upon its completion.

§ 5.1.5.3.2 The amount of each progress payment shall then be reduced by:

- .1 The aggregate of any amounts previously paid by the Owner;
- .2 The amount, if any, for Work that remains uncorrected and for which the Architect has previously withheld a Certificate for Payment as provided in Article 9 of AIA Document A232-2019;
- .3 Any amount for which the Contractor does not intend to pay a Subcontractor or material supplier, unless the Work has been performed by others the Contractor intends to pay;
- .4 For Work performed or defects discovered since the last payment application, any amount for which the Architect may withhold payment, or nullify a Certificate of Payment in whole or in part, as provided in Article 9 of AIA Document A232-2019;
- .5 The shortfall, if any, indicated by the Contractor in the documentation required by Section 5.1.5.1 to substantiate prior Applications for Payment, or resulting from errors subsequently discovered by the Owner's auditors in such documentation; and
- .6 Retainage withheld pursuant to Section 5.1.7.

§ 5.1.5.4 The Owner, Construction Manager and Contractor shall agree upon a mutually acceptable procedure for review and approval of payments to Subcontractors and the percentage of retainage held on Subcontracts, and the Contractor shall execute subcontracts in accordance with those agreements.

§ 5.1.5.5 In taking action on the Contractor's Applications for Payment, the Construction Manager and Architect shall be entitled to rely on the accuracy and completeness of the information furnished by the Contractor, and such action shall not be deemed to be a representation that (1) the Construction Manager and Architect have made a detailed examination, audit or arithmetic verification of the documentation submitted in accordance with Article 5 or

other supporting data; (2) that the Construction Manager and Architect have made exhaustive or continuous on-site inspections; or (3) that the Construction Manager and Architect have made examinations to ascertain how or for what purposes the Contractor has used amounts previously paid on account of the Contract. Such examinations, audits and verifications, if required by the Owner, will be performed by the Owner's auditors acting in the sole interest of the Owner.

§ 5.1.5.6 Except with the Owner's prior approval, the Contractor shall not make advance payments to suppliers for materials or equipment which have not been delivered and stored at the site.

§ 5.1.5.7 If final completion of the Work is materially delayed through no fault of the Contractor, then the Owner shall pay the Contractor any additional amounts in accordance with Article 9 of AIA Document A232-2019.

§ 5.1.6 Progress Payments Where the Contract Sum is Based on the Cost of the Work with a Guaranteed Maximum Price

§ 5.1.6.1 With each Application for Payment, the Contractor shall submit payrolls, petty cash accounts, receipted invoices or invoices with check vouchers attached, and any other evidence required by the Owner, Construction Manager or Architect to demonstrate that payments already made by the Contractor on account of the Cost of the Work equal or exceed progress payments already received by the Contractor plus payrolls for the period covered by the present Application for Payment, less that portion of the progress payments attributable to the Contractor's Fee.

§ 5.1.6.2 Each Application for Payment shall be based on the most recent schedule of values submitted by the Contractor in accordance with the Contract Documents. The schedule of values shall allocate the entire Guaranteed Maximum Price among: (1) the various portions of the Work; (2) any contingency for costs that are included in the Guaranteed Maximum Price but not otherwise allocated to another line item or included in a Change Order; and (3) the Contractor's Fee.

§ 5.1.6.2.1 The schedule of values shall be prepared in such form, and supported by such data to substantiate its accuracy, as the Construction Manager and Architect may require. This schedule of values shall be used as a basis for reviewing the Contractor's Applications for Payment.

§ 5.1.6.2.2 The allocation of the Guaranteed Maximum Price under this Section 5.1.6.2 shall not constitute a separate guaranteed maximum price for the Cost of the Work of each individual line item in the schedule of values.

§ 5.1.6.2.3 When the Contractor allocates costs from a contingency to another line item in the schedule of values, the Contractor shall submit supporting documentation to the Architect and Construction Manager.

§ 5.1.6.3 Applications for Payment shall show the percentage of completion of each portion of the Work as of the end of the period covered by the Application for Payment. The percentage of completion shall be the lesser of (1) the percentage of that portion of the Work which has actually been completed; or (2) the percentage obtained by dividing (a) the expense that has actually been incurred by the Contractor on account of that portion of the Work and for which the Contractor has made payment or intends to make payment prior to the next Application for Payment by (b) the share of the Guaranteed Maximum Price allocated to that portion of the Work in the schedule of values.

§ 5.1.6.4 In accordance with AIA Document A232-2019, and subject to other provisions of the Contract Documents, the amount of each progress payment shall be computed as follows:

§ 5.1.6.4.1 The amount of each progress payment shall first include:

- 1 That portion of the Guaranteed Maximum Price properly allocable to completed Work as determined by multiplying the percentage of completion of each portion of the Work by the share of the Guaranteed Maximum Price allocated to that portion of the Work in the most recent schedule of values;
- 2 That portion of the Guaranteed Maximum Price properly allocable to materials and equipment delivered and suitably stored at the site for subsequent incorporation in the completed construction or, if approved in writing in advance by the Owner, suitably stored off the site at a location agreed upon in writing;
- 3 That portion of Construction Change Directives that the Architect determines, in the Architect's professional judgment, to be reasonably justified; and

- .4 The Contractor's Fee, computed upon the Cost of the Work described in the preceding Sections 5.1.6.4.1.1 and 5.1.6.4.1.2 at the rate stated in Section 4.4.2 or, if the Contractor's Fee is stated as a fixed sum in that Section, an amount that bears the same ratio to that fixed-sum fee as the Cost of the Work included in Sections 5.1.6.4.1.1 and 5.1.6.4.1.2 bears to a reasonable estimate of the probable Cost of the Work upon its completion.

§ 5.1.6.4.2 The amount of each progress payment shall then be reduced by:

- .1 The aggregate of any amounts previously paid by the Owner;
- .2 The amount, if any, for Work that remains uncorrected and for which the Architect has previously withheld a Certificate for Payment as provided in Article 9 of AIA Document A232-2019;
- .3 Any amount for which the Contractor does not intend to pay a Subcontractor or material supplier, unless the Work has been performed by others the Contractor intends to pay;
- .4 For Work performed or defects discovered since the last payment application, any amount for which the Architect may withhold payment, or nullify a Certificate of Payment in whole or in part, as provided in Article 9 of AIA Document A232-2019;
- .5 The shortfall, if any, indicated by the Contractor in the documentation required by Section 5.1.6.1 to substantiate prior Applications for Payment, or resulting from errors subsequently discovered by the Owner's auditors in such documentation; and
- .6 Retainage withheld pursuant to Section 5.1.7.

§ 5.1.6.5 The Owner and the Contractor shall agree upon a mutually acceptable procedure for review and approval of payments to Subcontractors and the percentage of retainage held on Subcontracts, and the Contractor shall execute subcontracts in accordance with those agreements.

§ 5.1.6.6 In taking action on the Contractor's Applications for Payment, the Construction Manager and Architect shall be entitled to rely on the accuracy and completeness of the information furnished by the Contractor and such action shall not be deemed to be a representation that (1) the Construction Manager or Architect have made a detailed examination, audit, or arithmetic verification of the documentation submitted in accordance with Section 5.1.6.1 or other supporting data; (2) that the Construction Manager or Architect have made exhaustive or continuous on-site inspections; or (3) that the Construction Manager or Architect have made examinations to ascertain how or for what purposes the Contractor has used amounts previously paid on account of the Contract. Such examinations, audits, and verifications, if required by the Owner, will be performed by the Owner's auditors acting in the sole interest of the Owner.

§ 5.1.6.7 Except with the Owner's prior approval, the Contractor shall not make advance payments to suppliers for materials or equipment which have not been delivered and stored at the site.

§ 5.1.6.8 If final completion of the Work is materially delayed through no fault of the Contractor, then the Owner shall pay the Contractor any additional amounts in accordance with Article 9 of AIA Document A232-2019.

§ 5.1.7 Retainage

§ 5.1.7.1 For each progress payment made prior to when the Work of this Contract is substantially complete, the Owner may withhold the following amount, as retainage, from the payment otherwise due:

(Insert a percentage or amount to be withheld as retainage from each Application for Payment. The amount of retainage may be limited by governing law.)

§ 5.1.7.1.1 The following items are not subject to retainage:

(Insert any items not subject to the withholding of retainage, such as general conditions, insurance, etc.)

§ 5.1.7.2 Reduction or limitation of retainage, if any, shall be as follows:

(If the retainage established in Section 5.1.7.1 is to be modified prior to when the entire Work of this Contract is substantially complete, including modifications for completion of portions of the Work as provided in Section 3.4.2, insert provisions for such modifications.)

§ 5.1.7.3 Except as set forth in this Section 5.1.7.3, when the Work of this Contract is substantially complete, the Contractor may submit an Application for Payment that includes the retainage withheld from prior Applications for Payment pursuant to this Section 5.1.7. The Application for Payment submitted when the Work of this Contract is substantially complete shall not include retainage as follows:

(Insert any other conditions for release of retainage when the Work of this Contract is substantially complete, or upon Substantial Completion of the Work of all Contractors on the Project or portions thereof.)

§ 5.2 Final Payment

§ 5.2.1 Final Payment Where the Contract Sum is Based on a Stipulated Sum

§ 5.2.1.1 Final payment, constituting the entire unpaid balance of the Contract Sum, shall be made by the Owner to the Contractor when

- .1 the Contractor has fully performed the Contract except for the Contractor's responsibility to correct Work as provided in Article 12 of AIA Document A232-2019, and to satisfy other requirements, if any, which extend beyond final payment; and
- .2 a final Certificate for Payment or Project Certificate for Payment has been issued by the Architect.

§ 5.2.1.2 The Owner's final payment to the Contractor shall be made no later than 30 days after the issuance of the final Certificate for Payment or Project Certificate for Payment, or as follows:

§ 5.2.2 Final Payment Where the Contract Sum is Based on the Cost of the Work with or without a Guaranteed Maximum Price

§ 5.2.2.1 Final payment, constituting the entire unpaid balance of the Contract Sum, shall be made by the Owner to the Contractor when

- .1 the Contractor has fully performed the Contract except for the Contractor's responsibility to correct Work as provided in Article 12 of AIA Document A232-2019, and to satisfy other requirements, if any, which extend beyond final payment;
- .2 the Contractor has submitted a final accounting for the Cost of the Work, pursuant to Exhibit B, Determination of the Cost of the Work and a final Application for Payment; and
- .3 a final Certificate for Payment or Project Certificate for Payment has been issued by the Architect in accordance with Exhibit B, Determination of the Cost of the Work.

§ 5.2.2.2 The Owner's final payment to the Contractor shall be made no later than 30 days after the issuance of the final Certificate for Payment or Project Certificate for Payment, or as follows:

§ 5.3 Payments due and unpaid under the Contract shall bear interest from the date payment is due at the rate stated below, or in the absence thereof, at the legal rate prevailing from time to time at the place where the Project is located.

(Insert rate of interest agreed upon, if any.)

%

ARTICLE 6 DISPUTE RESOLUTION

§ 6.1 Initial Decision Maker

The Architect will serve as Initial Decision Maker pursuant to Article 15 of AIA Document A232-2019, unless the parties appoint below another individual, not a party to this Agreement, to serve as Initial Decision Maker.

(If the parties mutually agree, insert the name, address and other contact information of the Initial Decision Maker, if other than the Architect.)

Init.

§ 6.2 Binding Dispute Resolution

For any Claim subject to, but not resolved by, mediation pursuant to Article 15 of AIA Document A232–2019, the method of binding dispute resolution shall be as follows:

(Check the appropriate box.)

- ☐ Arbitration pursuant to Article 15 of AIA Document A232–2019.
- ☐ Litigation in a court of competent jurisdiction.
- ☐ Other: *(Specify)*

If the Owner and Contractor do not select a method of binding dispute resolution, or do not subsequently agree in writing to a binding dispute resolution method other than litigation, Claims will be resolved by litigation in a court of competent jurisdiction.

ARTICLE 7 TERMINATION OR SUSPENSION

§ 7.1 Where the Contract Sum is a Stipulated Sum

§ 7.1.1 The Contract may be terminated by the Owner or the Contractor as provided in Article 14 of AIA Document A232–2019.

§ 7.1.1.1 If the Contract is terminated for the Owner's convenience in accordance with Article 14 of AIA Document A232–2019, then the Owner shall pay the Contractor a termination fee as follows:

(Insert the amount of, or method for determining, the fee if any, payable to the Contractor following a termination for the Owner's convenience.)

§ 7.1.2 The Work may be suspended by the Owner as provided in Article 14 of AIA Document A232–2019.

§ 7.2 Where the Contract Sum is Based on the Cost of the Work with or without a Guaranteed Maximum Price

§ 7.2.1 Termination

§ 7.2.1.1 The Contract may be terminated by the Owner or the Contractor as provided in Article 14 of AIA Document A232–2019.

§ 7.2.1.2 Termination by the Owner for Cause

§ 7.2.1.2.1 If the Owner terminates the Contract for cause as provided in Article 14 of AIA Document A232–2019, the Owner shall then only pay the Contractor an amount as follows:

- 1 Take the Cost of the Work incurred by the Contractor to the date of termination;
- 2 Add the Contractor's Fee, computed upon the Cost of the Work to the date of termination at the rate stated in Section 4.3.2 or 4.4.2, as applicable, or, if the Contractor's Fee is stated as a fixed sum in that Section, an amount that bears the same ratio to that fixed-sum Fee as the Cost of the Work at the time of termination bears to a reasonable estimate of the probable Cost of the Work upon its completion;
- 3 Subtract the aggregate of previous payments made by the Owner; and
- 4 Subtract the costs and damages incurred, or to be incurred, by the Owner under Article 14 of AIA Document A232–2019.

§ 7.2.1.2.2 When the Contract Sum is based on the Cost of the Work with a Guaranteed Maximum Price, if the Owner terminates the Contract for cause as provided in Article 14 of AIA Document A232–2019, the amount, if any,

to be paid to the Contractor under Article 14 of AIA Document A232-2019 shall not cause the Guaranteed Maximum Price to be exceeded, nor shall it exceed the amount calculated in Section 7.2.1.2.1.

§ 7.2.1.2.3 The Owner shall also pay the Contractor fair compensation, either by purchase or rental at the election of the Owner, for any equipment owned by the Contractor that the Owner elects to retain and that is not otherwise included in the Cost of the Work under Section 7.2.1.2.1.1. To the extent that the Owner elects to take legal assignment of subcontracts and purchase orders (including rental agreements), the Contractor shall, as a condition of receiving the payments referred to in this Article 7, execute and deliver all such papers and take all such steps, including the legal assignment of such subcontracts and other contractual rights of the Contractor, as the Owner may require for the purpose of fully vesting in the Owner the rights and benefits of the Contractor under such subcontracts or purchase orders. All Subcontracts, purchase orders and rental agreements entered into by the Contractor will contain provisions allowing for assignment to the Owner as described above.

§ 7.2.1.3 Termination by the Owner for Convenience

If the Owner terminates the Contract for convenience in accordance with Article 14 of AIA Document A232-2019, then the Owner shall pay the Contractor a termination fee as follows:

(Insert the amount of or method for determining the fee, if any, payable to the Contractor following a termination for the Owner's convenience.)

§ 7.3 Suspension

The Work may be suspended by the Owner as provided in Article 14 of AIA Document A232-2019; in such case, the Contract Sum and Contract Time shall be increased as provided in Article 14 of AIA Document A232-2019, except that the term "profit" shall be understood to mean the Contractor's Fee as described in Section 4.3.2 or 4.4.2, as applicable, of this Agreement.

ARTICLE 8 MISCELLANEOUS PROVISIONS

§ 8.1 Where reference is made in this Agreement to a provision of AIA Document A232-2019 or another Contract Document, the reference refers to that provision as amended or supplemented by other provisions of the Contract Documents.

§ 8.2 The Owner's representative:

(Name, address, email address, and other information)

§ 8.3 The Contractor's representative:

(Name, address, email address, and other information)

§ 8.4 Neither the Owner's nor the Contractor's representative shall be changed without ten days' prior notice to the other party.

Init.

§ 8.5 Insurance and Bonds

§ 8.5.1 The Owner and the Contractor shall purchase and maintain insurance as set forth in AIA Document A132™–2019, Standard Form of Agreement Between Owner and Contractor, Construction Manager as Adviser Edition, Exhibit A, Insurance and Bonds, and elsewhere in the Contract Documents.

§ 8.5.2 The Contractor shall provide bonds as set forth in AIA Document A132™–2019, Exhibit A, and elsewhere in the Contract Documents.

§ 8.6 Notice in electronic format, pursuant to Article 1 of AIA Document A232–2019, may be given in accordance with AIA Document E203™–2013, Building Information Modeling and Digital Data Exhibit, if completed, or as otherwise set forth below:

(If other than in accordance with AIA Document E203–2013, insert requirements for delivering notice in electronic format such as name, title, and email address of the recipient and whether and how the system will be required to generate a read receipt for the transmission.)

§ 8.7 Relationship of the Parties

Where the Contract is based on the Cost of the Work plus the Contractor's Fee, with or without a Guaranteed Maximum Price, the Contractor accepts the relationship of trust and confidence established by this Agreement and covenants with the Owner to cooperate with the Architect and exercise the Contractor's skill and judgment in furthering the interests of the Owner; to furnish efficient business administration and supervision; to furnish at all times an adequate supply of workers and materials; and to perform the Work in an expeditious and economical manner consistent with the Owner's interests. The Owner agrees to furnish and approve, in a timely manner, information required by the Contractor and to make payments to the Contractor in accordance with the requirements of the Contract Documents.

§ 8.8 Other provisions:

ARTICLE 9 ENUMERATION OF CONTRACT DOCUMENTS

§ 9.1 This Agreement is comprised of the following documents:

- .1 AIA Document A132™–2019, Standard Form of Agreement Between Owner and Contractor, Construction Manager as Adviser Edition
- .2 AIA Document A132™–2019, Exhibit A, Insurance and Bonds Exhibit
- .3 AIA Document A232™–2019, General Conditions of the Contract for Construction, Construction Manager as Adviser Edition
- .4 AIA Document E203™–2013, Building Information Modeling and Digital Data Exhibit, dated as indicated below.
(Insert the date of the E203-2013 incorporated into this Agreement.)

.5 Drawings

Number	Title	Date

.6 Specifications

Section	Title	Date	Pages

.7 Addenda, if any:

Init.

Number	Date	Pages

Portions of Addenda relating to bidding or proposal requirements are not part of the Contract Documents unless the bidding or proposal requirements are also enumerated in this Article 9.

.8 Other Exhibits:

(Check all boxes that apply and include appropriate information identifying the exhibit where required.)

☐ AIA Document A132™–2019, Exhibit B, Determination of the Cost of the Work

☐ AIA Document E235™–2019, Sustainable Projects Exhibit, Construction Manager as Adviser Edition, dated as indicated below:

(Insert the date of the E235-2019 incorporated into this Agreement.)

☐ The Sustainability Plan:

Title	Date	Pages

☐ Supplementary and other Conditions of the Contract.

Document	Title	Date	Pages

.9 Other documents, if any, listed below:

(List here any additional documents that are intended to form part of the Contract Documents. AIA Document A232–2019 provides that the advertisement or invitation to bid, Instructions to Bidders, sample forms, the Contractor's bid or proposal, portions of Addenda relating to bidding or proposal requirements, and other information furnished by the Owner in anticipation of receiving bids or proposals, are not part of the Contract Documents unless enumerated in this Agreement. Any such documents should be listed here only if intended to be part of the Contract Documents.)

This Agreement is entered into as of the day and year first written above.

OWNER (Signature)

CONTRACTOR (Signature)

(Printed name and title)

(Printed name and title)

Additions and Deletions Report for **AIA® Document A132™ – 2019**

This Additions and Deletions Report, as defined on page 1 of the associated document, reproduces below all text the author has added to the standard form AIA document in order to complete it, as well as any text the author may have added to or deleted from the original AIA text. Added text is shown underlined. Deleted text is indicated with a horizontal line through the original AIA text.

Note: This Additions and Deletions Report is provided for information purposes only and is not incorporated into or constitute any part of the associated AIA document. This Additions and Deletions Report and its associated document were generated simultaneously by AIA software at 09:04:21 ET on 12/09/2021.

NOT FOR BIDDING

Certification of Document's Authenticity

AIA® Document D401™ – 2003

I, , hereby certify, to the best of my knowledge, information and belief, that I created the attached final document simultaneously with its associated Additions and Deletions Report and this certification at 09:04:21 ET on 12/09/2021 under Order No. 6216521775 from AIA Contract Documents software and that in preparing the attached final document I made no changes to the original text of AIA® Document A132™ - 2019, Standard Form of Agreement Between Owner and Contractor, Construction Manager as Adviser Edition, as published by the AIA in its software, other than those additions and deletions shown in the associated Additions and Deletions Report.

(Signed) _____

(Title) _____

(Dated) _____

NOT FOR BIDDING

Amendment to Contract for Construction
Between
Delaware Technical and Community College
And

The parties hereby agree and reaffirm that the AIA Document A132 – 2019 “Standard Form of Agreement between Owner and Contractor” between Delaware Technical and Community College (“Owner”) and _____, a _____ corporation (“Contractor”), dated _____, 202_, shall govern this transaction as supplemented by A232-2019 General Conditions of the Contract for Construction, Supplementary General Conditions, and as amended herein (“Contract Documents”). At times Owner and Contractor shall be collectively referred to the “Parties”.

The parties expressly agree to enter into this amendment (“Amendment”) which shall govern in the event of a conflict between the terms of the Contract Documents or any document referenced or incorporated therein, and that any contrary provision of any such document shall be superseded hereby. The parties agree to this Amendment as follows:

1. Contractor represents and warrants that it has not employed or retained any company or person, other than a bona fide employee working primarily for the firm offering professional services, to solicit or secure this agreement, and that he has not been paid or agreed to pay any person, company, corporation, individual, or firm, other than a bona fide employee working primarily for the firm offering professional services, any fee, commission, percentage, gift, or any other consideration, contingent upon or resulting from the award or making of this agreement;
2. All provisions of the Bid Package and Project manual are incorporated herein by reference as though fully set forth. In the event of a conflict between any provision of the Bid Package or Project Manual and the bid or proposal submitted by Contractor, the Bid Package and Project Manual shall control.
3. §3.3 is amended to require substantial completion of all construction not later than _____ days from the commencement of construction. Time is of the essence. If the Contractor fails to complete the work within the time specified, the Contractor shall pay liquidated damages to the Owner in the amount of \$ _____ for each calendar day of delay until the work is completed or accepted. If the Owner terminates the Contractor’s right to proceed, liquidated damages will continue to accrue until the work is completed. These liquidated damages are in addition to all sums and remedies available to Owner upon termination for cause.
4. In the event the attached contract or aggregate of contracts is in excess of \$500,000 for new construction (including painting and decorating) or \$45,000 for alteration, repair,

renovation, rehabilitation, demolition or reconstruction (including painting and decorating of buildings or works) and requires or involves the employment of mechanics and/or laborers, then the minimum wages to be paid to the various classes of laborers and mechanics shall be based upon greater of the Davis-Bacon Wage Rates (if the project is federally funded) or the wages that will be determined by the Delaware Department of Labor, Division of Industrial Affairs, to be prevailing in the county in which the work is to be performed.

5. Contractor shall pay all mechanics and laborers employed directly upon the site of the work, unconditionally and not less often than once a week and without subsequent deduction or rebate on any account, the full amounts accrued at time of payment, computed at wage rates not less than the prevailing wages, regardless of any contractual relationship which may be alleged to exist between the employer and such laborers and mechanics, and shall provide sworn payroll information, as required by the Department of Labor, on a weekly basis.
6. All changes to the scope of construction shall be authorized in writing by Owner in advance. Owner shall not be liable for payment of any change order that has not received prior written authorization. The cost of any change order shall be set forth therein. If no such provision is set forth in the change order, then the cost to the Owner shall be the Contractor's costs for wages, labor costs other than wages, wage taxes, materiel, equipment rentals, insurance and subcontract attributable to the additional activity plus a reasonable sum for overhead and profit not to exceed 5%;
7. Preference in employment of laborers, workers or mechanics shall be given to bona fide legal citizens of the State who have established citizenship by residence of at least 90 days in the State. Contractor shall pay a penalty to the Secretary of Finance equal to the amount of compensation paid to any person in violation of this section;
8. Contractor shall not substitute another subcontractor for any subcontractor whose name was set forth in the statement which accompanied the bid without the written consent of Owner. Contractor shall pay a penalty equal to 150% of the amount of the proposal or subcontract submitted by the subcontractor identified in the accompanying statement for violating this paragraph.
9. Payments are due 30 days after receipt of a valid Application for Payment. Payments due and unpaid after 30 days shall bear simple interest at the rate of 1 percent per month not greater than 12% annual percentage rate;
10. Final payment shall not be due until all non-conforming work has been corrected and all other provisions of the agreement have been met, including, but not limited to, all reporting requirements. Furthermore, a written release of mechanics' liens signed by all persons who would otherwise be entitled to avail themselves of the provisions of Chapter 27 of Title 25 of the Delaware Code, containing a notarized, verified certification signed by the Contractor that all of the persons signing the release constitute all of the persons who have furnished materials and performed labor in and for the construction, erection,

building, improvement, alteration and repair to the date of the release and who would be entitled otherwise to file mechanics' liens claims shall be provided simultaneously with the receipt of final payment;

11. Owner may terminate this agreement or suspend work hereunder for any reason authorized by applicable Delaware law;
12. §6.2 is hereby deleted. The parties reserve all remedies available at law or equity for any dispute not resolved in accordance with §6.1;
13. §7.1.1 is hereby deleted and there shall be no Termination Fee or paid to Contractor. Any reference to a Termination Fee in §14.4.3 of the A232-2019 is also deleted.
14. Article 10 Insurance and Bonds is hereby deleted. Simultaneous with the execution of this contract, Contractor shall also execute a good and sufficient bond for the benefit of Owner, with corporate surety authorized to do business in this State, in a sum equal to 100% of the contract price and the bond form used shall be the standard form issued by the Office of Management and Budget. The bond shall be conditioned upon the faithful compliance and performance by the successful bidder of each and every term and condition of the contract and the proposal and plans and specifications thereof, at the time and in the manner prescribed by the contract and the plans and specifications, including the payment in full, to every firm furnishing materiel or performing labor in the performance of the contract, of all sums of money due it for such labor or materiel. The bond shall also contain the Contractor's guarantee to indemnify and save harmless the Owner from all costs, damages and expenses growing out of or by reason of Contractor's failure to comply and perform the work and complete the contract in accordance with its terms. No firm or surety, in any action brought under 29 Del C §6962, or any successor law, or on the bond required by such statute, shall assert as a defense to such action the claim that the bond given contained a limitation or restriction not provided for by Chapter 69, Title 29 of the Delaware Code, the provisions of which are incorporated herein by reference as though fully set forth. Contractor shall obtain all insurance required by Owner and provide proof thereof prior to execution.;
15. Owner shall have the right to terminate the contract upon receipt of notice from Contractor's surety that bond claims have been made or are anticipated to be made against Contractor on this or any other project of Contractor. If Owner elects to terminate the contract pursuant to this paragraph, it shall be deemed a termination for cause.
16. Owner may, when it considers that its interests so require, cause judgment to be confessed upon the bond. All sums received through confession of judgment shall be paid for the credit of the Owner to the Secretary of Finance;
17. Owner or any of its duly authorized representatives shall have access to any documents, books, papers, and records of Contractor (which are directly pertinent to a specific grant program) for the purpose of making an audit, examination, excerpts, and transcriptions.

Contractor shall maintain all required records for at least three years after Owner makes final payment and all pending matters are closed;

18. Contractor shall submit a report to Owner not less frequently than monthly covering the general progress of the job and describing any problems or factors contributing to delay;
19. During the performance of this contract, the contractor agrees as follows:

The Contractor will not discriminate against any employee or applicant for employment because of race, creed, color, sex, sexual orientation, gender identity, pregnancy, or national origin. The Contractor will take positive steps to ensure that applicants are employed and that employees are treated during employment without regard to their race, creed, color, sex, sexual orientation, gender identity, pregnancy, or national origin. Such action shall include, but not be limited to, the following: employment, upgrading, demotion or transfer; recruitment or recruitment advertising; layoff or termination; rates of pay or other forms of compensation; and selection for training, including apprenticeship. The Contractor agrees to post in conspicuous places available to employees and applicants for employment notices to be provided by the contracting agency setting forth this nondiscrimination clause.

The Contractor will, in all solicitations or advertisements for employees placed by or on behalf of the Contractor, state that all qualified applicants will receive consideration for employment without regard to race, creed, color, sex, sexual orientation or national origin.

All Owner facilities and campus locations, both indoor and outdoor, are tobacco free. Contractor agrees that it will not permit smoking nor the use of any tobacco product by Contractor, its employees, agents, and/or guests or invitees on any Owner facility or campus location utilized in connection with this contract.

20. The parties agree that this agreement shall be governed by and construed pursuant to the laws of The State of Delaware, and that the Delaware courts shall have sole and exclusive jurisdiction of any dispute arising under this agreement.

[Signatures Begin on Following Page]

IN WITNESS WHEREOF, the parties, through their acknowledged and duly authorized agents set forth below, have set their hand and seal on this indenture on this ____ day of _____, 202__.

Delaware Technical and Community College

_____(Seal)
Mark T. Brainard, President

(Contractor)

_____(Seal)
By:

NOT FOR BIDDING

PERFORMANCE BOND

Bond Number: _____

KNOW ALL PERSONS BY THESE PRESENTS, that we, _____, as principal (“**Principal**”), and _____, a _____ corporation, legally authorized to do business in the State of Delaware, as surety (“**Surety**”), are held and firmly bound unto the _____ (“**Owner**”) (*insert State agency name*), in the amount of _____ (\$ _____), to be paid to **Owner**, for which payment well and truly to be made, we do bind ourselves, our and each and every of our heirs, executors, administrations, successors and assigns, jointly and severally, for and in the whole, firmly by these presents.

Sealed with our seals and dated this _____ day of _____, 20____.

NOW THE CONDITION OF THIS OBLIGATION IS SUCH, that if **Principal**, who has been awarded by **Owner** that certain contract known as Contract No. _____ dated the _____ day of _____, 20____ (the “**Contract**”), which Contract is incorporated herein by reference, shall well and truly provide and furnish all materials, appliances and tools and perform all the work required under and pursuant to the terms and conditions of the Contract and the Contract Documents (as defined in the Contract) or any changes or modifications thereto made as therein provided, shall make good and reimburse **Owner** sufficient funds to pay the costs of completing the Contract that **Owner** may sustain by reason of any failure or default on the part of **Principal**, and shall also indemnify and save harmless **Owner** from all costs, damages and expenses arising out of or by reason of the performance of the Contract and for as long as provided by the Contract; then this obligation shall be void, otherwise to be and remain in full force and effect.

Surety, for value received, hereby stipulates and agrees, if requested to do so by **Owner**, to fully perform and complete the work to be performed under the Contract pursuant to the terms, conditions and covenants thereof, if for any cause **Principal** fails or neglects to so fully perform and complete such work.

Surety, for value received, for itself and its successors and assigns, hereby stipulates and agrees that the obligation of **Surety** and its bond shall be in no way impaired or affected by any extension of time, modification, omission, addition or change in or to the Contract or the work to be performed thereunder, or by any payment thereunder before the time required therein, or by any waiver of any provisions thereof, or by any assignment, subletting or other transfer thereof or of any work to be performed or any monies due or to become due thereunder; and **Surety** hereby waives notice of any and all such extensions, modifications, omissions, additions, changes, payments, waivers, assignments, subcontracts and transfers and hereby expressly stipulates and agrees that any and all things done and omitted to be done by and in relation to assignees, subcontractors, and other transferees shall have the same effect as to **Surety** as though done or omitted to be done by or in relation to **Principal**.

Surety hereby stipulates and agrees that no modifications, omissions or additions in or to the terms of the Contract shall in any way whatsoever affect the obligation of **Surety** and its bond.

Any proceeding, legal or equitable, under this Bond may be brought in any court of competent jurisdiction in the State of Delaware. Notices to **Surety** or Contractor may be mailed or delivered to them at their respective addresses shown below.

IN WITNESS WHEREOF, **Principal** and **Surety** have hereunto set their hand and seals, and such of them as are corporations have caused their corporate seal to be hereto affixed and these presents to be signed by their duly authorized officers, the day and year first above written.

PRINCIPAL

Name: _____

Witness or Attest: Address: _____

Name: _____ By: _____ (SEAL)
Name: _____
Title: _____
(Corporate Seal)

SURETY

Name: _____

Witness or Attest: Address: _____

Name: _____ By: _____ (SEAL)
Name: _____
Title: _____
(Corporate Seal)

PAYMENT BOND

Bond Number: _____

KNOW ALL PERSONS BY THESE PRESENTS, that we, _____, as principal (“**Principal**”), and _____, a _____ corporation, legally authorized to do business in the State of Delaware, as surety (“**Surety**”), are held and firmly bound unto the _____ (“**Owner**”) (*insert State agency name*), in the amount of _____ (\$ _____), to be paid to **Owner**, for which payment well and truly to be made, we do bind ourselves, our and each and every of our heirs, executors, administrations, successors and assigns, jointly and severally, for and in the whole firmly by these presents.

Sealed with our seals and dated this _____ day of _____, 20__.

NOW THE CONDITION OF THIS OBLIGATION IS SUCH that if **Principal**, who has been awarded by **Owner** that certain contract known as Contract No. _____ dated the _____ day of _____, 20__ (the “Contract”), which Contract is incorporated herein by reference, shall well and truly pay all and every person furnishing materials or performing labor or service in and about the performance of the work under the Contract, all and every sums of money due him, her, them or any of them, for all such materials, labor and service for which **Principal** is liable, shall make good and reimburse **Owner** sufficient funds to pay such costs in the completion of the Contract as **Owner** may sustain by reason of any failure or default on the part of **Principal**, and shall also indemnify and save harmless **Owner** from all costs, damages and expenses arising out of or by reason of the performance of the Contract and for as long as provided by the Contract; then this obligation shall be void, otherwise to be and remain in full force and effect.

Surety, for value received, for itself and its successors and assigns, hereby stipulates and agrees that the obligation of **Surety** and its bond shall be in no way impaired or affected by any extension of time, modification, omission, addition or change in or to the Contract or the work to be performed thereunder, or by any payment thereunder before the time required therein, or by any waiver of any provisions thereof, or by any assignment, subletting or other transfer thereof or of any work to be performed or any monies due or to become due thereunder; and **Surety** hereby waives notice of any and all such extensions, modifications, omissions, additions, changes, payments, waivers, assignments, subcontracts and transfers and hereby expressly stipulates and agrees that any and all things done and omitted to be done by and in relation to assignees, subcontractors, and other transferees shall have the same effect as to **Surety** as though done or omitted to be done by or in relation to **Principal**.

Surety hereby stipulates and agrees that no modifications, omission or additions in or to the terms of the Contract shall in any way whatsoever affect the obligation of **Surety** and its bond.

Any proceeding, legal or equitable, under this Bond may be brought in any court of competent jurisdiction in the State of Delaware. Notices to **Surety** or Contractor may be mailed or delivered to them at their respective addresses shown below.

IN WITNESS WHEREOF, **Principal** and **Surety** have hereunto set their hand and seals, and such of them as are corporations have caused their corporate seal to be hereto affixed and these presents to be signed by their duly authorized officers, the day and year first above written.

PRINCIPAL

Name: _____

Witness or Attest: Address: _____

Name:

(Corporate Seal)

By: _____ (SEAL)
Name:
Title:

SURETY

Name: _____

Witness or Attest: Address: _____

Name:

(Corporate Seal)

By: _____ (SEAL)
Name:
Title:



AIA Document G732™ – 2019

Application and Certificate for Payment, Construction Manager as Adviser Edition

TO OWNER:	PROJECT: DT & CC	APPLICATION NO: 001	Distribution to:
FROM CONTRACTOR:	VIA CONSTRUCTION MANAGER:	PERIOD TO:	OWNER: ☐
CONTRACT FOR: General Construction	VIA ARCHITECT:	CONTRACT DATE:	CONSTRUCTION MANAGER: ☐
		PROJECT NOS: / /	ARCHITECT: ☐
			CONTRACTOR: ☐
			FIELD: ☐
			OTHER: ☐

CONTRACTOR'S APPLICATION FOR PAYMENT
Application is made for payment, as shown below, in connection with the Contract AIA Document G703™, Continuation Sheet, is attached.

1. ORIGINAL CONTRACT SUM \$0.00
2. NET CHANGES IN THE WORK \$0.00
3. CONTRACT SUM TO DATE (Line 1 + 2) \$0.00 By: _____ Date: _____

4. TOTAL COMPLETED AND STORED TO DATE (Column G on G703) \$0.00 State of: _____

5. RETAINAGE: a. 0 % of Completed Work (Column D + E on G703) \$0.00

b. 0 % of Stored Material (Column F on G703) \$0.00

My Commission expires: _____

CERTIFICATE FOR PAYMENT

Total Retainage (Lines 5a + 5b or Total in Column I of G703) \$0.00

6. TOTAL EARNED LESS RETAINAGE \$0.00 In accordance with the Contract Documents, the Construction Manager and Architect certify to the Owner

(Line 4 minus Line 5 Total) \$0.00 that to the best of their knowledge, information and belief the Work has progressed as

7. LESS PREVIOUS CERTIFICATES FOR PAYMENT \$0.00 indicated, the quantity of the Work is in accordance with the Contract Documents, and the

(Line 6 from prior Certificate) \$0.00 Contractor is entitled to payment of the AMOUNT CERTIFIED.

8. CURRENT PAYMENT DUE \$0.00 (Attach explanation if amount certified differs from the amount applied. Initial all figures on this

9. BALANCE TO FINISH, INCLUDING RETAINAGE \$0.00 Application and on the Continuation Sheet that are changed to conform with the amount certified.)

(Line 3 minus Line 6)

By: _____ Date: _____

By: _____ Date: _____

By: _____ Date: _____

By: _____ Date: _____

By: _____ Date: _____

By: _____ Date: _____

By: _____ Date: _____

By: _____ Date: _____

By: _____ Date: _____

By: _____ Date: _____

By: _____ Date: _____

By: _____ Date: _____

By: _____ Date: _____

By: _____ Date: _____

By: _____ Date: _____



Document G703 CW – 2021

Continuation Sheet for Cost of the Work Projects

[illegible]

SECTION 006300 - CLARIFICATION AND MODIFICATION FORMS

PART 1 - GENERAL

1.1 SECTION INCLUDES

- A. Standard Forms.

1.2 RELATED SECTIONS

- A. General and Supplementary Conditions.

1.3 STANDARD FORMS

- A. Following is a list of the standard Documents published by the American Institute of Architects which will be used during the performance of Work covered by the Contract Documents.
- B. The Contractor shall familiarize himself with the contents of the Documents, as he will not only be required to execute certain Documents, but will be required to prepare certain others in performing his work in accordance with the Contract Documents.
- C. The Contractor will be required to obtain for his own use, those Documents marked with an asterisk (*). The Documents can be obtained, at nominal cost, from the Documents Division, The American Institute of Architects, 1735 New York Avenue, NW, Washington, DC 20006, as well as other local sources.

D. FORMS

A232*	General Conditions of the Contract for Construction
	Change Order (Architect Form)
G732/CM*	Application and Certificate for Payment
G703*	Continuation Sheet
G704	Certificate of Substantial Completion
G705*	Certificate of Insurance
G706*	Contractor's Affidavit of Payment of Debts and Claims
G706A*	Contractor's Affidavit of Release of Liens
G707*	Consent of Surety Company to Final Payment
G707A*	Consent of Surety to Reduction in or Partial Release of Retainage
G805*	List of Subcontractors

PART 2 - PRODUCTS

Not Used

PART 3 - EXECUTION

Not Used

END OF SECTION 006300

AIA® Document A232™ – 2019

General Conditions of the Contract for Construction, Construction Manager as Adviser Edition

for the following PROJECT:

(Name, and location or address)

THE CONSTRUCTION MANAGER:

(Name, legal status, and address)

THE OWNER:

(Name, legal status, and address)

THE ARCHITECT:

(Name, legal status, and address)

TABLE OF ARTICLES

- 1 GENERAL PROVISIONS
- 2 OWNER
- 3 CONTRACTOR
- 4 ARCHITECT AND CONSTRUCTION MANAGER
- 5 SUBCONTRACTORS
- 6 CONSTRUCTION BY OWNER OR BY SEPARATE CONTRACTORS
- 7 CHANGES IN THE WORK
- 8 TIME
- 9 PAYMENTS AND COMPLETION
- 10 PROTECTION OF PERSONS AND PROPERTY
- 11 INSURANCE AND BONDS
- 12 UNCOVERING AND CORRECTION OF WORK

ADDITIONS AND DELETIONS:

The author of this document has added information needed for its completion. The author may also have revised the text of the original AIA standard form. An *Additions and Deletions Report* that notes added information as well as revisions to the standard form text is available from the author and should be reviewed. A vertical line in the left margin of this document indicates where the author has added necessary information and where the author has added to or deleted from the original AIA text.

This document has important legal consequences. Consultation with an attorney is encouraged with respect to its completion or modification.

This document is intended to be used in conjunction with AIA Documents A132™–2019, Standard Form of Agreement Between Owner and Contractor, Construction Manager as Adviser Edition; B132™–2019, Standard Form of Agreement Between Owner and Architect, Construction Manager as Adviser Edition; and C132™–2019, Standard Form of Agreement Between Owner and Construction Manager as Adviser.

Init.

13 MISCELLANEOUS PROVISIONS

14 TERMINATION OR SUSPENSION OF THE CONTRACT

15 CLAIMS AND DISPUTES

NOT FOR BIDDING

Init.

/

AIA Document A232[®] - 2019. Copyright © 1992, 2009, and 2019 by The American Institute of Architects. All rights reserved. The "American Institute of Architects," "AIA," the AIA Logo, and "AIA Contract Documents" are registered trademarks and may not be used without permission. This document was produced by AIA software at 09:09:53 ET on 12/09/2021 under Order No.6216521775 which expires on 08/13/2022, is not for resale, is licensed for one-time use only, and may only be used in accordance with the AIA Contract Documents[®] Terms of Service. To report copyright violations, e-mail copyright@aia.org.
User Notes:

(3B9ADA51)

ARTICLE 1 GENERAL PROVISIONS

§ 1.1 Basic Definitions

§ 1.1.1 The Contract Documents. The Contract Documents are enumerated in the Agreement between the Owner and Contractor (hereinafter the Agreement) and consist of the Agreement, Conditions of the Contract (General, Supplementary and other Conditions), Drawings, Specifications, Addenda issued prior to execution of the Contract, other documents listed in the Agreement, and Modifications issued after execution of the Contract. A Modification is (1) a written amendment to the Contract signed by both parties, (2) a Change Order, (3) a Construction Change Directive, or (4) a written order for a minor change in the Work issued by the Architect. Unless specifically enumerated in the Agreement, the Contract Documents do not include the advertisement or invitation to bid, Instructions to Bidders, sample forms, other information furnished by the Owner in anticipation of receiving bids or proposals, the Contractor's bid or proposal, or portions of addenda relating to bidding or proposal requirements.

§ 1.1.2 The Contract. The Contract Documents form the Contract for Construction. The Contract represents the entire and integrated agreement between the parties hereto and supersedes prior negotiations, representations, or agreements, either written or oral. The Contract may be amended or modified only by a Modification. The Contract Documents shall not be construed to create a contractual relationship of any kind (1) between the Contractor and the Architect or the Architect's consultants, (2) between the Owner and the Construction Manager or the Construction Manager's consultants, (3) between the Owner and the Architect or the Architect's consultants, (4) between the Contractor and the Construction Manager or the Construction Manager's consultants, (5) between the Owner and a Subcontractor or Sub-subcontractor (6) between the Construction Manager and the Architect, or (7) between any persons or entities other than the Owner and Contractor. The Construction Manager and Architect shall, however, be entitled to performance and enforcement of obligations under the Contract intended to facilitate performance of their duties.

§ 1.1.3 The Work. The term "Work" means the construction and services required by the Contract Documents, whether completed or partially completed, and includes all other labor, materials, equipment, and services provided or to be provided by the Contractor to fulfill the Contractor's obligations. The Work may constitute the whole or a part of the Project.

§ 1.1.4 The Project. The Project is the total construction of which the Work performed under the Contract Documents may be the whole or a part and which may include construction by other Contractors, and by the Owner's own forces and Separate Contractors.

§ 1.1.5 Contractors. Contractors are persons or entities, other than the Contractor or Separate Contractors, who perform Work under contracts with the Owner that are administered by the Architect and Construction Manager.

§ 1.1.6 Separate Contractors. Separate Contractors are persons or entities who perform construction under separate contracts with the Owner not administered by the Architect and Construction Manager.

§ 1.1.7 The Drawings. The Drawings are the graphic and pictorial portions of the Contract Documents showing the design, location and dimensions of the Work, generally including plans, elevations, sections, details, schedules, and diagrams.

§ 1.1.8 The Specifications. The Specifications are that portion of the Contract Documents consisting of the written requirements for materials, equipment, systems, standards and workmanship for the Work, and performance of related services.

§ 1.1.9 Instruments of Service. Instruments of Service are representations, in any medium of expression now known or later developed, of the tangible and intangible creative work performed by the Architect and the Architect's consultants under their respective professional services agreements. Instruments of Service may include, without limitation, studies, surveys, models, sketches, drawings, specifications, and other similar materials.

§ 1.1.10 Initial Decision Maker. The Initial Decision Maker is the person identified in the Agreement to render initial decisions on Claims in accordance with Section 15.2. The Initial Decision Maker shall not show partiality to the Owner or Contractor and shall not be liable for results of interpretations or decisions rendered in good faith.

§ 1.2 Correlation and Intent of the Contract Documents

§ 1.2.1 The intent of the Contract Documents is to include all items necessary for the proper execution and completion of the Work by the Contractor. The Contract Documents are complementary, and what is required by one shall be as binding as if required by all; performance by the Contractor shall be required only to the extent consistent with the Contract Documents and reasonably inferable from them as being necessary to produce the indicated results.

§ 1.2.1.1 The invalidity of any provision of the Contract Documents shall not invalidate the Contract or its remaining provisions. If it is determined that any provision of the Contract Documents violates any law, or is otherwise invalid or unenforceable, then that provision shall be revised to the extent necessary to make that provision legal and enforceable. In such case the Contract Documents shall be construed, to the fullest extent permitted by law, to give effect to the parties' intentions and purposes in executing the Contract.

§ 1.2.2 Organization of the Specifications into divisions, sections and articles, and arrangement of Drawings shall not control the Contractor in dividing the Work among Subcontractors or in establishing the extent of Work to be performed by any trade.

§ 1.2.3 Unless otherwise stated in the Contract Documents, words that have well-known technical or construction industry meanings are used in the Contract Documents in accordance with such recognized meanings.

§ 1.3 Capitalization

Terms capitalized in these General Conditions include those that are (1) specifically defined, (2) the titles of numbered articles, or (3) the titles of other documents published by the American Institute of Architects.

§ 1.4 Interpretation

In the interest of brevity the Contract Documents frequently omit modifying words such as "all" and "any" and articles such as "the" and "an," but the fact that a modifier or an article is absent from one statement and appears in another is not intended to affect the interpretation of either statement.

§ 1.5 Ownership and Use of Drawings, Specifications, and Other Instruments of Service

§ 1.5.1 The Architect and the Architect's consultants shall be deemed the authors and owners of their respective Instruments of Service, including the Drawings and Specifications, and retain all common law, statutory, and other reserved rights in their Instruments of Service, including copyrights. The Contractor, Subcontractors, sub-subcontractors, and suppliers shall not own or claim a copyright in the Instruments of Service. Submittal or distribution to meet official regulatory requirements or for other purposes in connection with the Project is not to be construed as publication in derogation of the Architect's or Architect's consultants' reserved rights.

§ 1.5.2 The Contractor, Subcontractors, Sub-subcontractors, and suppliers are authorized to use and reproduce the Instruments of Service provided to them, subject to any protocols established pursuant to Sections 1.7 and 1.8, solely and exclusively for execution of the Work. All copies made under this authorization shall bear the copyright notice, if any, shown on the Instruments of Service. The Contractor, Subcontractors, Sub-subcontractors, and suppliers may not use the Instruments of Service on other projects or for additions to the Project outside the scope of the Work without the specific written consent of the Owner, Architect, and the Architect's consultants.

§ 1.6 Notice

§ 1.6.1 Except as otherwise provided in Section 1.6.2, where the Contract Documents require one party to notify or give notice to the other party, such notice shall be provided in writing to the designated representative of the party to whom the notice is addressed and shall be deemed to have been duly served if delivered in person, by mail, by courier, or by electronic transmission if a method for electronic transmission is set forth in the Agreement.

§ 1.6.2 Notice of Claims as provided in Section 15.1.3 shall be provided in writing and shall be deemed to have been duly served only if delivered to the designated representative of the party to whom the notice is addressed by certified or registered mail, or by courier providing proof of delivery.

§ 1.7 Digital Data Use and Transmission

The parties shall agree upon protocols governing the transmission and use of Instruments of Service or any other information or documentation in digital form. The parties will use AIA Document E203™-2013, Building

Information Modeling and Digital Data Exhibit, to establish the protocols for the development, use, transmission, and exchange of digital data.

§ 1.8 Building Information Models Use and Reliance

Any use of, or reliance on, all or a portion of a building information model without agreement to protocols governing the use of, and reliance on, the information contained in the model and without having those protocols set forth in AIA Document E203™-2013, Building Information Modeling and Digital Data Exhibit, and the requisite AIA Document G202™-2013, Project Building Information Modeling Protocol Form, shall be at the using or relying party's sole risk and without liability to the other party and its contractors or consultants, the authors of, or contributors to, the building information model, and each of their agents and employees.

ARTICLE 2 OWNER

§ 2.1 General

§ 2.1.1 The Owner is the person or entity identified as such in the Agreement and is referred to throughout the Contract Documents as if singular in number. The Owner shall designate in writing a representative who shall have express authority to bind the Owner with respect to all matters requiring the Owner's approval or authorization. Except as otherwise provided in Section 4.2.1, the Construction Manager and the Architect do not have such authority. The term "Owner" means the Owner or the Owner's authorized representative.

§ 2.1.2 The Owner shall furnish to the Contractor, within fifteen days after receipt of a written request, information necessary and relevant for the Contractor to evaluate, give notice of, or enforce mechanic's lien rights. Such information shall include a correct statement of the record legal title to the property on which the Project is located, usually referred to as the site, and the Owner's interest therein.

§ 2.2 Evidence of the Owner's Financial Arrangements

§ 2.2.1 Prior to commencement of the Work, and upon written request by the Contractor, the Owner shall furnish to the Contractor reasonable evidence that the Owner has made financial arrangements to fulfill the Owner's obligations under the Contract. The Contractor shall have no obligation to commence the Work until the Owner provides such evidence. If commencement of the Work is delayed under this Section 2.2.1, the Contract Time shall be extended appropriately.

§ 2.2.2 Following commencement of the Work and upon written request by the Contractor, the Owner shall furnish to the Contractor reasonable evidence that the Owner has made financial arrangements to fulfill the Owner's obligations under the Contract only if (1) the Owner fails to make payments to the Contractor as the Contract Documents require; (2) the Contractor identifies in writing a reasonable concern regarding the Owner's ability to make payment when due; or (3) a change in the Work materially changes the Contract Sum. If the Owner fails to provide such evidence, as required, within fourteen days of the Contractor's request, the Contractor may immediately stop the Work and, in that event, shall notify the Owner that the Work has stopped. However, if the request is made because a change in the Work materially changes the Contract Sum under (3) above, the Contractor may immediately stop only that portion of the Work affected by the change until reasonable evidence is provided. If the Work is stopped under this Section 2.2.2, the Contract Time shall be extended appropriately and the Contract Sum shall be increased by the amount of the Contractor's reasonable costs of shutdown, delay and start-up, plus interest as provided in the Contract Documents.

§ 2.2.3 After the Owner furnishes evidence of financial arrangements under this Section 2.2, the Owner shall not materially vary such financial arrangements without prior notice to the Contractor.

§ 2.2.4 Where the Owner has designated information furnished under this Section 2.2 as "confidential," the Contractor shall keep the information confidential and shall not disclose it to any other person. However, the Contractor may disclose "confidential" information, after seven (7) days' notice to the Owner, where disclosure is required by law, including a subpoena or other form of compulsory legal process issued by a court or governmental entity, or by court or arbitrator(s) order. The Contractor may also disclose "confidential" information to its employees, consultants, sureties, Subcontractors and their employees, Sub-subcontractors, and others who need to know the content of such information solely and exclusively for the Project and who agree to maintain the confidentiality of such information.

§ 2.3 Information and Services Required of the Owner

§ 2.3.1 Except for permits and fees that are the responsibility of the Contractor under the Contract Documents, including those required under Section 3.7.1, the Owner shall secure and pay for necessary approvals, easements, assessments and charges required for construction, use or occupancy of permanent structures or for permanent changes in existing facilities. Unless otherwise provided under the Contract Documents, the Owner, assisted by the Construction Manager, shall secure and pay for the building permit.

§ 2.3.2 The Owner shall retain an architect lawfully licensed to practice architecture, or an entity lawfully practicing architecture, in the jurisdiction where the Project is located. That person or entity is identified as the Architect in the Agreement and is referred to throughout the Contract Documents as if singular in number.

§ 2.3.3 The Owner shall retain a construction manager adviser lawfully practicing construction management in the jurisdiction where the Project is located. That person or entity is identified as the Construction Manager in the Agreement and is referred to throughout the Contract Documents as if singular in number.

§ 2.3.4 If the employment of the Construction Manager or Architect terminates, the Owner shall employ a successor construction manager or architect to whom the Contractor has no reasonable objection and whose status under the Contract Documents shall be that of the Construction Manager or Architect, respectively.

§ 2.3.5 The Owner shall furnish surveys describing physical characteristics, legal limitations and utility locations for the site of the Project, and a legal description of the site. The Contractor shall be entitled to rely on the accuracy of information furnished by the Owner but shall exercise proper precautions relating to the safe performance of the Work.

§ 2.3.6 The Owner shall furnish information or services required of the Owner by the Contract Documents with reasonable promptness. The Owner shall also furnish any other information or services under the Owner's control and relevant to the Contractor's performance of the Work with reasonable promptness after receiving the Contractor's written request for such information or services.

§ 2.3.7 Unless otherwise provided in the Contract Documents, the Owner shall furnish to the Contractor one copy of the Contract Documents for purposes of making reproductions pursuant to Section 1.5.2.

§ 2.3.8 The Owner shall forward all communications to the Contractor through the Construction Manager. Other communication shall be made as set forth in Section 4.2.6.

§ 2.4 Owner's Right to Stop the Work

If the Contractor fails to correct Work that is not in accordance with the requirements of the Contract Documents as required by Section 12.2 or repeatedly fails to carry out Work in accordance with the Contract Documents, the Owner may issue a written order to the Contractor to stop the Work, or any portion thereof, until the cause for such order has been eliminated; however, the right of the Owner to stop the Work shall not give rise to a duty on the part of the Owner to exercise this right for the benefit of the Contractor or any other person or entity, except to the extent required by Section 6.1.3.

§ 2.5 Owner's Right to Carry Out the Work

If the Contractor defaults or neglects to carry out the Work in accordance with the Contract Documents and fails within a ten-day period after receipt of notice from the Owner to commence and continue correction of such default or neglect with diligence and promptness, the Owner may, without prejudice to other remedies the Owner may have, correct such default or neglect. Such action by the Owner and amounts charged to the Contractor are both subject to review by the Construction Manager and prior approval of the Architect, and the Construction Manager or Architect may, pursuant to Section 9.5.1, withhold or nullify a Certificate for Payment in whole or in part, to the extent reasonably necessary to reimburse the Owner for the reasonable cost of correcting such deficiencies, including Owner's expenses and compensation for the Construction Manager's and Architect's and their respective consultants' additional services made necessary by such default, neglect, or failure. If current and future payments are not sufficient to cover such amounts, the Contractor shall pay the difference to the Owner. If the Contractor disagrees with the actions of the Owner or the Architect, or the amounts claimed as costs to the Owner, the Contractor may file a Claim pursuant to Article 15.

Init.

ARTICLE 3 CONTRACTOR

§ 3.1 General

§ 3.1.1 The Contractor is the person or entity identified as such in the Agreement and is referred to throughout the Contract Documents as if singular in number. The Contractor shall be lawfully licensed, if required in the jurisdiction where the Project is located. The Contractor shall designate in writing a representative who shall have express authority to bind the Contractor with respect to all matters under this Contract. The term "Contractor" means the Contractor or the Contractor's authorized representative.

§ 3.1.2 The Contractor shall perform the Work in accordance with the Contract Documents.

§ 3.1.3 The Contractor shall not be relieved of its obligations to perform the Work in accordance with the Contract Documents either by activities or duties of the Construction Manager or Architect in their administration of the Contract, or by tests, inspections or approvals required or performed by persons or entities other than the Contractor.

§ 3.2 Review of Contract Documents and Field Conditions by Contractor

§ 3.2.1 Execution of the Contract by the Contractor is a representation that the Contractor has visited the site, become generally familiar with local conditions under which the Work is to be performed, and correlated personal observations with requirements of the Contract Documents.

§ 3.2.2 Because the Contract Documents are complementary, the Contractor shall, before starting each portion of the Work, carefully study and compare the various Contract Documents relative to that portion of the Work, as well as the information furnished by the Owner pursuant to Section 2.3.5, shall take field measurements of any existing conditions related to that portion of the Work, and shall observe any conditions at the site affecting it. These obligations are for the purpose of facilitating coordination and construction by the Contractor and are not for the purpose of discovering errors, omissions, or inconsistencies in the Contract Documents; however, the Contractor shall promptly report to the Construction Manager and Architect any errors, inconsistencies or omissions discovered by or made known to the Contractor as a request for information submitted to the Construction Manager in such form as the Construction Manager and Architect may require. It is recognized that the Contractor's review is made in the Contractor's capacity as a contractor and not as a licensed design professional, unless otherwise specifically provided in the Contract Documents.

§ 3.2.3 The Contractor is not required to ascertain that the Contract Documents are in accordance with applicable laws, statutes, ordinances, codes, rules and regulations, or lawful orders of public authorities, but the Contractor shall promptly report to the Construction Manager and Architect any nonconformity discovered by or made known to the Contractor as a request for information submitted to Construction Manager in such form as the Construction Manager and Architect may require.

§ 3.2.4 If the Contractor believes that additional cost or time is involved because of clarifications or instructions the Architect issues in response to the Contractor's notices or requests for information pursuant to Sections 3.2.2 or 3.2.3, the Contractor shall submit Claims as provided in Article 15. If the Contractor fails to perform the obligations of Sections 3.2.2 or 3.2.3, the Contractor shall pay such costs and damages to the Owner, subject to section 15.1.7, as would have been avoided if the Contractor had performed such obligations. If the Contractor performs those obligations, the Contractor shall not be liable to the Owner or Architect for damages resulting from errors, inconsistencies or omissions in the Contract Documents, for differences between field measurements or conditions and the Contract Documents, or for nonconformities of the Contract Documents to applicable laws, statutes, ordinances, codes, rules and regulations, and lawful orders of public authorities.

§ 3.3 Supervision and Construction Procedures

§ 3.3.1 The Contractor shall supervise and direct the Work, using the Contractor's best skill and attention. The Contractor shall be solely responsible for, and have control over, construction means, methods, techniques, sequences, and procedures, and for coordinating all portions of the Work under the Contract. If the Contract Documents give specific instructions concerning construction means, methods, techniques, sequences, or procedures, the Contractor shall evaluate the jobsite safety thereof and shall be solely responsible for the jobsite safety of such means, methods, techniques, sequences, or procedures. If the Contractor determines that such means, methods, techniques, sequences or procedures may not be safe, the Contractor shall give timely notice to the Owner, the Construction Manager, and the Architect, and shall propose alternative means, methods, techniques, sequences, or procedures. The Architect shall evaluate the proposed alternative solely for conformance with the design intent

for the completed construction. The Construction Manager shall review the proposed alternative for sequencing, constructability, and coordination impacts on the other Contractors. Unless the Architect or the Construction Manager objects to the Contractor's proposed alternative, the Contractor shall perform the Work using its alternative means, methods, techniques, sequences, or procedures.

§ 3.3.2 The Contractor shall be responsible to the Owner for acts and omissions of the Contractor's employees, Subcontractors and their agents and employees, and other persons or entities performing portions of the Work for, or on behalf of, the Contractor or any of its Subcontractors.

§ 3.3.3 The Contractor shall be responsible for inspection of portions of the Project already performed to determine that such portions are in proper condition to receive subsequent Work.

§ 3.4 Labor and Materials

§ 3.4.1 Unless otherwise provided in the Contract Documents, the Contractor shall provide and pay for labor, materials, equipment, tools, construction equipment and machinery, water, heat, utilities, transportation, and other facilities and services necessary for proper execution and completion of the Work, whether temporary or permanent and whether or not incorporated or to be incorporated in the Work.

§ 3.4.2 Except in the case of minor changes in the Work approved by the Architect in accordance with Section 3.12.8 or ordered by the Architect in accordance with Section 7.4, the Contractor may make substitutions only with the consent of the Owner, after evaluation by the Architect, in consultation with the Construction Manager, and in accordance with a Change Order or Construction Change Directive.

§ 3.4.3 The Contractor shall enforce strict discipline and good order among the Contractor's employees and other persons carrying out the Work. The Contractor shall not permit employment of unfit persons or persons not properly skilled in tasks assigned to them.

§ 3.5 Warranty

§ 3.5.1 The Contractor warrants to the Owner, Construction Manager, and Architect that materials and equipment furnished under the Contract will be of good quality and new unless the Contract Documents require or permit otherwise. The Contractor further warrants that the Work will conform to the requirements of the Contract Documents and will be free from defects, except for those inherent in the quality of the Work the Contract Documents require or permit. Work, materials or equipment not conforming to these requirements may be considered defective. The Contractor's warranty includes remedy for damage or defect caused by abuse, alterations to the Work not executed by the Contractor, improper or insufficient maintenance, improper operation, or normal wear and tear and normal usage. If required by the Construction Manager or Architect, the Contractor shall furnish satisfactory evidence as to the kind and quality of materials and equipment.

§ 3.5.2 All material, equipment, or other special warranties required by the Contract Documents shall be issued in the name of the Owner, or shall be transferable to the Owner, and shall commence in accordance with Section 9.8.4.

§ 3.6 Taxes

The Contractor shall pay sales, consumer, use and similar taxes for the Work or portions thereof provided by the Contractor that are legally enacted when bids are received or negotiations concluded, whether or not yet effective or merely scheduled to go into effect.

§ 3.7 Permits, Fees, Notices, and Compliance with Laws

§ 3.7.1 Unless otherwise provided in the Contract Documents, the Owner, assisted by the Construction Manager, shall secure and pay for the building permit. The Contractor shall secure and pay for other permits, fees, licenses, and inspections by government agencies necessary for proper execution and completion of the Work that are customarily secured after execution of the Contract and legally required at the time bids are received or negotiations concluded.

§ 3.7.2 The Contractor shall comply with and give notices required by applicable laws, statutes, ordinances, codes, rules and regulations, and lawful orders of public authorities applicable to performance of the Work.

Init.

§ 3.7.3 If the Contractor performs Work knowing it to be contrary to applicable laws, statutes, ordinances, codes, rules and regulations, or lawful orders of public authorities, the Contractor shall assume appropriate responsibility for such Work and shall bear the costs attributable to correction.

§ 3.7.4 **Concealed or Unknown Conditions.** If the Contractor encounters conditions at the site that are (1) subsurface or otherwise concealed physical conditions that differ materially from those indicated in the Contract Documents or (2) unknown physical conditions of an unusual nature that differ materially from those ordinarily found to exist and generally recognized as inherent in construction activities of the character provided for in the Contract Documents, the Contractor shall promptly provide notice to the Owner, Construction Manager, and the Architect before conditions are disturbed and in no event later than 14 days after first observance of the conditions. The Architect and Construction Manager will promptly investigate such conditions and, if the Architect, in consultation with the Construction Manager, determines that they differ materially and cause an increase or decrease in the Contractor's cost of, or time required for, performance of any part of the Work, will recommend that an equitable adjustment be made in the Contract Sum or Contract Time, or both. If the Architect, in consultation with the Construction Manager, determines that the conditions at the site are not materially different from those indicated in the Contract Documents and that no change in the terms of the Contract is justified, the Architect shall promptly notify the Owner, Construction Manager, and Contractor, stating the reasons. If the Owner or Contractor disputes the Architect's determination or recommendation, either party may submit a Claim as provided in Article 15.

§ 3.7.5 If, in the course of the Work, the Contractor encounters human remains or recognizes the existence of burial markers, archaeological sites or wetlands not indicated in the Contract Documents, the Contractor shall immediately suspend any operations that would affect them and shall notify the Owner, Construction Manager, and Architect. Upon receipt of such notice, the Owner shall promptly take any action necessary to obtain governmental authorization required to resume the operations. The Contractor shall continue to suspend such operations until otherwise instructed by the Owner but shall continue with all other operations that do not affect those remains or features. Requests for adjustments in the Contract Sum and Contract Time arising from the existence of such remains or features may be made as provided in Article 15.

§ 3.8 Allowances

§ 3.8.1 The Contractor shall include in the Contract Sum all allowances stated in the Contract Documents. Items covered by allowances shall be supplied for such amounts and by such persons or entities as the Owner may direct, but the Contractor shall not be required to employ persons or entities to whom the Contractor has reasonable objection.

§ 3.8.2 Unless otherwise provided in the Contract Documents:

- .1 allowances shall cover the cost to the Contractor of materials and equipment delivered at the site and all required taxes, less applicable trade discounts;
- .2 Contractor's costs for unloading and handling at the site, labor, installation costs, overhead, profit, and other expenses contemplated for stated allowance amounts shall be included in the Contract Sum but not in the allowances; and
- .3 whenever costs are more than or less than allowances, the Contract Sum shall be adjusted accordingly by Change Order. The amount of the Change Order shall reflect (1) the difference between actual costs and the allowances under Section 3.8.2.1 and (2) changes in Contractor's costs under Section 3.8.2.2.

§ 3.8.3 Materials and equipment under an allowance shall be selected by the Owner with reasonable promptness.

§ 3.9 Superintendent

§ 3.9.1 The Contractor shall employ a competent superintendent and necessary assistants who shall be in attendance at the Project site during performance of the Work. The superintendent shall represent the Contractor, and communications given to the superintendent shall be as binding as if given to the Contractor.

§ 3.9.2 The Contractor, as soon as practicable after award of the Contract, shall notify the Owner and Architect, through the Construction Manager, of the name and qualifications of a proposed superintendent. Within 14 days of receipt of the information, the Construction Manager may notify the Contractor, stating whether the Owner, the Construction Manager, or the Architect (1) has reasonable objection to the proposed superintendent or (2) require

additional time for review. Failure of the Construction Manager to provide notice within the 14-day period shall constitute notice of no reasonable objection.

§ 3.9.3 The Contractor shall not employ a proposed superintendent to whom the Owner, Construction Manager, or Architect has made reasonable and timely objection. The Contractor shall not change the superintendent without the Owner's consent, which shall not unreasonably be withheld or delayed.

§ 3.10 Contractor's Construction and Submittal Schedules

§ 3.10.1 The Contractor, promptly after being awarded the Contract, shall submit for the Owner's and Architect's information, and the Construction Manager's use in developing the Project schedule, a Contractor's construction schedule for the Work. The schedule shall contain detail appropriate for the Project, including (1) the date of commencement of the Work, interim schedule milestone dates, and the date of Substantial Completion; (2) an apportionment of the Work by construction activity; and (3) the time required for completion of each portion of the Work. The schedule shall provide for the orderly progression of the Work to completion and shall not exceed time limits current under the Contract Documents. The schedule shall be revised at appropriate intervals as required by the conditions of the Work and Project. The Contractor shall cooperate with the Construction Manager in scheduling and performing the Contractor's Work to avoid conflict with, and as to cause no delay in the work or activities of other Contractors, or the construction or operations of the Owner's own forces or Separate Contractors.

§ 3.10.2 The Contractor, promptly after being awarded the Contract and thereafter as necessary to maintain a current submittal schedule, shall submit a submittal schedule for the Construction Manager's and Architect's approval. The Architect and Construction Manager's approval shall not be unreasonably delayed or withheld. The submittal schedule shall (1) be coordinated with the Contractor's construction schedule, and (2) allow the Construction Manager and Architect reasonable time to review submittals. If the Contractor fails to submit a submittal schedule, or fails to provide submittals in accordance with the approved submittal schedule, the Contractor shall not be entitled to any increase in Contract Sum or extension of Contract Time based on the time required for review of submittals.

§ 3.10.3 The Contractor shall participate with other Contractors, the Construction Manager, and the Owner in reviewing and coordinating all schedules for incorporation into the Project schedule that is prepared by the Construction Manager. The Contractor shall make revisions to the construction schedule and submittal schedule as deemed necessary by the Construction Manager to conform to the Project schedule.

§ 3.10.4 The Contractor shall perform the Work in general accordance with the most recent schedules submitted to the Owner, Construction Manager, and Architect, and incorporated into the approved Project schedule.

§ 3.11 Documents and Samples at the Site

The Contractor shall make available, at the Project site, the Contract Documents, including Change Orders, Construction Change Directives, and other Modifications, in good order and marked currently to indicate field changes and selections made during construction, and the approved Shop Drawings, Product Data, Samples, and similar required submittals. These shall be in electronic form or paper copy, available to the Construction Manager, Architect, and Owner, and delivered to the Construction Manager for submittal to the Owner upon completion of the Work as a record of the Work as constructed.

§ 3.12 Shop Drawings, Product Data, and Samples

§ 3.12.1 Shop Drawings are drawings, diagrams, schedules, and other data specially prepared for the Work by the Contractor or a Subcontractor, Sub-subcontractor, manufacturer, supplier, or distributor to illustrate some portion of the Work.

§ 3.12.2 Product Data are illustrations, standard schedules, performance charts, instructions, brochures, diagrams, and other information furnished by the Contractor to illustrate materials or equipment for some portion of the Work.

§ 3.12.3 Samples are physical examples that illustrate materials, equipment, or workmanship, and establish standards by which the Work will be judged.

§ 3.12.4 Shop Drawings, Product Data, Samples, and similar submittals are not Contract Documents. Their purpose is to demonstrate how the Contractor proposes to conform to the information given and the design concept expressed

Init.

in the Contract Documents for those portions of the Work for which the Contract Documents require submittals. Review by the Architect and Construction Manager is subject to the limitations of Sections 4.2.10 through 4.2.12. Informational submittals upon which the Construction Manager and Architect are not expected to take responsive action may be so identified in the Contract Documents. Submittals that are not required by the Contract Documents may be returned by the Construction Manager or Architect without action.

§ 3.12.5 The Contractor shall review for compliance with the Contract Documents, approve, and submit to the Construction Manager, Shop Drawings, Product Data, Samples, and similar submittals required by the Contract Documents, in accordance with the Project submittal schedule approved by the Construction Manager and Architect or, in the absence of an approved Project submittal schedule, with reasonable promptness and in such sequence as to cause no delay in the Work or in the activities of other Contractors, Separate Contractors, or the Owner's own forces. The Contractor shall cooperate with the Construction Manager in the coordination of the Contractor's Shop Drawings, Product Data, Samples, and similar submittals with related documents submitted by other Contractors.

§ 3.12.6 By submitting Shop Drawings, Product Data, Samples, and similar submittals, the Contractor represents to the Owner, Construction Manager, and Architect, that the Contractor has (1) reviewed and approved them, (2) determined and verified materials, field measurements and field construction criteria related thereto, or will do so, and (3) checked and coordinated the information contained within such submittals with the requirements of the Work and of the Contract Documents.

§ 3.12.7 The Contractor shall perform no portion of the Work for which the Contract Documents require submittal and review of Shop Drawings, Product Data, Samples, or similar submittals until the respective submittal has been reviewed and approved by the Architect.

§ 3.12.8 The Work shall be in accordance with approved submittals except that the Contractor shall not be relieved of responsibility for deviations from the requirements of the Contract Documents by the Architect's approval of Shop Drawings, Product Data, Samples, or similar submittals, unless the Contractor has specifically notified the Construction Manager and Architect of such deviation at the time of submittal and (1) the Architect has given written approval to the specific deviation as a minor change in the Work, or (2) a Change Order or Construction Change Directive has been issued authorizing the deviation. The Contractor shall not be relieved of responsibility for errors or omissions in Shop Drawings, Product Data, Samples, or similar submittals, by the Architect's approval thereof.

§ 3.12.9 The Contractor shall direct specific attention, in writing or on resubmitted Shop Drawings, Product Data, Samples, or similar submittals, to revisions other than those requested by the Construction Manager and Architect on previous submittals. In the absence of such notice, the Architect's approval of a resubmission shall not apply to such revisions.

§ 3.12.10 The Contractor shall not be required to provide professional services that constitute the practice of architecture or engineering unless such services are specifically required by the Contract Documents for a portion of the Work or unless the Contractor needs to provide such services in order to carry out the Contractor's responsibilities for construction means, methods, techniques, sequences, and procedures. The Contractor shall not be required to provide professional services in violation of applicable law.

§ 3.12.10.1 If professional design services or certifications by a design professional related to systems, materials, or equipment are specifically required of the Contractor by the Contract Documents, the Owner and the Architect will specify all performance and design criteria that such services must satisfy. The Contractor shall be entitled to rely upon the adequacy and accuracy of the performance and design criteria provided in the Contract Documents. The Contractor shall cause such services or certifications to be provided by an appropriately licensed design professional, whose signature and seal shall appear on all drawings, calculations, specifications, certifications, Shop Drawings, and other submittals prepared by such professional. Shop Drawings, and other submittals related to the Work, designed or certified by such professional, if prepared by others, shall bear such professional's written approval when submitted to the Architect. The Owner, the Architect, and the Construction Manager shall be entitled to rely upon the adequacy and accuracy of the services, certifications, and approvals performed or provided by such design professionals, provided the Owner and Architect have specified to the Contractor the performance and design criteria that such services must satisfy. Pursuant to this Section 3.12.10, the Architect will review and approve or take other appropriate action on submittals only for the limited purpose of checking for conformance with

information given and the design concept expressed in the Contract Documents. The Construction Manager shall review submittals for sequencing, constructability, and coordination impacts on other Contractors.

§ 3.12.10.2 If the Contract Documents require the Contractor's design professional to certify that the Work has been performed in accordance with the design criteria, the Contractor shall furnish such certifications to the Construction Manager and Architect at the time and in the form specified by the Architect.

§ 3.13 Use of Site

§ 3.13.1 The Contractor shall confine operations at the site to areas permitted by applicable laws, statutes, ordinances, codes, rules and regulations, lawful orders of public authorities, and the Contract Documents and shall not unreasonably encumber the site with materials or equipment.

§ 3.13.2 The Contractor shall coordinate the Contractor's operations with, and secure the approval of, the Construction Manager before using any portion of the site.

§ 3.14 Cutting and Patching

§ 3.14.1 The Contractor shall be responsible for cutting, fitting, or patching required to complete the Work or to make its parts fit together properly. All areas requiring cutting, fitting, or patching shall be restored to the condition existing prior to the cutting, fitting, or patching, unless otherwise required by the Contract Documents.

§ 3.14.2 The Contractor shall not damage or endanger a portion of the Work or fully or partially completed construction of the Owner, Separate Contractors, or of other Contractors by cutting, patching, or otherwise altering such construction, or by excavation. The Contractor shall not cut or otherwise alter construction by the Owner, Separate Contractors, or by other Contractors except with written consent of the Construction Manager, Owner, and such other Contractors or Separate Contractors. Consent shall not be unreasonably withheld. The Contractor shall not unreasonably withhold, from the Separate Contractors, other Contractors, or the Owner, its consent to cutting or otherwise altering the Work.

§ 3.15 Cleaning Up

§ 3.15.1 The Contractor shall keep the premises and surrounding area free from accumulation of waste materials and rubbish caused by operations under the Contract. At completion of the Work, the Contractor shall remove waste materials, rubbish, the Contractor's tools, construction equipment, machinery, and surplus materials from and about the Project.

§ 3.15.2 If the Contractor fails to clean up as provided in the Contract Documents, the Owner, or Construction Manager with the Owner's approval may do so and the Owner shall be entitled to reimbursement from the Contractor.

§ 3.16 Access to Work

The Contractor shall provide the Owner, Construction Manager, and Architect with access to the Work in preparation and progress wherever located.

§ 3.17 Royalties, Patents and Copyrights

The Contractor shall pay all royalties and license fees. The Contractor shall defend suits or claims for infringement of copyrights and patent rights and shall hold the Owner, Construction Manager, and Architect harmless from loss on account thereof, but shall not be responsible for defense or loss when a particular design, process, or product of a particular manufacturer or manufacturers is required by the Contract Documents, or where the copyright violations are contained in Drawings, Specifications, or other documents prepared by the Owner, Architect, or Construction Manager. However, if an infringement of a copyright or patent is discovered by, or made known to, the Contractor, the Contractor shall be responsible for the loss unless the information is promptly furnished to the Architect through the Construction Manager.

§ 3.18 Indemnification

§ 3.18.1 To the fullest extent permitted by law, the Contractor shall indemnify and hold harmless the Owner, Construction Manager, Architect, Construction Manager's and Architect's consultants, and agents and employees of any of them from and against claims, damages, losses, and expenses, including but not limited to attorneys' fees, arising out of or resulting from performance of the Work, provided that such claim, damage, loss, or expense is

Init.

attributable to bodily injury, sickness, disease or death, or to injury to or destruction of tangible property (other than the Work itself), but only to the extent caused by the negligent acts or omissions of the Contractor, a Subcontractor, anyone directly or indirectly employed by them, or anyone for whose acts they may be liable, regardless of whether or not such claim, damage, loss, or expense is caused in part by a party indemnified hereunder. Such obligation shall not be construed to negate, abridge, or reduce other rights or obligations of indemnity that would otherwise exist as to a party or person described in this Section 3.18.

§ 3.18.2 In claims against any person or entity indemnified under this Section 3.18 by an employee of the Contractor, a Subcontractor, anyone directly or indirectly employed by them, or anyone for whose acts they may be liable, the indemnification obligation under Section 3.18.1 shall not be limited by a limitation on amount or type of damages, compensation, or benefits payable by or for the Contractor or a Subcontractor under workers' compensation acts, disability benefit acts, or other employee benefit acts.

ARTICLE 4 ARCHITECT AND CONSTRUCTION MANAGER

§ 4.1 General

§ 4.1.1 The Architect is the person or entity retained by the Owner pursuant to Section 2.3.2 and identified as such in the Agreement.

§ 4.1.2 The Construction Manager is the person or entity retained by the Owner pursuant to Section 2.3.3 and identified as such in the Agreement.

§ 4.1.3 Duties, responsibilities, and limitations of authority of the Construction Manager and Architect as set forth in the Contract Documents shall not be restricted, modified, or extended without written consent of the Owner, Construction Manager, Architect, and Contractor. Consent shall not be unreasonably withheld.

§ 4.2 Administration of the Contract

§ 4.2.1 The Construction Manager and Architect will provide administration of the Contract as described in the Contract Documents and will be the Owner's representatives during construction until the date the Architect issues the final Certificate for Payment. The Construction Manager and Architect will have authority to act on behalf of the Owner only to the extent provided in the Contract Documents.

§ 4.2.2 The Architect will visit the site at intervals appropriate to the stage of construction, or as otherwise agreed with the Owner, to become generally familiar with the progress and quality of the portion of the Work completed, and to determine in general if the Work observed is being performed in a manner indicating that the Work, when fully completed, will be in accordance with the Contract Documents. However, the Architect will not be required to make exhaustive or continuous on-site inspections to check the quality or quantity of the Work. On the basis of the site visits, the Architect will keep the Owner and the Construction Manager reasonably informed about the progress and quality of the portion of the Work completed, and promptly report to the Owner and Construction Manager known deviations from the Contract Documents and defects and deficiencies observed in the Work.

§ 4.2.3 The Construction Manager shall provide one or more representatives who shall be in attendance at the Project site whenever the Work is being performed. The Construction Manager will determine in general if the Work observed is being performed in accordance with the Contract Documents, will keep the Owner and Architect reasonably informed of the progress of the Work, and will promptly report to the Owner and Architect known deviations from the Contract Documents and the most recent Project schedule, and defects and deficiencies observed in the Work.

§ 4.2.4 The Construction Manager will schedule and coordinate the activities of the Contractor and other Contractors in accordance with the latest approved Project schedule.

§ 4.2.5 The Construction Manager, except to the extent required by Section 4.2.4, and Architect will not have control over, charge of, or responsibility for, the construction means, methods, techniques, sequences or procedures, or for the safety precautions and programs in connection with the Work, since these are solely the Contractor's rights and responsibilities under the Contract Documents, and neither will be responsible for the Contractor's failure to perform the Work in accordance with the requirements of the Contract Documents. Neither the Construction Manager nor the Architect will have control over or charge of, or be responsible for acts or omissions of, the

Contractor, Subcontractors, or their agents or employees, or of any other persons or entities performing portions of the Work.

§ 4.2.6 Communications. The Owner shall communicate with the Contractor and the Construction Manager's consultants through the Construction Manager about matters arising out of or relating to the Contract Documents. The Owner and Construction Manager shall include the Architect in all communications that relate to or affect the Architect's services or professional responsibilities. The Owner shall promptly notify the Architect of the substance of any direct communications between the Owner and the Construction Manager otherwise relating to the Project. Communications by and with the Architect's consultants shall be through the Architect. Communications by and with Subcontractors and suppliers shall be through the Contractor. Communications by and with other Contractors shall be through the Construction Manager. Communications by and with the Owner's own forces and Separate Contractors shall be through the Owner. The Contract Documents may specify other communication protocols.

§ 4.2.7 The Construction Manager and Architect will review and certify all Applications for Payment by the Contractor, in accordance with the provisions of Article 9.

§ 4.2.8 The Architect and Construction Manager have authority to reject Work that does not conform to the Contract Documents, and will notify each other about the rejection. Whenever the Construction Manager considers it necessary or advisable, the Construction Manager will have authority to require inspection or testing of the Work in accordance with Sections 13.4.2 and 13.4.3, upon written authorization of the Owner, whether or not the Work is fabricated, installed or completed. The foregoing authority of the Construction Manager will be subject to the provisions of Sections 4.2.18 through 4.2.20 inclusive, with respect to interpretations and decisions of the Architect. However, neither the Architect's nor the Construction Manager's authority to act under this Section 4.2.8 nor a decision made by either of them in good faith either to exercise or not to exercise such authority shall give rise to a duty or responsibility of the Architect or the Construction Manager to the Contractor, Subcontractors, suppliers, their agents or employees, or other persons performing any of the Work.

§ 4.2.9 Utilizing the submittal schedule provided by the Contractor, the Construction Manager shall prepare, and revise as necessary, a Project submittal schedule incorporating information from other Contractors, the Owner, Owner's consultants, Owner's Separate Contractors and vendors, governmental agencies, and participants in the Project under the management of the Construction Manager. The Project submittal schedule and any revisions shall be submitted to the Architect for approval.

§ 4.2.10 The Construction Manager will receive and promptly review for conformance with the submittal requirements of the Contract Documents, all submittals from the Contractor such as Shop Drawings, Product Data, and Samples. Where there are other Contractors, the Construction Manager will also check and coordinate the information contained within each submittal received from the Contractor and other Contractors, and transmit to the Architect those recommended for approval. By submitting Shop Drawings, Product Data, Samples, and similar submittals, the Construction Manager represents to the Owner and Architect that the Construction Manager has reviewed and recommended them for approval. The Construction Manager's actions will be taken in accordance with the Project submittal schedule approved by the Architect or, in the absence of an approved Project submittal schedule, with reasonable promptness while allowing sufficient time to permit adequate review by the Architect.

§ 4.2.11 The Architect will review and approve, or take other appropriate action upon, the Contractor's submittals such as Shop Drawings, Product Data, and Samples, but only for the limited purpose of checking for conformance with information given and the design concept expressed in the Contract Documents. The Architect's action will be taken in accordance with the submittal schedule approved by the Architect or, in the absence of an approved submittal schedule, with reasonable promptness while allowing sufficient time in the Architect's professional judgment to permit adequate review. Upon the Architect's completed review, the Architect shall transmit its submittal review to the Construction Manager.

§ 4.2.12 Review of the Contractor's submittals by the Construction Manager and Architect is not conducted for the purpose of determining the accuracy and completeness of other details such as dimensions and quantities, or for substantiating instructions for installation or performance of equipment or systems, all of which remain the responsibility of the Contractor as required by the Contract Documents. The Construction Manager and Architect's review of the Contractor's submittals shall not relieve the Contractor of the obligations under Sections 3.3, 3.5, and 3.12. The Construction Manager and Architect's review shall not constitute approval of safety precautions or of any

Init.

construction means, methods, techniques, sequences, or procedures. The Architect's approval of a specific item shall not indicate approval of an assembly of which the item is a component.

§ 4.2.13 The Construction Manager will prepare Change Orders and Construction Change Directives.

§ 4.2.14 The Construction Manager and the Architect will take appropriate action on Change Orders or Construction Change Directives in accordance with Article 7, and the Architect will have authority to order minor changes in the Work as provided in Section 7.4. The Architect, in consultation with the Construction Manager, will investigate and make determinations and recommendations regarding concealed and unknown conditions as provided in Section 3.7.4.

§ 4.2.15 Utilizing the documents provided by the Contractor, the Construction Manager will maintain at the site for the Owner one copy of all Contract Documents, approved Shop Drawings, Product Data, Samples, and similar required submittals, in good order and marked currently to record all changes and selections made during construction. These will be available to the Architect and the Contractor, and will be delivered to the Owner upon completion of the Project.

§ 4.2.16 The Construction Manager will assist the Architect in conducting inspections to determine the date or dates of Substantial Completion and the date of final completion; issue Certificates of Substantial Completion in conjunction with the Architect pursuant to Section 9.8; and receive and forward to the Owner written warranties and related documents required by the Contract and assembled by the Contractor pursuant to Section 9.10. The Construction Manager will forward to the Architect a final Application and Certificate for Payment or final Project Application and Project Certificate for Payment upon the Contractor's compliance with the requirements of the Contract Documents.

§ 4.2.17 If the Owner and Architect agree, the Architect will provide one or more Project representatives to assist in carrying out the Architect's responsibilities at the site. The Owner shall notify the Construction Manager of any change in the duties, responsibilities and limitations of authority of the Project representatives.

§ 4.2.18 The Architect will interpret and decide matters concerning performance under, and requirements of, the Contract Documents on written request of the Construction Manager, Owner, or Contractor through the Construction Manager. The Architect's response to such requests will be made in writing within any time limits agreed upon or otherwise with reasonable promptness.

§ 4.2.19 Interpretations and decisions of the Architect will be consistent with the intent of, and reasonably inferable from, the Contract Documents and will be in writing or in the form of drawings. When making such interpretations and decisions, the Architect will endeavor to secure faithful performance by both Owner and Contractor, will not show partiality to either, and will not be liable for results of interpretations or decisions so rendered in good faith.

§ 4.2.20 The Architect's decisions on matters relating to aesthetic effect will be final if consistent with the intent expressed in the Contract Documents.

§ 4.2.21 The Construction Manager will receive and review requests for information from the Contractor, and forward each request for information to the Architect, with the Construction Manager's recommendation. The Architect will review and respond in writing, through the Construction Manager, to requests for information about the Contract Documents. The Construction Manager's recommendation and the Architect's response to each request will be made in writing within any time limits agreed upon or otherwise with reasonable promptness. If appropriate, the Architect will prepare and issue supplemental Drawings and Specifications in response to the requests for information.

ARTICLE 5 SUBCONTRACTORS

§ 5.1 Definitions

§ 5.1.1 A Subcontractor is a person or entity who has a direct contract with the Contractor to perform a portion of the Work at the site. The term "Subcontractor" is referred to throughout the Contract Documents as if singular in number and means a Subcontractor or an authorized representative of the Subcontractor. The term "Subcontractor" does not include other Contractors or Separate Contractors or the subcontractors of other Contractors or Separate Contractors.

§ 5.1.2 A Sub-subcontractor is a person or entity who has a direct or indirect contract with a Subcontractor to perform a portion of the Work at the site. The term "Sub-subcontractor" is referred to throughout the Contract Documents as if singular in number and means a Sub-subcontractor or an authorized representative of the Sub-subcontractor.

§ 5.2 Award of Subcontracts and Other Contracts for Portions of the Work

§ 5.2.1 Unless otherwise stated in the Contract Documents, the Contractor, as soon as practicable after award of the Contract, shall notify the Construction Manager, for review by the Owner, Construction Manager and Architect, of the persons or entities proposed for each principal portion of the Work, including those who are to furnish materials or equipment fabricated to a special design. Within 14 days of receipt of the information, the Construction Manager may notify the Contractor whether the Owner, the Construction Manager or the Architect (1) has reasonable objection to any such proposed person or entity or, (2) requires additional time for review. Failure of the Construction Manager to provide notice within the 14-day period shall constitute notice of no reasonable objection.

§ 5.2.2 The Contractor shall not contract with a proposed person or entity to whom the Owner, Construction Manager or Architect has made reasonable and timely objection. The Contractor shall not be required to contract with anyone to whom the Contractor has made reasonable objection.

§ 5.2.3 If the Owner, Construction Manager or Architect has reasonable objection to a person or entity proposed by the Contractor, the Contractor shall propose another to whom the Owner, Construction Manager or Architect has no reasonable objection. If the proposed but rejected Subcontractor was reasonably capable of performing the Work, the Contract Sum and Contract Time shall be increased or decreased by the difference, if any, occasioned by such change, and an appropriate Change Order shall be issued before commencement of the substitute Subcontractor's Work. However, no increase in the Contract Sum or Contract Time shall be allowed for such change unless the Contractor has acted promptly and responsively in submitting names as required.

§ 5.2.4 The Contractor shall not substitute a Subcontractor, person, or entity for one previously selected if the Owner, Construction Manager or Architect makes reasonable objection to such substitution.

§ 5.3 Subcontractual Relations

By appropriate written agreement, the Contractor shall require each Subcontractor, to the extent of the Work to be performed by the Subcontractor, to be bound to the Contractor by terms of the Contract Documents, and to assume toward the Contractor all the obligations and responsibilities, including the responsibility for safety of the Subcontractor's Work, that the Contractor, by these Contract Documents, assumes toward the Owner, Construction Manager and Architect. Each subcontract agreement shall preserve and protect the rights of the Owner, Construction Manager and Architect under the Contract Documents with respect to the Work to be performed by the Subcontractor so that subcontracting thereof will not prejudice such rights, and shall allow to the Subcontractor, unless specifically provided otherwise in the subcontract agreement, the benefit of all rights, remedies, and redress against the Contractor that the Contractor, by the Contract Documents, has against the Owner. Where appropriate, the Contractor shall require each Subcontractor to enter into similar agreements with Sub-subcontractors. The Contractor shall make available to each proposed Subcontractor, prior to the execution of the subcontract agreement, copies of the Contract Documents to which the Subcontractor will be bound, and, upon written request of the Subcontractor, identify to the Subcontractor terms and conditions of the proposed subcontract agreement that may be at variance with the Contract Documents. Subcontractors will similarly make copies of applicable portions of such documents available to their respective proposed Sub-subcontractors.

§ 5.4 Contingent Assignment of Subcontracts

§ 5.4.1 Each subcontract agreement for a portion of the Work is assigned by the Contractor to the Owner, provided that

- .1 assignment is effective only after termination of the Contract by the Owner for cause pursuant to Section 14.2 and only for those subcontract agreements that the Owner accepts by notifying the Subcontractor and Contractor; and
- .2 assignment is subject to the prior rights of the surety, if any, obligated under bond relating to the Contract.

When the Owner accepts the assignment of a subcontract agreement, the Owner assumes the Contractor's rights and obligations under the subcontract.

§ 5.4.2 Upon such assignment, if the Work has been suspended for more than 30 days, the Subcontractor's compensation shall be equitably adjusted for increases in cost resulting from the suspension.

§ 5.4.3 Upon assignment to the Owner under this Section 5.4, the Owner may further assign the subcontract to a successor Contractor or other entity. If the Owner assigns the subcontract to a successor Contractor or other entity, the Owner shall nevertheless remain legally responsible for all of the successor Contractor's obligations under the subcontract.

ARTICLE 6 CONSTRUCTION BY OWNER OR BY SEPARATE CONTRACTORS

§ 6.1 Owner's Right to Perform Construction with Own Forces and to Award Other Contracts

§ 6.1.1 The Owner reserves the right to perform construction or operations related to the Project with the Owner's own forces, and with Separate Contractors retained under Conditions of the Contract substantially similar to those of this Contract, including those provisions of the Conditions of the Contract related to insurance and waiver of subrogation.

§ 6.1.2 When the Owner performs construction or operations with the Owner's own forces or Separate Contractors, the Owner shall provide for coordination of such forces and Separate Contractors with the work of the Contractor, who shall cooperate with them.

§ 6.1.3 Unless otherwise provided in the Contract Documents, when the Owner performs construction or operations related to the Project with the Owner's own forces or with Separate Contractors, the Owner or its Separate Contractors shall have the same obligations and rights that the Contractor has under the Conditions of the Contract, including, without excluding others, those stated in Article 3, this Article 6, and Articles 10, 11, and 12.

§ 6.2 Mutual Responsibility

§ 6.2.1 The Contractor shall afford the Owner's own forces, Separate Contractors, Construction Manager and other Contractors reasonable opportunity for introduction and storage of their materials and equipment and performance of their activities, and shall connect and coordinate the Contractor's construction and operations with theirs as required by the Contract Documents.

§ 6.2.2 If part of the Contractor's Work depends for proper execution or results upon construction or operations by the Owner's own forces, Separate Contractors or other Contractors, the Contractor shall, prior to proceeding with that portion of the Work, promptly notify the Construction Manager and Architect of apparent discrepancies or defects in the construction or operations by the Owner or Separate Contractor or other Contractors that would render it unsuitable for proper execution and results of the Contractor's Work. Failure of the Contractor to notify the Construction Manager and the Architect of apparent discrepancies or defects prior to proceeding with the Work shall constitute an acknowledgment that the Owner's or Separate Contractor's or other Contractors' completed or partially completed construction is fit and proper to receive the Contractor's Work. The Contractor shall not be responsible for discrepancies or defects in the construction or operations by the Owner or Separate Contractors or other Contractors that are not apparent.

§ 6.2.3 The Contractor shall reimburse the Owner for costs the Owner incurs, including costs that are payable to a Separate Contractors or to other Contractors, because of the Contractor's delays, improperly timed activities or defective construction. The Owner shall be responsible to the Contractor for costs the Contractor incurs because of delays, improperly timed activities, damage to the Work or defective construction by the Owner's own forces, Separate Contractors, or other Contractors.

§ 6.2.4 The Contractor shall promptly remedy damage that the Contractor wrongfully causes to completed or partially completed construction, or to property of the Owner, Separate Contractors, or other Contractors as provided in Section 10.2.5.

§ 6.2.5 The Owner, Separate Contractors, and other Contractors shall have the same responsibilities for cutting and patching as are described for the Contractor in Section 3.14.

§ 6.3 Owner's Right to Clean Up

If a dispute arises among the Contractor, Separate Contractors, other Contractors, and the Owner as to the responsibility under their respective contracts for maintaining the premises and surrounding area free from waste materials and rubbish, the Owner may clean up and the Construction Manager, with notice to the Architect, will allocate the cost among those responsible.

ARTICLE 7 CHANGES IN THE WORK

§ 7.1 General

§ 7.1.1 Changes in the Work may be accomplished after execution of the Contract, and without invalidating the Contract, by Change Order, Construction Change Directive or order for a minor change in the Work, subject to the limitations stated in this Article 7 and elsewhere in the Contract Documents.

§ 7.1.2 A Change Order shall be based upon agreement among the Owner, Construction Manager, Architect and Contractor. A Construction Change Directive requires agreement by the Owner, Construction Manager and Architect and may or may not be agreed to by the Contractor. An order for a minor change in the Work may be issued by the Architect alone.

§ 7.1.3 Changes in the Work shall be performed under applicable provisions of the Contract Documents. The Contractor shall proceed promptly with changes in the Work, unless otherwise provided in the Change Order, Construction Change Directive, or order for a minor change in the Work.

§ 7.2 Change Orders

A Change Order is a written instrument prepared by the Construction Manager and signed by the Owner, Construction Manager, Architect, and Contractor, stating their agreement upon all of the following:

- .1 The change in the Work;
- .2 The amount of the adjustment, if any, in the Contract Sum; and
- .3 The extent of the adjustment, if any, in the Contract Time.

§ 7.3 Construction Change Directives

§ 7.3.1 A Construction Change Directive is a written order prepared by the Construction Manager and signed by the Owner, Construction Manager and Architect, directing a change in the Work prior to agreement on adjustment, if any, in the Contract Sum or Contract Time, or both. The Owner may by Construction Change Directive, without invalidating the Contract, order changes in the Work within the general scope of the Contract consisting of additions, deletions, or other revisions, the Contract Sum and Contract Time being adjusted accordingly.

§ 7.3.2 A Construction Change Directive shall be used in the absence of total agreement on the terms of a Change Order.

§ 7.3.3 If the Construction Change Directive provides for an adjustment to the Contract Sum, the adjustment shall be based on one of the following methods:

- .1 Mutual acceptance of a lump sum properly itemized and supported by sufficient substantiating data to permit evaluation;
- .2 Unit prices stated in the Contract Documents or subsequently agreed upon;
- .3 Cost to be determined in a manner agreed upon by the parties and a mutually acceptable fixed or percentage fee; or
- .4 As provided in Section 7.3.4.

§ 7.3.4 If the Contractor does not respond promptly or disagrees with the method for adjustment in the Contract Sum, the Construction Manager shall determine the adjustment on the basis of reasonable expenditures and savings of those performing the Work attributable to the change, including, in case of an increase in the Contract Sum, an amount for overhead and profit as set forth in the Agreement, or if no such amount is set forth in the Agreement, a reasonable amount. In such case, and also under Section 7.3.3.3, the Contractor shall keep and present, in such form as the Construction Manager may prescribe, an itemized accounting together with appropriate supporting data. Unless otherwise provided in the Contract Documents, costs for the purposes of this Section 7.3.4 shall be limited to the following:

Init.

1. Costs of labor, including applicable payroll taxes, fringe benefits required by agreement or custom, workers' compensation insurance, and other employee costs approved by the Construction Manager and Architect;
2. Costs of materials, supplies, and equipment, including cost of transportation, whether incorporated or consumed;
3. Rental costs of machinery and equipment, exclusive of hand tools, whether rented from the Contractor or others;
4. Costs of premiums for all bonds and insurance, permit fees, and sales, use, or similar taxes, directly related to the change; and
5. Costs of supervision and field office personnel directly attributable to the change.

§ 7.3.5 If the Contractor disagrees with the adjustment in the Contract Time, the Contractor may make a Claim in accordance with applicable provisions of Article 15.

§ 7.3.6 Upon receipt of a Construction Change Directive, the Contractor shall promptly proceed with the change in the Work involved and advise the Construction Manager of the Contractor's agreement or disagreement with the method, if any, provided in the Construction Change Directive for determining the proposed adjustment in the Contract Sum or Contract Time.

§ 7.3.7 A Construction Change Directive signed by the Contractor indicates the Contractor's agreement therewith, including adjustment in Contract Sum and Contract Time or the method for determining them. Such agreement shall be effective immediately and shall be recorded as a Change Order.

§ 7.3.8 The amount of credit to be allowed by the Contractor to the Owner for a deletion or change that results in a net decrease in the Contract Sum shall be actual net cost as confirmed by the Construction Manager and Architect. When both additions and credits covering related Work or substitutions are involved in a change, the allowance for overhead and profit shall be figured on the basis of net increase, if any, with respect to that change.

§ 7.3.9 Pending final determination of the total cost of a Construction Change Directive to the Owner, the Contractor may request payment for Work completed under the Construction Change Directive in Applications for Payment. The Construction Manager and Architect will make an interim determination for purposes of monthly certification for payment for those costs and certify for payment the amount that the Construction Manager and Architect determine to be reasonably justified. The interim determination of cost shall adjust the Contract Sum on the same basis as a Change Order, subject to the right of either party to disagree and assert a Claim in accordance with Article 15.

§ 7.3.10 When the Owner and Contractor agree with a determination made by the Construction Manager and Architect concerning the adjustments in the Contract Sum and Contract Time, or otherwise reach agreement upon the adjustments, such agreement shall be effective immediately and the Construction Manager shall prepare a Change Order. Change Orders may be issued for all or any part of a Construction Change Directive.

§ 7.4 Minor Changes in the Work

The Architect may order minor changes in the Work that are consistent with the intent of the Contract Documents and do not involve an adjustment in the Contract Sum or an extension of the Contract Time. The Architect's order for minor changes shall be in writing. If the Contractor believes that the proposed minor change in the Work will affect the Contract Sum or Contract Time, the Contractor shall notify the Construction Manager and shall not proceed to implement the change in the Work. If the Contractor performs the Work set forth in the Architect's order for a minor change without prior notice to the Construction Manager that such change will affect the Contract Sum or Contract Time, the Contractor waives any adjustment to the Contract Sum or extension of the Contract Time.

ARTICLE 8 TIME

§ 8.1 Definitions

§ 8.1.1 Unless otherwise provided, Contract Time is the period of time, including authorized adjustments, allotted in the Contract Documents for Substantial Completion of the Work.

§ 8.1.2 The date of commencement of the Work is the date established in the Agreement.

§ 8.1.3 The date of Substantial Completion is the date certified by the Architect in accordance with Section 9.8.

§ 8.1.4 The term "day" as used in the Contract Documents shall mean calendar day unless otherwise specifically defined.

§ 8.2 Progress and Completion

§ 8.2.1 Time limits stated in the Contract Documents are of the essence of the Contract. By executing the Agreement, the Contractor confirms that the Contract Time is a reasonable period for performing the Work.

§ 8.2.2 The Contractor shall not knowingly, except by agreement or instruction of the Owner in writing, commence the Work prior to the effective date of insurance required to be furnished by the Contractor and Owner.

§ 8.2.3 The Contractor shall proceed expeditiously with adequate forces and shall achieve Substantial Completion within the Contract Time.

§ 8.3 Delays and Extensions of Time

§ 8.3.1 If the Contractor is delayed at any time in the commencement or progress of the Work by (1) an act or neglect of the Owner, Architect, Construction Manager, or an employee of any of them, or of the Owner's own forces, Separate Contractors, or other Contractors; (2) by changes ordered in the Work; (3) by labor disputes, fire, unusual delay in deliveries, unavoidable casualties, adverse weather conditions documented in accordance with Section 15.1.6.2, or other causes beyond the Contractor's control; (4) by delay authorized by the Owner pending mediation and binding dispute resolution; or (5) by other causes that the Contractor asserts, and the Architect, based on the recommendation of the Construction Manager, determines justify delay, then the Contract Time shall be extended for such reasonable time as the Architect may determine.

§ 8.3.2 Claims relating to time shall be made in accordance with applicable provisions of Article 15.

§ 8.3.3 This Section 8.3 does not preclude recovery of damages for delay by either party under other provisions of the Contract Documents.

ARTICLE 9 PAYMENTS AND COMPLETION

§ 9.1 Contract Sum

§ 9.1.1 The Contract Sum is stated in the Agreement and, including authorized adjustments, is the total amount payable by the Owner to the Contractor for performance of the Work under the Contract Documents.

§ 9.1.2 If unit prices are stated in the Contract Documents or subsequently agreed upon, and if quantities originally contemplated are materially changed so that application of such unit prices to the actual quantities causes substantial inequity to the Owner or Contractor, the applicable unit prices shall be equitably adjusted.

§ 9.2 Schedule of Values

Where the Contract is based on a stipulated sum or Guaranteed Maximum Price, the Contractor shall submit a schedule of values to the Construction Manager, before the first Application for Payment, allocating the entire Contract Sum to the various portions of the Work. The schedule of values shall be prepared in the form, and supported by the data to substantiate its accuracy, required by the Construction Manager and the Architect. This schedule, unless objected to by the Construction Manager or Architect, shall be used as a basis for reviewing the Contractor's Applications for Payment. The Construction Manager shall forward to the Architect the Contractor's schedule of values. Any changes to the schedule of values shall be submitted to the Construction Manager and supported by such data to substantiate its accuracy as the Construction Manager and the Architect may require, and unless objected to by the Construction Manager or the Architect, shall be used as a basis for reviewing the Contractor's subsequent Applications for Payment.

§ 9.3 Applications for Payment

§ 9.3.1 At least fifteen days before the date established for each progress payment, the Contractor shall submit to the Construction Manager an itemized Application for Payment prepared in accordance with the schedule of values, if required under Section 9.2, for completed portions of the Work. The application shall be notarized, if required, and supported by all data substantiating the Contractor's right to payment that the Owner, Construction Manager or

Architect require, such as copies of requisitions, and releases of waivers of lien from Subcontractors and suppliers, and shall reflect retainage if provided for in the Contract Documents.

§ 9.3.1.1 As provided in Section 7.3.9, such applications may include requests for payment on account of changes in the Work that have been properly authorized by Construction Change Directives, or by interim determinations of the Construction Manager and Architect, but not yet included in Change Orders.

§ 9.3.1.2 Applications for Payment shall not include requests for payment for portions of the Work for which the Contractor does not intend to pay a Subcontractor or supplier, unless such Work has been performed by others whom the Contractor intends to pay.

§ 9.3.2 Unless otherwise provided in the Contract Documents, payments shall be made on account of materials and equipment delivered and suitably stored at the site for subsequent incorporation in the Work. If approved in advance by the Owner, payment may similarly be made for materials and equipment suitably stored off the site at a location agreed upon in writing. Payment for materials and equipment stored on or off the site shall be conditioned upon compliance by the Contractor with procedures satisfactory to the Owner to establish the Owner's title to such materials and equipment or otherwise protect the Owner's interest, and shall include the costs of applicable insurance, storage, and transportation to the site, for such materials and equipment stored off the site.

§ 9.3.3 The Contractor warrants that title to all Work covered by an Application for Payment will pass to the Owner no later than the time of payment. The Contractor further warrants that upon submission of an Application for Payment all Work for which Certificates for Payment have been previously issued and payments received from the Owner shall, to the best of the Contractor's knowledge, information, and belief, be free and clear of liens, claims, security interests, or encumbrances, in favor of the Contractor, Subcontractors, suppliers, or other persons or entities that provided labor, materials and equipment relating to the Work.

§ 9.4 Certificates for Payment

§ 9.4.1 Where there is only one Contractor, the Construction Manager will, within seven days after the Construction Manager's receipt of the Contractor's Application for Payment, review the Application, certify the amount the Construction Manager determines is due the Contractor, and forward the Contractor's Application and Certificate for Payment to the Architect. Within seven days after the Architect receives the Contractor's Application for Payment from the Construction Manager, the Architect will either (1) issue to the Owner a Certificate for Payment, in the full amount of the Application for Payment, with a copy to the Construction Manager; or (2) issue to the Owner a Certificate for Payment for such amount as the Architect determines is properly due, and notify the Construction Manager and Owner of the Architect's reasons for withholding certification in part as provided in Section 9.5.1; or (3) withhold certification of the entire Application for Payment, and notify the Construction Manager and Owner of the Architect's reason for withholding certification in whole as provided in Section 9.5.1. The Construction Manager will promptly forward to the Contractor the Architect's notice of withholding certification.

§ 9.4.2 Where there is more than one Contractor performing portions of the Project, the Construction Manager will, within seven days after the Construction Manager receives all of the Contractors' Applications for Payment: (1) review the Applications and certify the amount the Construction Manager determines is due each of the Contractors; (2) prepare a Summary of Contractors' Applications for Payment by combining information from each Contractor's application with information from similar applications for progress payments from the other Contractors; (3) prepare a Project Application and Certificate for Payment; (4) certify the amount the Construction Manager determines is due all Contractors; and (5) forward the Summary of Contractors' Applications for Payment and Project Application and Certificate for Payment to the Architect.

§ 9.4.2.1 Within seven days after the Architect receives the Project Application and Project Certificate for Payment and the Summary of Contractors' Applications for Payment from the Construction Manager, the Architect will either (1) issue to the Owner a Project Certificate for Payment, with a copy to the Construction Manager; or (2) issue to the Owner a Project Certificate for Payment for such amount as the Architect determines is properly due, and notify the Construction Manager and Owner of the Architect's reasons for withholding certification in part as provided in Section 9.5.1; or (3) withhold certification of the entire Project Application for Payment, and notify the Construction Manager and Owner of the Architect's reason for withholding certification in whole as provided in

Section 9.5.1. The Construction Manager will promptly forward the Architect's notice of withholding certification to the Contractors.

§ 9.4.3 The Construction Manager's certification of an Application for Payment or, in the case of more than one Contractor, a Project Application and Certificate for Payment, shall be based upon the Construction Manager's evaluation of the Work and the data in the Application or Applications for Payment. The Construction Manager's certification will constitute a representation that, to the best of the Construction Manager's knowledge, information, and belief, the Work has progressed to the point indicated, the quality of the Work is in accordance with the Contract Documents, and that the Contractor is, or Contractors are, entitled to payment in the amount certified.

§ 9.4.4 The Architect's issuance of a Certificate for Payment or, in the case of more than one Contractor, Project Application and Certificate for Payment, shall be based upon the Architect's evaluation of the Work, the recommendation of the Construction Manager, and data in the Application for Payment or Project Application for Payment. The Architect's certification will constitute a representation that, to the best of the Architect's knowledge, information, and belief, the Work has progressed to the point indicated, the quality of the Work is in accordance with the Contract Documents, and that the Contractor is, or Contractors are, entitled to payment in the amount certified.

§ 9.4.5 The representations made pursuant to Sections 9.4.3 and 9.4.4 are subject to an evaluation of the Work for conformance with the Contract Documents upon Substantial Completion, to results of subsequent tests and inspections, to correction of minor deviations from the Contract Documents prior to completion, and to specific qualifications expressed by the Construction Manager or Architect.

§ 9.4.6 The issuance of a Certificate for Payment or a Project Certificate for Payment will not be a representation that the Construction Manager or Architect has (1) made exhaustive or continuous on-site inspections to check the quality or quantity of the Work; (2) reviewed construction means, methods, techniques, sequences, or procedures; (3) reviewed copies of requisitions received from Subcontractors and suppliers and other data requested by the Owner to substantiate the Contractor's right to payment; or (4) made examination to ascertain how or for what purpose the Contractor has used money previously paid on account of the Contract Sum.

§ 9.5 Decisions to Withhold Certification

§ 9.5.1 The Construction Manager or Architect may withhold a Certificate for Payment or Project Certificate for Payment in whole or in part, to the extent reasonably necessary to protect the Owner, if in the Construction Manager's or Architect's opinion the representations to the Owner required by Section 9.4.3 and 9.4.4 cannot be made. If the Construction Manager or Architect is unable to certify payment in the amount of the Application, the Construction Manager will notify the Contractor and Owner as provided in Section 9.4.1 and 9.4.2. If the Contractor, Construction Manager and Architect cannot agree on a revised amount, the Architect will promptly issue a Certificate for Payment or a Project Certificate for Payment for the amount for which the Architect is able to make such representations to the Owner. The Construction Manager or Architect may also withhold a Certificate for Payment or, because of subsequently discovered evidence, may nullify the whole or a part of a Certificate for Payment or Project Certificate for Payment previously issued, to such extent as may be necessary in the Construction Manager's or Architect's opinion to protect the Owner from loss for which the Contractor is responsible, including loss resulting from the acts and omissions described in Section 3.3.2 because of

- .1 defective Work not remedied;
- .2 third party claims filed or reasonable evidence indicating probable filing of such claims, unless security acceptable to the Owner is provided by the Contractor;
- .3 failure of the Contractor to make payments properly to Subcontractors or suppliers for labor, materials or equipment;
- .4 reasonable evidence that the Work cannot be completed for the unpaid balance of the Contract Sum;
- .5 damage to the Owner or a Separate Contractor or other Contractor;
- .6 reasonable evidence that the Work will not be completed within the Contract Time, and that the unpaid balance would not be adequate to cover actual or liquidated damages for the anticipated delay; or
- .7 repeated failure to carry out the Work in accordance with the Contract Documents.

§ 9.5.2 When either party disputes the Architect's decision regarding a Certificate for Payment under Section 9.5.1, in whole or in part, that party may submit a Claim in accordance with Article 15.

Init.

§ 9.5.3 When the reasons for withholding certification are removed, certification will be made for amounts previously withheld.

§ 9.5.4 If the Architect or Construction Manager withholds certification for payment under Section 9.5.1, the Owner may, at its sole option, issue joint checks to the Contractor and to any Subcontractor or supplier to whom the Contractor failed to make payment for Work properly performed or material or equipment suitably delivered. If the Owner makes payments by joint check, the Owner shall notify the Architect and the Construction Manager, and both will reflect such payment on the next Certificate for Payment.

§ 9.6 Progress Payments

§ 9.6.1 After the Architect has issued a Certificate for Payment or Project Certificate for Payment, the Owner shall make payment in the manner and within the time provided in the Contract Documents, and shall so notify the Construction Manager and Architect.

§ 9.6.2 The Contractor shall pay each Subcontractor, no later than seven days after receipt of payment from the Owner, the amount to which the Subcontractor is entitled, reflecting percentages actually retained from payments to the Contractor on account of the Subcontractor's portion of the Work. The Contractor shall, by appropriate agreement with each Subcontractor, require each Subcontractor to make payments to Sub-subcontractors in a similar manner.

§ 9.6.3 The Construction Manager will, on request, furnish to a Subcontractor, if practicable, information regarding percentages of completion or amounts applied for by the Contractor and action taken thereon by the Owner, Construction Manager and Architect on account of portions of the Work done by such Subcontractor.

§ 9.6.4 The Owner has the right to request written evidence from the Contractor that the Contractor has properly paid Subcontractors and suppliers amounts paid by the Owner to the Contractor for subcontracted Work. If the Contractor fails to furnish such evidence within seven days, the Owner shall have the right to contact Subcontractors and suppliers to ascertain whether they have been properly paid. Neither the Owner, Construction Manager nor Architect shall have an obligation to pay, or to see to the payment of money to, a Subcontractor or supplier, except as may otherwise be required by law.

§ 9.6.5 The Contractor's payments to suppliers shall be treated in a manner similar to that provided in Sections 9.6.2, 9.6.3 and 9.6.4.

§ 9.6.6 A Certificate for Payment, a progress payment, or partial or entire use or occupancy of the Project by the Owner shall not constitute acceptance of Work not in accordance with the Contract Documents.

§ 9.6.7 Unless the Contractor provides the Owner with a payment bond in the full penal sum of the Contract Sum, payments received by the Contractor for Work properly performed by Subcontractors or provided by suppliers shall be held by the Contractor for those Subcontractors or suppliers who performed Work or furnished materials, or both, under contract with the Contractor for which payment was made by the Owner. Nothing contained herein shall require money to be placed in a separate account and not commingled with money of the Contractor, create any fiduciary liability or tort liability on the part of the Contractor for breach of trust, or entitle any person or entity to an award of punitive damages against the Contractor for breach of the requirements of this provision.

§ 9.6.8 Provided the Owner has fulfilled its payment obligations under the Contract Documents, the Contractor shall defend and indemnify the Owner from all loss, liability, damage or expense, including reasonable attorney's fees and litigation expenses, arising out of any lien claim or other claim for payment by any Subcontractor or supplier of any tier. Upon receipt of notice of a lien claim or other claim for payment, the Owner shall notify the Contractor. If approved by the applicable court, when required, the Contractor may substitute a surety bond for the property against which the lien or other claim for payment has been asserted.

§ 9.7 Failure of Payment

If the Construction Manager and Architect do not issue a Certificate for Payment or a Project Certificate for Payment, through no fault of the Contractor, within fourteen days after the Construction Manager's receipt of the Contractor's Application for Payment, or if the Owner does not pay the Contractor within seven days after the date established in the Contract Documents, the amount certified by the Construction Manager and Architect or awarded

by binding dispute resolution, then the Contractor may, upon seven additional days' notice to the Owner, Construction Manager and Architect, stop the Work until payment of the amount owing has been received. The Contract Time shall be extended appropriately and the Contract Sum shall be increased by the amount of the Contractor's reasonable costs of shutdown, delay and start-up, plus interest as provided for in the Contract Documents.

§ 9.8 Substantial Completion

§ 9.8.1 Substantial Completion is the stage in the progress of the Work when the Work or designated portion thereof is sufficiently complete in accordance with the Contract Documents so the Owner can occupy or utilize the Work for its intended use.

§ 9.8.2 When the Contractor considers that the Work, or a portion thereof which the Owner agrees to accept separately, is substantially complete, the Contractor shall notify the Construction Manager, and the Contractor and Construction Manager shall jointly prepare and submit to the Architect a comprehensive list of items to be completed or corrected prior to final payment. Failure to include an item on such list does not alter the responsibility of the Contractor to complete all Work in accordance with the Contract Documents.

§ 9.8.3 Upon receipt of the list, the Architect, assisted by the Construction Manager, will make an inspection to determine whether the Work or designated portion thereof is substantially complete. If the Architect's inspection discloses any item, whether or not included on the list, which is not sufficiently complete in accordance with the Contract Documents so that the Owner can occupy or utilize the Work or designated portion thereof for its intended use, the Contractor shall, before issuance of the Certificate of Substantial Completion, complete or correct such item upon notification by the Architect. In such case, the Contractor shall then submit a request for another inspection by the Architect, assisted by the Construction Manager, to determine Substantial Completion.

§ 9.8.4 When the Architect, assisted by the Construction Manager, determines that the Work of all of the Contractors, or designated portion thereof, is substantially complete, the Construction Manager will prepare, and the Construction Manager and Architect shall execute, a Certificate of Substantial Completion that shall establish the date of Substantial Completion; establish responsibilities of the Owner and Contractor for security, maintenance, heat, utilities, damage to the Work and insurance; and fix the time within which the Contractor shall finish all items on the list accompanying the Certificate. Warranties required by the Contract Documents shall commence on the date of Substantial Completion of the Work or designated portion thereof unless otherwise provided in the Certificate of Substantial Completion.

§ 9.8.5 The Certificate of Substantial Completion shall be submitted to the Owner and Contractor for their written acceptance of responsibilities assigned to them in the Certificate. Upon such acceptance, and consent of surety if any, the Owner shall make payment of retainage applying to the Work or designated portion thereof. Such payment shall be adjusted for Work that is incomplete or not in accordance with the requirements of the Contract Documents.

§ 9.9 Partial Occupancy or Use

§ 9.9.1 The Owner may occupy or use any completed or partially completed portion of the Work at any stage when such portion is designated by separate agreement with the Contractor, provided such occupancy or use is consented to by the insurer and authorized by public authorities having jurisdiction over the Project. Such partial occupancy or use may commence whether or not the portion is substantially complete, provided the Owner and Contractor have accepted in writing the responsibilities assigned to each of them for payments, retainage if any, security, maintenance, heat, utilities, damage to the Work and insurance, and have agreed in writing concerning the period for correction of the Work and commencement of warranties required by the Contract Documents. When the Contractor considers a portion substantially complete, the Contractor and Construction Manager shall jointly prepare and submit a list to the Architect as provided under Section 9.8.2. Consent of the Contractor to partial occupancy or use shall not be unreasonably withheld. The stage of the progress of the Work shall be determined by written agreement between the Owner and Contractor or, if no agreement is reached, by decision of the Architect after consultation with the Construction Manager.

§ 9.9.2 Immediately prior to such partial occupancy or use, the Owner, Construction Manager, Contractor, and Architect shall jointly inspect the area to be occupied or portion of the Work to be used in order to determine and record the condition of the Work.

§ 9.9.3 Unless otherwise agreed upon, partial occupancy or use of a portion or portions of the Work shall not constitute acceptance of Work not complying with the requirements of the Contract Documents.

§ 9.10 Final Completion and Final Payment

§ 9.10.1 Upon completion of the Work, the Contractor shall forward to the Construction Manager a notice that the Work is ready for final inspection and acceptance, and shall also forward to the Construction Manager a final Contractor's Application for Payment. Upon receipt, the Construction Manager shall perform an inspection to confirm the completion of Work of the Contractor. The Construction Manager shall make recommendations to the Architect when the Work of all of the Contractors is ready for final inspection, and shall then forward the Contractors' notices and Application for Payment or Project Application for Payment, to the Architect, who will promptly make such inspection. When the Architect finds the Work acceptable under the Contract Documents and the Contract fully performed, the Construction Manager and Architect will promptly issue a final Certificate for Payment or Project Certificate for Payment stating that to the best of their knowledge, information and belief, and on the basis of their on-site visits and inspections, the Work has been completed in accordance with the Contract Documents and that the entire balance found to be due the Contractor and noted in the final Certificate is due and payable. The Construction Manager's and Architect's final Certificate for Payment or Project Certificate for Payment will constitute a further representation that conditions listed in Section 9.10.2 as precedent to the Contractor's being entitled to final payment have been fulfilled.

§ 9.10.2 Neither final payment nor any remaining retained percentage shall become due until the Contractor submits to the Architect through the Construction Manager (1) an affidavit that payrolls, bills for materials and equipment, and other indebtedness connected with the Work for which the Owner or the Owner's property might be responsible or encumbered (less amounts withheld by Owner) have been paid or otherwise satisfied, (2) a certificate evidencing that insurance required by the Contract Documents to remain in force after final payment is currently in effect, (3) a written statement that the Contractor knows of no reason that the insurance will not be renewable to cover the period required by the Contract Documents, (4) consent of surety, if any, to final payment (5) documentation of any special warranties, such as manufacturers' warranties or specific Subcontractor warranties, and (6), if required by the Owner, other data establishing payment or satisfaction of obligations, such as receipts and releases and waivers of liens, claims, security interests, or encumbrances arising out of the Contract, to the extent and in such form as may be designated by the Owner. If a Subcontractor refuses to furnish a release or waiver required by the Owner, the Contractor may furnish a bond satisfactory to the Owner to indemnify the Owner against such lien, claim, security interest, or encumbrance. If a lien, claim, security interest, or encumbrance remains unsatisfied after payments are made, the Contractor shall refund to the Owner all money that the Owner may be compelled to pay in discharging the lien, claim, security interest, or encumbrance, including all costs and reasonable attorneys' fees.

§ 9.10.3 If, after Substantial Completion of the Work, final completion thereof is materially delayed through no fault of the Contractor or by issuance of Change Orders affecting final completion, and the Construction Manager and Architect so confirm, the Owner shall, upon application by the Contractor and certification by the Construction Manager and Architect, and without terminating the Contract, make payment of the balance due for that portion of the Work fully completed, corrected, and accepted. If the remaining balance for Work not fully completed or corrected is less than retained, stipulated in the Contract Documents, and if bonds have been furnished, the written consent of the surety to payment of the balance due for that portion of the Work fully completed and accepted shall be submitted by the Contractor to the Architect through the Construction Manager prior to certification of such payment. Such payment shall be made under terms and conditions governing final payment, except that it shall not constitute a waiver of Claims.

§ 9.10.4 The making of final payment shall constitute a waiver of Claims by the Owner except those arising from

- .1 liens, Claims, security interests, or encumbrances arising out of the Contract and unsettled;
- .2 failure of the Work to comply with the requirements of the Contract Documents;
- .3 terms of special warranties required by the Contract Documents; or
- .4 audits performed by the Owner, if permitted by the Contract Documents, after final payment.

§ 9.10.5 Acceptance of final payment by the Contractor, a Subcontractor, or a supplier, shall constitute a waiver of claims by that payee except those previously made in writing and identified by that payee as unsettled at the time of final Application for Payment.

ARTICLE 10 PROTECTION OF PERSONS AND PROPERTY

§ 10.1 Safety Precautions and Programs

The Contractor shall be responsible for initiating, maintaining, and supervising all safety precautions and programs in connection with the performance of the Contract. The Contractor shall submit the Contractor's safety program to the Construction Manager for review and coordination with the safety programs of other Contractors. The Construction Manager's responsibilities for review and coordination of safety programs shall not extend to direct control over or charge of the acts or omissions of the Contractors, Subcontractors, agents or employees of the Contractors or Subcontractors, or any other persons performing portions of the Work and not directly employed by the Construction Manager.

§ 10.2 Safety of Persons and Property

§ 10.2.1 The Contractor shall take reasonable precautions for safety of, and shall provide reasonable protection to prevent damage, injury, or loss to

- 1 employees on the Work and other persons who may be affected thereby;
- 2 the Work and materials and equipment to be incorporated therein, whether in storage on or off the site, under care, custody, or control of the Contractor, a Subcontractor, or a Sub-subcontractor;
- 3 other property at the site or adjacent thereto, such as trees, shrubs, lawns, walks, pavements, roadways, structures, and utilities not designated for removal, relocation, or replacement in the course of construction; and
- 4 construction or operations by the Owner, Separate Contractors, or other Contractors.

§ 10.2.2 The Contractor shall comply with, and give notices required by applicable laws, statutes, ordinances, codes, rules and regulations, and lawful orders of public authorities, bearing on safety of persons or property or their protection from damage, injury, or loss.

§ 10.2.3 The Contractor shall implement, erect, and maintain, as required by existing conditions and performance of the Contract, reasonable safeguards for safety and protection, including posting danger signs and other warnings against hazards; promulgating safety regulations; and notifying the owners and users of adjacent sites and utilities of the safeguards.

§ 10.2.4 When use or storage of explosives or other hazardous materials or equipment or unusual methods are necessary for execution of the Work, the Contractor shall exercise utmost care and carry on such activities under supervision of properly qualified personnel.

§ 10.2.5 The Contractor shall promptly remedy damage and loss (other than damage or loss insured under property insurance required by the Contract Documents) to property referred to in Sections 10.2.1.2, 10.2.1.3 and 10.2.1.4 caused in whole or in part by the Contractor, a Subcontractor, a Sub-subcontractor, or anyone directly or indirectly employed by any of them, or by anyone for whose acts they may be liable and for which the Contractor is responsible under Sections 10.2.1.2, 10.2.1.3 and 10.2.1.4. The Contractor may make a Claim for the cost to remedy the damage or loss to the extent such damage or loss is attributable to acts or omissions of the Owner, Construction Manager or Architect or anyone directly or indirectly employed by any of them, or by anyone for whose acts any of them may be liable, and not attributable to the fault or negligence of the Contractor. The foregoing obligations of the Contractor are in addition to the Contractor's obligations under Section 3.18.

§ 10.2.6 The Contractor shall designate a responsible member of the Contractor's organization at the site whose duty shall be the prevention of accidents. This person shall be the Contractor's superintendent unless otherwise designated by the Contractor in writing to the Owner, Construction Manager and Architect.

§ 10.2.7 The Contractor shall not permit any part of the construction or site to be loaded so as to cause damage or create an unsafe condition.

§ 10.2.8 Injury or Damage to Person or Property

If either party suffers injury or damage to person or property because of an act or omission of the other party, or of others for whose acts such party is legally responsible, notice of the injury or damage, whether or not insured, shall be given to the other party within a reasonable time not exceeding 21 days after discovery. The notice shall provide sufficient detail to enable the other party to investigate the matter.

Init.

§ 10.3 Hazardous Materials

§ 10.3.1 The Contractor is responsible for compliance with any requirements included in the Contract Documents regarding hazardous materials or substances. If the Contractor encounters a hazardous material or substance not addressed in the Contract Documents and if reasonable precautions will be inadequate to prevent foreseeable bodily injury or death to persons resulting from a material or substance, including but not limited to asbestos or polychlorinated biphenyl (PCB), encountered on the site by the Contractor, the Contractor shall, upon recognizing the condition, immediately stop Work in the affected area and notify the Owner, Construction Manager and Architect of the condition.

§ 10.3.2 Upon receipt of the Contractor's notice, the Owner shall obtain the services of a licensed laboratory to verify the presence or absence of the material or substance reported by the Contractor and, in the event such material or substance is found to be present, to cause it to be rendered harmless. Unless otherwise required by the Contract Documents, the Owner shall furnish in writing to the Contractor, Construction Manager and Architect the names and qualifications of persons or entities who are to perform tests verifying the presence or absence of the material or substance or who are to perform the task of removal or safe containment of the material or substance. The Contractor, the Construction Manager and the Architect will promptly reply to the Owner in writing stating whether or not any of them has reasonable objection to the persons or entities proposed by the Owner. If the Contractor, Construction Manager or Architect has an objection to a person or entity proposed by the Owner, the Owner shall propose another to whom the Contractor, the Construction Manager and the Architect have no reasonable objection. When the material or substance has been rendered harmless, Work in the affected area shall resume upon written agreement of the Owner and Contractor. By Change Order, the Contract Time shall be extended appropriately and the Contract Sum shall be increased by the amount of the Contractor's reasonable additional costs of shutdown, delay, and start-up.

§ 10.3.3 To the fullest extent permitted by law, the Owner shall indemnify and hold harmless the Contractor, Subcontractors, Construction Manager, Architect, their consultants, and agents and employees of any of them from and against claims, damages, losses, and expenses, including but not limited to attorneys' fees, arising out of or resulting from performance of the Work in the affected area if in fact the material or substance presents the risk of bodily injury or death as described in Section 10.3.1 and has not been rendered harmless, provided that such claim, damage, loss, or expense is attributable to bodily injury, sickness, disease or death, or to injury to or destruction of tangible property (other than the Work itself), except to the extent that such damage, loss, or expense is due to the fault or negligence of the party seeking indemnity.

§ 10.3.4 The Owner shall not be responsible under this Section 10.3 for hazardous materials or substances the Contractor brings to the site unless such materials or substances are required by the Contract Documents. The Owner shall be responsible for hazardous materials or substances required by the Contract Documents, except to the extent of the Contractor's fault or negligence in the use and handling of such materials or substances.

§ 10.3.5 The Contractor shall reimburse the Owner for the cost and expense the Owner incurs (1) for remediation of hazardous materials or substances the Contractor brings to the site and negligently handles, or (2) where the Contractor fails to perform its obligations under Section 10.3.1, except to the extent that the cost and expense are due to the Owner's fault or negligence.

§ 10.3.6 If, without negligence on the part of the Contractor, the Contractor is held liable by a government agency for the cost of remediation of a hazardous material or substance solely by reason of performing Work as required by the Contract Documents, the Owner shall reimburse the Contractor for all cost and expense thereby incurred.

§ 10.4 Emergencies

In an emergency affecting safety of persons or property, the Contractor shall act, at the Contractor's discretion, to prevent threatened damage, injury, or loss. Additional compensation or extension of time claimed by the Contractor on account of an emergency shall be determined as provided in Article 15 and Article 7.

ARTICLE 11 INSURANCE AND BONDS

§ 11.1 Contractor's Insurance and Bonds

§ 11.1.1 The Contractor shall purchase and maintain insurance of the types and limits of liability, containing the endorsements, and subject to the terms and conditions, as described in the Agreement or elsewhere in the Contract Documents. The Contractor shall purchase and maintain the required insurance from an insurance company or

insurance companies lawfully authorized to issue insurance in the jurisdiction where the Project is located. The Owner, Construction Manager and Construction Manager's consultants, and the Architect and Architect's consultants, shall be named as additional insureds under the Contractor's commercial general liability policy or as otherwise described in the Contract Documents.

§ 11.1.2 The Contractor shall provide surety bonds of the types, for such penal sums, and subject to such terms and conditions as required by the Contract Documents. The Contractor shall purchase and maintain the required bonds from a company or companies lawfully authorized to issue surety bonds in the jurisdiction where the Project is located.

§ 11.1.3 Upon the request of any person or entity appearing to be a potential beneficiary of bonds covering payment of obligations arising under the Contract, the Contractor shall promptly furnish a copy of the bonds or shall authorize a copy to be furnished.

§ 11.1.4 Notice of Cancellation or Expiration of Contractor's Required Insurance. Within three (3) business days of the date the Contractor becomes aware of an impending or actual cancellation or expiration of any insurance required by the Contract Documents, the Contractor shall provide notice directly to the Owner, and separately to the Construction Manager, of such impending or actual cancellation or expiration. Upon receipt of notice from the Contractor, the Owner shall, unless the lapse in coverage arises from an act or omission of the Owner, have the right to stop the Work until the lapse in coverage has been cured by the procurement of replacement coverage by the Contractor. The furnishing of notice by the Contractor shall not relieve the Contractor of any contractual obligation to provide any required coverage.

§ 11.2 Owner's Insurance

§ 11.2.1 The Owner shall purchase and maintain insurance of the types and limits of liability, containing the endorsements, and subject to the terms and conditions, as described in the Agreement or elsewhere in the Contract Documents. The Owner shall purchase and maintain the required insurance from an insurance company or insurance companies lawfully authorized to issue insurance in the jurisdiction where the Project is located.

§ 11.2.2 Failure to Purchase Required Property Insurance. If the Owner fails to purchase and maintain the required property insurance, with all of the coverages and in the amounts described in the Agreement or elsewhere in the Contract Documents, the Owner shall inform both the Contractor and the Construction Manager, separately and in writing, prior to commencement of the Work. Upon receipt of notice from the Owner, the Contractor may delay commencement of the Work and may obtain insurance that will protect the interests of the Contractor, Subcontractors, and Sub-Subcontractors in the Work. When the failure to provide coverage has been cured or resolved, the Contract Sum and Contract Time shall be equitably adjusted. In the event the Owner fails to procure coverage, the Owner waives all rights against the Contractor, Subcontractors, and Sub-subcontractors to the extent the loss to the Owner would have been covered by the insurance to have been procured by the Owner. The cost of the insurance shall be charged to the Owner by a Change Order. If the Owner does not provide written notice, and the Contractor is damaged by the failure or neglect of the Owner to purchase or maintain the required insurance, the Owner shall reimburse the Contractor for all reasonable costs and damages attributable thereto.

§ 11.2.3 Notice of Cancellation or Expiration of Owner's Required Property Insurance. Within three (3) business days of the date the Owner becomes aware of an impending or actual cancellation or expiration of any property insurance required by the Contract Documents, the Owner shall provide notice directly to the Contractor, and separately to the Construction Manager, of such impending or actual cancellation or expiration. Unless the lapse in coverage arises from an act or omission of the Contractor: (1) the Contractor, upon receipt of notice from the Owner, shall have the right to stop the Work until the lapse in coverage has been cured by the procurement of replacement coverage by either the Owner or the Contractor; (2) the Contract Time and Contract Sum shall be equitably adjusted; and (3) the Owner waives all rights against the Contractor, Subcontractors, and Sub-subcontractors to the extent any loss to the Owner would have been covered by the insurance had it not expired or been cancelled. If the Contractor purchases replacement coverage, the cost of the insurance shall be charged to the Owner by an appropriate Change Order. The furnishing of notice by the Owner shall not relieve the Owner of any contractual obligation to provide required insurance.

§ 11.3 Waivers of Subrogation

§ 11.3.1 The Owner and Contractor waive all rights against (1) each other and any of their subcontractors, sub-subcontractors, agents, and employees, each of the other; (2) the Construction Manager and Construction Manager's consultants; (3) the Architect and Architect's consultants; (4) other Contractors and any of their subcontractors, sub-subcontractors, agents, and employees; and (5) Separate Contractors, if any, and any of their subcontractors, sub-subcontractors, agents, and employees, for damages caused by fire, or other causes of loss, to the extent those losses are covered by property insurance required by the Agreement or other property insurance applicable to the Project, except such rights as they have to proceeds of such insurance. The Owner or Contractor, as appropriate, shall require similar written waivers in favor of the individuals and entities identified above from the Construction Manager, Construction Manager's consultants, Architect, Architect's consultants, other Contractors, Separate Contractors, subcontractors, and sub-subcontractors. The policies of insurance purchased and maintained by each person or entity agreeing to waive claims pursuant to this Section 11.3.1 shall not prohibit this waiver of subrogation. This waiver of subrogation shall be effective as to a person or entity (1) even though that person or entity would otherwise have a duty of indemnification, contractual or otherwise, (2) even though that person or entity did not pay the insurance premium directly or indirectly, or (3) whether or not the person or entity had an insurable interest in the damaged property.

§ 11.3.2 If during the Project construction period the Owner insures properties, real or personal or both, at or adjacent to the site by property insurance under policies separate from those insuring the Project, or if after final payment property insurance is to be provided on the completed Project through a policy or policies other than those insuring the Project during the construction period, to the extent permissible by such policies, the Owner waives all rights in accordance with the terms of Section 11.3.1 for damages caused by fire or other causes of loss covered by this separate property insurance.

§ 11.4 Loss of Use, Business Interruption, and Delay in Completion Insurance

The Owner, at the Owner's option, may purchase and maintain insurance that will protect the Owner against loss of use of the Owner's property, or the inability to conduct normal operations, due to fire or other causes of loss. The Owner waives all rights of action against the Contractor, Architect, and Construction Manager for loss of use of the Owner's property, due to fire or other hazards however caused.

§ 11.5 Adjustment and Settlement of Insured Loss

§ 11.5.1 A loss insured under the property insurance required by the Agreement shall be adjusted by the Owner as fiduciary and made payable to the Owner as fiduciary for the insureds, as their interests may appear, subject to requirements of any applicable mortgage clause and of Section 11.5.2. The Owner shall pay the Construction Manager, Architect and Contractor their just shares of insurance proceeds received by the Owner, and by appropriate agreements the Construction Manager, Architect and Contractor shall make payments to their consultants and Subcontractors in similar manner.

§ 11.5.2 Prior to settlement of an insured loss, the Owner shall notify the Contractor of the terms of the proposed settlement as well as the proposed allocation of the insurance proceeds. The Contractor shall have 14 days from receipt of notice to object to the proposed settlement or allocation of the proceeds. If the Contractor does not object, the Owner shall settle the loss and the Contractor shall be bound by the settlement and allocation. Upon receipt, the Owner shall deposit the insurance proceeds in a separate account and make the appropriate distributions. Thereafter, if no other agreement is made or the Owner does not terminate the Contract for convenience, the Owner and Contractor shall execute a Change Order for reconstruction of the damaged or destroyed Work in the amount allocated for that purpose. If the Contractor timely objects to either the terms of the proposed settlement or the allocation of the proceeds, the Owner may proceed to settle the insured loss, and any dispute between the Owner and Contractor arising out of the settlement or allocation of the proceeds shall be resolved pursuant to Article 15. Pending resolution of any dispute, the Owner may issue a Construction Change Directive for the reconstruction of the damaged or destroyed Work.

ARTICLE 12 UNCOVERING AND CORRECTION OF WORK

§ 12.1 Uncovering of Work

§ 12.1.1 If a portion of the Work is covered contrary to the Construction Manager's or Architect's request or to requirements specifically expressed in the Contract Documents, it must, if requested in writing by either, be uncovered for their examination and be replaced at the Contractor's expense without change in the Contract Time.

§ 12.1.2 If a portion of the Work has been covered that the Construction Manager or Architect has not specifically requested to examine prior to its being covered, the Construction Manager or Architect may request to see such Work and it shall be uncovered by the Contractor. If such Work is in accordance with the Contract Documents, the Contractor shall be entitled to an equitable adjustment to the Contract Sum and Contract Time as may be appropriate. If such Work is not in accordance with the Contract Documents, the costs of uncovering the Work, and the cost of correction, shall be at the Contractor's expense.

§ 12.2 Correction of Work

§ 12.2.1 Before Substantial Completion

The Contractor shall promptly correct Work rejected by the Construction Manager or Architect or failing to conform to the requirements of the Contract Documents, discovered before Substantial Completion, and whether or not fabricated, installed or completed. Costs of correcting such rejected Work, including additional testing and inspections, the cost of uncovering and replacement, and compensation for the Construction Manager's and Architect's services and expenses made necessary thereby, shall be at the Contractor's expense.

§ 12.2.2 After Substantial Completion

§ 12.2.2.1 In addition to the Contractor's obligations under Section 3.5, if, within one year after the date of Substantial Completion of the Work or designated portion thereof, or after the date for commencement of warranties established under Section 9.9.1, or by terms of any applicable special warranty required by the Contract Documents, any of the Work is found to be not in accordance with the requirements of the Contract Documents, the Contractor shall correct it promptly after receipt of notice from the Owner to do so, unless the Owner has previously given the Contractor a written acceptance of such condition. The Owner shall give such notice promptly after discovery of the condition. During the one-year period for correction of Work, if the Owner fails to notify the Contractor and give the Contractor an opportunity to make the correction, the Owner waives the rights to require correction by the Contractor and to make a claim for breach of warranty. If the Contractor fails to correct nonconforming Work within a reasonable time during that period after receipt of notice from the Owner, Construction Manager or Architect, the Owner may correct it in accordance with Section 2.5.

§ 12.2.2.2 The one-year period for correction of Work shall be extended with respect to portions of Work first performed after Substantial Completion by the period of time between Substantial Completion and the actual completion of that portion of the Work.

§ 12.2.2.3 The one-year period for correction of Work shall not be extended by corrective Work performed by the Contractor pursuant to this Section 12.2.

§ 12.2.3 The Contractor shall remove from the site portions of the Work that are not in accordance with the requirements of the Contract Documents and are neither corrected by the Contractor nor accepted by the Owner.

§ 12.2.4 The Contractor shall bear the cost of correcting destroyed or damaged construction of the Owner, Separate Contractors, or other Contractors, whether completed or partially completed, caused by the Contractor's correction or removal of Work that is not in accordance with the requirements of the Contract Documents.

§ 12.2.5 Nothing contained in this Section 12.2 shall be construed to establish a period of limitation with respect to other obligations the Contractor has under the Contract Documents. Establishment of the one-year period for correction of Work as described in Section 12.2.2 relates only to the specific obligation of the Contractor to correct the Work, and has no relationship to the time within which the obligation to comply with the Contract Documents may be sought to be enforced, nor to the time within which proceedings may be commenced to establish the Contractor's liability with respect to the Contractor's obligations other than specifically to correct the Work.

§ 12.3 Acceptance of Nonconforming Work

If the Owner prefers to accept Work that is not in accordance with the requirements of the Contract Documents, the Owner may do so instead of requiring its removal and correction, in which case the Contract Sum will be reduced as appropriate and equitable. Such adjustment shall be effected whether or not final payment has been made.

ARTICLE 13 MISCELLANEOUS PROVISIONS

§ 13.1 Governing Law

The Contract shall be governed by the law of the place where the Project is located excluding that jurisdiction's choice of law rules. If the parties have selected arbitration as the method of binding dispute resolution, the Federal Arbitration Act shall govern Section 15.4.

§ 13.2 Successors and Assigns

§ 13.2.1 The Owner and Contractor respectively bind themselves, their partners, successors, assigns, and legal representatives to covenants, agreements, and obligations contained in the Contract Documents. Except as provided in Section 13.2.2, neither party to the Contract shall assign the Contract as a whole without written consent of the other. If either party attempts to make an assignment without such consent, that party shall nevertheless remain legally responsible for all obligations under the Contract.

§ 13.2.2 The Owner may, without consent of the Contractor, assign the Contract to a lender providing construction financing for the Project, if the lender assumes the Owner's rights and obligations under the Contract Documents. The Contractor shall execute all consents reasonably required to facilitate the assignment.

§ 13.3 Rights and Remedies

§ 13.3.1 Duties and obligations imposed by the Contract Documents and rights and remedies available thereunder shall be in addition to and not a limitation of duties, obligations, rights, and remedies otherwise imposed or available by law.

§ 13.3.2 No action or failure to act by the Owner, Construction Manager, Architect, or Contractor shall constitute a waiver of a right or duty afforded them under the Contract, nor shall such action or failure to act constitute approval of or acquiescence in a breach thereunder, except as may be specifically agreed upon in writing.

§ 13.4 Tests and Inspections

§ 13.4.1 Tests, inspections, and approvals of portions of the Work shall be made as required by the Contract Documents and by applicable laws, statutes, ordinances, codes, rules, and regulations or lawful orders of public authorities. Unless otherwise provided, the Contractor shall make arrangements for such tests, inspections, and approvals with an independent testing laboratory or entity acceptable to the Owner, or with the appropriate public authority, and shall bear all related costs of tests, inspections, and approvals. The Contractor shall give the Construction Manager and Architect timely notice of when and where tests and inspections are to be made so that the Construction Manager and Architect may be present for such procedures. The Owner shall bear costs of tests, inspections, or approvals that do not become requirements until after bids are received or negotiations concluded. The Owner shall directly arrange and pay for tests, inspections, or approvals where building codes or applicable laws or regulations so require.

§ 13.4.2 If the Construction Manager, Architect, Owner, or public authorities having jurisdiction determine that portions of the Work require additional testing, inspection, or approval not included under Section 13.4.1, the Construction Manager and Architect will, upon written authorization from the Owner, instruct the Contractor to make arrangements for such additional testing, inspection, or approval, by an entity acceptable to the Owner, and the Contractor shall give timely notice to the Construction Manager and Architect of when and where tests and inspections are to be made so that the Construction Manager and Architect may be present for such procedures. Such costs, except as provided in Section 13.4.3, shall be at the Owner's expense.

§ 13.4.3 If procedures for testing, inspection, or approval under Sections 13.4.1 and 13.4.2 reveal failure of the portions of the Work to comply with requirements established by the Contract Documents, all costs made necessary by such failure, including those of repeated procedures and compensation for the Construction Manager's and Architect's services and expenses, shall be at the Contractor's expense.

§ 13.4.4 Required certificates of testing, inspection, or approval shall, unless otherwise required by the Contract Documents, be secured by the Contractor and promptly delivered to the Construction Manager for transmittal to the Architect.

§ 13.4.5 If the Construction Manager or Architect is to observe tests, inspections, or approvals required by the Contract Documents, the Construction Manager or Architect will do so promptly and, where practicable, at the normal place of testing.

§ 13.4.6 Tests or inspections conducted pursuant to the Contract Documents shall be made promptly to avoid unreasonable delay in the Work.

§ 13.5 Interest

Payments due and unpaid under the Contract Documents shall bear interest from the date payment is due at the rate the parties agree upon in writing or, in the absence thereof, at the legal rate prevailing from time to time at the place where the Project is located.

ARTICLE 14 TERMINATION OR SUSPENSION OF THE CONTRACT

§ 14.1 Termination by the Contractor

§ 14.1.1 The Contractor may terminate the Contract if the Work is stopped for a period of 30 consecutive days through no act or fault of the Contractor, a Subcontractor, a Sub-subcontractor, their agents or employees, or any other persons or entities performing portions of the Work, for any of the following reasons:

- .1 Issuance of an order of a court or other public authority having jurisdiction that requires all Work to be stopped;
- .2 An act of government, such as a declaration of national emergency, that requires all Work to be stopped;
- .3 Because the Construction Manager has not certified or the Architect has not issued a Certificate for Payment and has not notified the Contractor of the reason for withholding certification as provided in Section 9.4, or because the Owner has not made payment on a Certificate for Payment within the time stated in the Contract Documents; or
- .4 The Owner has failed to furnish to the Contractor reasonable evidence as required by Section 2.2.

§ 14.1.2 The Contractor may terminate the Contract if, through no act or fault of the Contractor, a Subcontractor, a Sub-subcontractor, their agents or employees, or any other persons or entities performing portions of the Work, repeated suspensions, delays, or interruptions of the entire Work by the Owner as described in Section 14.3, constitute in the aggregate more than 100 percent of the total number of days scheduled for completion, or 120 days in any 365-day period, whichever is less.

§ 14.1.3 If one of the reasons described in Section 14.1.1 or 14.1.2 exists, the Contractor may, upon seven days' notice to the Owner, Construction Manager and Architect, terminate the Contract and recover from the Owner payment for Work executed, as well as reasonable overhead and profit on Work not executed, and costs incurred by reason of such termination.

§ 14.1.4 If the Work is stopped for a period of 60 consecutive days through no act or fault of the Contractor, a Subcontractor, a Sub-subcontractor, or their agents or employees, or any other persons performing portions of the Work because the Owner has repeatedly failed to fulfill the Owner's obligations under the Contract Documents with respect to matters important to the progress of the Work, the Contractor may, upon seven additional days' notice to the Owner, Construction Manager and Architect, terminate the Contract and recover from the Owner as provided in Section 14.1.3.

§ 14.2 Termination by the Owner for Cause

§ 14.2.1 The Owner may terminate the Contract if the Contractor

- .1 repeatedly refuses or fails to supply enough properly skilled workers or proper materials;
- .2 fails to make payment to Subcontractors or suppliers in accordance with the respective agreements between the Contractor and the Subcontractors or suppliers;
- .3 repeatedly disregards applicable laws, statutes, ordinances, codes, rules and regulations, or lawful orders of a public authority; or
- .4 otherwise is guilty of substantial breach of a provision of the Contract Documents.

§ 14.2.2 When any of the reasons described in Section 14.2.1 exist, after consultation with the Construction Manager, and upon certification by the Architect that sufficient cause exists to justify such action, the Owner may, without

prejudice to any other rights or remedies of the Owner and after giving the Contractor and the Contractor's surety, if any, seven days' notice, terminate employment of the Contractor and may, subject to any prior rights of the surety:

- .1 Exclude the Contractor from the site and take possession of all materials, equipment, tools, and construction equipment and machinery thereon owned by the Contractor;
- .2 Accept assignment of subcontracts pursuant to Section 5.4; and
- .3 Finish the Work by whatever reasonable method the Owner may deem expedient. Upon written request of the Contractor, the Owner shall furnish to the Contractor a detailed accounting of the costs incurred by the Owner in finishing the Work.

§ 14.2.3 When the Owner terminates the Contract for one of the reasons stated in Section 14.2.1, the Contractor shall not be entitled to receive further payment until the Work is finished.

§ 14.2.4 If the unpaid balance of the Contract Sum exceeds costs of finishing the Work, including compensation for the Construction Manager's and Architect's services and expenses made necessary thereby, and other damages incurred by the Owner and not expressly waived, such excess shall be paid to the Contractor. If such costs and damages exceed the unpaid balance, the Contractor shall pay the difference to the Owner. The amount to be paid to the Contractor or Owner, as the case may be, shall, upon application, be certified by the Initial Decision Maker after consultation with the Construction Manager, and this obligation for payment shall survive termination of the Contract.

§ 14.3 Suspension by the Owner for Convenience

§ 14.3.1 The Owner may, without cause, order the Contractor in writing to suspend, delay or interrupt the Work, in whole or in part for such period of time as the Owner may determine.

§ 14.3.2 The Contract Sum and the Contract Time shall be adjusted for increases in the cost and time caused by suspension, delay, or interruption under Section 14.3.1. Adjustment of the Contract Sum shall include profit. No adjustment shall be made to the extent:

- .1 that performance is, was, or would have been, so suspended, delayed, or interrupted, by another cause for which the Contractor is responsible; or
- .2 that an equitable adjustment is made or denied under another provision of this Contract.

§ 14.4 Termination by the Owner for Convenience

§ 14.4.1 The Owner may, at any time, terminate the Contract for the Owner's convenience and without cause.

§ 14.4.2 Upon receipt of notice from the Owner of such termination for the Owner's convenience, the Contractor shall

- .1 cease operations as directed by the Owner in the notice;
- .2 take actions necessary, or that the Owner may direct, for the protection and preservation of the Work; and
- .3 except for Work directed to be performed prior to the effective date of termination stated in the notice, terminate all existing subcontracts and purchase orders and enter into no further subcontracts and purchase orders.

§ 14.4.3 In case of such termination for the Owner's convenience, the Owner shall pay the Contractor for Work properly executed; costs incurred by reason of the termination, including costs attributable to termination of Subcontracts; and the termination fee, if any, set forth in the Agreement.

ARTICLE 15 CLAIMS AND DISPUTES

§ 15.1 Claims

§ 15.1.1 Definition. A Claim is a demand or assertion by one of the parties seeking, as a matter of right, payment of money, a change in the Contract Time, or other relief with respect to the terms of the Contract. The term "Claim" also includes other disputes and matters in question between the Owner and Contractor arising out of or relating to the Contract. The responsibility to substantiate Claims shall rest with the party making the Claim. This Section 15.1.1 does not require the Owner to file a Claim in order to impose liquidated damages in accordance with the Contract Documents.

§ 15.1.2 Time Limits on Claims

The Owner and Contractor shall commence all Claims and causes of action against the other and arising out of or related to the Contract, whether in contract, tort, breach of warranty or otherwise, in accordance with the requirements of the binding dispute resolution method selected in the Agreement and within the period specified by applicable law, but in any case not more than 10 years after the date of Substantial Completion of the Work. The Owner and Contractor waive all Claims and causes of action not commenced in accordance with this Section 15.1.2.

§ 15.1.3 Notice of Claims

§ 15.1.3.1 Claims by either the Owner or Contractor, where the condition giving rise to the Claim is first discovered prior to expiration of the period for correction of the Work set forth in Section 12.2.2, shall be initiated by notice to the other party and to the Initial Decision Maker with a copy sent to the Construction Manager and Architect, if the Architect is not serving as the Initial Decision Maker. Claims by either party under this Section 15.1.3.1 shall be initiated within 21 days after occurrence of the event giving rise to such Claim or within 21 days after the claimant first recognizes the condition giving rise to the Claim, whichever is later.

§ 15.1.3.2 Claims by either the Owner or Contractor, where the condition giving rise to the Claim is first discovered after expiration of the period for correction of the Work set forth in Section 12.2.2, shall be initiated by notice to the other party. In such event, no decision by the Initial Decision Maker is required.

§ 15.1.4 Continuing Contract Performance

§ 15.1.4.1 Pending final resolution of a Claim, except as otherwise agreed in writing or as provided in Section 9.7 and Article 14, the Contractor shall proceed diligently with performance of the Contract and the Owner shall continue to make payments in accordance with the Contract Documents.

§ 15.1.4.2 The Contract Sum and Contract Time shall be adjusted in accordance with the Initial Decision Maker's decision, subject to the right of either party to proceed in accordance with this Article 15. The Architect will issue Certificates for Payment in accordance with the decision of the Initial Decision Maker.

§ 15.1.5 Claims for Additional Cost. If the Contractor wishes to make a Claim for an increase in the Contract Sum, notice as provided in Section 15.1.3 shall be given before proceeding to execute the portion of the Work that is the subject of the Claim. Prior notice is not required for Claims relating to an emergency endangering life or property arising under Section 10.4.

§ 15.1.6 Claims for Additional Time

§ 15.1.6.1 If the Contractor wishes to make a Claim for an increase in the Contract Time, notice as provided in Section 15.1.3 shall be given. The Contractor's Claim shall include an estimate of cost and of probable effect of delay on progress of the Work. In the case of a continuing delay only one Claim is necessary.

§ 15.1.6.2 If adverse weather conditions are the basis for a Claim for additional time, such Claim shall be documented by data substantiating that weather conditions were abnormal for the period of time, could not have been reasonably anticipated and had an adverse effect on the scheduled construction.

§ 15.1.7 Waiver of Claims for Consequential Damages. The Contractor and Owner waive Claims against each other for consequential damages arising out of or relating to this Contract. This mutual waiver includes

- .1 damages incurred by the Owner for rental expenses, for losses of use, income, profit, financing, business and reputation, and for loss of management or employee productivity or of the services of such persons; and
- .2 damages incurred by the Contractor for principal office expenses including the compensation of personnel stationed there, for losses of financing, business and reputation, and for loss of profit except anticipated profit arising directly from the Work.

This mutual waiver is applicable, without limitation, to all consequential damages due to either party's termination in accordance with Article 14. Nothing contained in this Section 15.1.7 shall be deemed to preclude assessment of liquidated damages, when applicable, in accordance with the requirements of the Contract Documents.

§ 15.2 Initial Decision

§ 15.2.1 Claims, excluding those where the condition giving rise to the Claim is first discovered after expiration of the period for correction of the Work set forth in Section 12.2.2 or arising under Sections 10.3, 10.4, and 11.5, shall be referred to the Initial Decision Maker for initial decision. The Architect will serve as the Initial Decision Maker, unless otherwise indicated in the Agreement. Except for those Claims excluded by this Section 15.2.1, an initial decision shall be required as a condition precedent to mediation of any Claim. If an initial decision has not been rendered within 30 days after the Claim has been referred to the Initial Decision Maker, the party asserting the Claim may demand mediation and binding dispute resolution without a decision having been rendered. Unless the Initial Decision Maker and all affected parties agree, the Initial Decision Maker will not decide disputes between the Contractor and persons or entities other than the Owner.

§ 15.2.2 The Initial Decision Maker will review Claims and within ten days of the receipt of a Claim take one or more of the following actions: (1) request additional supporting data from the claimant or a response with supporting data from the other party, (2) reject the Claim in whole or in part, (3) approve the Claim, (4) suggest a compromise, or (5) advise the parties that the Initial Decision Maker is unable to resolve the Claim if the Initial Decision Maker lacks sufficient information to evaluate the merits of the Claim or if the Initial Decision Maker concludes that, in the Initial Decision Maker's sole discretion, it would be inappropriate for the Initial Decision Maker to resolve the Claim.

§ 15.2.3 In evaluating Claims, the Initial Decision Maker may, but shall not be obligated to, consult with or seek information from either party or from persons with special knowledge or expertise who may assist the Initial Decision Maker in rendering a decision. The Initial Decision Maker may request the Owner to authorize retention of such persons at the Owner's expense.

§ 15.2.4 If the Initial Decision Maker requests a party to provide a response to a Claim or to furnish additional supporting data, such party shall respond, within ten days after receipt of the request, and shall either (1) provide a response on the requested supporting data, (2) advise the Initial Decision Maker when the response or supporting data will be furnished, or (3) advise the Initial Decision Maker that no supporting data will be furnished. Upon receipt of the response or supporting data, if any, the Initial Decision Maker will either reject or approve the Claim in whole or in part.

§ 15.2.5 The Initial Decision Maker will render an initial decision approving or rejecting the Claim, or indicating that the Initial Decision Maker is unable to resolve the Claim. This initial decision shall (1) be in writing; (2) state the reasons therefor; and (3) notify the parties, the Construction Manager, and the Architect, if the Architect is not serving as the Initial Decision Maker, of any change in the Contract Sum or Contract Time or both. The initial decision shall be final and binding on the parties but subject to mediation and, if the parties fail to resolve their dispute through mediation, to binding dispute resolution.

§ 15.2.6 Either party may file for mediation of an initial decision at any time, subject to the terms of Section 15.2.6.1.

§ 15.2.6.1 Either party may, within 30 days from the date of receipt of an initial decision, demand in writing that the other party file for mediation. If such a demand is made and the party receiving the demand fails to file for mediation within 30 days of receipt thereof, then both parties waive their rights to mediate or pursue binding dispute resolution proceedings with respect to the initial decision.

§ 15.2.7 In the event of a Claim against the Contractor, the Owner may, but is not obligated to, notify the surety, if any, of the nature and amount of the Claim. If the Claim relates to a possibility of a Contractor's default, the Owner may, but is not obligated to, notify the surety and request the surety's assistance in resolving the controversy.

§ 15.2.8 If a Claim relates to or is the subject of a mechanic's lien, the party asserting such Claim may proceed in accordance with applicable law to comply with the lien notice or filing deadlines.

§ 15.3 Mediation

§ 15.3.1 Claims, disputes, or other matters in controversy arising out of or related to the Contract, except those waived as provided for in Sections 9.10.4, 9.10.5, and 15.1.7, shall be subject to mediation as a condition precedent to binding dispute resolution.

§ 15.3.2 The parties shall endeavor to resolve their Claims by mediation which, unless the parties mutually agree otherwise, shall be administered by the American Arbitration Association in accordance with its Construction Industry Mediation Procedures in effect on the date of the Agreement. A request for mediation shall be made in writing, delivered to the other party to the Contract, and filed with the person or entity administering the mediation. The request may be made concurrently with the filing of binding dispute resolution proceedings but, in such event, mediation shall proceed in advance of binding dispute resolution proceedings, which shall be stayed pending mediation for a period of 60 days from the date of filing, unless stayed for a longer period by agreement of the parties or court order. If an arbitration is stayed pursuant to this Section 15.3.2, the parties may nonetheless proceed to the selection of the arbitrator(s) and agree upon a schedule for later proceedings.

§ 15.3.3 Either party may, within 30 days from the date that mediation has been concluded without resolution of the dispute or 60 days after mediation has been demanded without resolution of the dispute, demand in writing that the other party file for binding dispute resolution. If such a demand is made and the party receiving the demand fails to file for binding dispute resolution within 60 days after receipt thereof, then both parties waive their rights to binding dispute resolution proceedings with respect to the initial decision.

§ 15.3.4 The parties shall share the mediator's fee and any filing fees equally. The mediation shall be held in the place where the Project is located, unless another location is mutually agreed upon. Agreements reached in mediation shall be enforceable as settlement agreements in any court having jurisdiction thereof.

§ 15.4 Arbitration

§ 15.4.1 If the parties have selected arbitration as the method for binding dispute resolution in the Agreement, any Claim subject to, but not resolved by, mediation shall be subject to arbitration which, unless the parties mutually agree otherwise, shall be administered by the American Arbitration Association in accordance with its Construction Industry Arbitration Rules in effect on the date of the Agreement. The Arbitration shall be conducted in the place where the Project is located, unless another location is mutually agreed upon. A demand for arbitration shall be made in writing, delivered to the other party to the Contract, and filed with the person or entity administering the arbitration. The party filing a notice of demand for arbitration must assert in the demand all Claims then known to that party on which arbitration is permitted to be demanded.

§ 15.4.1.1 A demand for arbitration shall be made no later than concurrently with the filing of a request for mediation, but in no event shall it be made after the date when the institution of legal or equitable proceedings based on the Claim would be barred by the applicable statute of limitations. For statute of limitations purposes, receipt of a written demand for arbitration by the person or entity administering the arbitration shall constitute the institution of legal or equitable proceedings based on the Claim.

§ 15.4.2 The award rendered by the arbitrator or arbitrators shall be final, and judgment may be entered upon it in accordance with applicable law in any court having jurisdiction thereof.

§ 15.4.3 The foregoing agreement to arbitrate and other agreements to arbitrate with an additional person or entity duly consented to by parties to the Agreement, shall be specifically enforceable under applicable law in any court having jurisdiction thereof.

§ 15.4.4 Consolidation or Joinder

§ 15.4.4.1 Subject to the rules of the American Arbitration Association or other applicable arbitration rules, either party may consolidate an arbitration conducted under this Agreement with any other arbitration to which it is a party provided that (1) the arbitration agreement governing the other arbitration permits consolidation, (2) the arbitrations to be consolidated substantially involve common questions of law or fact, and (3) the arbitrations employ materially similar procedural rules and methods for selecting arbitrator(s).

§ 15.4.4.2 Subject to the rules of the American Arbitration Association or other applicable arbitration rules, either party may include by joinder persons or entities substantially involved in a common question of law or fact whose presence is required if complete relief is to be accorded in arbitration, provided that the party sought to be joined consents in writing to such joinder. Consent to arbitration involving an additional person or entity shall not constitute consent to arbitration of any claim, dispute or other matter in question not described in the written consent.

§ 15.4.4.3 The Owner and Contractor grant to any person or entity made a party to an arbitration conducted under this Section 15.4, whether by joinder or consolidation, the same rights of joinder and consolidation as those of the Owner and Contractor under this Agreement.

NOT FOR BIDDING

Init.

Additions and Deletions Report for **AIA® Document A232™ – 2019**

This Additions and Deletions Report, as defined on page 1 of the associated document, reproduces below all text the author has added to the standard form AIA document in order to complete it, as well as any text the author may have added to or deleted from the original AIA text. Added text is shown underlined. Deleted text is indicated with a horizontal line through the original AIA text.

Note: This Additions and Deletions Report is provided for information purposes only and is not incorporated into or constitute any part of the associated AIA document. This Additions and Deletions Report and its associated document were generated simultaneously by AIA software at 09:09:53 ET on 12/09/2021.

NOT FOR BIDDING

Certification of Document's Authenticity

AIA® Document D401™ – 2003

I, , hereby certify, to the best of my knowledge, information and belief, that I created the attached final document simultaneously with its associated Additions and Deletions Report and this certification at 09:09:53 ET on 12/09/2021 under Order No. 6216521775 from AIA Contract Documents software and that in preparing the attached final document I made no changes to the original text of AIA® Document A232™ - 2019, General Conditions of the Contract for Construction, Construction Manager as Adviser Edition, as published by the AIA in its software, other than those additions and deletions shown in the associated Additions and Deletions Report.

(Signed)

(Title)

(Dated)

NOT FOR BIDDING

NOT FOR BIDDING

SECTION 007313 - SUPPLEMENTARY GENERAL CONDITIONS A232-2009

The following supplements modify the "General Conditions of the Contract for Construction," AIA Document A201-1997. Where a portion of the General Conditions is modified or deleted by the Supplementary Conditions, the unaltered portions of the General Conditions shall remain in effect.

TABLE OF ARTICLES

1. GENERAL PROVISIONS
2. OWNER
3. CONTRACTOR
4. ADMINISTRATION OF THE CONTRACT
5. SUBCONTRACTORS
6. CONSTRUCTION BY OWNER OR BY SEPARATE CONTRACTORS
7. CHANGES IN THE WORK
8. TIME
9. PAYMENTS AND COMPLETION
10. PROTECTION OF PERSONS AND PROPERTY
11. INSURANCE AND BONDS
12. UNCOVERING AND CORRECTION OF WORK
13. MISCELLANEOUS PROVISIONS
14. TERMINATION OR SUSPENSION OF THE CONTRACT
15. ATTACHMENT A – CONSTRUCTION MANAGEMENT GENERAL CONDITIONS

ARTICLE 1: GENERAL PROVISIONS

1.1 BASIC DEFINITIONS

1.1.1 THE CONTRACT DOCUMENTS

Delete the last sentence in its entirety and replace with the following:

“The Contract Documents also include Advertisement for Bid, Instructions to Bidder, sample forms, the Bid Form, the Contractor’s completed Bid and the Award Letter.”

1.2 CORRELATION AND INTENT OF THE CONTRACT DOCUMENTS

Add the following Paragraphs:

1.2.2 In the case of an inconsistency between the Drawings and the Specifications, or within either document not clarified by addendum the better quality or greater quantity of work shall be provided in accordance with the Architect’s interpretation.

1.2.3 The word “PROVIDE” as used in the Contract Documents shall mean “FURNISH AND INSTALL” and shall include, without limitation, all labor, materials, equipment, transportation, services and other items required to complete the Work.

1.2.4 The word “PRODUCT” as used in the Contract Documents means all materials, systems and equipment.

1.5.3 OWNERSHIP AND USE OF DRAWINGS, SPECIFICATIONS AND OTHER INSTRUMENTS OF SERVICE

Add the following paragraphs:

“All pre-design studies, drawings, specifications and other documents, including those in electronic form prepared by the Architect under this Agreement are, and shall remain, the property of the Owner whether the Project for which they are made is executed or not. Such documents may be used by the Owner to construct one or more like Projects without the approval of, or additional compensation to, the Architect. The Contractor, Subcontractors, Sub-subcontractors and Material or Equipment Suppliers are authorized to use and reproduce applicable portions of the Drawings, Specifications and other documents prepared by the Architect and the Architect’s consultants appropriate to and for use in the execution of their Work under the Contract Documents. They are not to be used by the Contractor or any Subcontractor, Sub-subcontractor or Material and Equipment Supplier on other Projects or for additions to this Project outside the scope of the Work without the specific written consent of the Owner, Architect and Architect’s consultants.

The Architect shall not be liable for injury or damage resulting from the re-use of drawings and specifications if the Architect is not involved in the re-use Project. Prior to re-use of construction documents for a Project in which the Architect is not also involved, the Owner will remove from such documents all identification of the original Architect, including name, address and professional seal or stamp.”

ARTICLE 2: OWNER

2.2 INFORMATION AND SERVICES REQUIRED OF THE OWNER

To Subparagraph 2.2.3 – Add the following sentence:

“The Contractor, at their expense shall bear the costs to accurately identify the location of all underground utilities in the area of their excavation and shall bear all cost for any repairs required, out of failure to accurately identify said utilities.”

Delete Subparagraph 2.2.5 in its entirety and substitute the following:

2.2.5 The Contractor shall be furnished free of charge up to one (1) set of the Drawings and Project Manuals. Additional sets will be furnished at the cost of reproduction, postage and handling.

ARTICLE 3: CONTRACTOR

3.2 REVIEW OF CONTRACT DOCUMENTS AND FIELD CONDITIONS BY CONTRACTOR

Amend Paragraph 3.2.2 to state that any errors, inconsistencies or omissions discovered shall be reported to the Architect and Owner immediately.

3.2.5 The Contractor shall own all entities (products, materials, equipment and systems) identified in the Project Manual (Specifications) and drawings, regardless of whether said entities are only referenced in either the Project Manual or the drawings. Failure of the successful low bidder to identify all required quantities and locations of all project entities in the bidding period will not exempt the low bidder from the contractual responsibility for these items. In the event of a conflict between the Project Manual and the drawings, the Contractor shall own the more costly of the conflicting scenarios. The conflict, once identified and reported by the Contractor, will be resolved by the Architect.”

3.3 SUPERVISION AND CONSTRUCTION PROCEDURES

Add the following Paragraphs:

3.3.2.1 The Contractor shall immediately remove from the Work, whenever requested to do so by the Owner, any person who is considered by the Owner or Construction Manager to be incompetent or disposed to be so disorderly, or who for any reason is not satisfactory to the Owner, and that person shall not again be employed on the Work without the consent of the Owner or the Architect.

3.3.4 The Contractor must provide suitable storage facilities at the Site for the proper protection and safe storage of their materials. Consult the Owner and the Construction Manager before storing any materials.

3.3.5 When any room is used as a shop, storeroom, office, etc., by the Contractor or Subcontractor(s) during the construction of the Work, the Contractor making use of these areas will be held responsible for any repairs, patching or cleaning arising from such use.

3.4 LABOR AND MATERIALS

Add the Following Paragraphs:

- 3.4.4 Before starting the Work, each Contractor shall carefully examine all preparatory Work that has been executed to receive their Work. Check carefully, by whatever means are required, to insure that its Work and adjacent, related Work, will finish to proper contours, planes and levels. Promptly notify the Construction Manager of any defects or imperfections in preparatory Work which will in any way affect satisfactory completion of its Work. Absence of such notification will be construed as an acceptance of preparatory Work and later claims of defects will not be recognized.
- 3.4.5 Under no circumstances shall the Contractor's Work proceed prior to preparatory Work having been completely cured, dried and/or otherwise made satisfactory to receive this Work. Responsibility for timely installation of all materials rests solely with the Contractor responsible for that Work, who shall maintain coordination at all times.

3.5 **WARRANTY**

Add the following Paragraphs:

- 3.5.1 The Contractor will guarantee all materials and workmanship against original defects, except injury from proper and usual wear when used for the purpose intended, for two (2) years after Acceptance by the Owner, and will maintain all items in perfect condition during the period of guarantee.
- 3.5.2 Defects appearing during the period of guarantee will be made good by the Contractor at his expense upon demand of the Owner, it being required that all work will be in perfect condition when the period of guarantee will have elapsed.
- 3.5.3 In addition to the General Guarantee there are other guarantees required for certain items for different periods of time than the two (2) years as above, and are particularly so stated in that part of the specifications referring to same. The said guarantees will commence at the same time as the General Guarantee.
- 3.5.4 If the Contractor fails to remedy any failure, defect or damage within a reasonable time after receipt of notice, the Owner will have the right to replace, repair, or otherwise remedy the failure, defect or damage at the Contractor's expense.

3.11 **DOCUMENTS AND SAMPLES AT THE SITE**

Add the following Paragraphs:

- 3.11.1 During the course of the Work, the Contractor shall maintain a record set of drawings on which the Contractor shall mark the actual physical location of all piping, valves, equipment, conduit, outlets, access panels, controls, actuators, including all appurtenances that will be concealed once construction is complete, etc., including all invert elevations.
- 3.11.2 At the completion of the project, the Contractor shall obtain a set of reproducible drawings from the Architect, and neatly transfer all information outlined in 3.11.1 to provide a complete record of the as-built conditions.

- 3.11.3 The Contractor shall provide two (2) prints of the as-built conditions, along with the reproducible drawings themselves, to the Owner and one (1) set to the Architect. In addition, attach one complete set to each of the Operating and Maintenance Instructions/Manuals.

ARTICLE 4: ADMINISTRATION OF THE CONTRACT

4.2

Add the following Paragraph:

- 4.2.16.1 There will be no full-time project representative provided by the Owner or Architect on this project. The construction manager will be the owner's representative.

ARTICLE 5: SUBCONTRACTORS

5.2 AWARD OF SUBCONTRACTS AND OTHER CONTRACTS FOR PORTIONS OF THE WORK

Delete Paragraph 5.2.3 in its entirety and replace with the following:

- 5.2.3 If the Owner or Architect has reasonable objection to a person or entity proposed by the Contractor, the Contractor shall propose another to whom the Owner or Architect has no reasonable objection, subject to the statutory requirements of 29 Delaware Code § 6962(d)(10)b.3, 4.

ARTICLE 7: CHANGES IN THE WORK

(SEE ARTICLE 7: CHANGES IN WORK OF THE GENERAL REQUIREMENTS)

ARTICLE 8: TIME

8.2 PROGRESS AND COMPLETION

Add the following Paragraphs:

- 8.2.1.1 Refer to Specification Section SUMMARY OF WORK for Contract time requirements.
- 8.2.4 If the Work falls behind the Progress Schedule as submitted by the Contractor, the Contractor shall employ additional labor and/or equipment necessary to bring the Work into compliance with the Progress Schedule at no additional cost to the Owner.

8.3 DELAYS AND EXTENSION OF TIME

Add the following Paragraph:

- 8.3.2.1 The Contractor shall update the status of the suspension, delay, or interruption of the Work with each Application for Payment. (The Contractor shall report the termination of such cause immediately upon the termination thereof.) Failure to comply with this procedure shall constitute a waiver for any claim for adjustment of time or price based upon said cause.

Delete Paragraph 8.3.3 in its entirety and replace with the following:

- 8.3.3 Except in the case of a suspension of the Work directed by the Owner, an extension of time under the provisions of Paragraph 8.3.1., shall be the Contractor's sole remedy in the progress of the Work and there shall be no payment or compensation to the Contractor for any expense or damage resulting from the delay.

Add the following Paragraph:

- 8.3.4 By permitting the Contractor to work after the expired time for completion of the project, the Owner does not waive their rights under the Contract.

ARTICLE 9: PAYMENTS AND COMPLETION

9.2 SCHEDULE OF VALUES

Add the following Paragraphs:

- 9.2.1 The Schedule of Values shall be submitted using AIA Document G702, Continuation Sheet to G703.
- 9.2.2 The Schedule of Values is to include a line item for Project Closeout Document Submittal. The value of this item is to be no less than 1% of the initial contract amount.

9.3 APPLICATIONS FOR PAYMENT

Add the following Paragraph:

- 9.3.1.3 Application for Payment shall be submitted on AIA Document G702 "Application and Certificate for Payment", supported by AIA Document G703 "Continuation Sheet". Said Applications shall be fully executed and notarized.

Add the following Paragraphs:

- 9.3.4 Until Closeout Documents have been received and outstanding items completed the Owner will pay 95% (ninety-five percent) of the amount due the Contractor on account of progress payments.
- 9.3.5 The Contractor shall provide a current and updated Progress Schedule to the Architect with each Application for Payment. Failure to provide Schedule will be just cause for rejection of Application for Payment.

9.5 DECISIONS TO WITHHOLD CERTIFICATION

Add the following to 9.5.1:

- .8 failure to provide a current Progress Schedule;
- .9 a lien or attachment is filed;
- .10 failure to comply with mandatory requirements for maintaining Record Documents.

9.6 PROGRESS PAYMENTS

Delete Paragraph 9.6.1 in its entirety and replace with the following:

- 9.6.1 After the Architect has approved and issued a Certificate for Payment, payment shall be made by the Owner within 30 days after Owner's receipt of the Certificate for Payment.

ARTICLE 10: PROTECTION OF PERSONS AND PROPERTY

10.1 SAFETY PRECAUTIONS AND PROGRAMS

Add the following Paragraphs:

- 10.1.2 Each Contractor shall develop a safety program in accordance with the Occupational Safety and Health Act of 1970. A copy of said plan shall be furnished to the Owner and Architect prior to the commencement of that Contractor's Work.
- 10.1.3 Each Contractor shall appoint a Safety Representative. Safety Representatives shall be someone who is on site on a full time basis. If deemed necessary by the Owner, Construction Manager or Architect, Contractor Safety meetings will be scheduled. The attendance of all Safety Representatives will be required. Minutes will be recorded of said meetings by the Contractor and will be distributed to all parties as well as posted in all job offices/trailers etc.

10.2 SAFETY OF PERSONS AND PROPERTY

Add the following Paragraph:

- 10.2.1.1 As required in the Hazardous Chemical Act of June 1984, all vendors supplying any material that may be defined as hazardous, must provide Material Safety Data Sheets for those products. Any chemical product should be considered hazardous if it has a caution warning on the label relating to a potential physical or health hazard, if it is known to be present in the work place, and if employees may be exposed under normal conditions or in foreseeable emergency situations. Material Safety Data Sheets shall be provided directly to the Owner, along with the shipping slips that include those products.

ARTICLE 11: INSURANCE AND BONDS

11.1 CONTRACTOR'S LIABILITY INSURANCE

- 11.1.4 Strike "the owner" immediately following "(1)" and strike "and (2) the Owner as an additional insured for claims caused in whole or in part by the Contractor's negligent acts or omissions during the Contractor's completed operations."

11.2 OWNER'S LIABILITY INSURANCE

Delete Paragraph 11.2 in its entirety.

11.3 PROPERTY INSURANCE

Delete Paragraph 11.3 in its entirety and replace with the following:

11.3 The Owner will not provide Builder's All Risk Insurance for the Project. The Contractor and all Subcontractors shall provide property coverage for their tools and equipment, as necessary. Any mandatory deductible required by the Contractor's Insurance shall be the responsibility of the Contractor.

11.4 PERFORMANCE BOND AND PAYMENT BOND

Add the following sentence: "The bonds will conform to those forms approved by the Office of Management and Budget."

ARTICLE 12: UNCOVERING AND CORRECTION OF WORK

12.2.2 AFTER SUBSTANTIAL COMPLETION

Add the following Paragraph:

12.2.2.1.1 At any time during the progress of the Work, or in any case where the nature of the defects will be such that it is not expedient to have corrected, the Owner, at its option, will have the right to deduct such sum, or sums, of money from the amount of the Contract as it considers justified to adjust the difference in value between the defective work and that required under contract including any damage to the structure.

12.2.2.1 Strike "one" and insert "two".

12.2.2.2 Strike "one" and insert "two".

12.2.2.3 Strike "one" and insert "two".

12.2.5 In second sentence, strike "one" and insert "two".

ARTICLE 13: MISCELLANEOUS PROVISIONS

Add the following Paragraph:

13.1 GOVERNING LAW

Strike "except that, if the parties have selected arbitration as the method of binding dispute resolution, the Federal Arbitration Act shall govern Section 15.4."

13.6 INTEREST

Strike "the date payment is due at such rate as the parties may agree upon in writing or, in the absence thereof, at the legal rate prevailing from time to time at the place where the

Project is located." Insert "30 days of presentment of the authorized Certificate of Payment at the annual rate of 12% or 1% per month.

13.8 CONFLICTS WITH FEDERAL STATUTES OR REGULATIONS

13.8.1 If any provision, specifications or requirement of the Contract Documents conflict or is inconsistent with any statute, law or regulation of the government of the United State of America, the Contractor shall notify the Architect and Owner immediately upon discovery.

ARTICLE 14: TERMINATION OR SUSPENSION OF THE CONTRACT

14.4 TERMINATION BY THE OWNER FOR CONVENIENCE

Delete Paragraph 14.4.3 in its entirety and replace with the following:

14.4.3 In case of such termination for the Owner's convenience, the Contractor shall be entitled to receive payment for Work executed, and cost incurred by reason of such termination along with reasonable overhead

END OF SUPPLEMENTARY GENERAL CONDITIONS

SECTION 007313 - ATTACHMENT A - CONSTRUCTION MANAGER GENERAL CONDITIONS

COORDINATION OF THE CONTRACT

1. The Construction Manager will provide general coordination of all contracts between the Owner and Contractors, including the functions hereinafter described.
2. Coordinator, and in addition, home office executive, technical and clerical support for management, communications, documentation, inspection, planning, scheduling, estimating and accounting. He will furnish, maintain and operate a temporary field office and telephone.
3. The Construction Manager will provide support for the Contractors by providing the following General Condition Construction Items: ceremonies construction work; temporary toilets; first aid stations; bulletin board; job signs; temporary fire extinguishers.

Temporary heat provided by Mechanical Contractor is space heat for certain finish trades unless otherwise specifically required by the trade specification. In no way should the contractor misconstrue this item to include weather protection for concrete or masonry.

4. The Construction Manager will establish a reference point and benchmark for layout and engineering. Further actual layout and engineering required on the site to accomplish this Bid Pac work shall be the responsibility of the Contractor.
5. The Construction Manager will:
 - (a) Review all changes proposed by the Contractor, Architect or Owner and make recommendations to the Architect and Owner on the schedule and cost implications and may initiate requests for changes in its opinion required by field conditions or progress of the work.
 - (b) Review the adequacy of each Contractor's personnel and equipment and the availability of necessary materials and supplies. If, in the opinion of the Construction Manager, a Contractor's personnel or equipment or the availability of necessary materials and supplies is inadequate, the Construction Manager shall give written notice to the Contractor specifying such inadequacy. If such inadequacy is not cured within five (5) working days after receipt of such notice, the Construction Manager shall have the right to order the Contractor and all of his subcontractors to stop work until the inadequacy is cured. Such a work stoppage shall not entitle the Contractor or any subcontractors to any extension of the schedule, and the Contractor shall remain responsible for completing its work on time.
 - (c) Establish and maintain a complete onsite library of all Contract Documents, approved shop drawings and approved material samples. Maintain an onsite directory which includes contracts for all sources of materials, labor and services relating to the project, and maintain at the job site a current marked record set of the contract drawings and specifications.

- (d) Conduct pre-construction conferences with successful bidders. Schedule and conduct job meetings to be attended by the Contractors and representatives of the Owner to discuss such matters as procedures, progress, problems and scheduling. Distribute minutes of such meetings to all parties.
- 6. Construction Manager's Daily Inspection Review:
 - (a) The Construction Manager will make daily review of work. In the event the interpretation of the meaning and intent of the plans and specifications becomes necessary during construction, he will consult with the Architect, request the Architect's interpretation in writing and transmit same to the appropriate Contractor. Pending receipt of such interpretation from the Architect, the Construction Manager shall have the right to stop the work of the Contractor. These reviews are intended to supplement but not replace those inspections that are the responsibility of the Architects and their consultants. These reviews do not relieve the Contractor from his responsibility to the Owner.
- 7. Construction Manager's Review of Safety Program:
 - (a) The Construction Manager will review the safety program as developed by each Contractor. (The Performance of such services by the Construction Manager shall not relieve the Contractor of his responsibilities for the safety of persons or property, and compliance with statutes, rules regulations and orders applicable to the conduct of the work.)
- 8. Construction Manager – Submittals Expediting Schedule:
 - (a) The Construction Manager will prepare and maintain a separate Submittals Expediting Schedule which schedules construction items requiring submission to Architect or Owner for review and approval prior to ordering, fabrication or delivery, such as: shop drawings preparation, submission of shop drawings samples – color schedules, templates, coordination drawings, equipment and fixture schedules, manufacturer literature, review and approval of submittal items, fabrication of equipment and products, shipping and delivery.
- 9. Construction Manager – Contractor's Progress Payments:
 - (a) The Construction Manager will review application for each Contractor's Progress Payments for compliance with the value of work accomplished and submit recommendations to the Architect.
- 10. Construction Manager – Change Orders:
 - (a) The Construction Manager will review all change order requests and submit recommendations to the Architect.
- 11. Construction Manager – Expansion of the Construction Schedule:

- (a) The Construction Manager will meet with each Contractor who receives an award to expand the construction schedule to include: shop drawings preparation, samples, review and approvals, fabrication, equipment and product delivery and testing activities. He will monitor schedule periodically to identify slippage. He will recommend to each Contractor corrective action as required to maintain schedule compliance.

12. Construction Manager – Master Schedule Bar Chart:

- (a) The Construction Manager will display a Master Schedule Bar Chart in the job office showing the duration and location of each activity and a summary bar chart depicting each major construction activity time scaled to a calendar. He will also furnish identical information to the Architect and Owner.

RECORD DRAWINGS

13. All Contractors shall report to the Construction Manager all changes, deviations, additions or deletions related to the contract documents along with dimensional locations of underground utilities and other items which will be hidden from view in the completed construction. The Construction Manager will maintain a complete set of separable reproductions of the contract documents upon which these items shall be recorded. At the completion of the project their record drawings will be turned over to the Owner for his use in building maintenance.

COOPERATION OF PRIME CONTRACTORS

14. In as much as the completion of the building within the prescribed time is dependent very largely upon the close and active cooperation of all those engaged therein, it is, therefore, expressly understood and agreed that each Contractor will layout and install his work as such time or times and in such manner as consistent with the Master Schedule Bar Chart to permit the carrying forward of the work of other Contractors.

JOB MEETINGS

15. A meeting shall be conducted bi-weekly by the Construction Manager for the purpose of coordinating and expediting the work. It shall be mandatory that each Contractor and/or his Superintendent be in attendance. Also, from time to time, the Construction Manager will designate certain subcontractors to attend. Additional mandatory meetings may be called by the Construction Manager. Such as weekly progress meetings on Mondays with the onsite Superintendent or others needed to attend for all trades working on the site to discuss job problems.

CONTRACTOR'S PLANT AND PERSONNEL

16. Each Contractor shall provide for his own forces the following as necessary:

- (a) Job Site Office with telephone.
- (b) Personnel/Tool Locker.
- (c) Equipment and Material Storage Facilities.

- (d) Onsite supervision of personnel and plant acceptable to the Construction Manager. Supervisions shall not be changed during the project duration without approval of the Construction Manager. If required by the Construction Manager, the Contractor shall immediately remove any personnel from the project and replace same with approved personnel.
- (e) The Contractor shall provide drinking water in accordance with Public Health requirements.
- (f) Provide any additional temporary lighting as required and protection for new or existing finishes.
- (g) Extension cords and light bulbs.
- (h) The Contractor shall at the completion of his work remove all such temporary utilities.
- (i) Pay for all power consumed.

SAFETY

- 17. The Construction Manager will have the right to correct any unsafe project conditions that exist due to the negligence of any Contractor and may reduce the Contractor's payments in the amount required to make necessary safe project conditions. In no way does this mean that the Construction Manager has the responsibility for any safety requirements that are specifically that of the Contractor.
- 17.1 Prime Contractor acknowledges that it is solely responsible for the health and safety of its employees, agents, subcontractors, and other persons on the adjacent to the Work Site. Prime contractor agrees that it shall be liable for any violation of any law, regulation, statute or ordinance applicable to Prime Contractor's work. The Prime Contractor shall be liable to the Owner and Construction Manager for all loss, cost and expense attributable to any act or omission by the Prime Contractor, or anyone acting on its behalf, including but not limited to any fines, penalties or assessments levied against the Owner and/or Construction Manager, and agrees that any such amounts may be deducted from any payment due to the Prime Contractor.
- 18. The Carpentry and General Work Contract will provide and install temporary safety rails for guarding any floor and wall openings during construction.

SCHEDULE

- 19. If the project progresses well and the project is ahead of schedule, the Contractor must take this point into consideration. At no time shall a Contractor use the Schedule Advancement as a reason for not completing work.

CONSTRUCTION MANAGER'S AUTHORITY REGARDING CLEANUP

- 20. The site and all portions of the work in progress shall be cleaned up daily.

21. In the event that any contractor fails to properly do his cleanup work during the construction period (as noted in subparagraph 4.15.1), the Construction Manager shall, after giving the contractor a 48 hour written notice, hire a clean up crew to do the necessary cleanup and then back-charge the contractor for doing this cleanup work. Note that when performing his required cleanup, the contractor shall deposit all debris at a place designated by the Construction Manager, or remove debris from the site. No burning will be permitted on this site.
22. The contractor shall furnish, at the construction manager's discretion, one (1) man for two (2) hours per week to police the construction site clean up of miscellaneous debris.

END CM GENERAL CONDITIONS

NOT FOR BIDDING

SECTION 007316 – INSURANCE REQUIREMENTS

ACORD CERTIFICATE OF LIABILITY INSURANCE						DATE (MM/DD/YYYY)
PRODUCER		THIS CERTIFICATE IS ISSUED AS A MATTER OF INFORMATION ONLY AND CONFERS NO RIGHTS UPON THE CERTIFICATE HOLDER. THIS CERTIFICATE DOES NOT AMEND, EXTEND OR ALTER THE COVERAGE AFFORDED BY THE POLICIES BELOW.				
INSURED		INSURERS AFFORDING COVERAGE				NAIC #
		INSURER A:				
		INSURER B:				
		INSURER C:				
		INSURER D:				
		INSURER E:				
COVERAGES						
THE POLICIES OF INSURANCE LISTED BELOW HAVE BEEN ISSUED TO THE INSURED NAMED ABOVE FOR THE POLICY PERIOD INDICATED. NOTWITHSTANDING ANY REQUIREMENT, TERM OR CONDITION OF ANY CONTRACT OR OTHER DOCUMENT WITH RESPECT TO WHICH THIS CERTIFICATE MAY BE ISSUED OR MAY PERTAIN, THE INSURANCE AFFORDED BY THE POLICIES DESCRIBED HEREIN IS SUBJECT TO ALL THE TERMS, EXCLUSIONS AND CONDITIONS OF SUCH POLICIES. AGGREGATE LIMITS SHOWN MAY HAVE BEEN REDUCED BY PAID CLAIMS.						
FORM NO. 101	LTR. INSRD.	TYPE OF INSURANCE	POLICY NUMBER	POLICY EFFECTIVE DATE (MM/DD/YYYY)	POLICY EXPIRATION DATE (MM/DD/YYYY)	LIMITS
		GENERAL LIABILITY				EACH OCCURRENCE \$
		COMMERCIAL GENERAL LIABILITY				PER OCCURRENCE (per occurrence) \$
		CLAIMS MADE ☐ OCCUR ☐				VEH. EXP. (Any person) \$
						PERSONAL & ADV. INJURY \$
		GEN'L AGGREGATE LIMIT APPLIES PER:				GENERAL AGGREGATE \$
		POLICY ☐ PRO. ☐ LOC. ☐				PRODUCTS - COMPROP AGG. \$
		AUTOMOBILE LIABILITY				COMBINED SINGLE LIMIT (Per accident) \$
		ANY AUTO				BODILY INJURY (Per person) \$
		OWNED AUTOS				BODILY INJURY (Per accident) \$
		NON-OWNED AUTOS				PROPERTY DAMAGE (Per occurrence) \$
		HIRER AUTOS				AUTO ONLY - EA ACCIDENT \$
		NON-OWNED AUTOS				OTHER THAN AUTO ONLY - EA ACC. \$
		GARAGE LIABILITY				AGG. \$
		ANY AUTO				EACH OCCURRENCE \$
		EXCESS/UMBRELLA LIABILITY				AGGREGATE \$
		OCCUR ☐ CLAIMS MADE ☐				\$
		DEDUCTIBLE \$				\$
		RETENTION \$				\$
		WORKERS COMPENSATION AND EMPLOYERS' LIABILITY				E.L. EACH ACCIDENT \$
		ANY PROPRIETOR/PARTNER/EXECUTIVE OFFICER/OWNER EXCLUDED?				E.L. DISEASE - EA EMPLOYEE \$
		If yes, specify here SPECIAL PROVISIONS below				E.L. DISEASE - POLICY LIMIT \$
		OTHER				
DESCRIPTION OF OPERATIONS / LOCATIONS / VEHICLES / EXCLUSIONS ADDED BY ENDORSEMENT / SPECIAL PROVISIONS						
CERTIFICATE HOLDER						CANCELLATION
						SHOULD ANY OF THE ABOVE DESCRIBED POLICIES BE CANCELLED BEFORE THE EXPIRATION DATE THEREOF, THE ISSUING INSURER WILL ENDEAVOR TO MAIL _____ DAYS WRITTEN NOTICE TO THE CERTIFICATE HOLDER NAMED TO THE LEFT, BUT FAILURE TO DO SO SHALL IMPOSE NO OBLIGATION OR LIABILITY OF ANY KIND UPON THE INSURER, ITS AGENTS OR REPRESENTATIVES.
						AUTHORIZED REPRESENTATIVE

ACORD 25 (2001/08)

© ACORD CORPORATION 1988

END OF SECTION

SECTION 007346 – WAGE DETERMINATION REQUIREMENTS (DELAWARE PREVAILING WAGE RATES)

STATE OF DELAWARE
DEPARTMENT OF LABOR
DIVISION OF INDUSTRIAL AFFAIRS
OFFICE OF LABOR LAW ENFORCEMENT
PHONE: (302) 318-2769

Mailing Address:
252 Chapman Road
Suite 210
Newark, DE 19702

Located at:
252 Chapman Road
Suite 210
Newark, DE 19702

PREVAILING WAGES FOR **BUILDING CONSTRUCTION** EFFECTIVE MARCH 14, 2025

CLASSIFICATION	NEW CASTLE	KENT	SUSSEX
ASBESTOS WORKERS	29.89	36.79	53.56
BOILERMAKERS	89.46	48.39	66.72
BRICKLAYERS	66.79	66.79	66.79
CARPENTERS	62.56	62.56	50.80
CEMENT FINISHERS	94.36	67.11	52.04
ELECTRICAL LINE WORKERS	59.42	50.96	38.85
ELECTRICIANS	83.92	83.92	83.92
ELEVATOR CONSTRUCTORS	117.63	84.30	100.06
GLAZIERS	82.50	85.50	74.04
INSULATORS	61.12	69.12	69.12
IRON WORKERS	77.73	77.73	77.73
LABORERS	57.65	57.65	57.65
MILLWRIGHTS	88.35	88.35	70.97
PAINTERS	59.63	59.63	59.63
PILEDRIVERS	91.12	51.44	41.60
PLASTERERS	39.01	39.01	28.91
PLUMBERS/PIPEFITTERS/STEAMFITTERS	79.55	82.95	73.71
POWER EQUIPMENT OPERATORS	83.29	83.29	83.29
ROOFERS-COMPOSITION	32.40	30.53	32.76
ROOFERS-SHINGLE/SLATE/TILE	24.03	28.59	22.47
SHEET METAL WORKERS	86.84	86.84	86.84
SOFT FLOOR LAYERS	61.68	61.68	47.74
SPRINKLER FITTERS	73.13	73.13	73.13
TERRAZZO/MARBLE/TILE FNRS	70.79	70.79	81.89
TERRAZZO/MARBLE/TILE STRS	78.73	78.73	90.82
TRUCK DRIVERS	56.88	35.86	27.91

CERTIFIED: 4-9-2025

BY: Solima Chasland / Gu Francis Chasland

ADMINISTRATOR, OFFICE OF LABOR LAW ENFORCEMENT

NOTE: THESE RATES ARE PROMULGATED AND ENFORCED PURSUANT TO THE PREVAILING WAGE REGULATIONS ADOPTED BY THE DEPARTMENT OF LABOR ON APRIL 3, 1992.

CLASSIFICATIONS OF WORKERS ARE DETERMINED BY THE DEPARTMENT OF LABOR. FOR ASSISTANCE IN CLASSIFYING WORKERS, OR FOR A COPY OF THE REGULATIONS OR CLASSIFICATIONS, PHONE (302) 318-2769.

NON-REGISTERED APPRENTICES MUST BE PAID THE MECHANIC'S RATE.

PROJECT: 23.003 Terry Office of the President, Kent County



END OF SECTION

WAGE DETERMINATION REQUIREMENTS (DELAWARE PREVAILING WAGE RATES)

007316-1

SECTION 00 81 13

GENERAL REQUIREMENTS

TABLE OF ARTICLES

1. GENERAL PROVISIONS
2. OWNER
3. CONTRACTOR
4. ADMINISTRATION OF THE CONTRACT
5. SUBCONTRACTORS
6. CONSTRUCTION BY OWNER OR BY SEPARATE CONTRACTORS
7. CHANGES IN THE WORK
8. TIME
9. PAYMENTS AND COMPLETION
10. PROTECTION OF PERSONS AND PROPERTY
11. INSURANCE AND BONDS
12. UNCOVERING AND CORRECTION OF WORK
13. MISCELLANEOUS PROVISIONS
14. TERMINATION OR SUSPENSION OF THE CONTRACT

1.1 CONTRACT DOCUMENTS

1.1.1 The intent of the Contract Documents is to include all items necessary for the proper execution and completion of the Work by the Contractor. The Contract Documents are complementary and what is required by one shall be as binding as if required by all. Performance by the Contractor shall be required to an extent consistent with the Contract Documents and reasonably inferable from them as being necessary to produce the intended results.

1.1.2 Work including material purchases shall not begin until the Contractor is in receipt of a bonafide State of Delaware Purchase Order. Any work performed or material purchases prior to the issuance of the Purchase Order is done at the Contractor's own risk and cost.

1.2 **EQUALITY OF EMPLOYMENT OPPORTUNITY ON PUBLIC WORKS**

1.2.1 For Public Works Projects financed in whole or in part by state appropriation the Contractor agrees that during the performance of this contract:

1. The Contractor will not discriminate against any employee or applicant for employment because of race, creed, sex, color, sexual orientation, gender identity or national origin. The Contractor will take positive steps to ensure that applicants are employed and that employees are treated during employment without regard to their race, creed, sex, color, sexual orientation, gender identity or national origin. Such action shall include, but not be limited to, the following: employment, upgrading, demotion or transfer; recruitment or recruitment advertising; layoff or termination; rates of pay or other forms of compensation; and selection for training, including apprenticeship. The Contractor agrees to post in conspicuous places available to employees and applicants for employment notices to be provided by the contracting agency setting forth this nondiscrimination clause.
2. The Contractor will, in all solicitations or advertisements for employees placed by or on behalf of the Contractor, state that all qualified applicants will receive consideration for employment without regard to race, creed, sex, color, sexual orientation, gender identity or national origin."

ARTICLE 2: OWNER

(NO ADDITIONAL GENERAL REQUIREMENTS – SEE SUPPLEMENTARY GENERAL CONDITIONS)

ARTICLE 3: CONTRACTOR

3.1 **Schedule of Values:** The successful Bidder shall within twenty (20) days after receiving notice to proceed with the work, furnish to the Owner a complete schedule of values on the various items comprising the work.

3.2 **Subcontracts:** Upon approval of Subcontractors, the Contractor shall award their Subcontracts as soon as possible after the signing of their own contract and see that all material, their own and those of their Subcontractors, are promptly ordered so that the work will not be delayed by failure of materials to arrive on time.

- 3.3 Before commencing any work or construction, the General Contractor is to consult with the Owner as to matters in connection with access to the site and the allocation of Ground Areas for the various features of hauling, storage, etc.
- 3.4 The Contractor shall supervise and direct the Work, using the Contractor's best skill and attention. The Contractor shall be solely responsible for and have control over construction means, methods, techniques, sequences and procedures and for coordinating all portions of the Work under the Contract, unless the Contract Documents give other specific instructions.
- 3.5 The Contractor shall enforce strict discipline and good order among the Contractor's employees and other persons carrying out the Contract. The Contractor shall not permit employment of unfit persons or persons not skilled in tasks assigned to them.
- 3.6 The Contractor warrants to the Owner that materials and equipment furnished will be new and of good quality, unless otherwise permitted, and that the work will be free from defects and in conformance with the Contract Documents. Work not conforming to these requirements, including substitutions not properly approved, may be considered defective. If required by the Owner, the Contractor shall furnish evidence as to the kind and quality of materials and equipment provided.
- 3.7 Unless otherwise provided, the Contractor shall pay all sales, consumer, use and other similar taxes, and shall secure and pay for required permits, fees, licenses, and inspections necessary for proper execution of the Work.
- 3.8 The Contractor shall comply with and give notices required by laws, ordinances, rules, regulations, and lawful orders of public authorities bearing on performance of the Work. The Contractor shall promptly notify the Owner if the Drawings and Specifications are observed to be at variance therewith.
- 3.9 The Contractor shall be responsible to the Owner for the acts and omissions of the Contractor's employees, Subcontractors and their agents and employees, and other persons performing portions of the Work under contract with the Contractor.
- 3.10 The Contractor shall keep the premises and surrounding area free from accumulation of waste materials or rubbish caused by operations under the Contract. At completion of the Work the Contractor shall remove from and about the Project all waste materials, rubbish, the Contractor's tools, construction equipment, machinery and surplus materials. The Contractor shall be responsible for returning all damaged areas to their original conditions.
- 3.11 STATE LICENSE AND TAX REQUIREMENTS
- 3.11.1 Each Contractor and Subcontractor shall be licensed to do business in the State of Delaware and shall pay all fees and taxes due under State laws. In conformance with Section 2503, Chapter 25, Title 30, Delaware Code, "the Contractor shall furnish the Delaware Department of Finance within ten (10) days after entering into any contract with a contractor or subcontractor not a resident of this State, a statement of total value of such contract or contracts together with the names and addresses of the contracting parties."
- 3.12 The Contractor shall comply with all requirements set forth in Section 6962, Chapter 69, Title 29 of the Delaware Code.

- 3.13 During the contract Work, the Contractor and each Subcontractor, shall implement an Employee Drug Testing Program in accordance with OMB Regulation 4104 - "Regulations for the Drug Testing of Contractor and Subcontractor Employees Working on "Large Public Works Projects". "Large Public Works" is based upon the current threshold required for bidding Public Works as set by the Purchasing and Contracting Advisory Council.

ARTICLE 4: ADMINISTRATION OF THE CONTRACT

4.1 CONTRACT SURETY

4.1.1 PERFORMANCE BOND AND LABOR AND MATERIAL PAYMENT BOND

- 4.1.2 All bonds will be required as follows unless specifically waived elsewhere in the Bidding Documents.

- 4.1.3 Contents of Performance Bonds – The bond shall be in the form approved by the Office of Management and Budget. The bond shall be conditioned upon the faithful compliance and performance by the successful bidder of each and every term and condition of the contract and the proposal, plans, specifications, and bid documents thereof. Each term and condition shall be met at the time and in the manner prescribed by the Contract, Bid documents and the specifications, including the payment in full to every person furnishing material or performing labor in the performance of the Contract, of all sums of money due the person for such labor and material. (The bond shall also contain the successful bidder's guarantee to indemnify and save harmless the State and the agency from all costs, damages and expenses growing out of or by reason of the Contract in accordance with the Contract.)

- 4.1.4 Invoking a Performance Bond – The agency may, when it considers that the interest of the State so require, cause judgement to be confessed upon the bond.

- 4.1.5 Within twenty (20) days after the date of notice of award of contract, the Bidder to whom the award is made shall furnish a Performance Bond and Labor and Material Payment Bond, each equal to the full amount of the Contract price to guarantee the faithful performance of all terms, covenants and conditions of the same. The bonds are to be issued by an acceptable Bonding Company licensed to do business in the State of Delaware and shall be issued in duplicate.

- 4.1.6 Performance and Payment Bonds shall be maintained in full force (warranty bond) for a period of two (2) years after the date of the Certificate for Final Payment. The Performance Bond shall guarantee the satisfactory completion of the Project and that the Contractor will make good any faults or defects in his work which may develop during the period of said guarantees as a result of improper or defective workmanship, material or apparatus, whether furnished by themselves or their Sub-Contractors. The Payment Bond shall guarantee that the Contractor shall pay in full all persons, firms or corporations who furnish labor or material or both labor and material for, or on account of, the work included herein. The bonds shall be paid for by this Contractor. The Owner shall have the right to demand that the proof parties signing the bonds are duly authorized to do so.

4.2 FAILURE TO COMPLY WITH CONTRACT

- 4.2.1 If any firm entering into a contract with the State, or Agency that neglects or refuses to perform or fails to comply with the terms thereof, the Agency which signed the Contract may terminate the Contract and proceed to award a new contract in accordance with this Chapter 69, Title 29 of the Delaware Code or may require the Surety on the Performance Bond to complete the Contract in accordance with the terms of the Performance Bond. Nothing herein shall preclude the Agency from pursuing additional remedies as otherwise provided by law.

4.3 CONTRACT INSURANCE AND CONTRACT LIABILITY

- 4.3.1 In addition to the bond requirements stated in the Bid Documents, each successful Bidder shall purchase adequate insurance for the performance of the Contract and, by submission of a Bid, agrees to indemnify and save harmless and to defend all legal or equitable actions brought against the State, any Agency, officer and/or employee of the State, for and from all claims of liability which is or may be the result of the successful Bidder's actions during the performance of the Contract.

- 4.3.2 The purchase or nonpurchase of such insurance or the involvement of the successful Bidder in any legal or equitable defense of any action brought against the successful Bidder based upon work performed pursuant to the Contract will not waive any defense which the State, its agencies and their respective officers, employees and agents might otherwise have against such claims, specifically including the defense of sovereign immunity, where applicable, and by the terms of this section, the State and all agencies, officers and employees thereof shall not be financially responsible for the consequences of work performed, pursuant to said contract.

4.4 RIGHT TO AUDIT RECORDS

- 4.4.1 The Owner shall have the right to audit the books and records of a Contractor or any Subcontractor under any Contract or Subcontract to the extent that the books and records relate to the performance of the Contract or Subcontract.

- 4.4.2 Said books and records shall be maintained by the Contractor for a period of seven (7) years from the date of final payment under the Prime Contract and by the Subcontractor for a period of seven (7) years from the date of final payment under the Subcontract.

ARTICLE 5: SUBCONTRACTORS

5.1 SUBCONTRACTING REQUIREMENTS

- 5.1.1 All contracts for the construction, reconstruction, alteration or repair of any public building (not a road, street or highway) shall be subject to the following provisions:
1. A contract shall be awarded only to a Bidder whose Bid is accompanied by a statement containing, for each Subcontractor category, the name and address (city or town and State only – street number and P.O. Box addresses not required) of the subcontractor whose services the Bidder intends to use in performing the Work and providing the material for such Subcontractor category.

2. A Bid will not be accepted nor will an award of any Contract be made to any Bidder which, as the Prime Contractor, has listed itself as the Subcontractor for any Subcontractor unless:
 - A. It has been established to the satisfaction of the awarding Agency that the Bidder has customarily performed the specialty work of such Subcontractor category by artisans regularly employed by the Bidder's firm;
 - B. That the Bidder is duly licensed by the State to engage in such specialty work, if the State requires licenses; and
 - C. That the Bidder is recognized in the industry as a bona fide Subcontractor or Contractor in such specialty work and Subcontractor category.
- 5.1.2 The decision of the awarding Agency as to whether a Bidder who list itself as the Subcontractor for a Subcontractor category shall be final and binding upon all Bidders, and no action of any nature shall lie against any awarding agency or its employees or officers because of its decision in this regard.
- 5.1.3 After such a Contract has been awarded, the successful Bidder shall not substitute another Subcontractor for any Subcontractor whose name was set forth in the statement which accompanied the Bid without the written consent of the awarding Agency.
- 5.1.4 No Agency shall consent to any substitution of Subcontractors unless the Agency is satisfied that the Subcontractor whose name is on the Bidders accompanying statement:
 - A. Is unqualified to perform the work required;
 - B. Has failed to execute a timely reasonable Subcontract;
 - C. Has defaulted in the performance on the portion of the work covered by the Subcontract; or
 - D. Is no longer engaged in such business.
- 5.1.5 Should a Bidder be awarded a contract, such successful Bidder shall provide to the agency the taxpayer identification license numbers of such subcontractors. Such numbers shall be provided on the later of the date on which such subcontractor is required to be identified or the time the contract is executed. The successful Bidder shall provide to the agency to which it is contracting, within 30 days of entering into such public works contract, copies of all Delaware Business licenses of subcontractors and/or independent contractors that will perform work for such public works contract. However, if a subcontractor or independent contractor is hired or contracted more than 20 days after the Bidder entered the public works contract the Delaware Business license of such subcontractor or independent contractor shall be provided to the agency within 10 days of being contracted or hired.

- 5.1.6 The Contractor may employ additional Subcontractors on the jobsite only after submitting a copy of the Subcontractor's Employee Drug Testing Program to the Owner for approval. A Contractor or Subcontractor shall not commence work until the Owner has concluded its review and determined that the submitted Employee Drug Testing Program complies with OMB Regulation 4104.

5.2 **PENALTY FOR SUBSTITUTION OF SUBCONTRACTORS**

- 5.2.1 Should the Contractor fail to utilize any or all of the Subcontractors in the Contractor's Bid statement in the performance of the Work on the public bidding, the Contractor shall be penalized in the amount of (project specific amount*). The Agency may determine to deduct payments of the penalty from the Contractor or have the amount paid directly to the Agency. Any penalty amount assessed against the Contractor may be remitted or refunded, in whole or in part, by the Agency awarding the Contract, only if it is established to the satisfaction of the Agency that the Subcontractor in question has defaulted or is no longer engaged in such business. No claim for the remission or refund of any penalty shall be granted unless an application is filed within one year after the liability of the successful Bidder accrues. All penalty amounts assessed and not refunded or remitted to the contractor shall be reverted to the State.

*one (1) percent of contract amount not to exceed \$10,000

5.3 **ASBESTOS ABATEMENT**

- 5.3.1 The selection of any Contractor to perform asbestos abatement for State-funded projects shall be approved by the Office of Management and Budget, Division of Facilities Management pursuant to Chapter 78 of Title 16.

5.4 **STANDARDS OF CONSTRUCTION FOR THE PROTECTION OF THE PHYSICALLY HANDICAPPED**

- 5.4.1 All Contracts shall conform with the standard established by the Delaware Architectural Accessibility Board unless otherwise exempted by the Board.

5.5 **CONTRACT PERFORMANCE**

- 5.5.1 Any firm entering into a Public Works Contract that neglects or refuses to perform or fails to comply with its terms, the Agency may terminate the Contract and proceed to award a new Contract or may require the Surety on the Performance Bond to complete the Contract in accordance with the terms of the Performance Bond.

ARTICLE 6: CONSTRUCTION BY OWNER OR SEPARATE CONTRACTORS

- 6.1 The Owner reserves the right to simultaneously perform other construction or operations related to the Project with the Owner's own forces, and to award separate contracts in connection with other portions of the Project or other Projects at the same site.
- 6.2 The Contractor shall afford the Owner and other Contractors reasonable opportunity for access and storage of materials and equipment, and for the performance of their activities,

and shall connect and coordinate their activities with other forces as required by the Contract Documents.

ARTICLE 7: CHANGES IN THE WORK

- 7.1 The Owner, without invalidating the Contract, may order changes in the Work consisting of Additions, Deletions, Modifications or Substitutions, with the Contract Sum and Contract completion date being adjusted accordingly. Such changes in the Work shall be authorized by written Change Order signed by the Professional, as the duly authorized agent, the Contractor and the Owner.
- 7.2 The Contract Sum and Contract Completion Date shall be adjusted only by a fully executed Change Order.
- 7.3 The additional cost, or credit to the Owner resulting from a change in the Work shall be by mutual agreement of the Owner, Contractor and the Architect. In all cases, this cost or credit shall be based on the 'DPE' wages required and the "invoice price" of the materials/equipment needed.
- 7.3.1 "DPE" shall be defined to mean "direct personnel expense". Direct payroll expense includes prevailing wage rates plus a maximum multiplier of 1.35 times DPE. For example, if the prevailing wage rate is \$50/hour, the DPE would be \$67.50/hour (50 x 1.35).
- 7.3.2 "Invoice price" of materials/equipment shall be defined to mean the actual cost of materials and/or equipment that is paid by the Contractor, (or subcontractor), to a material distributor, direct factory vendor, store material provider, or equipment leasing entity. Rates for equipment that is leased and/or owned by the Contractor or subcontractor(s) shall not exceed those listed in the latest version of the "Means Building Construction Cost Data" publication.
- 7.3.3 In addition to the above, the General Contractor is allowed a fifteen percent (15%) markup for overhead and profit for additional work performed by the General Contractor's own forces. For additional subcontractor work, the Subcontractor is allowed a fifteen (15) percent overhead and profit on change order work above and beyond the direct costs stated previously. To this amount, the General Contractor will be allowed a mark-up not exceeding seven and one half percent (7.5%) on the subcontractors work. These mark-ups shall include all costs including, but not limited to: overhead, profit, bonds, insurance, supervision, etc. No markup is permitted on the work of the subcontractors subcontractor. No additional costs shall be allowed for changes related to the Contractor's onsite superintendent/staff, or project manager, unless a change in the work changes the project duration and is identified by the CPM schedule. There will be no other costs associated with the change order.

ARTICLE 8: TIME

- 8.1 Time limits, if any, are as stated in the Project Manual. By executing the Agreement, the Contractor confirms that the stipulated limits are reasonable, and that the Work will be completed within the anticipated time frame.
- 8.2 If progress of the Work is delayed at any time by changes ordered by the Owner, by labor disputes, fire, unusual delay in deliveries, abnormal adverse weather conditions, unavoidable

casualties or other causes beyond the Contractor's control, the Contract Time shall be extended for such reasonable time as the Owner may determine.

- 8.3 Any extension of time beyond the date fixed for completion of the construction and acceptance of any part of the Work called for by the Contract, or the occupancy of the building by the Owner, in whole or in part, previous to the completion shall not be deemed a waiver by the Owner of his right to annul or terminate the Contract for abandonment or delay in the matter provided for, nor relieve the Contractor of full responsibility.

8.4 **SUSPENSION AND DEBARMENT**

- 8.4.1 Per Section 6962(d)(14), Title 29, Delaware Code, "Any Contractor who fails to perform a public works contract or complete a public works project within the time schedule established by the Agency in the Invitation To Bid, may be subject to Suspension or Debarment for one or more of the following reasons: a) failure to supply the adequate labor supply ratio for the project; b) inadequate financial resources; or c) poor performance on the Project."

- 8.4.2 "Upon such failure for any of the above stated reasons, the Agency that contracted for the public works project may petition the Director of the Office of Management and Budget for Suspension or Debarment of the Contractor. The Agency shall send a copy of the petition to the Contractor within three (3) working days of filing with the Director. If the Director concludes that the petition has merit, the Director shall schedule and hold a hearing to determine whether to suspend the Contractor, debar the Contractor or deny the petition. The Agency shall have the burden of proving, by a preponderance of the evidence, that the Contractor failed to perform or complete the public works project within the time schedule established by the Agency and failed to do so for one or more of the following reasons: a) failure to supply the adequate labor supply ratio for the project; b) inadequate financial resources; or, c) poor performance on the project. Upon a finding in favor of the Agency, the Director may suspend a Contractor from Bidding on any project funded, in whole or in part, with public funds for up to 1 year for a first offense, up to 3 years for a second offense and permanently debar the Contractor for a third offense. The Director shall issue a written decision and shall send a copy to the Contractor and the Agency. Such decision may be appealed to the Superior Court within thirty (30) days for a review on the record."

8.5 **RETAINAGE**

- 8.5.1 Per Section 6962(d)(5) a.3, Title 29, Delaware Code: The Agency may at the beginning of each public works project establish a time schedule for the completion of the project. If the project is delayed beyond the completion date due to the Contractor's failure to meet their responsibilities, the Agency may forfeit, at its discretion, all or part of the Contractor's retainage.

- 8.5.2 This forfeiture of retainage also applies to the timely completion of the punchlist. A punchlist will only be prepared upon the mutual agreement of the Owner, Architect and Contractor. Once the punchlist is prepared, all three parties will by mutual agreement, establish a schedule for its completion. Should completion of the punchlist be delayed beyond the established date due to the Contractor's failure to meet their responsibilities, the Agency may hold permanently, at its discretion, all or part of the Contractor's retainage.

ARTICLE 9: PAYMENTS AND COMPLETION

9.1 APPLICATION FOR PAYMENT

9.1.1 Applications for payment shall be made upon AIA Document G702. There will be a five percent (5%) retainage on all Contractor's monthly invoices until completion of the project. This retainage may become payable upon receipt of all required closeout documentation, provided all other requirements of the Contract Documents have been met.

9.1.2 A date will be fixed for the taking of the monthly account of work done. Upon receipt of Contractor's itemized application for payment, such application will be audited, modified, if found necessary, and approved for the amount. Statement shall be submitted to the Owner.

9.1.3 Section 6516, Title 29 of the Delaware Code annualized interest is not to exceed 12% per annum beginning thirty (30) days after the "presentment" (as opposed to the date) of the invoice.

9.2 PARTIAL PAYMENTS

9.2.1 Any public works Contract executed by any Agency may provide for partial payments at the option of the Owner with respect to materials placed along or upon the sites or stored at secured locations, which are suitable for use in the performance of the contract.

9.2.2 When approved by the agency, partial payment may include the values of tested and acceptable materials of a nonperishable or noncontaminative nature which have been produced or furnished for incorporation as a permanent part of the work yet to be completed, provided acceptable provisions have been made for storage.

9.2.2.1 Any allowance made for materials on hand will not exceed the delivered cost of the materials as verified by invoices furnished by the Contractor, nor will it exceed the contract bid price for the material complete in place.

9.2.3 If requested by the Agency, receipted bills from all Contractors, Subcontractors, and material, men, etc., for the previous payment must accompany each application for payment. Following such a request, no payment will be made until these receipted bills have been received by the Owner.

9.3 SUBSTANTIAL COMPLETION

9.3.1 When the building has been made suitable for occupancy, but still requires small items of miscellaneous work, the Owner will determine the date when the project has been substantially completed.

9.3.2 If, after the Work has been substantially completed, full completion thereof is materially delayed through no fault of the Contractor, and without terminating the Contract, the Owner may make payment of the balance due for the portion of the Work fully completed and accepted. Such payment shall be made under the terms and conditions governing final payment that it shall not constitute a waiver of claims.

- 9.3.3 On projects where commissioning is included, the commissioning work as defined in the specifications must be complete prior to the issuance of substantial completion.
- 9.4 FINAL PAYMENT
- 9.4.1 Final payment, including the five percent (5%) retainage if determined appropriate, shall be made within thirty (30) days after the Work is fully completed and the Contract fully performed and provided that the Contractor has submitted the following closeout documentation (in addition to any other documentation required elsewhere in the Contract Documents):
- 9.4.1.1 Evidence satisfactory to the Owner that all payrolls, material bills, and other indebtedness connected with the work have been paid,
- 9.4.1.2 An acceptable RELEASE OF LIENS,
- 9.4.1.3 Copies of all applicable warranties,
- 9.4.1.4 As-built drawings,
- 9.4.1.5 Operations and Maintenance Manuals,
- 9.4.1.6 Instruction Manuals,
- 9.4.1.7 Consent of Surety to final payment.
- 9.4.1.8 The Owner reserves the right to retain payments, or parts thereof, for its protection until the foregoing conditions have been complied with, defective work corrected and all unsatisfactory conditions remedied.

ARTICLE 10: PROTECTION OF PERSONS AND PROPERTY

- 10.1 The Contractor shall be responsible for initiating, maintaining, and supervising all safety precaution and programs in connection with the performance of the Contract. The Contractor shall take all reasonable precautions to prevent damage, injury or loss to: workers, persons nearby who may be affected, the Work, materials and equipment to be incorporated, and existing property at the site or adjacent thereto. The Contractor shall give notices and comply with applicable laws ordinances, rules regulations, and lawful orders of public authorities bearing on the safety of persons and property and their protection from injury, damage, or loss. The Contractor shall promptly remedy damage and loss to property at the site caused in whole or in part by the Contractor, a Subcontractor, or anyone directly or indirectly employed by any of them, or by anyone for whose acts they may be liable.
- 10.2 The Contractor shall notify the Owner in the event any existing hazardous material such as lead, PCBs, asbestos, etc. is encountered on the project. The Owner will arrange with a qualified specialist for the identification, testing, removal, handling and protection against exposure or environmental pollution, to comply with applicable regulation laws and ordinances. The Contractor and Architect will not be required to participate in or to perform this operation. Upon completion of this work, the Owner will notify the Contractor and Architect in writing the area has been cleared and approved by the authorities in order for the

work to proceed. The Contractor shall attach documentation from the authorities of said approval.

- 10.3 As required in the Hazardous Chemical Information Act of June 1984, all vendors supplying any materials that may be defined as hazardous, must provide Material Safety Data Sheets for those products. Any chemical product should be considered hazardous if it has a warning caution on the label relating to a potential physical or health hazard, if it is known to be present in the work place, and if employees may be exposed under normal conditions or in any foreseeable emergency situation. Material Safety Data Sheets must be provided directly to the Owner along with the shipping slips that include those products.
- 10.4 The Contractor shall certify to the Owner that materials incorporated into the Work are free of all asbestos. This certification may be in the form of Material Safety Data Sheet (MSDS) provided by the product manufacturer for the materials used in construction, as specified or as provided by the Contractor.

ARTICLE 11: INSURANCE AND BONDS

- 11.1 The Contractor shall carry all insurance required by law, such as Unemployment Insurance, etc. The Contractor shall carry such insurance coverage as they desire on their own property such as a field office, storage sheds or other structures erected upon the project site that belong to them and for their own use. The Subcontractors involved with this project shall carry whatever insurance protection they consider necessary to cover the loss of any of their personal property, etc.
- 11.2 Upon being awarded the Contract, the Contractor shall obtain a minimum of two (2) copies of all required insurance certificates called for herein, and submit one (1) copy of each certificate, to the Owner, within 20 days of contract award.
- 11.3 Bodily Injury Liability and Property Damage Liability Insurance shall, in addition to the coverage included herein, include coverage for injury to or destruction of any property arising out of the collapse of or structural injury to any building or structure due to demolition work, and evidence of these coverages shall be filed with and approved by the Owner.
- 11.4 The Contractor's Property Damage Liability Insurance shall, in addition to the coverage noted herein, include coverage on all real and personal property in their care, custody and control damaged in any way by the Contractor or their Subcontractors during the entire construction period on this project.
- 11.5 Builders Risk (including Standard Extended Coverage Insurance) on the existing building during the entire construction period, shall not be provided by the Contractor under this contract. The Owner shall insure the existing building and all of its contents and all this new alteration work under this contract during entire construction period for the full insurable value of the entire work at the site. Note, however, that the Contractor and their Subcontractors shall be responsible for insuring building materials (installed and stored) and their tools and equipment whenever in use on the project, against fire damage, theft, vandalism, etc.
- 11.6 Certificates of the insurance company or companies stating the amount and type of coverage, terms of policies, etc., shall be furnished to the Owner, within 20 days of contract award.

11.7 The Contractor shall, at their own expense, (in addition to the above) carry the following forms of insurance:

11.7.1 Contractor's Contractual Liability Insurance

Minimum coverage to be:

Bodily Injury	\$500,000	for each person
	\$1,000,000	for each occurrence
	\$3,000,000	aggregate
Property Damage	\$500,000	for each occurrence
	\$3,000,000	aggregate

11.7.2 Contractor's Protective Liability Insurance

Minimum coverage to be:

Bodily Injury	\$500,000	for each person
	\$1,000,000	for each occurrence
	\$3,000,000	aggregate
Property Damage	\$500,000	for each occurrence
	\$300,000	aggregate

11.7.3 Automobile Liability Insurance

Minimum coverage to be:

Bodily Injury	\$1,000,000	for each person
	\$1,000,000	for each occurrence
Property Damage	\$500,000	per accident

11.7.4 Prime Contractor's and Subcontractors' policies shall include contingent and contractual liability coverage in the same minimum amounts as 11.7.1 above.

11.7.5 Workmen's Compensation (including Employer's Liability):

11.7.5.1 Minimum Limit on employer's liability to be as required by law.

11.7.5.2 Minimum Limit for all employees working at one site.

11.7.6 Certificates of Insurance must be filed with the Owner guaranteeing fifteen (15) days prior notice of cancellation, non-renewal, or any change in coverages and limits of liability shown as included on certificates.

11.7.7 Social Security Liability

11.7.7.1 With respect to all persons at any time employed by or on the payroll of the Contractor or performing any work for or on their behalf, or in connection with or arising out of the

Contractor's business, the Contractor shall accept full and exclusive liability for the payment of any and all contributions or taxes or unemployment insurance, or old age retirement benefits, pensions or annuities now or hereafter imposed by the Government of the United States and the State or political subdivision thereof, whether the same be measured by wages, salaries or other remuneration paid to such persons or otherwise.

11.7.7.2 Upon request, the Contractor shall furnish Owner such information on payrolls or employment records as may be necessary to enable it to fully comply with the law imposing the aforesaid contributions or taxes.

11.7.7.3 If the Owner is required by law to and does pay any and/or all of the aforesaid contributions or taxes, the Contractor shall forthwith reimburse the Owner for the entire amount so paid by the Owner.

ARTICLE 12: UNCOVERING AND CORRECTION OF WORK

12.1 The Contractor shall promptly correct Work rejected by the Owner or failing to conform to the requirements of the Contract Documents, whether observed before or after Substantial Completion and whether or not fabricated, installed or completed, and shall correct any Work found to be not in accordance with the requirements of the Contract Documents within a period of two years from the date of Substantial Completion, or by terms of an applicable special warranty required by the Contract Documents. The provisions of this Article apply to work done by Subcontractors as well as to Work done by direct employees of the Contractor.

12.2 At any time during the progress of the work, or in any case where the nature of the defects shall be such that it is not expedient to have them corrected, the Owner, at their option, shall have the right to deduct such sum, or sums, of money from the amount of the contract as they consider justified to adjust the difference in value between the defective work and that required under contract including any damage to the structure.

ARTICLE 13: MISCELLANEOUS PROVISIONS

13.1 CUTTING AND PATCHING

13.1.1 The Contractor shall be responsible for all cutting and patching. The Contractor shall coordinate the work of the various trades involved.

13.2 DIMENSIONS

13.2.1 All dimensions shown shall be verified by the Contractor by actual measurements at the project site. Any discrepancies between the drawings and specifications and the existing conditions shall be referred to the Owner for adjustment before any work affected thereby has been performed.

13.3 LABORATORY TESTS

13.3.1 Any specified laboratory tests of material and finished articles to be incorporated in the work shall be made by bureaus, laboratories or agencies approved by the Owner and reports of such tests shall be submitted to the Owner. The cost of the testing shall be paid for by the Contractor.

- 13.3.2 The Contractor shall furnish all sample materials required for these tests and shall deliver same without charge to the testing laboratory or other designated agency when and where directed by the Owner.
- 13.4 ARCHAEOLOGICAL EVIDENCE
- 13.4.1 Whenever, in the course of construction, any archaeological evidence is encountered on the surface or below the surface of the ground, the Contractor shall notify the authorities of the State Historic Preservation Office and suspend work in the immediate area for a reasonable time to permit those authorities, or persons designated by them, to examine the area and ensure the proper removal of the archaeological evidence for suitable preservation by the Division of Historical and Cultural Affairs.
- 13.5 GLASS REPLACEMENT AND CLEANING
- 13.5.1 The General Contractor shall replace without expense to the Owner all glass broken during the construction of the project. If job conditions warrant, at completion of the job the General Contractor shall have all glass cleaned and polished.
- 13.6 WARRANTY
- 13.6.1 For a period of two (2) years from the date of substantial completion, as evidenced by the date of final acceptance of the work, the contractor warrants that work performed under this contract conforms to the contract requirements and is free of any defect of equipment, material or workmanship performed by the contractor or any of his subcontractors or suppliers. However, manufacturer's warranties and guarantees, if for a period longer than two (2) years, shall take precedence over the above warranties. The contractor shall remedy, at his own expense, any such failure to conform or any such defect. The protection of this warranty shall be included in the Contractor's Performance Bond.

ARTICLE 14: TERMINATION OF CONTRACT

- 14.1 If the Contractor defaults or persistently fails or neglects to carry out the Work in accordance with the Contract Documents or fails to perform a provision of the Contract, the Owner, after seven days written notice to the Contractor, may make good such deficiencies and may deduct the cost thereof from the payment then or thereafter due the Contractor. Alternatively, at the Owner's option, and the Owner may terminate the Contract and take possession of the site and of all materials, equipment, tools, and machinery thereon owned by the Contractor and may finish the Work by whatever method the Owner may deem expedient. If the costs of finishing the Work exceed any unpaid compensation due the Contractor, the Contractor shall pay the difference to the Owner.
- 14.2 "If the continuation of this Agreement is contingent upon the appropriation of adequate state, or federal funds, this Agreement may be terminated on the date beginning on the first fiscal year for which funds are not appropriated or at the exhaustion of the appropriation. The Owner may terminate this Agreement by providing written notice to the parties of such non-appropriation. All payment obligations of the Owner will cease upon the date of termination. Notwithstanding the foregoing, the Owner agrees that it will use its best efforts to obtain approval of necessary funds to continue the Agreement by taking appropriate action to request adequate funds to continue the Agreement."

END OF SECTION 00 81 13

NOT FOR BIDDING

EMPLOYEE DRUG TESTING REPORT FORM

Period Ending: _____

4104 Regulations for the Drug Testing of Contractor and Subcontractor Employees Working on Large Public Works Projects requires that Contractors and Subcontractors who work on Large Public Works Contracts funded all or in part with public funds submit Testing Report Forms to the Owner no less than quarterly.

Project Number: _____

Project Name: _____

Contractor/Subcontractor Name: _____

Contractor/Subcontractor Address: _____

Number of employees who worked on the jobsite during the report period: _____

Number of employees subject to random testing during the report period: _____

Number of Negative Results _____ Number of Positive Results _____

Action taken on employee(s) in response to a failed or positive random test:

Authorized Representative of Contractor/Subcontractor: _____
(typed or printed)

Authorized Representative of Contractor/Subcontractor: _____
(signature)

Date: _____

**EMPLOYEE DRUG TESTING
REPORT OF POSITIVE RESULTS**

4104 Regulations for the Drug Testing of Contractor and Subcontractor Employees Working on Large Public Works Projects requires that Contractors and Subcontractors who work on Large Public Works Contracts funded all or in part with public funds to notify the Owner in writing of a positive random drug test.

Project Number: _____

Project Name: _____

Contractor/Subcontractor Name: _____

Contractor/Subcontractor Address: _____

Name of employee with positive test result: _____

Last 4 digits of employee SSN: _____

Date test results received: _____

Action taken on employee in response to a positive test result:

Authorized Representative of Contractor/Subcontractor: _____
(typed or printed)

Authorized Representative of Contractor/Subcontractor: _____
(signature)

Date: _____

This form shall be sent by mail to the Owner within 24 hours of receipt of test results.

Enclose this test results form in a sealed envelope with the notation "Drug Testing Form – DO NOT OPEN" on the face thereof and place in a separate mailing envelope.

SECTION 009300 – RECORD CLARIFICATIONS AND PROPOSALS

The information described herein is believed to be accurate and representative, but no guarantee can be made that actual conditions encountered during construction will not vary or be changed.

1. SURVEY:

2. CADD FILES

Electronic Media (CADD files) drawings will be provided for contractors' reference subject to the terms and conditions outlined in Tetra Tech's "Release Form for Electronic Files" in Section 013301.

Upon request contractor shall sign a release form provided by the Architect and payment of \$200 processing fee for each consultant drawings requested.

CADD files shall be provided for use as background plans only. Contractors shall be responsible verifications of all dimensions and revisions. Contractor shall not copy or reproduce details, elevations, sections, schedules or other similar data.

Electronic Media (CADD files) drawings will be provided for contractors' reference subject to the terms and conditions outlined in Tetra Tech's "Release Form for Electronic Files".

3. WAGE DETERMINATION

Wage Rates and Payroll Reporting: Contractors shall comply with all requirements of the State of Delaware regarding wage rates and payroll reporting. These requirements include, but are not limited to, the following:

- a. **Wage Rates:** The wage rates that shall be used for this project are attached to this Section. This scale of wages shall be posted in a prominent and easily accessible location on the job site. All employees shall be paid directly upon the site of the work, not less often than once a week.
- b. **Payroll Reporting:** Per Section 6912 of Title 29, payroll information shall be reported weekly to the Owner (refer to Section 01311 "Schedules and Reports"). Contractors shall retain copies Payroll Reports for inspection upon request by Delaware Department of Labor.

END OF SECTION

(For Contractor's Optional Use; See Instructions, Form WH-347 Inst.)



Rev. April 2006

Persons are not required to respond to the collection of information unless it displays a currently valid OMB control number.

OMB No.: 1215-0149
Expires: 04/30/2009

NAME OF CONTRACTOR ☐ OR SUBCONTRACTOR ☐		ADDRESS	OMB No.: 1215-0145 Expires: 04/30/2009
PAYROLL NO.	FOR WEEK ENDING	PROJECT AND LOCATION	
			PROJECT OR CONTRACT NO.

[illegible]

The Copeland Act (40 U.S.C. 3145) requires contractors and subcontractors performing work on Federally financed or assisted construction contracts to "furnish weekly a statement with respect to the wages paid each employee during the preceding week." U.S. Department of Labor (DOL) Regulations 29 CFR Part 5.5(a)(3)(ii) require contractors to submit weekly a copy of all payrolls to the Federal agency contracting for or financing the construction project, accompanied by a signed "Statement of Compliance" indicating that the payrolls are correct and complete and that each laborer or mechanic has been paid not less than the proper Davis-Bacon prevailing wage rate for the work performed. Compliance with these requirements is mandatory. DOL and federal contracting agencies receiving this information review the information to determine that employees have received legally required wages and fringe benefits.

We estimate that it will take an average of 56 minutes to complete this collection of information, including time for reviewing instructions, searching existing data sources, gathering and maintaining the data needed, and completing and reviewing the collection of information. If you have any comments regarding these estimates or any other aspect of this collection of information, including suggestions for reducing this burden, send them to the Administrator, Wage and Hour Division, ESA, U. S. Department of Labor, Room S3502, 200 Constitution Avenue, N. W., Washington, D. C. 20210.

Date _____

I, _____ (Name of Signatory Party) _____ (Title)
do hereby state:

(1) That I pay or supervise the payment of the persons employed by

_____ (Contractor or Subcontractor) _____ on the _____
_____ (Building or Work) _____; that during the payroll period commencing on the _____

_____ day of _____, _____, and ending the _____ day of _____, _____,
all persons employed on said project have been paid the full weekly wages earned, and no rebates have
been or will be made either directly or indirectly to or on behalf of said

_____ (Contractor or Subcontractor) _____ from the full
weekly wages earned by any person and that no deductions have been made either directly or indirectly
from the full wages earned by any person, other than permissible deductions as defined in Regulations, Part
3 (29 CFR Subtitle A), issued by the Secretary of Labor under the Copeland Act, as amended (48 Stat. 945,
63 Stat. 108, 72 Stat. 967; 76 Stat. 357; 40 U.S.C. 276c), and described below:

(2) That any payrolls otherwise under this contract required to be submitted for the above period are
correct and complete; that the wage rates for laborers or mechanics contained therein are not less than the
applicable wage rates contained in any wage determination incorporated into the contract; that the
classifications set forth therein for each laborer or mechanic conform with the work he performed.

(3) That any apprentices employed in the above period are duly registered in a bona fide
apprenticeship program registered with a State apprenticeship agency recognized by the Bureau of
Apprenticeship and Training, United States Department of Labor, or if no such recognized agency exists in a
State, are registered with the Bureau of Apprenticeship and Training, United States Department of Labor.

(4) That:
(a) WHERE FRINGE BENEFITS ARE PAID TO APPROVED PLANS, FUNDS, OR PROGRAMS

☐ — In addition to the basic hourly wage rates paid to each laborer or mechanic listed in
the above referenced payroll, payments of fringe benefits as listed in the contract
have been or will be made to appropriate programs for the benefit of such
employees, except as noted in Section 4(c) below.

(b) WHERE FRINGE BENEFITS ARE PAID IN CASH

☐ — Each laborer or mechanic listed in the above referenced payroll has been paid,
as indicated on the payroll, an amount not less than the sum of the applicable
basic hourly wage rate plus the amount of the required fringe benefits as listed
in the contract, except as noted in Section 4(c) below.

(c) EXCEPTIONS

EXCEPTION (CRAFT)	EXPLANATION

REMARKS:

NAME AND TITLE	SIGNATURE
THE WILLFUL FALSIFICATION OF ANY OF THE ABOVE STATEMENTS MAY SUBJECT THE CONTRACTOR OR SUBCONTRACTOR TO CIVIL OR CRIMINAL PROSECUTION. SEE SECTION 1001 OF TITLE 18 AND SECTION 231 OF TITLE 31 OF THE UNITED STATES CODE.	

SECTION 011100 – SUMMARY OF WORK

PART 1 – GENERAL

- 1.1 Drawings and general provisions of contract, including General and Supplementary Conditions and other Division – 1 Specifications Sections, apply to this Section.

1.2 PROJECT DESCRIPTION

- A. This part of the project consists of the Bid Pac A Contracts, No. 1 through No. 15.
The description of the contracts are as follows:

Bid Pac A

Contract 1	Site Work
Contract 2	Concrete Work
Contract 3	Masonry Work
Contract 4	Steel Work
Contract 5	Carpentry & General Work
Contract 6	Roofing Work
Contract 7	Furnish Hollow Metal/Doors/Hardware
Contract 8	Aluminum Storefront/Windows/Glass and Glazing
Contract 9	Drywall/Metal Stud
Contract 10	Acoustical Work
Contract 11	Floor Covering Work
Contract 12	Caulking/Painting
Contract 13	Mechanical
Contract 14	Sprinkler System
Contract 15	Electrical

1.3 CONTRACTOR USE OF PREMISES

- A. General: During the construction period the contractor will be allowed reasonable use of the premises. However, the contractors use of the premises will not limit the Owners use of premises.

- 1.4 The Construction Managers scope of work is part of this section and denotes the work to be performed.

1.5 MISCELLANEOUS PROVISIONS

A. Miscellaneous Provision

1. The construction will start in June 30, 2025 Note that weekend and evening work may be required to meet the schedule. All materials may be procured early so that they are readily available. The Owner will pay ninety-five percent (95%) of stored materials providing they are properly insured, stored and can be verified.

B. Project Meetings

1. Pre-Construction Conference: Attendance by Owner, Architect, Engineers, Construction Manager, Contractor, major Subcontractors, and Suppliers.
2. Progress Meetings: Bi-weekly; attendance by Owner, Architect, Engineers, Construction Manager, Contractor, applicable Subcontractors, and Suppliers.

NOTE: Meetings may be held more frequently as required. Must attend these meetings and missing meetings will not be tolerated from Primary Contractors. Missing meetings will result in a penalty of \$200.00 dollars per meeting if your firm was requested to attend at the previous progress meeting.

C. Record Drawings

1. The contractors of the respective Contracts 1 thru Contract 15 shall be responsible for maintaining record “as built” throughout construction as indicated in Section 017000.

D. Schedule

Construction starts June 30, 2025. Project has to be finished by January 30, 2026
Please provide sufficient manpower in your cost to meet the completion date of January 30, 2025.

Bid Pac A

Contract 1	Site Work
Contract 2	Concrete Work
Contract 3	Masonry Work
Contract 4	Steel Work
Contract 5	Carpentry & General Work
Contract 6	Roofing Work
Contract 7	Furnish Hollow Metal/Doors/Hardware
Contract 8	Aluminum Storefront/Windows/Glass and Glazing
Contract 9	Drywall/Metal Stud
Contract 10	Acoustical Work
Contract 11	Floor Covering Work
Contract 12	Caulking/Painting
Contract 13	Mechanical
Contract 14	Sprinkler System
Contract 15	Electrical

Bid Pac A

The following parts of the specifications are to be considered part of each and every one of the contracts of Bid Pac A, Contracts No. 1 through 15. However, they shall not be listed with the Scope of Work for each of the Scopes of Work for the contracts. They will be referred to as the Administrative Sections with each of the Scope of Work for the contracts.

DIVISION 00 – PROCUREMENT AND CONTRACTING REQUIREMENTS

000101	PROJECT CONTACTS
000111	TABLE OF CONTENTS
000115	LIST OF DRAWINGS
000113	ADVERTISEMENT FOR BIDS
002113	INSTRUCTIONS TO BIDDERS
004126	BID FORMS INCLUDING: BID FORM SUB LISTING NON-COLLUSION STATEMENT AFFIDAVIT OF EMPLOYEE DRUG TESTING PROGRAM AFFIDAVIT OF CONTRACTOR QUALIFICATIONS
004313	STATE OF DELAWARE BID BOND

CONTRACTING INFORMATION

005226	AGREEMENT INCLUDING STANDARD FORM OF AGREEMENT BETWEEN OWNER AND CONTRACTOR (AIA A132 – 2019)
005313	AMENDMENT TO CONTRACT FOR CONSTRUCTION BETWEEN DELAWARE TECHNICAL AND COMMUNITY COLLEGE AND CONTRACTOR
006113.13	STATE OF DELAWARE PERFORMANCE BOND FORM
006113.16	STATE OF DELAWARE PAYMENT BOND FORM
006276	MONTHLY REQUISITION & CONTINUATION SHEET (AIA G732-2019 & G703-2021)
006300	STANDARD FORMS CERTIFICATES AND MODIFICATION FORMS
007226	GENERAL CONDITIONS OF THE CONTRACT FOR CONSTRUCTION (AIA A232-2019)
007300	SUPPLEMENTARY GENERAL CONDITIONS A232-2019 INCLUDING ATTACHMENT “A”

	CONSTRUCTION MANAGER GENERAL CONDITIONS
007316	INSURANCE INCLUDING SAMPLE CERTIFICATE OF INSURANCE
007346	DELAWARE PREVAILING WAGE RATES
008013	GENERAL REQUIREMENTS
008114	DRUG TESTING FORMS
009300	RECORD CLARIFICATION AND PROPOSALS
	PAYROLL REPORT FORM

DIVISION 01 – GENERAL REQUIREMENTS

011100	SUMMARY OF WORK
011200	MULTIPLE CONTRACT SUMMARY
011216	WORK SEQUENCE
011400	WORK RESTRICTIONS
012000	PRICE AND PAYMENT PROCEDURES
012100	ALLOWANCES
012116	CONTINGENCY ALLOWANCES
012200	UNIT PRICES
012300	ALTERNATES
012500	SUBSTITUTION PROCEDURES
012500A	SUBSTITUTION REQUEST FORM
012600	CONTRACT MODIFICATION PROCEDURES
012900	PAYMENT PROCEDURES
012973	SCHEDULE OF VALUES
013100	PROJECT MANAGEMENT AND COORDINATION
013113	PROJECT COORDINATION
013216	CONSTRUCTION SCHEDULE
013233	CONSTRUCTION PROGRESS DOCUMENTATION
013300	SAFETY
013319	FIELD ENGINEERING
013500	SAFETY
014000	QUALITY REQUIREMENTS
014200	REFERENCES
015000	TEMPORARY CONSTRUCTION UTILITIES, FACILITIES & CONTROLS
016000	MATERIALS AND EQUIPMENT PRODUCT REQUIREMENTS
017000	CONTRACT CLOSEOUT
017329	CUTTING AND PATCHING
017419	CONSTRUCTION WASTE MANAGEMENT
017700	CLOSEOUT PROCEDURES
017836	WARRANTIES

SCOPE OF WORK - Bid Pac A
CONTRACT NO. 1 SITE WORK

- A. The administrative sections, prints, addendums, and technical specifications 024113, 079200 & 311000.
- B. Provide all layout work required to accomplish this Contract work. A Licensed surveyor must perform the layout work.
- C. Provide topsoil stripping as required. Retain and stockpile all topsoil or soil needed to re-grade the site. Any soils not needed will be disposed of offsite by this contract in a proper manner. This is inclusive of all new and renovated building area footprints.
- D. Provide all grading and fine grading of sub-grades for swales, berms and walks.
- E. Provide all site select fill for the building, and site concrete. Include excavation and grading of any crawlspaces or basements if noted in project documents.
- F. Provide all storm drainage and storm water control for a complete system including manholes, and catch basins.
- G. Provide all crusher run for paving and site concrete.
- H. Provide all lawns, grasses, hydro seeding, seeding, turf relocation and erosion control materials complete. Provide lawn maintenance (grass cutting) within the limits of disturbance for the entire construction schedule.
- I. Provide all sediment and erosion control, including the installation, maintenance, and removal after construction of the silt fence and construction entrance. Restore areas where sediment and erosion control has been removed after construction. Also, provide all bio-retention areas, detention basins complete. Maintain the construction entrance and a clean roadway and street.
- J. Provide any temporary seeding required for erosion control.
- K. Coordinate all construction work with other utilities and notify Miss Utility prior to the start of work to locate existing underground utilities. All other existing utilities on site to be located under this contract, including data communication lines if any. Any damage to the existing utilities will be repaired under this contract at no additional cost to the owner.
- L. Provide all excavation and backfill required to accomplish the work of this Contract, including the proper compaction of all backfill materials. Provide the removal off site of any and all excess fill. Provide compaction testing. Provide all final grading of site.
- M. Each prospective bidder must visit the site to familiarize themselves with the current existing conditions.
- N. Provide all site concrete work as shown. Run all concrete work to the face of the buildings to meet interior concrete work performed by Contract No. 2 Concrete Work. Provide all stone bases and preparation work to install the site concrete. Provide all slab work and frost walls at exterior, as well as any necessary demolition to install pads and frost walls if under a canopy roof.

- Provide colored, stamped and patterned concrete and exposed aggregate concrete if noted in contract documents.
- O. Construction Manager will provide all temporary fencing.
 - P. Provide exterior caulking of expansion joints at all concrete locations including sidewalks and curbs.
 - Q. Electrical service to your construction trailer to be provided by this contract.
 - R. Coordinate all construction work with other utilities and notify Miss Utility prior to the start of work to locate existing underground utilities. All other existing utilities on site to be located under this contract, including data communication lines if any.
 - S. Provide the demolition of all trees, shrubs and existing stumps as required. Provide offsite deposit of all demolition material.
 - T. Provide CCR Reports, soil testing and all license and permits to perform the Site Work scope of work. Owner will obtain the building permit.
 - U. All electric lines, data lines, phone lines, etc.. are to be provided by Contract No. 15 Electrical.
 - V. This contract is responsible for all demolition that pertains to your scope of work.
 - W. Provide all demolition required to install new work and shown on drawings including curbs sidewalks, storm drainage, manholes, catch basins, tree and shrub removal, etc. Provide the demolition of anything that gets removed outside of the footprint of the main existing building to build the new building. We suggest that the site work bidders visit the job site and note the extent of the demolition required to erect the new addition, and new site work. Also protect existing trees. Contract 1 Site Work is to remove all outdoor concrete and sidewalks not attached to the building such as concrete.
 - X. Provide the relocation or adjustment of existing utility lines as necessary to install new lines.
 - Y. Provide assistance of all testing and inspections for your work. Owner will provide an inspection agency to do the testing. If testing fails, contractor will pay for additional testing.
 - Z. Provide testing of trenches that are opened and backfilled pertaining to your scope of work.
 - AA. Provide dewatering if needed for your scope of work.
 - BB. Provide all fine grading of landscape beds.
 - CC. Provide all soil amendments and fertilizers and the blending of these items into the top soil.
 - DD. Provide weed-control barriers and mulches complete.
 - EE. Provide all landscaping, trees and shrubs and the planting and pruning of these items complete. Provide protection of existing landscaping that is not to be removed. Provide relocation of existing landscaping as noted.

- FF. Provide plant maintenance and watering of landscaping for a period noted in the project documents.
- GG. Provide planting bed irrigation complete if noted.
- HH. Provide concrete wash out station for your concrete work and spill control station, including removal once complete.
- II. This contract is to provide payment to construction manager for any fines this contract or its subcontractors receive for OSHA violations where the construction manager is fined from OSHA due to your or your subcontractor are creating the infraction.
- JJ. See section 012300 Alternates and bid form for your responsibility for the alternates.
- KK. The intent of the scope is **NOT** to denote every minute detail but to create an awareness of the scope of work for the project.
- LL. **It is the contracts responsibility to review all other contract scopes of work**

SCOPE OF WORK - Bid Pac A
CONTRACT NO. 2 CONCRETE WORK

- A. The administrative sections, prints, addendums, and technical specifications 024119, 033000, 072100 & 079200.
- B. Provide all layout for the building foundations, locations and elevations by a registered surveyor complete. **NOTE:** The site work layout will be provided by the site work contractor (coordinate with Bid Pac A Contract No. 1 Site Work).
- C. Install all anchor bolts and the leveling, grouting and setting of the bearing plates for the structural steel material furnished by Contract No. 4 Steel Work and Contract No. 9 Drywall/Metal Stud materials. Steel and metal stud shop drawings to be used for layout of anchor bolts.
- D. Provide all perimeter insulation under concrete slabs and foundation walls.
- E. Provide sufficient layout work in regards to the foundation so that the masonry contract can provide wall foundations. Maintain batter boards and lines until masonry contractor starts work after the masonry contract accepts layout and starts work. It is the masonry Contractors responsibility to maintain work from that point forward.
- F. Provide all grading and grading of sub-grades for footings, foundation, floors and cast in place walls.
- G. Provide all excavation required for foundation work and the backfill required to do the poured in place concrete work.
- H. Provide all concrete foundations and rebar complete including any foundations outside the building foot print.
- I. Compact and backfill all trenches, foundations and other concrete work associated with this work only. Provide removal off-site of all excess soils due to excavation of your work.
- J. Provide all floor slabs complete including weather (hot and cold) protection, mesh, vapor barriers, sealers, water proof barriers, composite waterproof membrane, expansion and control joints, caulking and perimeter insulation under slab for a complete system. Refer to Division 9 Flooring Sections in reference to floor finish tolerances. Concrete sealers and curing Compounds must be compatible with flooring adhesives. Any irregularities in concrete surfaces at expansion joints to be ground flat to meet flooring contractor's specifications. Provide all concrete floor slab infill areas where demolished masonry wall is removed below finish floor. Refer to Division 9 Flooring Sections in reference to floor finish tolerances.
- K. Provide all concrete slab work to the exterior face of the enclosed building area. The site contract will pick it up from that point except for exterior loading dock area noted on bid documents.
- L. Provide stone drainage fill under all concrete slabs within the building footprint or under exterior concrete provided by this contract.

- M. **NOTE:** The item X in the site work contract scope of work. All fill in the building, step and ramps are to be plus or minus one (1") inch. This Contract is responsible to handle the preparation from that point to the completion of the concrete work.
- N. Provide all depressed concrete for floor mats at entrance and all other items that need concrete depressions. Locations and sized to be coordinated with other contracts.
- O. All cast in place concrete beams, lintels and walls to be included in this contract. Bond beams and CMU grouting is responsibility of Masonry Scope.
- P. It is the responsibility of this contract to coordinate with the Mechanical and Electrical Contractors, the elevation and locations of all imbedded items, at the time of pour including the proper sloping of floors to floor drains and troughs.
- Q. Concrete footings to be clean of all debris and dirt prior to sign off to Masonry Contractor.
- R. Temporary electrical service to your construction trailer to be provided by this contract. A localized electrical panel will be provided for your power source. Removal of temporary electric is the responsibility of this contract at completion of job.
- S. Provide assistance of all testing and inspections for your work. Owner will provide an inspection agency to do the testing. If testing fails, contractor will pay for additional testing.
- T. Notify mechanical and electrical contractors with a schedule of when the concrete is to be poured so these contractors can verify their equipment locations.
- U. Provide colored concrete finish complete and pattern concrete if noted in finish schedule and specifications.
- V. Provide an allowance of \$10,000 for cold weather protection. All protection to be approved by construction manager before work is performed.
- W. Existing building elevations to be confirmed under this contract.
- X. Provide infill of concrete where demolition has been performed. Locations would be at floor level where ductwork has been removed, etc...
- Y. All concrete debris to be disposed of off-site in a required manner meeting all local, state and federal laws.
- Z. Provide installation of steel edging in concrete as noted. Contract No. 4 Steel Work will furnish.
- AA. Provide repair of concrete floor cracks if noted in documents.
- BB. Provide all caulking and sealants for concrete slabs provided by this contract.
- CC. The concrete contractor is to coordinate with surveyor on the amount of locations and elevations the surveyor is to locate. Concrete contractor is responsible for accuracy of the layout.
- DD. Provide testing of trenches that are opened and backfilled pertaining to your scope of work.

- EE. Provide dewatering if needed for your scope of work.
- FF. Provide reinforcement for all concrete provided by this contract.
- GG. Provide self adhering sheet waterproofing and composite waterproofing complete.
- HH. Provide termite control system.
- II. Provide concrete infill at existing walls and floors where demolition items have been removed.
- JJ. Provide concrete wash out station.
- KK. Provide insulation that is under concrete pads.
- LL. This contract is to provide payment to construction manager for any fines this contract or its subcontractors receive for OSHA violations where the construction manager is fined from OSHA due to your or your subcontractor are creating the infraction.
- MM. See section 012300 Alternates and bid form for your responsibility for the alternates.
- NN. The intent of the scope is **NOT** to denote every minute detail but to create an awareness of the scope of work for the project.
- OO. It is the contracts responsibility to review all other contract scopes of work.**

SCOPE OF WORK – Bid Pac A
CONTRACT NO. 3 – MASONRY WORK

- A. The administrative sections, prints, addendums, and technical specification sections 024119, 033000, 042000, 055000, 072100, 072500, 076200 & 079200.
- B. Provide all masonry work complete including cmu block, and brickwork, All hollow metal doors and frames are to be stored and set by Contract No.5 Carpentry and General Work.
- C. Provide all concealed and thru wall flashings.
- D. Provide cavity wall insulation and other insulation attached between masonry walls and masonry veneer. Perimeter foundation wall insulation to be provided by Contract No. 2 Concrete Work. Provide cavity drainage mat system. Provide all ridged insulation that is located between masonry and masonry veneer. Contract No. 9 Drywall/Metal Stud will provide ridged insulation where attached to metal stud framing or masonry wall and no masonry veneer is located. Contract 9 Drywall/Metal Stud will provide all spray applied membrane air barriers. Contract 3 Masonry provides transition membrane around window and doors, etc., where there is masonry backup and veneer.
- E. Provide the installation of all bearing plates and bolts associated with the masonry for the steelwork and cold formed metal framing. The plates and bolts will be furnished by Contract No. 4 Steel Work. Steel contractor and masonry contractor to coordinate locations and placement of items at the time of masonry construction.
- F. Install all steel lintels attached or resting on masonry work finished by contract No. 4 Steel Work. Provide masonry pockets and grout filling of masonry cores where steel beams are attached or resting on masonry work. All structural steel beams provided and installed by Contract No. 4 Steel Work.
- G. Provide all cast stone, limestone and architectural precast concrete and stone as shown including window sills, bands, copings, accents and modular units.
- H. Provide the concrete and rebar for all the filling of block cores, bond beams and bearing points. Include all reinforcements, wall anchors and fasteners to attach to sub surface.
- I. Install joist bearing plates furnished by Contract No. 4 Steel Work that rest on masonry. Coordinate with Contract No. 4 Steel Work.
- J. See Item F Contract No. 2 Concrete Work for the layout and maintenance responsibility. This contract is responsible for layout of their portion of their work.
- K. Provide all grouting of masonry walls required. Also provide grouting of new doors and frames in existing openings.
- L. Temporary electrical service to your construction trailer to be provided by this contract. A localized electrical panel will be provided for your power source. Removal of temporary electric is the responsibility of this contract at completion of job.

- M. Provide fire stopping and protection for masonry walls including fire safing with mineral wool insulation. Provide wall markings for masonry fire and smoke partitions. Provide fire or acoustical sealant where wall intersects with floor or roof deck.
- N. All masonry debris to be disposed of off-site in a required manner meeting all local, state and federal laws.
- O. Provide masonry opening required for mechanical and electrical equipment. Location and sizes must be coordinated with each contractor. Also include masonry openings for other trades and access panels and doors as noted by these trades.
- P. Provide an allowance of \$10,000 for cold weather protection. All protection to be approved by construction manager before work is performed.
- Q. All wall penetrations to be patched prior to painting or cost of touch up painting to be deducted from contract.
- R. Provide bituminous damp proofing and all related accessories as noted on the project documents that is attached to masonry. Also provide waterproof membrane at locations noted in project documents.
- S. Furnish all wall anchors that are welded to steel beams and coordinate with Contract No. 4 Steel Work for the welding of these anchors only. All other wall anchors are to be furnished by the mason.
- T. Provide water proof membrane at below grade masonry units.
- U. Provide the repairs of masonry due to the removal of existing attachments to the existing building due to demolition required to clear the area for the new building. Provide patching where the new and remaining existing building intersect.
- V. Masonry contractor to coordinate the cleaning of debris from the foundation with the concrete contractor in a timely manner. Concrete contractor to clean foundation one time.
- W. Provide modifications and relocation for masonry openings for windows, doors and louvers. Include patching and infill of masonry where new and existing windows and doors are to be located.
- X. Provide masonry infill as shown in details throughout the prints. **NOTE:** Read all prints carefully. Also provide all the flashing required as shown on the details to secure a waterproof building.
- Y. Provide all concrete floor slab infill areas where demolished masonry wall is removed below finish floor. Refer to Division 9 Flooring Sections in reference to floor finish tolerances.
- Z. All anchor bolts set in CMU is to be furnished by Contract 4 Steel Work and installed by Contract 3 Masonry. Any fasteners required other than anchor bolts provided by each contractor for their scope of work.
- AA. Provide assistance of all testing and inspections for your work. Owner will provide an inspection agency to do the testing. If testing fails, contractor will pay for additional testing.

- BB. Provide spray polyurethane foam between masonry wall and roof and floor connections.
- CC. Provide removal off site of all demolition debris in a required manner meeting all local, state and federal laws.
- DD. Provide all select demolition required of all interior and exterior masonry areas in the project. The debris must be disposed of off-site in a required manner meeting all local, state, and federal laws. Provide shoring, bracing or other support where required due to demolition.
- EE. Provide caulking for control joints in masonry, expansion joints in masonry, cast stone joints and any place that are similar products with masonry. Any masonry to a dissimilar product is to be by other contract.
- FF. Provide infill of brick at existing window openings.
- GG. Provide expansion joints in masonry walls as noted or required.
- HH. This contract is to provide payment to construction manager for any fines this contract or its subcontractors receive for OSHA violations where the construction manager is fined from OSHA due to your or your subcontractor are creating the infraction.
- II. See section 012300 Alternates and bid form for your responsibility for the alternates.
- JJ. The intent of the scope is **NOT** to denote every minute detail but to create an awareness of the scope of for the project.
- KK. It is this contracts responsibility to review all other contract scopes of work.**

SCOPE OF WORK – Bid Pac A
CONTRACT NO. 4 STEEL WORK

- A. The administrative sections, prints, addendums, and technical specification sections 024119 & 055000.
- B. Provide and install all structural steel, steel joist, bridging, decking, and other miscellaneous steel for a complete job. Touch up with metal primer all areas required caused by welding. Provide structural steel framing and supports for mechanical and electrical equipment.
- C. Furnish all steel lintels, bearing plates or bolts shown to install in the masonry by Contract No. 5 Masonry. Steel contractor is responsible for verifying dimensions and elevations of these items prior to setting steel. Provide required steel coatings on lintels.
- D. Furnish all anchor bolts for structural steel to be installed in concrete by Contract No. 4 Concrete Work. Steel contractor is responsible for verifying dimensions and elevations of these items prior to setting steel.”
- E. Temporary electrical service to your construction trailer to be provided by this contract. A localized electrical panel will be provided for your power source. Removal of temporary electric is the responsibility of this contract at completion of job.
- F. Provide all steel products that are anchored in to the walls. Provide steel post supports in stud walls complete. Also provide top of wall steel angle bracing, Provide metal fabrication complete. Provide bent plates and angles complete.
- G. Provide all steel decking, including any decking that maybe fastened to cold form metal trusses and framing if shown.
- H. Provide welding of wall anchors furnished and located by Contract No. 3 Masonry Work that are attached to steel.
- I. Provide assistance of all testing and inspections for your work. Owner will provide an inspection agency to do the testing. If testing fails, contractor will pay for additional testing.
- J. The AISC Certified Erection requirement is waived for this project. The Special Inspections set forth in the IBC should be followed closely.
- K. This contract is to provide payment to construction manager for any fines this contract or its subcontractors receive for OSHA violations where the construction manager is fined from OSHA due to your or your subcontractor are creating the infraction.
- L. See section 012300 Alternates and bid form for your responsibility for the alternates.
- M. The intent of the scope is **NOT** to denote every minute detail but to create an awareness of the scope of work for the project.
- N. **It is this contracts responsibility to review all other contract scopes of work.**

SCOPE OF WORK – Bid Pac A
CONTRACT NO. 5 CARPENTRY & GENERAL WORK

- A. The administrative sections, prints, addendums, and technical specification sections 024119, 055000, 061053, 061600, 064023, 072100, 076200, 078400, 079200, 081113, 081416, 087100 & 104400.
- B. Provide the installation and proper storage of all hollow metal frames furnished by Contract No. 7 Furnish Hollow Metal/Doors Hardware. These items will be tailgate delivery.
- C. Provide the installation and the proper storage of all wood, fiberglass and hollow metal doors furnished by Contract No. 7 Furnish Hollow Metal/Doors Hardware. These items will be tailgate delivery.
- D. Provide the installation and the proper storage of all hardware furnished by Contract No. 7 Furnish Hollow Metal/Doors Hardware. These items will be tailgate delivery.
- E. Provide fire extinguishers, AEDS, cabinets, and accessories including any wood blocking required to install the cabinets and extinguishers. Also, remove store and reinstall existing cabinets in new location if noted.
- F. Provide all wood window or solid surface stools complete plus any wood blocking required to install the stools.. Provide wall caps for intermediate height walls. Contract No. 5 Carpentry & General Works provides wall caps on half walls. I-lam or solid surface wall caps and sills provided by this contract.
- G. Provide all wood trims and panels complete including blocking required. Provide wood wall caps as noted. Provide wood base.
- H. Provide all expansion, fire rated and architectural control joint covers assemblies as shown. Coordinate with other contracts involved. Roof joint covers provided by roofing contract.
- I. Provide all plywood sheathing and wood framing required. Include all hurricane ties as shown. Provide fire rated plywood and lumber if noted in project documents. Provide wood blocking and furring for roof curb. Provide attic plywood flooring.
- J. Provide all visual display boards, display cases, tack boards, tack strips, tackable surfaces and wood blocking required.
- K. Provide all wood blocking required on the project whether shown on the contract documents or not, including casework blocking.
- L. Provide all architectural louvers that are required other than the louvers required by the mechanical equipment provided by Contract No.13 Mechanical. Louvers that is required for mechanical systems to be provided by Contract No. 13 Mechanical Complete. Contract No. 5 Carpentry and General Work to provide all other louvers complete that are not required for mechanical equipment. Provide louver siding.
- M. Temporary electrical service to your construction trailer to be provided by this contract. A localized electrical panel will be provided for your power source. Removal of temporary electric is the responsibility of this contract at completion of job.

- N. Provide all wood blocking required at roofing locations so that the roofer can install his work.
NOTE: all locations included but not limited to skylights, roof hatches, and other items. This includes rooftop mechanical items and wood roof curbs as required.
- O. Provide window roller shades and blinds including electric roller shades at all windows noted.
- P. Provide roof, wall and floor access doors or panels and materials to install compete. Mechanical, Sprinkler, and Electrical contractors to provide access panels or doors for their portion of work. All other panels or doors by this contract if shown on plans.
- Q. Provide the patching as required where doors and jambs are removed.
- R. Provide knox box complete.
- S. Provide decorative formed & metal closures, trims and all related items for complete systems. Also provide decorative formed metal closures and trims complete, fiberglass, and metal column covers complete.
- T. Provide all wood trims, wood bases, azek, moldings, field built columns, FRP panels and blocking required complete.
- U. Provide all wood framing for floor, walls, stairs, ceilings, and roof. Provide fire rated wood framing and plywood as noted.
- V. Provide asphalt felt barrier between all treated wood blocking that comes in contact with steel or cold formed framing.
- W. Provide all signage, ADA signage, for a complete system including wood blocking.
- X. Provide residential appliances complete. Electrical and plumbing hook ups and venting by Contracts 13 and 15.
- Y. Provide impact wall protection and corner guards complete.
- Z. Provide allowance of \$25,000 for temporary enclosures as described in Section 015000 Temporary Construction Utilities, Facilities & Control Item 3.14 Enclosures.
- AA. Provide all wood framing testing, inspections and special inspections as noted in your related specifications or noted on drawings that relates to your scope of work. Contractor is to provide all testing and inspections whether noted otherwise in other locations in the documents.
- BB. Include the lump sum of the following amount \$25,000 in the contract for unforeseen conditions that may arise during construction to be used at the discretion of the Construction Manager.
- CC. Provide wall protection complete.

- DD. Provide all complete selective demolition of joist, decking, miscellaneous steel, and structural steel. Provide the temporary shoring that may be necessary to remove existing steel that is replaced or modified for the new addition or the renovation of the existing.
- EE. Temporary Shoring has been avoided to the greatest extent possible with the current details. Any temporary shoring that is required is a delegated design item and the design and implementation of the shoring is the responsibility of the contractor.
- FF. Provide all casework in the office area, work room, conference room, bathrooms and other areas noted on drawings. Provide all wood work and trim that is attached to casework.
- GG. Provide all counters for casework and stationary counters as shown. Provide metal counter supports as shown.
- HH. Provide p-lam shelving inclosets and all other shelving, casework and counters for this project. Also provide melamine shelves complete.
- II. Provide p-lam or solid surface windows sills and aprons complete. Also provide all p-lam and solid surface trims, bench seattops and cubbies and any other items noted on documents. Also provide decorative coat hooks and dots.
- JJ. Provide removal off site of all debris in a required manner meeting all local, state and federal laws.
- KK. Provide temporary closures to the existing offices of any areas that are open to exterior from the result of demolition of portions of the building. Provide barricades between work zone and existing office space.
- LL. Provide removal of doors, frames and hardware as noted.
- MM. Provide the demolition permit and license to perform the demolition scope of work.
- NN. Provide all concrete demolition on interior of building. Contract No. 1 Sitework to provide exterior demolition.
- OO. Provide all temporary shoring and underpinning as needed where walls, roof, floors and foundations are removed or existing structure bears on a demolished structure.
- PP. If any areas that are to remain are damaged by this Contract's demolition, the areas are to be patched and repaired to a satisfactory condition acceptable to the Architect and Construction Manager.
- QQ. Provide all demolition required to install new product including the demolition of all built ins, , display cases, casework, doors, hollow metal windows, frames, shelving fire extinguishers, corner edge protection, book shelves, T.V. brackets, casework and window treatments as shown. Modification and demolition of chalk and tack boards, all wood framed walls with attachments, projection screens, expansion joint covers and column covers. Provide demolition to all wood stud walls and metal stud walls that are covered with any material. Drywall and plaster covered walls are demolished also by this contract.

- RR. This contract is to provide demolition of existing windows, storefront, curtain walls and doors complete. Temporary protection and waterproof existing openings until new unit is installed.
- SS. Provide the demolition of any drywall, metal or wood stud framing that have plaster or drywall installed on them. Plaster or drywall ceilings and soffits or attachment to these walls or soffits.
- TT. Provide removal of all existing acoustical ceilings, grids, supports and insulation and all other layers of ceiling assemblies.
- UU. Provide removal of wall tile and mastic as noted in project documents.
- WW. Provide moving and protection of existing furniture in the renovated areas so that you can do your portion of work. This includes the base bid and alternate areas of renovation. It is also your responsibility to put back furniture once your portion of work is complete. CM will coordinate with contractors. Each contractor is to include in bid to move and re set furniture to do their scope of work.
- XX. Remove existing furniture partitions and work stations and reset once renovation is complete.
- YY. Remove existing roof over hangs where new addition connects to existing building.
- ZZ. Provide removal and reinstall of ceiling tile in renovations locations after new heat pumps are installed.
- AAA. This contract is to provide payment to construction manager for any fines this contract or its subcontractors receive for OSHA violations where the construction manager is fined from OSHA due to your or your subcontractor are creating the infraction.
- BBB. See section 012300 Alternates and bid form for your responsibility for the alternates.
- CCC. The intent of the scope is **NOT** to denote every minute detail but to create an awareness of the scope of for the project.
- DDD. It is this contract responsibility to review all other contract scopes of work.**

SCOPE OF WORK Bid Pac A
CONTRACT NO. 6 ROOFING

- A. The administrative sections, prints, addendums, and technical specification sections 024119, 076200 & 078400.
- B. Provide all roof membrane and all other roofing complete including all ridged insulation, nailable deck sheathing, dens deck board, asphalt shingles and standing seam metal roofing..
- C. Provide all flashing required to make a complete roof system including fiberglass and hypalon flashing. Also, include any flashing necessary for the waterproofing of new mechanical and electrical equipment. Provide EPDM flashing with termination bar and sealants as noted in the project documents. Also provide all roof expansion joint covers if shown.
- D. Provide all aluminum trim, fascias abd soffits, roof accessories, ridge vent, gutters and downspouts, splash blocks, ice & water guards, roof curbs and roof accessories as shown.
- E. Temporary electrical service to your construction trailer to be provided by this contract. A localized electrical panel will be provided for your power source. Removal of temporary electric is the responsibility of this contract at completion of job.
- F. Provide all caulking sealants that are related to roofing that is provided under this contract. Provide reglets and counter flashings for all roof locations and Masonry Contract No. 3 will provide thru-wall flashings. Coordinate with Contract No. 3 Masonry for flashing compatibility.
- G. Provide all flashing for prefabricated roof curbs and rails to make water proof.
- H. Provide bituminous damp proofing and self adhering sheet waterproofing on roofing areas complete. Masonry Contract 3 will provide bituminous damp proofing applied to masonry and Contract No. 2 Concrete will provide waterproof barriers and composite waterproof membrane under concrete.
- I. Provide the roof construction infill at all existing roof penetrations where mechanical or electrical items have been removed so that the new roofing can be installed.
- J. This contract is responsible for all demolition that pertains to your scope of work. Provide demolition of copings, cornice, metal roof edge, metal flashings, sidings, roof hatch, roofing materials, etc.
- K. Provide the removal of all existing roofing that must be removed for the installation of the new roofing system complete. Provide temporary protection of exposed surfaces after demolition of existing roofing.
- L. Coordinate final connections of downspouts to underground piping with site contractor.
- M. Carpentry contract to provide floor, wall and ceiling expansion joint covers. Roofing contract to provide roof expansion joint cover.
- N. Provide the metal roof edge metals including all accessories for a complete system.

- O. Contract No. 8 Roofing will provide demolition of existing roofing product and wall panels at the time of installation of new roofing material. Provide temporary protection of exposed surfaces after demolition of existing roofing.
- P. Provide removal of existing gutters and downspouts if shown
- Q. Provide fluid-applied roofing complete.
- R. Provide roof edge fall protection complete.
- S. This contract is to provide payment to construction manager for any fines this contract or its subcontractors receive for OSHA violations where the construction manager is fined from OSHA due to your or your subcontractor are creating the infraction.
- T. See section 012300 Alternates and bid form for your responsibility for the alternates.
- U. The intent of the scope is **NOT** to denote every minute detail but to create an awareness of the scope for the project.
- V. **It is this contracts responsibility to review all other contract scopes of work.**

SCOPE OF WORK Bid Pac A

CONTRACT NO. 7 FURNISH HOLLOW METAL/DOORS HARDWARE

- A. The administrative sections, prints, addendums, and technical specification sections 081113, 081416, 084113 & 087100.
- B. Furnish all hollow metal frames, hollow metal barrow lites, all steel windows, hollow metal doors, all wood doors, and all hardware complete. Furnish wood infill panels window and door and louvers mullions that are fastened in hollow metal frames. Contract No.5 is responsible to place material in their storage area. Contract No. 7 to tailgate deliver to storage area. All materials need to be properly marked and identified for installation by Contract No. 5 Carpentry and General Work. Develop a sign-off system so that both parties of Contract No. 5 Carpentry and General Work and Contract No. 7 Furnish Hollow Metal/Doors Hardware agree the correct amount of material has been delivered.
- C. Provide all required hardware templates and reference material so that Contract No. 5 Carpentry may install the material. Contract No. 7 Furnish Hollow Metal/Doors Hardware will be responsible for providing and coordinating information with all other trades that interfaces such as Contract No. 5 Carpentry and General Work and Contract No. 8 Aluminum Storefront/Windows/Glass and Glazing and Contract No. 15 Electrical.
- D. Furnish the hardware to Contract No. 8 Aluminum Storefront/Windows/Glass and Glazing Contractor to install.
- E. Electrical service to your construction trailer to be provided by this contract. A localized electrical panel will be provided for your power source. Removal of temporary electric is the responsibility of this contract at completion of job.
- F. Access control system is to be provided by owner, doors/frames are to be prepped for them under your contract. Provide all hardware accept card readers as noted in the hardware specifications.
- G. Furnish fiberglass doors complete if noted.
- H. This contract is to provide payment to construction manager for any fines this contract or its subcontractors receive for OSHA violations where the construction manager is fined from OSHA due to your or your subcontractor are creating the infraction.
- I. See section 012300 Alternates and bid form for your responsibility for the alternates.
- J. The intent of the scope is **NOT** to denote every minute detail but to create an awareness of the scope of work for the project.
- K. **It is this contracts responsibility to review all other contract scopes of work.**

SCOPE OF WORK Bid Pac A

CONTRACT NO. 8 ALUMINUM STOREFRONT/WINDOWS/GLASS AND GLAZING

- A. The administrative sections, prints, addendums, and technical specification sections 079200, 084113 & 088000.
- B. Provide all aluminum windows, aluminum window sills, and doors complete. Provide all break metal around new windows and doors complete. Provide all window and door mullions that are attached to aluminum windows and doors. Also provide window panning, low pressure foam insulation around window units, and simulated divided lite with applied grids if shown.
- C. Provide all glass and glazing. Include all doors and windows furnished by Contract No. 7 Furnish Hollow Metal/Doors/Hardware. Also include applied grids for simulated divided lite if shown. Provide fire and insulated glazing and fire-rated aluminum door and window panels.
- D. Provide all caulking for new work provided by this contract including interior and exterior windows and storefront.
- E. Temporary electrical service to your construction trailer to be provided by this contract. A localized electrical panel will be provided for your power source. Removal of temporary electric is the responsibility of this contract at completion of job.
- F. Electrical service to your construction trailer to be provided by this contract. A localized electrical panel will be provided for your power source.
- G. Provide cleaning of glass and frames at completion of installation.
- H. Provide decorative surface applied film and ballistic film on glass if noted.
- I. Temporary closures may not be necessary during the period of construction. Once the interior finishes are to begin installation, temporary closures will be needed. If windows and doors are not available for installation when openings are ready; Contract No. 10 Aluminum Storefront is to provide temporary closures for the openings until finished windows and doors are installed.
- J. Provide aluminum head and sill flashings and all other associated flashings for your product for a complete system. Provide self adhering flashing around windows and doors.
- K. This contract is to provide payment to construction manager for any fines this contract or its subcontractors receive for OSHA violations where the construction manager is fined from OSHA due to your or your subcontractor are creating the infraction.
- L. See section 012300 Alternates and bid form for your responsibility for the alternates.
- M. The intent of the scope is **NOT** to denote every minute detail but to create an awareness of the scope of work for the project.
- N. **It is this contracts responsibility to review all other contract scopes of work.**

SCOPE OF WORK Bid Pac A
CONTRACT NO. 9 DRYWALL/METAL STUD

- A. The administrative sections, prints, addendums, and technical specification sections 024119, 054000, 061600, 072100, 072500, 078400, 092216 & 092900.
- B. Provide all batt insulation (walls and ceilings). Provide all rigid and spray applied insulation that attaches to all metal framing and masonry walls. Provide mineral wool board insulation. Provide structural nailable insulated sheathing and parapet sheathing. Provide transition membrane around window and doors, etc...
- C. Provide all metal stud, framing, furring and drywall work complete. Provide slide clips on structural beams for metal stud wall support. Provide metal furring whether shown or not on drawings at all locations including masonry walls for attachment of substrates. Also provide all cold formed metal trusses and all brackets and clips complete. Provide all tile backer board complete. Provide sealants to top and bottom of partitions and at penetrations to seal. Provide infill framing at existing walls add openings. Provide slide clip that attach to metal stud and structural steel. Provide girts and hat channels complete. Provide gypsum wall board on metal furring at wall and ceiling locations. Provide infill framing of existing windows.
- D. Provide all metal blocking required.
- E. Coordinate with Contract No. 5 Carpentry so that they can install any wood blocking required in the metal stud walls.
- F. Provide all bulkhead, soffit framing, parapet wall framing and framing for cants at roof complete. Provide z-furring and metal strapping for soffits and siding.
- G. Provide all gypsum sheathing work complete, including all vapor barrier, weather barriers and air infiltration barriers and building wrap or building paper. This contractor is responsible for maintaining the proper attachment of the barriers and building paper to the building until the final veneer covers the area.
- H. Provide all drywall suspended ceilings, walls, shaft walls, fascias and soffits called for on the prints complete including all framing required. Coordinate with Contract No. 13 Mechanical, No. 14 Sprinkler System and No. 15 Electrical. Provide framing for access panels supplied by this contract. Wrap steel columns with drywall.
- I. Provide all expansion control required for drywall and all gypsum board moldings and Z reveal trim. Provide sealant and caulk for the Z reveal trim.
- J. Temporary electrical service to your construction trailer to be provided by this contract. A localized electrical panel will be provided for your power source. Removal of temporary electric is the responsibility of this contract at completion of job.
- K. Provide fire protection for metal stud walls or ceilings as shown including fire safing mineral wool insulation and fire or acoustical sealant. Provide fire safing and smoke sealant between floors and curtain wall assemblies. Provide acoustical and fire rated insulation in deck flutes where walls intersect.

- L. Provide all hurricane ties and clips complete that are fastened to cold form framing.
- M. As part of the warranty portion. Provide an inspection of drywall and plaster with the owner after 1 year of substantial completion and identify locations to be re pointed due to flaws and cracks in the drywall and plaster. Repair all areas and repaint as needed. Any defect caused by abuse will be charged to the owner.
- N. Provide wall labeling for smoke and fire walls for drywall/metal stud walls or ceilings.
- O. Provide all cold formed metal framing testing, inspections and special inspections as noted in your related specifications or noted on drawings that relates to your scope of work. Contractor is to provide all testing and inspections whether noted otherwise in other locations in the documents.
- P. Provide insulated air barrier system to the complete exterior of the building including masonry and metal framed wall systems. Also include spray foam insulation with intumescent coating complete.
- Q. Provide modifications and relocation of metal framing for windows and door opening. Include patching and infill of metal framing and drywall where new and existing windows are to be located.
- R. Provide all sealant or elastomeric spray as noted where walls meet metal deck as shown on contract documents. Provide for metal stud and masonry walls complete.
- S. Provide all spray applied cellulosic and polyurethane foam insulation complete.
- T. Provide wall tile cement backer board in areas where tile wainscot is shown.
- U. Provide spray fire resistant materials and all associated accessories if noted in the project documents. Coordinate with other trades that have attachments to this location.
- V. Provide the insulation of all cold formed headers complete.
- W. Provide sprayed acoustical insulation and prep of surface to receive coating.
- X. Provide metal stud infill at renovated areas of construction.
- Y. Provide all intumescent coatings complete.
- Z. Provide moving and protection of existing furniture in the renovated areas so that you can do your portion of work. This includes the base bid and alternate areas of renovation. It is also your responsibility to put back furniture once your portion of work is complete. CM will coordinate with contractors. Each contractor is to include in bid to move and re set furniture to do their scope of work.
- AA. This contract is to provide payment to construction manager for any fines this contract or its subcontractors receive for OSHA violations where the construction manager is fined from OSHA due to your or your subcontractor are creating the infraction.

- BB. See section 012300 Alternates and bid form for your responsibility for the alternates.
- CC. The intent of the scope is **NOT** to denote every minute detail but to create an awareness of the scope of for the project.
- DD. It is this contracts responsibility to review all other contract scopes of work.**

NOT FOR BIDDING

SCOPE OF WORK Bid Pac A
CONTRACT NO. 10 ACOUSTICAL WORK

- A. The administrative sections, prints, addendums, and technical specification section 095113.
- B. Provide all the new acoustical and lay-in ceilings required including the hangers for a complete system. Also include all acoustical wall and ceiling panels, suspended decorative grid, clouds, wood panel ceilings and specialty ceilings. Provide aluminum fascias and trims as noted.
- C. Temporary electrical service to your construction trailer to be provided by this contract. A localized electrical panel will be provided for your power source. Removal of temporary electric is the responsibility of this contract at completion of job.
- D. Provide all insulation if shown above the acoustical ceilings.
- E. Provide metal lay in ceilings and egg create panels complete if noted in project documents.
- F. Provide new acoustical ceilings in existing areas where noted where acoustical ceilings are removal and reinstalled Contract 5 Carentry wil provide.
- G. Provide moving and protection of existing furniture in the renovated areas so that you can do your portion of work. This includes the base bid and alternate areas of renovation. It is also your responsibility to put back furniture once your portion of work is complete. CM will coordinate with contractors. Each contractor is to include in bid to move and re set furniture to do their scope of work.
- H. This contract is to provide payment to construction manager for any fines this contract or its subcontractors receive for OSHA violations where the construction manager is fined from OSHA due to your or your subcontractor are creating the infraction.
- I. See section 012300 Alternates and bid form for your responsibility for the alternates.
- J. The intent of the scope is **NOT** to denote every minute detail but to create an awareness of the scope of work for the project.
- K. **It is this contract's responsibility to review all other contract scopes of work**

SCOPE OF WORK Bid Pac A
CONTRACT NO. 11 FLOOR COVERINGS

- A. The administrative sections, prints, addendums, and technical specification sections 024119, 096513 & 096813.
- B. Provide all preparation of walls and floors to receive the new base and floor tile.
- C. Provide all base complete except the wood bases. Provide rubber profile base and millwork resilient base complete.
- D. Provide all resilient tile flooring complete including the concrete floor preparation and patching to receive the new material. This includes all VCT, rubber, luxury vinyls and VSF flooring.
- E. Refer to the Finish Schedule for the scope of work.
- F. Provide all carpet and carpet tile complete and all floor preparation and patching to receive the new material.
- G. Temporary electrical service to your construction trailer to be provided by this contract. A localized electrical panel will be provided for your power source. Removal of temporary electric is the responsibility of this contract at completion of job.
- H. Provide vinyl tile, walk off mats, and ceramic, porcelain and quarry tile and all associated accessories for a complete system. Include floor preparation and patching to receive the new material.
- I. Provide resilient sheet flooring and all associated materials including floor prep for a complete system. Provide seamless flooring complete. Provide static control tile complete.
- J. Provide all preparation of walls and floors to receive the new base, floor tile, and carpet after the existing materials have been removed. The debris can be placed in the jobsite dumpster. **NOTE:** Site visit is essential to determine your floor preparation.
- K. Provide final cleaning, waxing and sealing of all floor coverings furnished by this contract per manufacturers' recommendations and project specifications. Provide protection of finished floor coverings until completion of the project.
- L. Provide resinous flooring and base complete including preparation of sub base if noted.
- M. Provide all transitions for all the flooring types needed for the project complete.
- N. Provide removal and replacement of floor covering and base in new and renovated areas. Provide moving of furniture to install new flooring in renovated areas.
- O. Provide the demolition required to install new carpet, floor tile, ceramic tile, resinous flooring and base. Others will remove floor tile that has environmental issues but this Contract must remove all other flooring that does not contain asbestos and other floor coverings. Also provide removal of all glues, adhesives, grout, etc.. and coordinate with the flooring contract on method of removal to so it will not jeopardize new flooring installation and requirements.

- P. Provide moving and protection of existing furniture in the renovated areas so that you can do your portion of work. This includes the base bid and alternate areas of renovation. It is also your responsibility to put back furniture once your portion of work is complete. CM will coordinate with contractors. Each contractor is to include in bid to move and re set furniture to do their scope of work.
- Q. This contract is to provide payment to construction manager for any fines this contract or its subcontractors receive for OSHA violations where the construction manager is fined from OSHA due to your or your subcontractor are creating the infraction.
- R. See section 012300 Alternates and bid form for your responsibility for the alternates.
- S. The intent of the scope is **NOT** to denote every minute detail but to create an awareness of the scope of work for the project.
- T. **It is this contracts responsibility to review all other contract scopes of work.**

NOT FOR BIDDING

SCOPE OF WORK Bid Pac A
CONTRACT NO. 12 CAULKING/PAINTING

- A. The administrative sections, prints, addendums, and technical specification sections 078400, 079200 & 099100.
- B. Provide all exterior and interior caulking required except the caulking required by Contract No. 8 Aluminum Storefront/Windows/Glass and Glazing, Contract No. 1 Sitework, Contract No. 2 Concrete Work, Contract 3 Masonry work. Prepare the surfaces to receive the new caulking. Also, include any location where dissimilar materials meet not covered in above contracts. Provide caulking for all other areas of construction except those contracts listed above.
- C. Provide all exterior and interior painting including the preparation of new and existing surfaces to receive the new paint. Provide painted graphics as noted in project documents. **NOTE:** Special attention needs to be given for existing surface preparation. Paint all new and existing walls, ceilings, trims, frames, etc..
- D. Provide the sanding, cleaning and painting of all exterior lintels, and other metals.
- E. Reference the finish schedules for the scope of work as well as the prints.
- F. Provide all epoxy, high performance coatings, painting, concrete sealer paint and exposed ceiling painting including the preparation of the areas to receive painting. See the finish schedule.
- G. Painters option to apply finish coat of paint after all finishes are installed or be responsible for ALL touch up necessary.
- H. Electrical service to your construction trailer to be provided by this contract. A localized electrical panel will be provided for your power source. Removal of temporary electric is the responsibility of this contract at completion of job.
- I. Provide all caulking that is required where casework meets walls, floors or ceilings if required. Also provide caulking of dry wall trim/block interface as noted on the reveal details on the project documents. Provide caulking at all trims, moldings.
- J. Provide interior caulking to all windows and door frames. Drywall returns, sills and etc. would be the responsibility of this contract to caulk. Caulk between the top of wood base and wall.
- K. Provide the painting of exposed conduit, sprinkler, plumbing and mechanical piping and duct work. Painting Contractor shall coordinate work with Sprinkler, Mechanical and Electrical Contractors.
- L. Provide staining and varnishing of job site finished wood products include prep of material complete except wood flooring.
- M. Provide wall coverings including preparation of walls for a complete system.
- N. Included in all prep of surfaces is the light sanding of surface and filling of nail and screw holes.
- O. Provide painting of exposed fire sprinkler piping and connections.

- P. Provide all necessary wall prep as per specifications 099000 – Paints and Coatings and as noted on the plans.
- Q. Provide painting of renovated spaces as noted in base bid and alternate 1. Furniture will need to be moved and protected by this contract.
- R. Provide moving and protection of existing furniture in the renovated areas so that you can do your portion of work. This includes the base bid and alternate areas of renovation. It is also your responsibility to put back furniture once your portion of work is complete. CM will coordinate with contractors. Each contractor is to include in bid to move and re set furniture to do their scope of work.
- S. This contract is to provide payment to construction manager for any fines this contract or its subcontractors receive for OSHA violations where the construction manager is fined from OSHA due to your or your subcontractor are creating the infraction.
- T. See section 012300 Alternates and bid form for your responsibility for the alternates.
- U. The intent of the scope is **NOT** to denote every minute detail but to create an awareness of the scope of work for the project.
- V. **It is this contracts responsibility to review all other contract scopes of work.**

SCOPE OF WORK – Bid Pac A
CONTRACT NO. 13 MECHANICAL

- A. The administrative sections, prints, addendums and technical specification sections 024119, 078400, 079200, 230130.51, 230517, 230523, 230529, 230548, 230553, 230593, 230713, 230913, 230923, 230934, 232113, 232114, 232123, 232300, 233100, 233300, 233700, 237200, 238126.13, 238129 & 238146. Technical specifications are noted on mechanical and plumbing contract drawings. Also, refer to electrical drawings for any mechanical or plumbing equipment.
- B. Provide all plumbing complete including hook up to residential and commercial equipment. Also provide caulking of plumbing fixtures to countertops, walls or other surfaces. Provide lavatory shields complete.
- C. Provide all testing and permits for the plumbing work. Provide chlorination on all water lines.
- D. Provide all HVAC work complete including all required louvers for the mechanical work. Contract No. 5 Carpentry and General Work is responsible for other louvers. Provide fire dampers as required by all codes that apply.
- E. Provide all testing and balancing of the HVAC system.
- F. Provide Fire stopping and patching of wall and ceiling areas that require mechanical penetration. Coordinate with other trades. Provide access panels and doors as required. This contract to install the access doors.
- G. Provide the cutting of roof areas where mechanical penetration is required. If any framing or modification is required for the opening it is the responsibility of this Contract to provide. Also provided all roof curbs for all mechanical items.
- H. Provide all final connections from 5' outside of building to building for all site utilities. Includes water, sewer, and storm sewer.
- I. It is the responsibility of the mechanical contractor to coordinate and inspect at the time of pour all imbedded mechanical items in concrete or masonry units for proper elevations and locations.
- J. This contract is responsible to restore sub-grade to within 1" + / - of final grade. Provide compaction and testing as required.
- K. This contract is responsible for all temporary heat as needed through duration of construction. See allowances.
- L. Temporary electrical service to your construction trailer to be provided by this contract. A localized electrical panel will be provided for your power source. Removal of temporary electric is the responsibility of this contract at completion of job.
- M. Provided all roof curbs and rails for all mechanical items. Provide metal and gypsum chimney stack liners complete.
- N. Provide gas piping and final connections and all related items.

- O. Provide coordination of all mechanical penetrations with all trades involved. Hammer penetrations will not be tolerated. All wall penetrations to be patched prior to painting or cost for touch up paint to be deducted from contract.
- P. Provide all concrete housekeeping pads for mechanical and plumbing equipment as required.
- Q. Provide duct mounted smoke and heat detectors including all control wiring as needed for a complete system as required by all codes that apply.
- R. Provide the cutting, demolition and repair of all concrete floors and walls required to install new mechanical items. Also after the installation of work, repair and patch all concrete floors. Refer to Division 9 Flooring Sections in reference to floor finish tolerances. Provide the cutting demolition and repair of all walls required to install new mechanical items. After the installation of work, repair and patch all walls to match finish conditions.
- S. Coordinate the hook up with the storm water system provided by Contract No. 1 Site Work. Provide all final connections from 5' outside of building to building for all site utilities. Includes water, sewer, and storm sewer. Contract No. 1 Site Work will provide rain water conductor and cast iron rainwater boots.
- T. Provide the allowance of \$10,000 in the contract for temporary heat fuel cost. Cost of work to be determined by fuel company receipts with amount of fuel and cost per gallon. All equipment and labor for temporary heat is part of the contract. This allowance is for fuel cost only.
- U. Provide painting of roof top equipment if noted.
- V. Provide rooftop units, acoustical package, fire and smoke dampers, heat pumps, split systems, VRF system, electric heat, condensing units, energy recovery ventilation, ductless split system, fans, cabinet heaters, pumps, unit heaters, and all other mechanical equipment complete.
- W. Provide the mechanical controls system complete including low voltage wiring. Electrical contractor will provide power only.
- X. In regards to coordination drawings, the mechanical contractor has the responsibility to coordinate all the trades and producing a coordination drawing showing all trades.
- Y. Mechanical contract is to provide demolition and installation of new concrete floor pads where mechanical items are relocated, demolished, or added new.
- Z. Provide all sleeves for piping and ductwork complete.
- AA. Provide smoke vents complete if connected to HVAC system.
- BB. In alternate 1, provide removal of heat pump and replacement. Include protection and moving of furniture to perform your scope. Provide balancing of system and all transition ductwork for reconnection to existing ductwork.
- CC. Provide cleaning of existing duct in areas of renovations.

- DD. Provide documentation the proper removal and disposal of universal waste such as mercury thermostats, mercury containing fluorescent light bulbs, and lead acid batteries from emergency lighting.
- EE. Provide the draining and proper removal of all HVAC fluids, Freon and gas before the starting of demolition.
- FF. If any areas that are to remain are damaged by this Contract's demolition, the areas are to be patched and repaired to a satisfactory condition acceptable to the Architect and Construction Manager.
- GG. Provide the selective demolition of all existing mechanical items and plumbing items. This will require the capping of the utilities associated with the casework. Provide removal of louvers, water coolers, boilers, air handlers fans, ductwork, all piping, valves, unit ventilators, heat pumps VRF, roof top units, fans, plumbing fixtures, panels, etc..
- HH. Areas where selective demolition is being done, provide temporary weather protection to interior space where windows and doors and drains are being removed. Coordinate removal of roof drains at the time of roof removal with Contract 6 Roofing.
- II. Provide moving and protection of existing furniture in the renovated areas so that you can do your portion of work. This includes the base bid and alternate areas of renovation. It is also your responsibility to put back furniture once your portion of work is complete. CM will coordinate with contractors. Each contractor is to include in bid to move and re set furniture to do their scope of work.
- JJ. This contract is to provide payment to construction manager for any fines this contract or its subcontractors receive for OSHA violations where the construction manager is fined from OSHA due to your or your subcontractor are creating the infraction.
- KK. See section 012300 Alternates and bid form for your responsibility for the alternates.
- LL. The intent of this scope is **NOT** to denote every minute detail but to create an awareness of the scope of work for the project.
- MM. It is this contracts responsibility to review all other contract scopes of work.**

SCOPE OF WORK Bid Pac A
CONTRACT NO. 14 SPRINKLER SYSTEM

- A. The administrative sections, prints, addendums, and technical specifications sections 024119, 078400, 079200, 104400, 210500, 210523, 210548, 210553, 211300 & 284600. Technical specifications are noted on the mechanical and plumbing contract drawings. Also, refer to electrical drawings for any sprinkler equipment.
- B. Provide any fire stopping required where your work penetrated walls. Provide access panels and doors as required. This contract is to install their own panels.
- C. Provide all fire sprinkler/protection including, but not limited to, backflow preventers, sprinkler heads, piping, fittings, standpipe, fire department connection and fire pumps.
- D. Submit all required calculations and applications for review and approval by Sussex County and State of Delaware Fire Marshals Office.
- E. Provide all required flow switches, alarms, tamper switches, alarm clock valves, pipe, hangers, inserts, valves, fittings, fire department hose valves, access panels and access doors associated with your scope of work.
- F. Coordinate with all effected trades', provide coordination information to other contracts.
- G. Fire sprinkler contractor shall pick up all new water services from a flange 8" above finish floor in the fire pump room and other locations throughout the building.
- H. Temporary electrical service to your trailer to be provided by this contract. A localized electrical panel will provided for your power source. Removal of temporary electric is the responsibility of this contract at completion of job.
- I. Provide flushing for all interior and exterior fire water lines complete.
- J. Provide coordination of all sprinkler penetrations with all trades involved. Hammer penetrations will not be tolerated. All wall penetrations to be patched prior to painting or cost of touch up painting to be deducted from contract. Provide sleeves as required.
- K. Provide any demolition of existing walls required to install piping. Patch and repair as necessary. Provide any fire stopping required where your work penetration walls.
- L. Provide the cutting and patching of the concrete flooring to hook system to the waterlines. Patch concrete floors in a proper manner.
- M. Provide the removal of sprinkler heads so heat pumps can be removed in the renovated space.
- N. Provide demolition of existing sprinkler system as shown or noted in specifications.
- O. Provide moving and protection of existing furniture in the renovated areas so that you can do your portion of work. This includes the base bid and alternate areas of renovation. It is also your responsibility to put back furniture once your portion of work is complete. CM will coordinate

with contractors. Each contractor is to include in bid to move and re set furniture to do their scope of work.

- P. Provide demolition of existing fire alarm and electrical system.
- Q. This contract is to provide payment to construction manager for any fines this contract or its subcontractors receive for OSHA violations where the construction manager is fined from OSHA due to your or your subcontractor are creating the infraction.
- R. See section 012300 Alternates and bid form for your responsibility for the alternates.
- S. The intent of this scope is **NOT** to denote every minute detail but to create an awareness of the scope of work for the project.
- T. **It is this contracts responsibility to review all other contract scopes of work.**

NOT FOR BIDDING

SCOPE OF WORK Bid Pac A
CONTRACT NO. 15 ELECTRICAL

- A. The administrative sections, prints, addendums, and technical specification sections 024119, 078400, 079200, 260505, 260519, 260526, 260529, 260533.13, 260553, 260583, 260923, 262416, 262726, 262813, 265100, 271000 & 284600. Technical specifications are noted on the electrical contract drawings. Also, refer to mechanical and plumbing drawings for any technical equipment.
- B. Provide temporary lighting as required for all areas of construction. Provide temporary electric service to all construction managers' office trailers. Trench wire in ground. Remove temporary service at completion of job.
- C. Provide the patching and fire stopping required for any electrical penetration thru walls, ceilings and floors. Provide access doors and panels as required. This contract is to install their own panels.
- D. Provide all rough-in and final electrical connections to the commercial and residential equipment and mechanical equipment. Provide disconnection and rewiring of new equipment in the renovated space.
- E. Provide all equipment, material, testing, permits, and inspections required for a complete electrical system for the entire project.
- F. Provide all concrete work for the installation of all electrical equipment.
- G. Electrical contractor shall provide line power to fire alarm system as required by code.
- H. Electrical contractor shall provide power to all electric door hardware. This shall include wall boxes and conduit where necessary. Electrical contractor shall coordinate with Hardware contract and alarm company. This shall include wall boxes, conduit and installation of control boxes. Low voltage wiring by others; electrical contractor is to provide line voltage to all electric door hardware.
- I. Provide temporary distribution panel with six (6) 60-amp, 120/240 volt, single phase, 3-wire power for construction trailers for other contractors. Electrical hook-up, including conduit and wiring to trailer location shall be the responsibility of the Contractor requesting power not the Electrical Contract.
- J. This contract is responsible to restore sub-grade to within 1" + / - of final grade.
- K. If the Electrical contractor requires power for his construction trailer, he shall provide power to his trailer from the temporary distribution panel provided. Electrical contractor is responsible for all material, labor, and equipment necessary to extend power from panel to electrical site trailer. Electrical contractor shall make connection to panel
- L. Provide all heat and smoke detector power wiring per all codes that apply.
- M. Provide electrical connections for owner purchased equipment.

- N. Provide all conduits, wire and all related material to install all underground electric utilities complete.
- O. Provide all site lighting complete including concrete bases, conduit, wire and fixtures. Also provide power to exterior score board.
- P. Provide proper compaction and testing of all trenches associated with electrical work.
- Q. Provide coordination of all electrical penetrations with all trades involved. Hammer penetrations will not be tolerated. All wall penetrations to be patched prior to painting or cost of touch up painting to be deducted from this contract.
- R. Provide lightning protection system complete.
- S. Provide heat terminals complete.
- T. Provide the demolition, patching and fire stopping required for any electrical penetration thru walls. Also provide the patching of areas where existing electrical penetrations are removed due to demolition.
- U. Provide the saw cutting, demolition and repair for any floor areas required to run electrical work. Refer to Division 9 Flooring Sections in reference to floor finish tolerances.
- V. Provide the patching and fire stopping required for any electrical penetration thru walls.
- W. Provide pathways, conduit, boxes, raceways, cable trays, floor boxes, distribution backboards, electrical protection, bonding and grounding and power supplies only for Telecommunication system, structured cabling, audio visual and sound systems and secondary systems. Also provide site conduit and pull boxes for technology and communications systems. Structured Cabling, and Security systems provided by others.
- X. Provide owners interactive display devices electrical requirements complete.
- Y. Provide the fire alarm system and all hardware for a complete system.
- Z. Provide analysis and coordination study of electrical system.
- AA. Provide electrical power to electric hand dryers.
- BB. Provide all lighting for project including bollard lights.
- CC. Electrical Scope Clarification –Division 27 & 28 Items

Provide pathway and boxes only to the following items:

270500 – Telecommunications Pathways and Spaces
271000 – Structured Cabling
274100 – Audio Visual and Sound System
Intercom and Clocks
Network Equipment
Telephone

ERR/DAS
Intrusion Detection
Access Control
Video Surveillance

- DD. Provide the electrical telecom and alarm grounding and bonding system complete.
- EE. In regards to coordination drawings, the electrical contractor has the responsibility to coordinate all the trades and producing a coordination drawing showing all trades.
- FF. Provide all lighting complete including the testing of lighting and control systems.
- GG. Provide heat trace system complete.
- HH. Provide Provide an Allowance of \$10,000 in you price for short circuit analysis gear revisions.
- II. Provide all concrete housekeeping pads for electrical equipment required.
- JJ. Provide the relocation of fiber optic cable exterior wire and conduit to new locations inside the existing building. Figure this work to be done during off hours so it does not disrupt service.
- KK. Provide an allowance of \$10,000 in your cost for selective demolition of existing offices.
- LL. Provide removal and disposal of PCB ballasts per local and federal codes and guild lines. Cost will be determined by unit price and amount of ballast that are encountered during the demolition phase.
- MM. Provide documentation the proper removal and disposal of universal waste such as mercury thermostats, mercury containing fluorescent light bulbs, and lead acid batteries from emergency lighting.
- NN. If any areas that are to remain are damaged by this Contract's demolition, the areas are to be patched and repaired to a satisfactory condition acceptable to the Architect and Construction Manager.
- OO. Provide demolition of existing fire alarm and electrical system.
- PP. Provide demolition of all existing electrical items including wiring, lighting, boxes conduit as noted in documents.
- QQ. Provide demolition of all electrical items including lights, wiring, panels, speakers, water coolers, fire alarms, power poles, ect..
- RR. Provide moving and protection of existing furniture in the renovated areas so that you can do your portion of work. This includes the base bid and alternate areas of renovation. It is also your responsibility to put back furniture once your portion of work is complete. CM will coordinate with contractors. Each contractor is to include in bid to move and re set furniture to do their scope of work.
- SS. Provide new electrical connections and cable to new heat pump units located in renovated spaces.

- TT. This contract is to provide payment to construction manager for any fines this contract or its subcontractors receive for OSHA violations where the construction manager is fined from OSHA due to your or your subcontractor are creating the infraction.
- UU. See section 012300 Alternates and bid form for your responsibility for the alternates.
- VV. The intent of this scope is **NOT** to denote every minute detail but to create an awareness of the scope of work for the project.
- WW. It is this contracts responsibility to review all other contract scopes of work.**

END OF SECTION 011100

NOT FOR BIDDING

SECTION 011200 – MULTIPLE CONTRACT SUMMARY

PART 1 - GENERAL

1.1 SUMMARY

- A. This section describes certain responsibilities of the Contractors. These instructions shall be strictly followed unless more stringent requirements are contained within other Specification sections or written directions from the Construction Manager state otherwise.

Protection of Existing Conditions
Project Supervision
Project Coordination
Protection of Existing Conditions
Systems Coordination Drawings
Field Engineering
Testing
Fees, Licenses, and Permits
Sleeves, Hangers, and Inserts
Chases and Recesses
New and Existing Openings
Penetrations
Fireproof Repair
Equipment Foundations
Cutting and Patching
Access Doors and Panels
Touch-up Painting
Starters and Disconnects
Final Cleaning

1.2 PROTECTION OF EXISTING CONDITIONS

- A. Existing finished surfaces to remain in place in the existing site, shall be protected by the Trade Contractor performing the work in that area, by whatever materials and means are required to prevent any damage. Other surfaces shall be protected with tarpaulins, drop cloths, and similar coverings, as required.
- B. At the completion of the work, or when protection is no longer required, temporary enclosures, tarpaulins, building paper, drop cloths and other temporary materials, shall be removed and existing work and finishes in altered portions of the existing site shall be cleaned and left in condition acceptable to the Owner, Architect, and the Construction Manager.

1.3 PROJECT SUPERVISION

- A. Every Trade Contractor shall be responsible for the supervision of their work. Adequate supervision as required to maintain the progress schedule, shall be required within the scope of work within the contracts. When more than one major building phase is being constructed at different locations on the project site, separate supervision must be assigned to each phase when work of that contract is being performed. When performing construction work to maintain the progress schedule requires extended hours, multiple shifts, and/or additional work days, adequate

separate supervision shall be required for each Trade Contractor during these times. The competence level and ability of supervisory personnel must be adequate to perform the construction activities involved.

- B. Although these various second level supervision personnel may be reassigned from time to time, each contractor shall retain one superintendent with full responsibility while performing work on the project.
- C. The Construction Manager shall have the authority to direct the Trade Contractor to assign additional supervisory personnel to ensure compliance with the contract schedule and quality requirements at no addition to the contract price.

1.4 PROJECT COORDINATION

- A. Every Trade Contractor shall be responsible for the coordination of the progress of their work with the progress of all other Trade Contractors work.
- B. Inasmuch as Project completion within the time limit is dependent upon cooperation of those engaged therein, it is imperative that each Trade Contractor perform his work at such time and in such a manner as not to delay or otherwise interfere with work progress of other Trade Contractors. If any Trade Contractor's work depends upon proper execution or results of another Trade Contractor's work, the former shall inspect the work and report any defects therein to the Construction Manager.
- C. Trade Contractors shall afford each other every reasonable opportunity for installation of their work, and shall work in conjunction with each other in order to facilitate proper and intelligent execution of work.
- D. Plans are generally diagrammatic, and each Trade Contractor shall coordinate his work with the work of others, so that interference between mechanical, electrical, architectural and structural work does not occur. Each Trade Contractor shall furnish and install offsets, bends, turns, and the like in connection with his work to avoid interference with work of other Trade Contractors, to conceal work where required, and to secure necessary clearance and access for operation and maintenance. In case of interference or lack of clearance and access, the Construction Manager will be notified immediately, and shall, in turn, notify the Architect. The Architect will decide which work shall be relocated, regardless of which was installed first.
- E. Coordinate scheduling, submittals, and Work of the various sections of the Project Manual to assure efficient and orderly sequence of installation of interdependent construction elements, with provisions for accommodating items installed later.
- F. Verify utility requirements and characteristics of operating equipment are compatible with utilities. Coordinate work of various sections having interdependent responsibilities for installing, connecting to, and placing in service such equipment.
- G. Coordinate completion and clean up of Work of separate sections in preparation for Substantial Completion and for portions of Work designated for Owner's partial occupancy.
- H. After Owner occupancy, coordinate access to site for correction of defective Work and Work not in accordance with Contract Documents, to minimize disruption of Owner's activities.

1.5 FIELD ENGINEERING

H. Inspection:

1. Each Trade Contractor shall confirm locations of survey control points prior to starting work. Promptly notify Construction manager of any discrepancies discovered.
2. The Trade Contractor shall verify all measurements of the site and shall be responsible for the correctness of same. No extra charge or compensation will be allowed on account of differences between actual dimensions and the measurements indicated on the Drawings; any difference which may be found should be submitted to the Architect for consideration before proceeding with the work.

I. The Owner shall secure a professional engineer or surveyor licensed in the State of Delaware to perform the following:

1. Provide benchmark elevation to serve as the basis for the construction layout of the project.

J. Construction Layout:

1. The Sitework Trade Contractor shall be responsible to perform the layout and elevations required to complete his work.
2. The Site Concrete Work Trade Contractor shall layout to complete the scope of their work.
3. Each Trade Contractor shall layout the remainder of his own work and be responsible for all lines, levels, grades, elevations, and measurements.

1.6 TESTING

- A. The owner shall employ and pay for the services of a testing agency to perform the required construction material testing for specification divisions 1 through 3. Refer to section 014000 Quality Control for testing agency qualifications and test reporting requirements.

1.8 FEES, LICENSES, AND PERMITS

A. The following permits shall be purchased by the Owner:

1. Building Permit

B. All remaining fees, licenses, and permits shall be obtained and paid for by the trade contractor requiring them at no additional cost to the Owner to complete their work.

1. All Trade Contractors are advised that the Owner has reached an agreement with the County of Kent and the City of Dover to pay for the following permit fees: Building Construction.
2. Each respective contractor will still be required to obtain license from the County of Sussex and the City of Rehoboth Beach.
3. Additionally, all contractors are still responsible to coordinate required applicable inspections.

1.9 SLEEVES, HANGERS, AND INSERTS

- A. Each Trade Contractor shall furnish sleeves and inserts required to accommodate his work, together with instructions regarding their placement and location in the structure. Sleeves and inserts shall be furnished promptly in accordance with the established construction schedule so that they may be built-in as construction progresses.
- B. Trade Contractors to furnish all embeds, sleeves, inserts, etc., that are to be cast in concrete or built in masonry to the appropriate Trade Contractor for installation.
- C. Each Trade Contractor shall furnish and install hangers required to accommodate his work.

1.10 CHASES AND RECESSES

- A. Each Trade Contractor shall provide all blockouts shown on the Contract Documents and having either or both dimensions greater than 10" to the appropriate Trade Contractor for installation into his work. Any openings with dimensions smaller than 10" or not shown on drawings but required by a Trade Contractor shall be furnished and installed by the Trade Contractor requiring the same.
- B. It is the responsibility of the Trade Contractors requiring openings, chases, etc., to furnish information regarding size and location promptly in accordance with the established construction schedule, so that they may be built-in as construction progresses and avoid delays. Failure to provide the information promptly will result in the responsible Trade Contractor incurring any cost associated with the delay and the installation.
- C. Trade Contractors shall cooperate fully with each other in the performance of above work, as cutting and patching of new work is neither contemplated nor will it be tolerated.

1.11 NEW AND EXISTING OPENINGS

- A. Upon removal of existing work, which penetrates floors, walls, or ceilings, openings shall be immediately closed with material matching that adjacent to the opening. This shall include whatever structural support is required. The closing of existing openings shall be performed by the Trade Contractor who is responsible to perform this work as if it is new construction.
- B. Each Trade Contractor shall be responsible to install any new openings required to install his works in any existing construction and to furnish and install any additional structural support. All cutting and patching must be performed by journeymen or master trade mechanics for the trade work of the cutting/patching. Costs for all patching work are the responsibility of the trade contractor requiring the new opening.
- C. This structural support shall maintain the structural integrity of the building.
- D. Prior to cutting or drilling of any new openings that require additional structural support, the contractor shall submit a shop drawing to the Construction manager for review and acceptance by the Architect prior to demolition.
- E. Openings required by any Trade Contractor in new construction shall be coordinated with the

Trade Contractor(s) performing adjacent work.

1.12 PENETRATIONS

- A. Each Trade Contractor shall be responsible to seal his own penetrations in walls, floors, and ceilings, using fire resistant materials, as required.
- B. All roofing work shall be performed by the Roofing Trade Contractor, including patching penetrations made by the other Trade Contractors. Unless assigned specifically in section 011100 the cutting of roof openings, structural reinforcement, roof curbs, and counter flashing, shall be provided and installed by each Trade Contractor whose work penetrates the roofing surface, including all additional blocking associated with penetration.

1.13 FIREPROOF REPAIR

- A. Existing and new spray-on fireproofing which is damaged by Trade Contractors shall be repaired by the Trade Contractor who caused the damage. The repair work shall be performed by tradesman qualified and certified to perform the repair.

1.14 EQUIPMENT FOUNDATIONS

- B. The Concrete Work Trade Contractor shall provide all interior foundations and housekeeping pads indicated on the Contract Documents. The Site work Concrete Contractor shall place all exterior equipment foundations and housekeeping pads indicated on the Contract Documents. All other foundations, equipment, and housekeeping pads not shown, but required, shall be by the Trade Contractor requiring the same.
- C. Each Trade Contractor shall furnish anchor bolts and other accessories required to anchor his equipment in place, together with instructions regarding their placement and location in the foundation. Anchor bolts and other accessories shall be furnished promptly in accordance with the established construction schedule so that they may be built-in as construction progresses.

1.15 CUTTING AND PATCHING

- A. Responsibility: A Trade Contractor requiring the cutting of openings in new work, or in the existing work installed by others shall have such openings cut and patched by the trade which installed the original work and such cutting and patching shall be at the expense of the Trade Contractor requiring the opening.
- B. Approval: Approval to do such cutting and patching shall be received from the Architect through the Construction Manager prior to proceeding with the work. Approval of any structural cutting must be received from the structural engineer and architect before proceeding.
- C. Inspection:
 - 1. Inspect existing conditions, including elements subject to damage or movement during cutting and patching.
 - 2. After uncovering, inspect conditions affecting performance of work.
 - 3. If, in the course of cutting and patching the existing building for alteration work, a material is uncovered which appears to contain asbestos, the Contractor shall immediately notify the

Construction Manager. Contractors shall perform other construction activities until the area in question can be cleared.

D. Preparation:

1. Provide supports to assure structural integrity of surroundings, devices, and methods, to protect other portions of Project from damage.
2. Provide protection from elements for areas which may be exposed by uncovering work.

E. Performance:

1. Execute work by methods to avoid damage to other work and which provide proper surfaces to receive patching and finishing.
2. Employ original installer to perform cutting and patching for weather-exposed and moisture-resistant elements and sight-exposed surfaces.
3. Restore work with new products in accordance with requirements of Contract Documents.
4. Fit work tightly to pipes, sleeves, ducts, conduit and other penetrations through surfaces.
5. At penetrations of fire-rated wall, ceiling or floor construction, completely seal voids with fire-resistant materials as required to achieve fire-rating indicated.
6. Where fire protection materials are damaged or removed, reapply fire protection materials to achieve a rating equivalent to existing construction or as noted.
7. Refinish surfaces to match adjacent finishes. For continuous surfaces, refinish to nearest intersection; for an assembly, refinish entire unit.

1.16 ACCESS DOOR AND PANELS

- A. Access doors and panels, shown on architectural drawings, shall be furnished and installed by each Trade's Contractor whose product needs to be accessible.
- B. Access doors and panels shall be furnished by the trade contractor requiring access and delivered to the Drywall and Metal Stud Trade Contractor for installation.

1.17 FINAL CLEANING

- A. Trade Cleaning: Each contractor is responsible for final cleaning their own work as outlined in Section 011100 - Summary of Work. This initial cleaning must be completed before requesting inspection for Certification of Substantial Completion. This cleaning shall include, but not be limited to:
 1. Clean surfaces exposed to view; remove temporary labels, stains and foreign substances; polish transparent and glossy surfaces.
 2. Clean equipment and fixtures to a sanitary condition with cleaning materials appropriate to the surface and material being cleaned. Comply with Product manufacturer instruction and recommendations.
 3. Within limits of Contract, clean site, sweep paved areas, rake clean landscaped surfaces.
 4. Provide additional cleaning as required within individual Specification sections.
 5. Remove waste and surplus materials, rubbish and construction facilities from the site. Dispose of in a legal manner.
 6. Clean exposed exterior and interior hard-surfaced finishes to a dust-free condition, free of stains, films and similar foreign substances. Restore reflective surfaces to their original reflective condition. Leave concrete floors broom clean. Vacuum carpeted surfaces.

7. Wipe surfaces of mechanical and electrical equipment. Remove excess lubrication and other substances. Clean plumbing fixtures to a sanitary condition. Clean light fixtures and lamps.
8. Wipe down all walls, equipment, fixtures, casework and shelving to a dust-free sanitary condition.
9. Sweep, vacuum and mop all floors.
10. Clean all windows, glass and glazing.

1.18 TOUCH-UP PAINTING

- A. The Caulking and Painting Contractor shall coordinate and schedule his final coat as directed by the Construction Manager to reduce the amount of touch-up painting required.
- B. After the final coat has been applied, all touch-up paint and patching required to repair damage caused by other trade shall be reviewed by the Construction Manager and paid for from the construction contingency or back charged to the Trade Contractor who the Construction Manager determines is responsible.

1.19 STARTERS AND DISCONNECTS

- A. The Electrical Contractor shall furnish and install starters, power and starter control wiring per the electrical drawings and the specifications. The Electrical Contractor shall furnish and install starters in the motor control center.
- B. Individual starters and disconnects shown on other drawings and specifications shall be furnished by that Trade Contractor and will be installed and connected by the Electrical Contractor.

END OF SECTION 011200

SECTION 011216 – WORK SEQUENCE

PART 1 - GENERAL

1.1 SECTION INCLUDES

- A. Products and installation for patching and extending work.
- B. Transition and adjustments.
- C. Repair of damaged surfaces, finishes, and cleaning.

1.2 RELATED SECTIONS

- A. Section 013100 – Project Management and Coordination: Work sequence, owner occupancy, maintenance of utility services.
- B. Section 017329 - Cutting and Patching: Cutting and patching.
- C. Section 015000 – Temporary Construction Facilities and Temporary Controls: Temporary enclosures, protection of installed work, and cleaning during construction.
- D. Section 024119 – Selective Demolition

PART 2 - PRODUCTS

2.1 PRODUCTS FOR PATCHING AND EXTENDING WORK

- A. New Materials: As specified in product sections; match existing Products and work for patching and extending work.
- B. Type and Quality of Existing Products: Determine by inspecting and testing Products where necessary, referring to existing Work as a standard.

PART 3 - EXECUTION

3.1 EXAMINATION

- A. Verify that demolition is complete and areas are ready for installation of new Work.
- B. Beginning of restoration Work means acceptance of existing conditions.

3.2 PREPARATION

- A. Cut, move, or remove items as necessary for access to alterations and renovation Work. Replace and restore at completion.
- B. Remove unsuitable material not marked for salvage, such as rotted wood, corroded metals, and deteriorated masonry and concrete. Replace materials as specified for finished Work.

- C. Remove debris and abandoned items from area and from concealed spaces.
- D. Prepare surface and remove surface finishes to provide for proper installation of new work and finishes.
- E. Close openings in exterior surfaces to protect existing work and salvage items indicated from weather and extremes of temperature and humidity. Insulate ductwork and piping to prevent condensation in exposed areas.

3.3 INSTALLATION

- A. Coordinate work of alterations and renovations to expedite completion sequentially and to accommodate Owner occupancy.
- B. Remove, cut and patch work in a manner to minimize damage and to provide a means of restoring Products and finishes to original condition in accordance with Section 024500.
- C. Refinish visible existing surfaces to remain in renovated rooms and spaces, to specified condition for each material, with a neat transition to adjacent finishes in accordance with Section 024500.
- D. Project, Designated Areas, Rooms and Spaces, and Finishes: Complete including operational mechanical and electrical work.
- E. In addition to specified replacement of equipment and fixtures, restore existing plumbing, heating, ventilation, air conditioning, electrical, and other systems to full operational condition.
- F. Re-cover and refinish work that exposes mechanical and electrical work exposed accidentally during the work.
- G. Install Products as specified in individual sections.

3.4 TRANSITIONS

- A. Where new work abuts or aligns with existing, perform a smooth and even transition. Patch Work to match existing adjacent work in texture and appearance.
- B. When finished surfaces are cut so that a smooth transition with new work is not possible, terminate existing surface along a straight line at a natural line of division and make recommendation to Architect/Engineer.

3.5 ADJUSTMENTS

- A. Where removal of partitions or walls results in adjacent spaces becoming one, rework floors, walls, and ceilings to a smooth plane without breaks, steps, or bulkheads.
- B. Where a change of plane of 1/4 inch or more occurs, submit recommendation for providing a smooth transition for Architect/Engineer review.

- C. Trim existing doors as necessary to clear new floor finish. Refinish trim as required.
- D. Fit work at penetrations of surfaces as specified in Section 01045.

3.6 REPAIR OF DAMAGED SURFACES

- A. Patch or replace portions of existing surfaces which are damaged, lifted, discolored, or showing other imperfections.
- B. Repair substrate prior to patching finish.

3.7 FINISHES

- A. Finish surfaces as specified in individual Product sections.
- B. Finish patches to produce uniform finish and texture over entire area. When finish cannot be matched, refinish entire surface to nearest intersections.

3.8 CLEANING

- A. In addition to cleaning specified in Section 015000, clean Owner occupied areas of work.

END OF SECTION 011216

SECTION 011400 - WORK RESTRICTIONS

PART 1 - GENERAL

1.1 RELATED DOCUMENTS

- A. Drawings and general provisions of the Contract, including General and Supplementary Conditions and other Division 1 Specification Sections, apply to this Section.

1.2 USE OF PREMISES

- A. Use of Site: Limit use of premises to work in areas indicated. Do not disturb portions of site beyond areas in which the Work is indicated.
 - 1. Owner Occupancy: Allow for Owner occupancy of site.
 - 2. Driveways and Entrances: Keep driveways and entrances serving premises clear and available to Owner, Owner's employees, and emergency vehicles at all times. Do not use these areas for parking or storage of materials.
 - a. Schedule deliveries to minimize use of driveways and entrances.
 - b. Schedule deliveries to minimize space and time requirements for storage of materials and equipment on site.

1.3 OCCUPANCY REQUIREMENTS

- A. Partial Owner Occupancy: Owner reserves the right to occupy and to place and install equipment in completed areas of building, before Substantial Completion, provided such occupancy does not interfere with completion of the Work. Such placement of equipment and partial occupancy shall not constitute acceptance of the total Work.
 - 1. Architect will prepare a Certificate of Substantial Completion for each specific portion of the Work to be occupied before Owner occupancy.
 - 2. Obtain a Certificate of Occupancy from authorities having jurisdiction before Owner occupancy.
 - 3. Before partial Owner occupancy, mechanical and electrical systems shall be fully operational, and required tests and inspections shall be successfully completed. On occupancy, Owner will provide, operate, and maintain mechanical and electrical systems serving occupied portions of building.
 - 4. On occupancy, Owner will assume responsibility for maintenance and custodial service for occupied portions of building.

PART 2 - PRODUCTS (Not Used)

PART 3 - EXECUTION (Not Used)

END OF SECTION 011400

SECTION 012000 – PRICE AND PAYMENT PROCEDURES

PART 1 - GENERAL

1.1 SECTION INCLUDES

- A. Measurement and payment criteria applicable to portions of the Work performed under a unit price payment method.
- B. Defect assessment and non-payment for rejected work.

1.2 AUTHORITY

- A. Measurement methods delineated in the individual specification sections complement the criteria of this section.
- B. Take all measurements and compute quantities. The Construction Manager will verify measurements and quantities.
- C. Assist by providing necessary equipment, workers, and survey personnel as required.

1.3 UNIT QUANTITIES SPECIFIED

- A. Quantities indicated in the Bid Form as defined in individual Specification sections are for bidding and contract purposes only. Quantities and measurements supplied or placed in the Work and verified by the Construction Manager shall determine payment.
- B. If the actual Work requires more or fewer quantities than those quantities indicated, provide the required quantities at the unit sum/prices contracted.
- C. If the actual Work requires a 10 percent or greater change in quantity than those quantities indicated, the Owner may claim for a Contract Price adjustment.

1.4 MEASUREMENT OF QUANTITIES

- A. Measurement Devices:
 - 1. Weigh Scales: Inspected, tested and certified by the applicable state Weights and Measures department within the past year.
 - 2. Platform Scales: Of sufficient size and capacity to accommodate the conveying vehicle.
 - 3. Metering Devices: Inspected, tested and certified by the applicable State department within the past year.
- B. Measurement by Weight: Concrete reinforcing steel, rolled or formed steel or other metal shapes will be measured by handbook weights. Welded assemblies will be measured by handbook or scale weight.
- C. Measurement by Volume: Measured by cubic dimension using mean length, width and height or

thickness.

- D. Measurement by Area: Measured by square dimension using mean length and width or radius.
- E. Linear Measurement: Measured by linear dimension, at the item centerline or mean chord.
- F. Stipulated Sum/Price Measurement: Items measured by weight, volume, area, or linear means or combination, as appropriate, as a completed item or unit of the Work.

1.5 PAYMENT

- A. Payment Includes: Full compensation for all required labor, Products, tools, equipment, plant, transportation, services and incidentals; erection, application or installation of an item or the Work; overhead and profit.
- B. Final payment for Work governed by unit prices will be made on the basis of the actual measurements and quantities accepted by the Architect/Engineer multiplied by the unit sum/price for Work which is incorporated in or made necessary by the Work.

1.6 DEFECT ASSESSMENT

- A. Replace the Work, or portions of the Work, not conforming to specified requirements.
- B. If, in the opinion of the Architect, it is not practical to remove and replace the Work, the Architect will direct one of the following remedies:
 - 1. The defective Work may remain, but the unit sum/price will be adjusted to a new sum/price at the discretion of the Architect.
 - 2. The defective Work will be partially repaired to the instructions of the Architect, and the unit sum/price will be adjusted to a new sum/price at the discretion of the Architect.
- C. The individual specification sections may modify these options or may identify a specific formula or percentage sum/price reduction.
- D. The authority of the Architect to assess the defect and identify payment adjustment is final.

1.7 NON-PAYMENT FOR REJECTED PRODUCTS

- A. Payment will not be made for any of the following:
 - 1. Products wasted or disposed of in a manner that is not acceptable.
 - 2. Products determined as unacceptable before or after placement.
 - 3. Products not completely unloaded from the transporting vehicle.
 - 4. Products placed beyond the lines and levels of the required Work.
 - 5. Products remaining on hand after completion of the Work.
 - 6. Loading, hauling, and disposing of rejected Products.

1.8 SCHEDULE OF UNIT PRICES

N/A

PART 2 - PRODUCTS

Not Used

PART 3 - EXECUTION

Not Used

END OF SECTION 012000

NOT FOR BIDDING

SECTION 012100 - ALLOWANCES

PART 1 - GENERAL

1.1 RELATED DOCUMENTS

- A. Drawings and general provisions of the Contract, including General and Supplementary Conditions and other Division 1 Specification Sections, apply to this Section.

1.2 SUMMARY

- A. This Section includes administrative and procedural requirements governing allowances. Certain items are specified in the Contract Documents by allowances. Allowances have been established in lieu of additional requirements due to unknown conditions or to defer selection of actual materials and equipment and/or installation to a later date when additional information is available for evaluation. If necessary, additional requirements will be issued by Change Order.
- B. Types of allowances include the following:
 - 1. Lump-sum allowances.
 - 2. Unit-cost allowances.
 - 3. Quantity allowances.
 - 4. Contingency allowances.
 - 5. Testing and inspecting allowances.
- C. Related Sections include the following:
 - 1. Division 1 Section "Contract Modification Procedures" for procedures for submitting and handling Change Orders for allowances.
 - 2. Division 1 Section "Unit Prices" for procedures for using unit prices.
 - 3. Division 1 Section "Quality Requirements" for procedures governing the use of allowances for testing and inspecting.
 - 4. Divisions 2 through 35 Sections for items of Work covered by allowances.

1.3 SELECTION AND PURCHASE

- A. At the earliest practical date after award of the Contract, advise Architect of the date when final selection and purchase of each product or system described by an allowance must be completed to avoid delaying the Work.
- B. At Architect's request, obtain proposals for each allowance for use in making final selections. Include recommendations that are relevant to performing the Work.
- C. Purchase products and systems selected by Architect from the designated supplier.

1.4 SUBMITTALS

- A. Submit proposals for purchase of products or systems included in allowances, in the form specified for Change Orders.
- B. Submit invoices or delivery slips to show actual quantities of materials delivered to the site for use in fulfillment of each allowance.
- C. Coordinate and process submittals for allowance items in same manner as for other portions of the Work.

1.5 COORDINATION

- A. Coordinate allowance items with other portions of the Work. Furnish templates as required to coordinate installation.

1.6 LUMP-SUM ALLOWANCES

- A. Allowance shall include cost to Contractor of specific products and materials selected by Architect or specified herein and shall include taxes, freight, and delivery to Project site.
- B. Related costs for Supervision, field operation and temporary facilities; general overhead; profit; bond premiums; and taxes. costs are part of the Contract Sum.

1.7 TESTING AND INSPECTING ALLOWANCES

- A. Testing and inspecting allowances include the cost of engaging testing agencies, actual tests and inspections, and reporting results.
- B. The allowance does not include incidental labor required to assist the testing agency or costs for retesting if previous tests and inspections result in failure. The cost for incidental labor to assist the testing agency shall be included in the Contract Sum.
- C. Costs of services not required by the Contract Documents are not included in the allowance.
- D. At Project closeout, credit unused amounts remaining in the testing and inspecting allowance to Owner by Change Order.

1.8 UNUSED MATERIALS

- A. Return unused materials purchased under an allowance to manufacturer or supplier for credit to Owner, after installation has been completed and accepted.
 - 1. If requested by Architect, prepare unused material for storage by Owner when it is not economically practical to return the material for credit. If directed by Architect, deliver unused material to Owner's storage space. Otherwise, disposal of unused material is Contractor's responsibility.

PART 2 - PRODUCTS (Not Used)

PART 3 - EXECUTION

3.1 EXAMINATION

- A. Examine products covered by an allowance promptly on delivery for damage or defects. Return damaged or defective products to manufacturer for replacement.

3.2 PREPARATION

- A. Coordinate materials and their installation for each allowance with related materials and installations to ensure that each allowance item is completely integrated and interfaced with related work.

3.3 SCHEDULE OF ALLOWANCES

Contract No. 2 Concrete Work

1 – Include the lump sum of the following amount **\$20,000** in the contract for cold weather protection of concrete work.

Contract No. 3 Masonry Work

2 – Include the lump sum of the following amount **\$10,000** in the contract for cold weather protection of masonry work.

Contract No. 5 Carpentry & General Works

5 - Include the lump sum of the following amount **\$25,000** in the contract for unforeseen conditions that may arise during construction to be used at the discretion of the Construction Manager.

Contract No. 5 Carpentry & General Works

6 - Include the lump sum of the following amount **\$25,000** in the contract for temporary closures during construction for the exterior wall construction.

Contract No. 13 Mechanical

15 – Include the lump sum of the following amount **\$10,000** in the contract for the temp heat fuel cost. Cost of work to be determined by fuel company receipts with the amount of fuel and cost per gallon. All equipment and labor for temp heat is part of the contract. This allowance is for fuel cost only.

Contract No. 15 Electrical

17 – Include the lump sum of the following amount **\$10,000** in the contract for short circuit analysis gear revisions.

Contract No. 15 Electrical

17 – Include the lump sum of the following amount **\$10,000** in the contract for selective demolition of existing offices

END OF SECTION 012100

SECTION 012300 - ALTERNATES

PART 1 - GENERAL

1.1 RELATED DOCUMENTS

Drawings and general provisions of the Contract, including General and Supplementary Conditions and other Division 01 Specification Sections, apply to this Section.

1.2 SUMMARY

This Section includes administrative and procedural requirements for alternates.

1.3 DEFINITIONS

Alternate: An amount proposed by bidders and stated on the Bid Form for certain work defined in the Bidding Requirements that may be added to or deducted from the Base Bid amount if Owner decides to accept a corresponding change either in the amount of construction to be completed or in the products, materials, equipment, systems, or installation methods described in the Contract Documents.

1. The cost or credit for each alternate is the net addition to or deduction from the Contract Sum to incorporate alternate into the Work. No other adjustments are made to the Contract Sum.

1.4 PROCEDURES

Coordination: Modify or adjust affected adjacent work as necessary to completely integrate work of the alternate into Project.

1. Include as part of each alternate, miscellaneous devices, accessory objects, and similar items incidental to or required for a complete installation whether or not indicated as part of alternate.
2. Include as part of each alternate all costs of related coordination, modification or adjustment.

Notification: Immediately following award of the Contract, notify each party involved, in writing, of the status of each alternate. Indicate if alternates have been accepted, rejected, or deferred for later consideration. Include a complete description of negotiated modifications to alternates.

Execute accepted alternates under the same conditions as other work of the Contract.

Schedule: A Schedule of Alternates is included at the end of this Section. Specification Sections referenced in schedule contain requirements for materials necessary to achieve the work described under each alternate.

PART 2 - PRODUCTS (Not Used)

PART 3 - EXECUTION

3.1 SCHEDULE OF ALTERNATES

A. Alternate No. One - Flooring

1. Base Bid Item: No Additional Flooring, base or Paint.
2. Alternate Item: Provide additional flooring, base, and paint as indicated. Work includes removal of existing carpet and base and patching of subfloor if necessary, and patch/repair of drywall as necessary prior to painting. Work is to be coordinated with phased heat pump work throughout the existing building. Contractors are responsible to move and protect furniture as required to complete the work and place furniture back in its original location.

END SECTION 012300

NOT FOR BIDDING

SECTION 012500 – SUBSTITUTION PROCEDURES

PART 1 - GENERAL

1.1 RELATED DOCUMENTS

- A. Drawings and general provisions of the Contract, including General and Supplementary Conditions and other Division 1 Specification Sections, apply to this Section.

1.2 SUMMARY

- A. This Section includes administrative and procedural requirements for handling requests for substitutions made after award of the Contract.
 - 1. Multiple Prime Contracts: Provisions of this Section apply to the construction activities of each prime contractor.
- B. Related Sections: The following Sections contain requirements that relate to this Section:
 - 1. Division 1 Section "Reference Standards and Definitions" specifies the applicability of industry standards to products specified.
 - 2. Division 1 Section "Submittals" specifies requirements for submitting the Contractor's Construction Schedule and the Submittal Schedule.
 - 3. Division 1 Section "Materials and Equipment" specifies requirements governing the Contractor's selection of products and product options.

1.3 DEFINITIONS

- A. Definitions in this Article do not change or modify the meaning of other terms used in the Contract Documents.
- B. Substitutions: Changes in products, materials, equipment, and methods of construction required by the Contract Documents proposed by the Contractor after award of the Contract are considered to be requests for substitutions. The following are not considered to be requests for substitutions:
 - 1. Substitutions requested during the bidding period, and accepted by Addendum prior to award of the Contract, are included in the Contract Documents and are not subject to requirements specified in this Section for substitutions.
 - 2. Revisions to the Contract Documents requested by the Owner or Architect.
 - 3. Specified options of products and construction methods included in the Contract Documents.
 - 4. The Contractor's determination of and compliance with governing regulations and orders issued by governing authorities.

1.4 SUBMITTALS

- A. Substitution Request Submittal: The Architect will consider requests for substitution if received within 60 days after commencement of the Work. Requests received more than 60 days after commencement of the Work may be considered or rejected at the discretion of the Architect.

1. Submit 3 copies of each request for substitution for consideration. Submit requests in the form and according to procedures required for change-order proposals.
2. Identify the product or the fabrication or installation method to be replaced in each request. Include related Specification Section and Drawing numbers.
3. Provide complete documentation showing compliance with the requirements for substitutions, and the following information, as appropriate:
 - a. Coordination information, including a list of changes or modifications needed to other parts of the Work and to construction performed by the Owner and separate contractors that will be necessary to accommodate the proposed substitution.
 - b. A detailed comparison of significant qualities of the proposed substitution with those of the Work specified. Significant qualities may include elements, such as performance, weight, size, durability, and visual effect.
 - c. Product Data, including Drawings and descriptions of products and fabrication and installation procedures.
 - d. Samples, where applicable or requested.
 - e. A statement indicating the substitution's effect on the Contractor's Construction Schedule compared to the schedule without approval of the substitution. Indicate the effect of the proposed substitution on overall Contract Time.
 - f. Cost information, including a proposal of the net change, if any in the Contract Sum.
 - g. The Contractor's certification that the proposed substitution conforms to requirements in the Contract Documents in every respect and is appropriate for the applications indicated.
 - h. The Contractor's waiver of rights to additional payment or time that may subsequently become necessary because of the failure of the substitution to perform adequately.
4. Architect's Action: If necessary, the Architect will request additional information or documentation for evaluation within one week of receipt of a request for substitution. The Architect will notify the Contractor of acceptance or rejection of the substitution within 2 weeks of receipt of the request, or one week of receipt of additional information or documentation, whichever is later. Acceptance will be in the form of a change order.
 - a. Use the product specified if the Architect cannot make a decision on the use of a proposed substitute within the time allocated.

PART 2 - PRODUCTS

2.1 SUBSTITUTIONS

- A. Conditions: The Architect will receive and consider the Contractor's request for substitution when one or more of the following conditions are satisfied, as determined by the Architect. If the following conditions are not satisfied, the Architect will return the requests without action except to record noncompliance with these requirements.
 1. Extensive revisions to the Contract Documents are not required.
 2. Proposed changes are in keeping with the general intent of the Contract Documents.
 3. The request is timely, fully documented, and properly submitted.
 4. The specified product or method of construction cannot be provided within the Contract Time. The Architect will not consider the request if the product or method cannot be provided as a result of failure to pursue the Work promptly or coordinate activities properly.
 5. The request is directly related to an "or-equal" clause or similar language in the Contract

Documents.

6. The requested substitution offers the Owner a substantial advantage, in cost, time, energy conservation, or other considerations, after deducting additional responsibilities the Owner must assume. The Owner's additional responsibilities may include compensation to the Architect for redesign and evaluation services, increased cost of other construction by the Owner, and similar considerations.
 7. The specified product or method of construction cannot receive necessary approval by a governing authority, and the requested substitution can be approved.
 8. The specified product or method of construction cannot be provided in a manner that is compatible with other materials and where the Contractor certifies that the substitution will overcome the incompatibility.
 9. The specified product or method of construction cannot be coordinated with other materials and where the Contractor certifies that the proposed substitution can be coordinated.
 10. The specified product or method of construction cannot provide a warranty required by the Contract Documents and where the Contractor certifies that the proposed substitution provides the required warranty.
 11. Where a proposed substitution involves more than one prime contractor, each contractor shall cooperate with the other contractors involved to coordinate the Work, provide uniformity and consistency, and assure compatibility of products.
- B. The Contractor's submittal and the Architect's acceptance of Shop Drawings, Product Data, or Samples for construction activities not complying with the Contract Documents do not constitute an acceptable or valid request for substitution, nor do they constitute approval.

PART 3 - EXECUTION (Not Applicable)

END OF SECTION 012500

SUBSTITUTION REQUEST

Project: _____ Substitution Request Number: _____

From: _____
To: _____ Date: _____

A/E Project Number: _____
Re: _____ Contract For: _____

Specification Title: _____ Description: _____
Section: _____ Page: _____ Article/Paragraph: _____

Proposed Substitution: _____
Manufacturer: _____ Address: _____ Phone: _____
Trade Name: _____ Model No.: _____
Installer: _____ Address: _____ Phone: _____
History: ☐ New product ☐ 2-5 years old ☐ 5-10 yrs old ☐ More than 10 years old

Differences between proposed substitution and specified product: _____

☐ Point-by-point comparative data attached - REQUIRED BY A/E

Reason for not providing specified item: _____

Similar Installation:

Project: _____ Architect: _____
Address: _____ Owner: _____
_____ Date Installed: _____

Proposed substitution affects other parts of Work: ☐ No ☐ Yes; explain _____

Savings to Owner for accepting substitution: _____ (\$ _____).

Proposed substitution changes Contract Time: ☐ No ☐ Yes [Add] [Deduct] _____ days.

Supporting Data Attached: ☐ Drawings ☐ Product Data ☐ Samples ☐ Tests ☐ Reports ☐ _____

SUBSTITUTION REQUEST

The Undersigned certifies:

- Proposed substitution has been fully investigated and determined to be equal or superior in all respects to specified product.
- Same warranty will be furnished for proposed substitution as for specified product.
- Same maintenance service and source of replacement parts, as applicable, is available.
- Proposed substitution will have no adverse effect on other trades and will not affect or delay progress schedule.
- Cost data as stated above is complete. Claims for additional costs related to accepted substitution which may subsequently become apparent are to be waived.
- Proposed substitution does not affect dimensions and functional clearances.
- Payment will be made for changes to building design, including A/E design, detailing, and construction costs caused by the substitution.
- Coordination, installation, and changes in the Work as necessary for accepted substitution will be complete in all respects.

Submitted by: _____

Signed by: _____

Firm: _____

Address: _____

Telephone: _____

Attachments: _____

A/E's REVIEW AND ACTION

- ☐ Substitution approved - Make submittals in accordance with Specification Section 01330.
☐ Substitution approved as noted - Make submittals in accordance with Specification Section 01330.
☐ Substitution rejected - Use specified materials.
☐ Substitution Request received too late - Use specified materials.

Signed by: _____ Date: _____

Additional Comments: ☐ Contractor ☐ Subcontractor ☐ Supplier ☐ Manufacturer ☐ A/E ☐ _____

SECTION 012600 - CONTRACT MODIFICATION PROCEDURES

PART 1 - GENERAL

1.1 RELATED DOCUMENTS

- A. Drawings and general provisions of the Contract, including General and Supplementary Conditions and other Division 1 Specification Sections, apply to this Section.

1.2 SUMMARY

- A. This Section specifies administrative and procedural requirements for handling and processing Contract modifications.
- B. Related Sections include the following:
 - 1. Division 1 Section "Unit Prices" for administrative requirements for using unit prices.
 - 2. Division 1 Section "Product Requirements" for administrative procedures for handling requests for substitutions made after Contract award.

1.3 MINOR CHANGES IN THE WORK

- A. Architect or Construction Manager will issue supplemental instructions authorizing Minor Changes in the Work, not involving adjustment to the Contract Sum or the Contract Time, on AIA Document G710, "Architect's Supplemental Instructions."

1.4 PROPOSAL REQUESTS

- A. Owner-Initiated Proposal Requests: Architect will issue a detailed description of proposed changes in the Work that may require adjustment to the Contract Sum or the Contract Time. If necessary, the description will include supplemental or revised Drawings and Specifications.
 - 1. Proposal Requests issued by Architect are for information only. Do not consider them instructions either to stop work in progress or to execute the proposed change.
 - 2. Within time specified in Proposal Request after receipt of Proposal Request, submit a quotation estimating cost adjustments to the Contract Sum and the Contract Time necessary to execute the change.
 - a. Include a list of quantities of products required or eliminated and unit costs, with total amount of purchases and credits to be made. If requested, furnish survey data to substantiate quantities.
 - b. Indicate applicable taxes, delivery charges, equipment rental, and amounts of trade discounts.
 - c. Include an updated Contractor's Construction Schedule that indicates the effect of the change, including, but not limited to, changes in activity duration, start and finish times, and activity relationship. Use available total float before requesting an extension of the Contract Time.

- B. Contractor-Initiated Proposals: If latent or unforeseen conditions require modifications to the Contract, Contractor may propose changes by submitting a request for a change.
1. Include a statement outlining reasons for the change and the effect of the change on the Work. Provide a complete description of the proposed change. Indicate the effect of the proposed change on the Contract Sum and the Contract Time.
 2. Include a list of quantities of products required or eliminated and unit costs, with total amount of purchases and credits to be made. If requested, furnish survey data to substantiate quantities.
 3. Indicate applicable taxes, delivery charges, equipment rental, and amounts of trade discounts.
 4. Include an updated Contractor's Construction Schedule that indicates the effect of the change, including, but not limited to, changes in activity duration, start and finish times, and activity relationship. Use available total float before requesting an extension of the Contract Time.
 5. Comply with requirements in Division 1 Section "Product Requirements" if the proposed change requires substitution of one product or system for product or system specified.
- C. Proposal Request Form: Use AIA Document G709 for Proposal Requests.

1.5 CHANGE ORDER PROCEDURES

- A. On Owner's approval of a Proposal Request, Architect will issue a Change Order for signatures of Owner and Contractor on AIA Document G701.

1.6 CONSTRUCTION CHANGE DIRECTIVE

- A. Construction Change Directive: Architect may issue a Construction Change Directive on AIA Document G714. Construction Change Directive instructs Contractor to proceed with a change in the Work, for subsequent inclusion in a Change Order.
1. Construction Change Directive contains a complete description of change in the Work. It also designates method to be followed to determine change in the Contract Sum or the Contract Time.
- B. Documentation: Maintain detailed records on a time and material basis of work required by the Construction Change Directive.
1. After completion of change, submit an itemized account and supporting data necessary to substantiate cost and time adjustments to the Contract.

PART 2 - PRODUCTS (Not Used)

PART 3 - EXECUTION (Not Used)

END OF SECTION 012600

SECTION 012900 - PAYMENT PROCEDURES

PART 1 - GENERAL

1.1 RELATED DOCUMENTS

- A. Drawings and general provisions of the Contract, including General and Supplementary Conditions and other Division 1 Specification Sections, apply to this Section.

1.2 SUMMARY

- A. This Section specifies administrative and procedural requirements necessary to prepare and process Applications for Payment.
- B. Related Sections include the following:
 - 1. Division 1 Section "Unit Prices" for administrative requirements governing use of unit prices.
 - 2. Division 1 Section "Contract Modification Procedures" for administrative procedures for handling changes to the Contract.
 - 3. Division 1 Section "Construction Progress Documentation" for administrative requirements governing preparation and submittal of Contractor's Construction Schedule and Submittals Schedule.

1.3 SCHEDULE OF VALUES

- A. Coordination: Coordinate preparation of the Schedule of Values with preparation of Contractor's Construction Schedule.
 - 1. Correlate line items in the Schedule of Values with other required administrative forms and schedules, including the following:
 - a. Application for Payment forms with Continuation Sheets.
 - b. Submittals Schedule.
 - 2. Submit the Schedule of Values to Architect through the construction manager at earliest possible date but no later than 14 days before the date scheduled for submittal of initial Applications for Payment.
- B. Format and Content: Use the Project Manual table of contents as a guide to establish line items for the Schedule of Values. Provide at least one line item for each Specification Section.
 - 1. Identification: Include the following Project identification on the Schedule of Values:
 - a. Project name and location.
 - b. Name of Architect.
 - c. Architect's project number.
 - d. Contractor's name and address.
 - e. Date of submittal.

2. Arrange the Schedule of Values in tabular form with separate columns to indicate the following for each item listed:
 - a. Related Specification Section or Division.
 - b. Description of the Work.
 - c. Name of subcontractor.
 - d. Name of manufacturer or fabricator.
 - e. Name of supplier.
 - f. Change Orders (numbers) that affect value.
 - g. Dollar value.
 - 1) Percentage of the Contract Sum to nearest one-hundredth percent, adjusted to total 100 percent.
3. Provide a breakdown of the Contract Sum in enough detail to facilitate continued evaluation of Applications for Payment and progress reports. Coordinate with the Project Manual table of contents. Provide several line items for principal subcontract amounts, where appropriate.
4. Round amounts to nearest whole dollar; total shall equal the Contract Sum.
5. Provide a separate line item in the Schedule of Values for each part of the Work where Applications for Payment may include materials or equipment purchased or fabricated and stored, but not yet installed.
 - a. Differentiate between items stored on-site and items stored off-site. Include evidence of insurance or bonded warehousing if required.
6. Provide separate line items in the Schedule of Values for initial cost of materials, for each subsequent stage of completion, and for total installed value of that part of the Work.

1.4 APPLICATIONS FOR PAYMENT

- A. Each Application for Payment shall be consistent with previous applications and payments as certified by Architect and Construction Manager and paid for by Owner.
 1. Initial Application for Payment, Application for Payment at time of Substantial Completion, and final Application for Payment involve additional requirements.
- B. Payment Application Times: The date for each progress payment is indicated in the Agreement between Owner and Contractor. The period of construction Work covered by each Application for Payment is the period indicated in the Agreement.
- C. Payment Application Forms: Use AIA Document G702/CMA and AIA Document G703 Continuation Sheets as form for Applications for Payment.
- D. Application Preparation: Complete every entry on form. Notarize and execute by a person authorized to sign legal documents on behalf of Contractor. Construction Manager will return incomplete applications without action.
 1. Entries shall match data on the Schedule of Values and Contractor's Construction Schedule. Use updated schedules if revisions were made.

2. Include amounts of Change Orders and Construction Change Directives issued before last day of construction period covered by application.
- E. Transmittal: Submit 4 signed and notarized original copies of each Application for Payment to Construction Manager by a method ensuring receipt within 24 hours. One copy shall include waivers of lien and similar attachments if required.
1. Transmit each copy with a transmittal form listing attachments and recording appropriate information about application.
- F. Waivers of Mechanic's Lien: With each Application for Payment, submit waivers of mechanic's liens from subcontractors, sub-subcontractors, and suppliers for construction period covered by the previous application.
1. Submit partial waivers on each item for amount requested, before deduction for retainage, on each item.
 2. When an application shows completion of an item, submit final or full waivers.
 3. Owner reserves the right to designate which entities involved in the Work must submit waivers.
 4. Waiver Delays: Submit each Application for Payment with Contractor's waiver of mechanic's lien for construction period covered by the application.
 - a. Submit final Application for Payment with or proceeded by final waivers from every entity involved with performance of the Work covered by the application who is lawfully entitled to a lien.
 5. Waiver Forms: Submit waivers of lien on forms, executed in a manner acceptable to Owner.
- G. Initial Application for Payment: Administrative actions and submittals that must precede or coincide with submittal of first Application for Payment include the following:
1. List of subcontractors.
 2. Schedule of Values.
 3. Contractor's Construction Schedule (preliminary if not final).
 4. Products list.
 5. Submittals Schedule (preliminary if not final).
 6. List of Contractor's staff assignments.
 7. List of Contractor's principal consultants.
 8. Copies of building permits.
 9. Copies of authorizations and licenses from authorities having jurisdiction for performance of the Work.
 10. Initial progress report.
 11. Report of preconstruction conference.
 12. Certificates of insurance and insurance policies.
- H. Application for Payment at Substantial Completion: After issuing the Certificate of Substantial Completion, submit an Application for Payment showing 100 percent completion for portion of the Work claimed as substantially complete.

1. Include documentation supporting claim that the Work is substantially complete and a statement showing an accounting of changes to the Contract Sum.
 2. This application shall reflect Certificates of Partial Substantial Completion issued previously for Owner occupancy of designated portions of the Work.
- I. Final Payment Application: Submit final Application for Payment with releases and supporting documentation not previously submitted and accepted, including, but not limited, to the following:
1. Evidence of completion of Project closeout requirements.
 2. Insurance certificates for products and completed operations where required and proof that taxes, fees, and similar obligations were paid.
 3. Updated final statement, accounting for final changes to the Contract Sum.
 4. AIA Document G706, "Contractor's Affidavit of Payment of Debts and Claims."
 5. AIA Document G706A, "Contractor's Affidavit of Release of Liens."
 6. AIA Document G707, "Consent of Surety to Final Payment."
 7. Evidence that claims have been settled.
 8. Final meter readings for utilities, a measured record of stored fuel, and similar data as of date of Substantial Completion or when Owner took possession of and assumed responsibility for corresponding elements of the Work.
 9. Final, liquidated damages settlement statement.

PART 2 - PRODUCTS (Not Used)

PART 3 - EXECUTION (Not Used)

END OF SECTION 012900

SECTION 012973 – SCHEDULE OF VALUES

PART 1 - GENERAL

1.1 RELATED DOCUMENTS

- A. Drawings and general provisions of Contract, including General and Supplementary Conditions and other Division-0 Specification Sections, apply to this section.

1.2 CONTRACT SUM BREAKDOWN

- A. Within ten (10) days of receipt of Contract, each Trade Contractor shall submit to the Construction Manager for review a Contract Sum Breakdown, the total of which shall be equal to the initial contract sum.
- B. The General Trade Contractor shall list quantities and unit prices that correspond to the activities he is responsible for. All unit prices should include labor, tools, equipment, overhead, and profit required to perform a complete installation.

1.3 FORM AND CONTENT

- A. The breakdown shall be prepared on the forms provided with this Section. The schedule shall also indicate:
 - 1. Title of project and location
 - 2. Architect's name
 - 3. Name and address of Contractor
 - 4. Date of submission
- B. Provide a separate line item for General Conditions which would include home office support, bonds, insurance premiums, mobilization, field supervision, temporary construction utilities, facilities, and controls.
 - 1. Contractor must include line item amounts for General Condition Requirements as follows:
 - Submittals
 - Progress Meetings
 - Clean up
 - Progress Schedule Development
 - Coordination Drawing
 - Project Record Drawings
 - 2. Breakdown of major construction activities shall be submitted per building wing, per floor, separating labor and material values.

END OF SECTION 012973

SECTION 013100 – PROJECT MANAGEMENT AND COORDINATION

PART 1 – GENERAL

1.1 SECTION INCLUDES

- A. Coordination.
- B. Field engineering.
- C. Preconstruction meeting.
- D. Site mobilization meeting.
- E. Progress meetings.
- F. Preinstallation meetings.
- G. Examination.
- H. Preparation.

1.2 RELATED SECTIONS

- A. Section 011200 – Multiple Contract Summary
- B. Section 013113 –Project Coordination
- C. Section 017329 – Cutting and Patching

1.3 COORDINATION

- A. Coordinate scheduling, submittals, and work of the various sections of the Project Manual to assure efficient and orderly sequence of installation of interdependent construction elements, with provisions for accommodating items installed later.
- B. Verify utility requirements and characteristics of operating equipment are compatible with utilities. Coordinate work of various sections having interdependent responsibilities for installing, connecting to, and placing in service, such equipment.
- C. Coordinate space requirements and installation of mechanical and electrical work which are indicated diagrammatically on Drawings. Follow routing shown for pipes, ducts, and conduit, as closely as practicable. Utilize spaces efficiently to maximize accessibility for other installations, for maintenance, and for repairs.
- D. In finished areas, except as otherwise indicated, conceal pipes, ducts, and wiring within the construction. Coordinate locations of fixtures and outlets with finish elements.
- E. Coordinate completion and clean up of work of separate sections in preparation for Substantial Completion and for portions of Work designated for Owner's partial occupancy.
- F. After Owner occupancy, co-ordinate access to site for correction of defective work and work not in accordance with Contract Documents, to minimize disruption of Owner's activities.

1.4 FIELD ENGINEERING

- A. Contractor to locate and protect survey control and reference points.
- B. Control datum for survey is that established by Owner and shown on drawings.

- C. Verify set-backs and easements, confirm drawing dimensions and elevations.
- D. Provide field engineering services. Establish elevations, lines, and levels, utilizing recognized engineering survey practices.

1.5 PRECONSTRUCTION MEETING

- A. Construction Manager will schedule a meeting after Notice of Award.
- B. Attendance Required: Owner, Architect/Engineer, Contractors.
- C. Agenda:
 - 1. Submission of executed bonds and insurance certificates.
 - 2. Distribution of Contract Documents.
 - 3. Submission of list of Subcontractors, list of Products, schedule of values, and progress schedule not previously required.
 - 4. Designation of personnel representing the parties in contract, Architect and other Consultants.
 - 5. Procedures and processing of field decisions, submittals, substitutions, Applications for Payments.
 - 6. Scheduling.
 - 7. Scheduling activities of inspection and testing service.
- D. Construction Manager will record minutes and distribute copies within two days after meeting to participants, with copies to those affected by decisions made.

1.6 SITE MOBILIZATION MEETING

- A. Construction Manager shall schedule a meeting at the project site prior to Contractor occupancy.
- B. Attendance Required: Owner, Architect/Engineer, Special Consultants, Contractor, Contractors Superintendent, major Subcontractors, and other parties as required.
- C. Agenda:
 - 1. Use of premises by Owner and Contractor.
 - 2. Owner's requirements and occupancy.
 - 3. Construction facilities and controls provided by Owner.
 - 4. Temporary utilities provided by Owner.
 - 5. Survey and layout.
 - 6. Security and housekeeping procedures.
 - 7. Schedules.
 - 8. Procedures for testing.
 - 9. Procedures for maintaining record documents.
 - 10. Requirements for start-up of equipment.
 - 11. Inspection and acceptance of equipment put into service during construction period.

- D. Construction Manager shall record minutes and distribute copies within two days after meeting to participants, with copies to Architect/Engineer, Owner, participants, and those affected by decisions made.

1.7 PROGRESS MEETINGS

- A. Construction Manager shall schedule and administer meetings throughout progress of the work at weekly intervals unless otherwise required by the work.
- B. Construction Manager shall make arrangements for meetings, prepare agenda with copies for participants, and preside at meetings.
- C. Attendance Required: Job superintendents, Prime Trade Contractors, Owner, Architect/Engineer, Special Consultants as required and parties as appropriate to agenda topics for each meeting.
- D. Agenda
 - 1. Review minutes of previous meetings.
 - 2. Review work progress.
 - 3. Field observations, problems, and decisions.
 - 4. Identification of problems which impede planned progress.
 - 5. Review of submittals schedule and status of submittals.
 - 6. Review of delivery schedules.
 - 7. Maintenance of progress schedule.
 - 8. Corrective measures to regain projected schedules.
 - 9. Planned progress during succeeding work period.
 - 10. Coordination of projected progress.
 - 11. Maintenance of quality and work standards.
 - 12. Effect of proposed changes on progress schedule and coordination.
 - 13. Current safety changes.
 - 14. Other business relating to Work.
- E. Construction Manager shall record minutes and distribute copies within two days after meeting to participants, with copies to Architect / Engineer, Owner, participants, and those affected by decisions made.

1.8 PREINSTALLATION MEETING

- A. When required in individual specification sections, the respective Contractor shall convene a preinstallation meeting at the site prior to commencing work of the section.
- B. Require attendance of parties directly affecting or affected by, work of the specific section.
- C. Notify Architect, Owner and Construction Manager four days in advance of meeting date.
- D. Contractor shall prepare agenda and preside at meeting:
 - 1. Review conditions of installation, preparation and installation procedures.
 - 2. Review coordination with related work.

- E. Record minutes and distribute copies within five days after meeting to participants, with copies to Architect, Owner, Construction Manager, participants, and those affected by decisions made.

1.9 ADDITIONAL MEETING

- A. The Construction Manager may conduct additional meetings as required by the Project conditions or changes. All contractors must attend these meetings at no additional cost to the Owner.
- B. Daily Coordination meeting of approximately 15 minute duration will be conducted by the Construction Manager for all Contractor's superintendents on site.

PART 2 – PRODUCTS (NOT USED)

PART 3 – EXECUTION

3.1 EXAMINATION

- A. Verify that existing site conditions and substrate surfaces are acceptable for subsequent work. Beginning new work means acceptance of existing conditions.
- B. Verify that existing substrate is capable of structural attachment of new work being applied or attached.
- C. Examine and verify specific conditions described in individual specifications sections.
- D. Verify that utility services are available of the correct characteristics, and in the correct location.

3.2 PREPARATION

- A. Clean substrate surfaces prior to applying next material or substance.
- B. Seal cracks or openings of substrate prior to applying next material or substance.
- C. Apply any manufacturer required or recommended substrate primer, sealer, or conditioner prior to applying any new material or substance in contact or bond.

END OF SECTION 013100

SECTION 013113- PROJECT COORDINATION

PART I - GENERAL

1.1 SECTION INCLUDES

- A. Project coordination by the Project Coordinator.
- B. Construction Mobilization.
- C. Schedules.
- D. Submittals.
- E. Coordination drawings.
- F. Closeout procedures.

1.2 RELATED SECTIONS

- A. Document 007226- General Conditions – AIA G232-2009 CMA: Duties of the Construction Manager.
- B. Document 007300- Supplementary Conditions of the Contract.
- C. Section 011100 - Summary of Work: Work covered by each Contract. Work sequence. Owner occupancy.
- D. Section 013100 – Project Management and Coordination: Project meetings. Pre-construction Meetings. Progress meetings.
- F. Section 013300 - Submittal : Submittal procedures.
- F. Section 017700- Contract Closeout: Contract Closeout Procedures.

1.3 PROJECT COORDINATOR

- A. Project Coordinator: Construction Manager.

1.4 CONSTRUCTION MOBILIZATION

- A. Cooperate with the Project Coordinator in allocation of mobilization areas of site; for field office and sheds, for construction and Owner access, traffic, and parking facilities.
- B. During construction, coordinate use of site and facilities through the Project Coordinator.
- C. Comply with Project Coordinator's procedures for intraproject communications; submittals, reports and records, schedules, coordination drawings and recommendations; and resolution of ambiguities and conflicts.
- D. Comply with instructions of the Project Coordinator for use of temporary utilities and

construction facilities.

- F. Coordinate field engineering and layout work under instructions of the Project Coordinator.

1.5 SCHEDULES

- A. Submit preliminary manpower loaded bar chart schedule in accordance with Section 01310.
- B. After review, revise and resubmit schedule to comply with revised Project schedule.
- C. During progress of work, revise and resubmit with Applications for Payment or as directed.

1.6 SUBMITTALS

- A. Provide submittals to Project Coordinator for review and transmittal to Architect / Engineer.
- B. Submit requests for interpretation of Contract Documents, and obtain instructions through the Project Coordinator.
- C. Process requests for substitutions, and change orders, through the Project Coordinator.
- D. Deliver closeout submittals for review and preliminary inspection reports, for transmittal to

1.7 COORDINATION DRAWINGS

- A. Provide information required by Project Coordinator for preparation of coordination drawings.
- B. Systems Coordination Drawings are required from the Mechanical, Electrical, Plumbing and General Trade Contractors with the lead role assigned to the Mechanical Trade Contractor.
- C. The Mechanical Trade Contractor shall prepare 1/4" = 1 ft. scale Reproducible Systems Drawings for all areas with piping and ductwork. Drawings to indicate spatial relationship HVAC piping and ductwork.
- D. The Mechanical Trade Contractor shall prepare and submit to the Construction Manager a regularly updated schedule indicating the development and review of these drawings with other Trade Contractors. The drawing development and review schedule must follow the project construction schedule.
- E. The Mechanical Trade Contractor shall provide the Reproducible Systems Coordination the other Trade Contractors for their input and review. The routing is as follows: HVAC Ductwork / Piping, Plumbing, General Trades with the drawings being reamed to be

Contractor.

- F. Each Trade Contractor will add the work of his Contract on the Systems Coordination Drawings to -avoid interferences. All piping, equipment, light fixtures and in-ceiling equipment, such as rolling gates, must be shown on these drawings to include elevations and dimensions.
- G. Prior to forwarding the Systems Coordination Drawings to the next Trade Contractor, an approval stamp, initialed and dated, should be affixed by the reviewing Trade Contractor. This approval by the reviewing Trade Contractor will install his work accordingly.
- H. During the Systems Coordination Drawing process, the Construction Manager will conduct regularly scheduled meetings. Each Trade Contractor is required to attend these meetings. The Construction Manager is responsible for recording and distributing meeting minutes to all Trade Contractors and the Architect / Engineer. The purpose of the meetings will be to review and discuss interferences and conflicts as well as any modifications to the Systems Coordination Drawings. All resolutions of interferences and conflicts which required modifications shall be initiated by the appropriate Trade Contractors on the Systems Coordination Drawings. At each meeting, the General Trade Contractors will review and update the Systems Coordination Drawing Schedule.
- I. Once reviewed and approved by each General Trade Contractor, the Mechanical Trade Contractor will prepare the Final Reproducible Systems Coordination Drawings with the work of all trades included. Submit the Reproducible Drawings along with two (2) prints to the Construction Manager who will forward to the Architect for his review.
- J. The Mechanical Trade Contractor shall indicate any unresolved conflicts or interferences on the Systems Coordination Drawings. Those should be delineated by clouding, numbering and referencing to the affected contract drawings,
- K. Review drawings prior to submission to Architect / Engineer.
- L. The Architect will review and return drawings to the Construction Manager. The Construction Manager will distribute the number of drawings to the Trade Contractors for installation of their work.
- M. The Systems Coordination Drawings DO NOT REPLACE any fabrication and layout drawings required by individual Specification Sections.

1.8 CLOSEOUT PROCEDURES

- A. Notify Project Coordinator when work is considered ready for Substantial Completion. Accompany Project Coordinator on preliminary inspection to determine items to be listed for completion or correction in Contractors Notice of Substantial Completion.
- B. Comply with Project Coordinator's instructions to correct items of work listed in executed Certificates of Substantial Completion and for access to Owner occupied areas.

- C. Notify Project Coordinator when Work is considered finally complete. Accompany Project Coordinator on preliminary final inspection.
- D. Comply with Project Coordinators instructions for completion of items of Work determined by Architect / Engineers final inspection.

PART 2 - PRODUCTS – (NOT USED)

PARTS - EXECUTION— (NOT USED)

END OF SECTION 013113

NOT FOR BIDDING

SECTION 013216 - CONSTRUCTION PROGRESS SCHEDULE

PART 1 - GENERAL

1.1 SECTION INCLUDES

- A. Scheduling requirements and coordination.
- B. Construction Phasing Plans
- C. Construction Milestone Schedules (by Phase and by Trade)

1.2 RELATED DOCUMENTS

- A. Drawings and general provisions of Contract, including General and Supplementary Conditions and other Division-1 Specification Sections, apply to this section.

1.3 DEFINITIONS

- A. Activity: An activity is any single identifiable step in the Project. It depends upon preceding and succeeding activities.

1.4 CONSTRUCTION SCHEDULE

- A. The Construction Schedule, as reviewed by the Construction Manager and Owner, will be an integral part of the Contract, and will establish interim work completion dates for the various activities. Each Trade Contractor shall be responsible to achieve Starting Dates, Milestones or Target Dates, and Completion Dates established for each Phase of the overall Project.
- B. The Construction Schedule may vary in accordance with construction conditions. Each Contractor shall delay or expedite material and equipment deliveries, and modify the required labor forces to accommodate these varying conditions.
- C. This is a phased project. Multiple trips may be required to complete this Project.
- D. Within fifteen (15) days after receipt of Notice of Intent to Award, each Contractor shall submit a preliminary Construction Schedule, in accordance with the milestone construction schedule included in these documents under the summary of work, to the Construction Manager. The schedule will include breakdowns of total man days of field labor into major categories of work, time estimates of various categories of work, crew size for each category, and quantity and type of equipment to be utilized.
- E. Each Contractor shall provide to the Construction Manager a separate list of critical submittal dates for Shop Drawings, Product Data, and Samples, indicating delivery dates/lead times that may impact the construction schedule or completion of the Work. The critical submittal list shall accompany the Preliminary Submittal List as identified in Section 013300 - Submittals.
- F. Each Contractor shall organize his Construction Schedule per Phase, Building, Wing, Floor, and Area as required by the Construction Manager.

- G. The Construction Manager shall schedule a meeting with the Contractors, to review the contents of each Contractor's preliminary Construction Schedule, review the sequence of Work, and make all revisions required. The Construction manager shall have the final authority concerning the sequence of Work and durations of each activity. Each Contractor shall revise his schedule in accordance with that meeting and submit his schedule to the Construction Manager for review. The Construction Manager will then develop the Project Construction Schedule. Each Contractor shall schedule and perform his work in compliance with the Construction Manager's Project Construction Schedule.
- H. The Schedule shall be the basis for the dates to start and complete Work for the various portions of each Contract, and to complete Work (including changes) for the Project. IT shall be the duty of the Contractor to conform to the current Schedule and to arrange his work in such a manner that it will be installed in accordance with the Schedule.
- I. Each Contractor shall submit two (2) copies of a monthly updated Construction Schedule comparing the original schedule to actual work in progress and project work along with the Application for Payment.
- J. As required, a representative of each Contractor shall meet with the Construction Manager and furnish to him information necessary for such re-evaluating and updating of the Project schedule. Information with regard to changes in the work and the Contractor's proposed effort to overcome any delays incurred shall be provided (in writing) to the Construction Manager.
- K. Two (2) days after the Contractor has failed to Start on Schedule, Meet Assigned Milestone or Target Dates, or Completion of items such as Shop Drawing Submissions, Material - Equipment Deliveries, or Tasks according to the Master Construction Schedule or Revised Master Construction Schedule, the Construction Manager will forward a letter of Non-Conformance, via Facsimile Transmission and/or forward a letter of Non-Conformance, via Facsimile Transmission and/or Express Mail, to the Contractor and a copy to the Owner. Upon receipt of this notice, the Contractor is required to execute whatever measures as so directed by the Contract Manager including, but not specifically, assigning additional labor, shifts, overtime, materials, expediting of submittals or deliveries, equipment, scaffold, or any combination of these as deemed appropriate and necessary by the Construction Manager to return the above referenced activities back on schedule, without additional compensation to the Contractor.
- L. Costs incurred by the Construction Manager in connection with maintaining the Construction Schedule, caused by the Contractor's noncompliance with the scheduling requirements, shall be reimbursed to the Construction Manager by the Contractor.
- M. It is expressly understood and agreed that failure by the Construction Manager to exercise the option to either order the Contractor to expedite work, or to expedite the work by other means, shall not be considered precedent-setting for any other activities.

1.5 SCHEDULE COMPUTERIZATION

- A. All Trade Contractors shall provide all their scheduling information via a computer assisted scheduling program, acceptable to the Construction Manager. Format to be Bar Chart.
- B. All schedule information and updates for the above Contractors shall be provided to the

Construction Manager on 3.5" diskettes in format and density as required.

PART 2 – PRODUCTS – NOT USED

PART 3 – EXECUTION – NOT USED

PART 4 – SCHEDULE

Construction starts June 30, 2025. Project has to be finished by January 30, 2026
Please provide sufficient manpower in your cost to meet the completion date of
January 30, 2025.

END OF SECTION 013216

NOT FOR BIDDING

SECTION 013233 – PHOTOGRAPHIC DOCUMENTATION

PART 1 - GENERAL

1.1 RELATED DOCUMENTS

- A. Drawings and general provisions of the Contract, including General and Supplementary Conditions and other Division 1 Specification Sections, apply to this Section.

1.2 SUMMARY

- A. This Section includes administrative and procedural requirements for documenting the progress of construction during performance of the Work, including the following:

- 1. Preliminary Construction Schedule.
- 2. Contractor's Construction Schedule.
- 3. Submittals Schedule.
- 4. Daily construction reports.
- 5. Field condition reports.
- 6. Special reports.
- 7. Construction photographs.

- B. Related Sections include the following:

- 1. Division 1 Section "Payment Procedures" for submitting the Schedule of Values.
- 2. Division 1 Section "Project Management and Coordination" for submitting and distributing meeting and conference minutes.
- 3. Division 1 Section "Submittal Procedures" for submitting schedules and reports.
- 4. Division 1 Section "Quality Requirements" for submitting a schedule of tests and inspections.

1.3 DEFINITIONS

- A. Activity: A discrete part of a project that can be identified for planning, scheduling, monitoring, and controlling the construction project. Activities included in a construction schedule consume time and resources.

- 1. Critical activities are activities on the critical path. They must start and finish on the planned early start and finish times.
- 2. Predecessor activity is an activity that must be completed before a given activity can be started.

- B. Event: The starting or ending point of an activity.

- C. Float: The measure of leeway in starting and completing an activity.

- 1. Float time is not for the exclusive use or benefit of either Owner or Contractor, but is a jointly owned, expiring Project resource available to both parties as needed to meet schedule milestones and Contract completion date.

2. Free float is the amount of time an activity can be delayed without adversely affecting the early start of the following activity.
 3. Total float is the measure of leeway in starting or completing an activity without adversely affecting the planned Project completion date.
- D. Fragment: A partial or fragmentary network that breaks down activities into smaller activities for greater detail.
- E. Major Area: A story of construction, a separate building, or a similar significant construction element.
- F. Milestone: A key or critical point in time for reference or measurement.
- G. Network Diagram: A graphic diagram of a network schedule, showing activities and activity relationships.

1.4 SUBMITTALS

- A. Qualification Data: For firms and persons specified in "Quality Assurance" Article and in-house scheduling personnel to demonstrate their capabilities and experience. Include lists of completed projects with project names and addresses, names and addresses of architects and owners, and other information specified.
- B. Submittals Schedule: Submit three copies of schedule. Arrange the following information in a tabular format:
1. Scheduled date for first submittal.
 2. Specification Section number and title.
 3. Submittal category (action or informational).
 4. Name of subcontractor.
 5. Description of the Work covered.
 6. Scheduled date for Architect's and Construction Manager's final release or approval.
- C. Preliminary Construction Schedule: Submit three printed copies.
- D. Contractor's Construction Schedule: Submit two printed copies of initial schedule, one a reproducible print and one a blue- or black-line print, large enough to show entire schedule for entire construction period.
- E. Daily Construction Reports: Submit two copies at weekly intervals.
- F. Field Condition Reports: Submit two copies at time of discovery of differing conditions.
- G. Special Reports: Submit two copies at time of unusual event.

1.5 QUALITY ASSURANCE

- A. Scheduling Consultant Qualifications: An experienced specialist in CPM scheduling and reporting.

- B. Prescheduling Conference: Conduct conference at Project site to comply with requirements in Division 1 Section "Project Management and Coordination." Review methods and procedures related to the Preliminary Construction Schedule and Contractor's Construction Schedule, including, but not limited to, the following:
1. Review software limitations, content, and format for reports.
 2. Verify availability of qualified personnel needed to develop and update schedule.
 3. Discuss constraints, including phasing, work stages, area separations, and interim milestones.
 4. Review delivery dates for Owner-furnished products.
 5. Review schedule for work of Owner's separate contracts.
 6. Review time required for review of submittals and resubmittals.
 7. Review requirements for tests and inspections by independent testing and inspecting agencies.
 8. Review time required for completion and startup procedures.
 9. Review and finalize list of construction activities to be included in schedule.
 10. Review submittal requirements and procedures.
 11. Review procedures for updating schedule.

1.6 COORDINATION

- A. Coordinate preparation and processing of schedule and reports with performance of construction activities and with scheduling and reporting of separate contractors.
- B. Coordinate Contractor's Construction Schedule with the Schedule of Values, list of subcontracts, Submittals Schedule, progress reports, payment requests, and other required schedules and reports.
1. Secure time commitments for performing critical elements of the Work from parties involved.
 2. Coordinate each construction activity in the network with other activities and schedule them in proper sequence.
- C. Auxiliary Services: Cooperate with photographer and provide auxiliary services requested, including access to Project site and use of temporary facilities including temporary lighting.
- D. Each trade contractor is to submit preliminary manpower loaded bar chart schedule in accordance with section 013100.

PART 2 - PRODUCTS

2.1 SUBMITTALS SCHEDULE

- A. Preparation: Submit a schedule of submittals, arranged in chronological order by dates required by construction schedule. Include time required for review, resubmittal, ordering, manufacturing, fabrication, and delivery when establishing dates.
1. Coordinate Submittals Schedule with list of subcontracts, the Schedule of Values, and Contractor's Construction Schedule.

2. Initial Submittal: Submit concurrently with preliminary bar-chart schedule. Include submittals required during the first 60 days of construction. List those required to maintain orderly progress of the Work and those required early because of long lead-time for manufacture or fabrication.
 - a. At Contractor's option, show submittals on the Preliminary Construction Schedule, instead of tabulating them separately.
3. Final Submittal: Submit concurrently with the first complete submittal of Contractor's Construction Schedule.

2.2 CONTRACTOR'S CONSTRUCTION SCHEDULE, GENERAL

- A. Procedures: Comply with procedures contained in AGC's "Construction Planning & Scheduling."
- B. Time Frame: Extend schedule from date established for the Notice to Proceed to date of Final Completion.
 1. Contract completion date shall not be changed by submission of a schedule that shows an early completion date, unless specifically authorized by Change Order.
- C. Activities: Treat each story or separate area as a separate numbered activity for each principal element of the Work. Comply with the following:
 1. Activity Duration: Define activities so no activity is longer than 120 days, unless specifically allowed by Architect.
 2. Procurement Activities: Include procurement process activities for long lead items and major items, requiring a cycle of more than 60 days, as separate activities in schedule. Procurement cycle activities include, but are not limited to, submittals, approvals, purchasing, fabrication, and delivery.
 3. Submittal Review Time: Include review and resubmittal times indicated in Division 1 Section "Submittal Procedures" in schedule. Coordinate submittal review times in Contractor's Construction Schedule with Submittals Schedule.
 4. Startup and Testing Time: Include not less than 7 days for startup and testing.
 5. Substantial Completion: Indicate completion in advance of date established for Substantial Completion, and allow time for Architect and Construction Manager's administrative procedures necessary for certification of Substantial Completion.
- D. Constraints: Include constraints and work restrictions indicated in the Contract Documents and as follows in schedule, and show how the sequence of the Work is affected.
 1. Phasing: Arrange list of activities on schedule by phase.
 2. Products Ordered in Advance: Include a separate activity for each product. Include delivery date indicated in Division 1 Section "Summary." Delivery dates indicated stipulate the earliest possible delivery date.
 3. Owner-Furnished Products: Include a separate activity for each product. Include delivery date indicated in Division 1 Section "Summary." Delivery dates indicated stipulate the earliest possible delivery date.

4. Work Stages: Indicate important stages of construction for each major portion of the Work, including, but not limited to, the following:
 - a. Subcontract awards.
 - b. Submittals.
 - c. Purchases.
 - d. Mockups.
 - e. Fabrication.
 - f. Sample testing.
 - g. Deliveries.
 - h. Installation.
 - i. Tests and inspections.
 - j. Adjusting.
 - k. Curing.
 - l. Startup and placement into final use and operation.
 5. Area Separations: Identify each major area of construction for each major portion of the Work. Indicate where each construction activity within a major area must be sequenced or integrated with other construction activities to provide for the following:
 - a. Structural completion.
 - b. Permanent space enclosure.
 - c. Completion of mechanical installation.
 - d. Completion of electrical installation.
 - e. Substantial Completion.
 - E. Milestones: Include milestones indicated in the Contract Documents in schedule, including, but not limited to, the Notice to Proceed, Substantial Completion, and Final Completion.
 - F. Cost Correlation: At the head of schedule, provide a cost correlation line, indicating planned and actual costs. On the line, show dollar volume of the Work performed as of dates used for preparation of payment requests.
 1. Refer to Division 1 Section "Payment Procedures" for cost reporting and payment procedures.
 - G. Contract Modifications: For each proposed contract modification and concurrent with its submission, prepare a time-impact analysis using fragments to demonstrate the effect of the proposed change on the overall project schedule.
 - H. Computer Software: Prepare schedules using a program that has been developed specifically to manage construction schedules.
- 2.3 PRELIMINARY CONSTRUCTION SCHEDULE
- A. Bar-Chart Schedule: Submit preliminary horizontal bar-chart-type construction schedule within 14 days of date established for the Notice to Proceed.
 - B. Preparation: Indicate each significant construction activity separately. Identify first workday of each week with a continuous vertical line. Outline significant construction activities for first 60

days of construction. Include skeleton diagram for the remainder of the Work and a cash requirement prediction based on indicated activities.

2.4 CONTRACTOR'S CONSTRUCTION SCHEDULE (GANTT CHART)

- A. Gantt-Chart Schedule: Submit a comprehensive, fully developed, horizontal Gantt-chart-type, Contractor's Construction Schedule within 30 days of date established for the Notice to Proceed. Base schedule on the Preliminary Construction Schedule and whatever updating and feedback was received since the start of Project.
- B. Preparation: Indicate each significant construction activity separately. Identify first workday of each week with a continuous vertical line.
 - 1. For construction activities that require 3 months or longer to complete, indicate an estimated completion percentage in 10 percent increments within time bar.

2.5 REPORTS

- A. Daily Construction Reports: Prepare a daily construction report recording the following information concerning events at Project site:
 - 1. List of subcontractors at Project site.
 - 2. List of separate contractors at Project site.
 - 3. Approximate count of personnel at Project site.
 - 4. High and low temperatures and general weather conditions.
 - 5. Accidents.
 - 6. Meetings and significant decisions.
 - 7. Unusual events (refer to special reports).
 - 8. Stoppages, delays, shortages, and losses.
 - 9. Meter readings and similar recordings.
 - 10. Emergency procedures.
 - 11. Orders and requests of authorities having jurisdiction.
 - 12. Change Orders received and implemented.
 - 13. Construction Change Directives received.
 - 14. Services connected and disconnected.
 - 15. Equipment or system tests and startups.
 - 16. Partial Completions and occupancies.
 - 17. Substantial Completions authorized.
- B. Field Condition Reports: Immediately on discovery of a difference between field conditions and the Contract Documents, prepare a detailed report. Submit with a request for information. Include a detailed description of the differing conditions, together with recommendations for changing the Contract Documents.

2.6 SPECIAL REPORTS

- A. General: Submit special reports directly to Owner within one day of an occurrence. Distribute copies of report to parties affected by the occurrence.
- B. Reporting Unusual Events: When an event of an unusual and significant nature occurs at Project site, whether or not related directly to the Work, prepare and submit a special report.

List chain of events, persons participating, and response by Contractor's personnel, evaluation of results or effects, and similar pertinent information. Advise Owner in advance when these events are known or predictable.

PART 3 - EXECUTION

3.1 CONTRACTOR'S CONSTRUCTION SCHEDULE

- A. Contractor's Construction Schedule Updating: At monthly intervals, update schedule to reflect actual construction progress and activities. Issue schedule one week before each regularly scheduled progress meeting.
 - 1. Revise schedule immediately after each meeting or other activity where revisions have been recognized or made. Issue updated schedule concurrently with the report of each such meeting.
 - 2. Include a report with updated schedule that indicates every change including, but not limited to, changes in logic, durations, actual starts and finishes, and activity durations.
 - 3. As the Work progresses, indicate Actual Completion percentage for each activity.
- B. Distribution: Distribute copies of approved schedule to Architect Owner, separate contractors, testing and inspecting agencies, and other parties identified by Contractor with a need-to-know schedule responsibility.
 - 1. Post copies in Project meeting rooms and temporary field offices.
 - 2. When revisions are made, distribute updated schedules to the same parties and post in the same locations. Delete parties from distribution when they have completed their assigned portion of the Work and are no longer involved in performance of construction activities.

END OF SECTION 013233

#

SECTION 013319 FIELD TEST REPORTING

PART 1 GENERAL

1.1 RELATED DOCUMENTS:

- A. Drawings and general provisions of Contract, including General and Supplementary Conditions and Division-1 Specification sections, apply to work on this section.
- B. Throughout the specifications, types of materials may be specified by manufacturer's name and catalogue number in order to establish standards of quality and performance and not for the purpose of limiting competition. Alternate methods and/or materials may be submitted to the Architect for consideration. Those judged to be equal to that specified will receive written approval.
- C. Delaware Department of Transportation Specifications for Road and Bridge Construction, August 2001 and as amended.
- D. Delaware Department of Natural Resources and Environmental Control (DNREC) Sediment and Stormwater Regulations.

1.2 SUMMARY

Work included: Provided at the Contractor's expense, such field engineering services as are required for proper completion of the Work including, but not necessarily limited to:

- A. The Contractor shall be responsible for all stakeouts and elevation checks required for construction. All such Work shall be performed by a professional land surveyor. The surveyor shall verify adequacy of benchmarks before starting construction.
- B. Before the start of any building construction, the Contractor shall have a professional land surveyor locate and stake building corners, driveway entrances, driveways, parking areas and playfields. If there are any discrepancies between the actual layout and the project site plan, they shall be brought to the attention of the Architect and resolved before Work proceeds. A building and site stake out drawing stamped and signed by a professional land surveyor may be submitted in lieu of this preliminary stake out.
- C. After the corners of the exterior walls have been started, the Contractor shall obtain a wall check survey certificate made by a professional land surveyor. This survey shall show the accurate location of the building with reference to property lines.
- D. After the first sections of slab-on-grade have been placed in the building, the Contractor shall have a professional land surveyor verify and record the finish floor elevations on the wall check survey.
- E. At the end of the project, the Contractor shall have a professional land surveyor prepare and certify an as-built survey showing the accurate horizontal and vertical locations of all building corners, paved areas, sidewalks, utilities (including inverts), fencing, site walls, etc. located within the project area.

#

#

- F. As-Built survey shall be included in a standard C.A.D. format such as AutoCad and/or MicroStation and shall include 2-foot contours within the project limits.
- G. A complete stormwater management as-built shall also be completed in accordance with DNREC's Standard Stormwater Management checklist. The Contractor's shall have a professional land surveyor prepare and certify an interim and final as-built, and the testing and inspection agent shall have a professional engineer certify the construction checklist at the interim and final stages of stormwater management facility construction.
- H. The contractor will be responsible for preparing and submitting to the project engineer five (5) copies of the interim and final stormwater management facility as-built, and additional facility information in accordance with the requirements set forth by DNREC.

1.3 RELATED WORK

- A. Documents affecting work of this Section include, but are not necessarily limited to, General Conditions, Supplementary Conditions, and Sections in Division 1 of these Specifications.
- B. Additional requirements for field engineering also may be described in other Sections of these Specifications.

1.4 QUALITY ASSURANCE

- A. Use adequate numbers of skilled workmen who are thoroughly trained and experienced in the necessary crafts and who are completely familiar with the specified requirements and the methods needed for proper performance of the work of this Section.

1.5 SUBMITTALS

- A. Comply with pertinent provisions of Section 013300-Submittals.
- B. Upon request of the Architect, submit;
 - 1. Data demonstrating qualifications of persons proposed to be engaged for field engineering services.
 - 2. Documentation verifying accuracy of field engineering work.
 - 3. Certifications, signed by the Contractor's retained field engineer, certifying that elevations and locations of improvements are in conformance with requirements of the Contract Documents.
 - 4. All certifications and surveys described in the Summary section of this specification.

#

#

1.6 PROCEDURES

- A. In addition to procedures directed by the Contractor for the proper performance of the Contractor's responsibilities:
1. Locate and protect control points before starting Work on the site.
 2. Preserve permanent reference points during process of the Work.
 3. Do not change or relocate reference points or items of the Work without specific approval from the Architect.
 4. Promptly advise the Architect when a reference point is lost or destroyed, or requires relations because of other changes in the Work.
 - a) Upon direction of the Architect, require the field engineer to replace reference stakes or markers.
 - b) Locate such replacements according to the original survey control.

PART 2 PRODUCTS

Not Applicable

PART 3 EXECUTION

Not Applicable

END OF SECTION 013319

SECTION 013500 – SPECIAL PROCEDURES

1.1 SAFETY REQUIREMENTS

- A. All work shall be performed in accordance with rules, regulations, procedures and safe practices and/or OSHA and all other Government agencies having jurisdiction over the project.

1.2 SAFETY PRECAUTIONS AND PROGRAMS:

- A. Each Contractor shall be responsible for initiating, maintaining and supervising safety precautions and programs in connection with the work. The name of the safety officer for each contractor shall be provided to the Construction Manager.
- B. All Contractors shall comply with the provisions of the "Occupational Safety and Health Act" and Federal, State and local requirements.
- C. If a Contractor fails to maintain the safety precautions required by law or directed by the Construction Manager, the Construction Manager may take such action as necessary and charge the Contractor therefore. The failure of the Construction Manager to take any such action shall not relieve the Contractor of his obligations.
- D. The Contractor individually shall be responsible for the safety, efficiency, and adequacy of his plant, appliances, and methods and for any damage which may result from their failure or their improper construction, maintenance or operation.
- E. Prior to mobilizing to the job, the Contractor shall submit to the Construction Manager in writing, a description of his safety program for review and comment. Failure of the Construction Manager to make any changes shall not relieve the contractor of his obligations. During the conduct of the work, the Contractor shall immediately notify the Construction Manager in writing of all accidents and shall submit a written report describing in detail the circumstances of each accident within 24 hours of its occurrence.
- F. All Contractors shall notify the Construction Manager of any flammable, combustible and/or toxic materials intended for use on the project and shall furnish the Construction Manager with literature pertinent to the use and control of all materials, including, but not limited to M.S.D.S. sheets.
- G. Each Contractor shall delegate one representative who shall be responsible to maintain all safety requirements of the Contractor, and shall attend all project meetings scheduled by the Construction Manager.

1.3 SAFETY OF PERSONS AND PROPERTY:

- A. The Contractor shall take all reasonable precautions for the safety of, and shall provide all reasonable protection to prevent damage or loss to:
 - 1. All Capital School District personnel and all other persons who may be affected thereby.

2. All the work and all materials and equipment to be incorporated therein, whether in storage on or off the site, under the care, custody or control of the Contractor or any of his Subcontractors or Sub-Subcontractors.
 3. Other property at the site or adjacent thereto, including but not limited to trees, shrubs, lawns, walks, pavements, roadways, structures and utilities not designated for removal, relocation or replacement in the course of construction and underground property.
- B. The Contractor shall give all notices and comply with all applicable laws, ordinances, rules, regulations and lawful orders of any public authority, including the Owner's requirements bearing on the Safety of persons or property or their protection from damage, injury or loss.
- C. The Contractor shall erect and maintain, as required by existing conditions and progress of the work, all reasonable safeguards for safety and protection, including danger signs and other warnings against hazards. He shall comply with safety regulations and notify the Construction Manager, until he is in compliance.
- D. The Contractor shall promptly remedy all damage or loss to any property caused in whole or in part by the Contractor, his Subcontractors, his Sub-Subcontractors, or anyone directly employed by any of them, or by anyone for whose acts any of them be liable.
- E. The Contractor shall not load or permit any part of the work to be loaded so as to endanger its integrity and safety.
- F. Contractors using a method of blasting to perform work on the project shall use all proper methods, including adequate safety matting and/or overburden, progressive time sequences and scaled distances, in accordance with all governmental regulations.
- G. The use of audio equipment and headsets will not be permitted on the construction site.

1.4 PERSONAL PROTECTION REQUIREMENTS

- A. All persons entering the project shall wear hard hats in good condition and meet ANSI Z89.1-1981 and ANSI Z89.2-1971. The hats shall be worn in the proper manner.
- B. All persons entering the project shall wear proper work boots, clothing attire including long trousers and shirts.
- C. All job site personnel are expected to strictly adhere to the following rules and regulations:
1. Use of approved eye protection by all Company personnel shall be required during all types of percussions and reciprocating work or when owner requirements govern.
 2. Approved respiratory equipment shall be worn by all personnel exposed to hazardous volumes of toxic or noxious dusts, fumes, mists, or gases. Check

M.S.D.S. if not sure.

3. Personal protective equipment is to be used under unusual conditions, such as high temperature work, handling caustic or corrosive liquids, or molten metals.
4. When lifting material, keep back straight, bend knees, and lift with your legs. Get help if the load is too heavy.
5. Work clear of suspended loads. If a load is moved above where you are working or walking, stand clear until it has passed.
6. Unless it is part of your regular work, do not attempt to repair or adjust any electrical equipment.
7. Kill any circuit before attempting to work on it. Even voltages lower than 110 will cause death under certain conditions.
8. Treat all electric wires as live. Do not touch exposed wires. Report them immediately to your supervisor.
9. The Contractor is responsible for providing safety training to all of his employees.
10. All shipments to the site shall have the required documentation and labels attached and the documentation and labels shall be maintained while the material is on site.
11. As defined in the Occupational Safety & Health Act, safety belts, complete with lanyards, or parachute-style harness, complete with lanyard, are to be used where there is a danger of falling.

1.5 HOUSEKEEPING

- A. Materials and equipment must be piled up or stored in a safe manner. Aisles must be kept clear.
- B. All drop cables/extension cords shall be elevated above the ground or protected in such a way to allow traffic to pass.
- C. Smoking will only be permitted in designated areas.
- D. Consumption of food and beverages in other than Company-designated areas and at specified times.
- E. Glass-bottled refreshments will not be allowed in the workplace.
- F. Graffiti will not be tolerated on the jobsite.
- G. All compressed gas cylinders must be stored in an upright position and tied off with the

cap placed on top.

- H. The cords and connections at temporary panels must be maintained in an orderly fashion at all times to prevent tripping.
- I. Welding stubs and shells from explosive activated tools shall be collected and properly disposed of by Contractor.
- J. Nails are to be bent over and/or removed from wood.
- K. Aisles and stairwells as well as base areas of ladders are to be kept clear at all times.

1.6 M.S.D.S.-CONTROLLED PRODUCTS

- A. The Contractor is responsible for notifying R.Y. Johnson & Son, Inc. of any controlled products that they bring or cause to have brought onto the site. The Contractor shall provide R.Y. Johnson & Son, Inc. with a copy of the Material Safety Data Sheet (M.S.D.S.) for the controlled product, and the Contractor shall retain a copy of the M.S.D.S. on site for their reference. The legal storage, use, and disposal of any controlled product is the responsibility of the Contractor.
- B. The Contractor shall comply with OSHA Communications' Standards 29 CFR 1910-1200 for hazardous materials. The Contractor shall maintain a Material Safety Data Sheet on file at the jobsite for each chemical brought to the site. M.S.D.S. sheets shall be submitted to R.Y. Johnson & Son, Inc. for record purposes.
- C. Temporary storage of hazardous materials shall be located in containment dikes provided by the Contractor requiring same in area identified by the Construction Manager. All tanks, drums, and containers are to be labeled with appropriate warnings (i.e., flammable, no smoking). Periodic inspections for leakage shall be the responsibility of the Contractor. Final cleanup and removal shall be by the Contractor.

1.7 EMERGENCIES

- A. In any emergency affecting the safety or persons or property, the Contractor shall act, at his discretion, to prevent threatened damage, injury or loss and shall immediately notify the Construction Manager of such emergency conditions. Any claims made by the Contractor for additional compensation or extension of time on account of emergency work shall be processed in accordance with Article 7, of the Supplementary Conditions.

1.8 ACCIDENT INVESTIGATION AND REPORTING

- A. All accident/incidents shall be reported.
- B. The Contractor shall submit an accident/incident report to R.Y. Johnson & Son, Inc. no later than 10 hours on the working day following the incident. A detailed report is to follow within 24 hours.

1.9 FIRST AID PROCEDURE

- A. The Contractor is to provide his own First Aid service.
- B. Each Contractor shall supply to R.Y. Johnson & Son, Inc. a list of their qualified First Aid personnel. Each Contractor is to have a minimum of one full-time qualified First Aid personnel on site. Contractor First Aid certificates shall be posted in the Contractor's site office and photocopies supplied to R.Y. Johnson & Son, Inc.

1.10 INDEMNIFICATION

- A. Contractors shall indemnify and hold harmless the Owner, the Construction Manager and the Architect/Engineer, all municipal authorities, and their agents and employees from and against all claims, damages, losses, and expenses including, but not limited to attorney's fees arising out of or resulting from the performance of the work, provided that any such claim, damage, loss or expense (1) is attributable to bodily injury, sickness, disease or death, or to injury to or destruction of tangible property (other work than the work itself) including the loss of use resulting therefrom, and (2) is caused in whole or in part by any negligent act or omission of the Contractor, any Subcontractor, anyone directly or indirectly employed by any of them or anyone for whose acts any of them may be liable, regardless of whether or not caused in part by a party indemnified hereunder.
- B. In any and all claims against the Owner, the Construction Manager or the Architect/Engineer or any of their agents or employees by any employee of a Contractor, and Subcontractor, anyone directly or indirectly employed by any of them or anyone for whose acts any of them may be liable, the indemnification obligation under this paragraph shall not be limited in any way by any limitation on the amount or type of damages, compensation or benefits payable by or for the type of damages, compensation or any Subcontractor under workmen's compensation acts, disability benefit acts or other employee benefit acts.
- C. To the fullest extent permitted by law the Contractor shall indemnify and hold harmless the Construction Manager, the Owner, and the Architect and their agents and employees from and against all claims, including citations and penalties imposed by the Occupational Safety and Health Administration, damages, losses, expenses and judgments including, but not limited to attorneys' fees, arising out of or resulting from performance of the work in an area which is unsafe, harmful, dangerous, or hazardous and which is caused in whole or in part by any act or omission of the Contractor, anyone directly or indirectly employed by it, or anyone for whose acts it may be liable, regardless of whether the claim, citation, penalty, damage, loss, expense or judgment results from unsafe, harmful, dangerous, hazardous or toxic materials or substances or whether from any other unsafe, harmful, dangerous or hazardous conditions.
- D. The obligations of the Contractor under this paragraph shall not extend to the liability of the Architect/Engineer or the Construction Manager, his agents or employees arising out of (1) the preparation or approval of maps, drawings, opinions, reports, surveys, design or specifications, or (2) the giving of or the failure to give directions or instructions by the

Architect/Engineer of the Construction Manager, their agents or employees provided such giving or failure to give is the primary cause of the injury or damage.

- E. No provision of this Subparagraph shall give rise to any duties on the part of the Architect or the Construction Manager not otherwise provided for by contract or by law.
- F. In the event that any party is requested but refuses to honor the indemnity obligations hereunder, then the party refusing to honor such requests shall, in addition to all other obligations, pay the cost of bringing any such action, including attorney's fees to the party requesting indemnity.

END OF SECTION 013500

NOT FOR BIDDING

SECTION 014000 - QUALITY REQUIREMENTS

PART 1 - GENERAL

1.1 RELATED DOCUMENTS

- A. Drawings and general provisions of the Contract, including General and Supplementary Conditions and other Division 1 Specification Sections, apply to this Section.

1.2 SUMMARY

- A. This Section includes administrative and procedural requirements for quality-control services.
- B. Quality-control services include inspections, tests, and related actions, including reports performed by Contractor, by independent agencies, and by governing authorities. They do not include contract enforcement activities performed by Architect.
- C. Inspection and testing services are required to verify compliance with requirements specified or indicated. These services do not relieve Contractor of responsibility for compliance with Contract Document requirements.
- D. Requirements of this Section relate to customized fabrication and installation procedures, not production of standard products.
 - 1. Specific quality-control requirements for individual construction activities are specified in the Sections that specify those activities. Requirements in those Sections may also cover production of standard products.
 - 2. Specified inspections, tests, and related actions do not limit Contractor's quality-control procedures that facilitate compliance with Contract Document requirements.
 - 3. Requirements for Contractor to provide quality-control services required by Architect, Owner, or authorities having jurisdiction are not limited by provisions of this Section.
- E. Related Sections: The following Sections contain requirements that relate to this Section:
 - 1. Division 1 Section "Cutting and Patching" specifies requirements for repair and restoration of construction disturbed by inspection and testing activities.
 - 2. Division 1 Section "Submittals" specifies requirements for development of a schedule of required tests and inspections.

1.3 RESPONSIBILITIES

- A. Contractor Responsibilities: Unless otherwise indicated as the responsibility of another identified entity, Contractor shall provide inspections, tests, and other quality-control services specified elsewhere in the Contract Documents and required by authorities having jurisdiction. Costs for these services are included in the Contract Sum.
 - 1. Where individual Sections specifically indicate that certain inspections, tests, and other quality-control services are the Contractor's responsibility, the Contractor shall employ and pay a qualified independent testing agency to perform quality-control services. Costs for these services are included in the Contract Sum.

- B. Retesting: The Contractor is responsible for retesting where results of inspections, tests, or other quality-control services prove unsatisfactory and indicate noncompliance with Contract Document requirements, regardless of whether the original test was Contractor's responsibility.
1. The cost of retesting construction, revised or replaced by the Contractor, is the Contractor's responsibility where required tests performed on original construction indicated noncompliance with Contract Document requirements.
- C. Associated Services: Cooperate with agencies performing required inspections, tests, and similar services, and provide reasonable auxiliary services as requested. Notify the agency sufficiently in advance of operations to permit assignment of personnel. Auxiliary services required include, but are not limited to, the following:
1. Provide access to the Work.
 2. Furnish incidental labor and facilities necessary to facilitate inspections and tests.
 3. Take adequate quantities of representative samples of materials that require testing or assist the agency in taking samples.
 4. Provide facilities for storage and curing of test sample.
 5. Deliver samples to testing laboratories.
 6. Provide the agency with a preliminary design mix proposed for use for materials mixes that require control by the testing agency.
 7. Provide security and protection of samples and test equipment at the Project Site.
- D. Duties of the Testing Agency: The independent agency engaged to perform inspections, sampling, and testing of materials and construction specified in individual Sections shall cooperate with the Architect and the Contractor in performance of the agency's duties. The testing agency shall provide qualified personnel to perform required inspections and tests.
1. The agency shall notify the Architect and the Contractor promptly of irregularities or deficiencies observed in the Work during performance of its services.
 2. The agency is not authorized to release, revoke, alter, or enlarge requirements of the Contract Documents or approve or accept any portion of the Work.
 3. The agency shall not perform any duties of the Contractor.
- E. Coordination: Coordinate the sequence of activities to accommodate required services with a minimum of delay. Coordinate activities to avoid the necessity of removing and replacing construction to accommodate inspections and tests.
1. The Contractor is responsible for scheduling times for inspections, tests, taking samples, and similar activities.

1.4 SUBMITTALS

- A. Unless the Contractor is responsible for this service, the independent testing agency shall submit a certified written report, in duplicate, of each inspection, test, or similar service to the Architect. If the Contractor is responsible for the service, submit a certified written report, in duplicate, of each inspection, test, or similar service through the Contractor.
1. Submit additional copies of each written report directly to the governing authority, when the authority so directs.

2. Report Data: Written reports of each inspection, test, or similar service include, but are not limited to, the following:
 - a. Date of issue.
 - b. Project title and number.
 - c. Name, address, and telephone number of testing agency.
 - d. Dates and locations of samples and tests or inspections.
 - e. Names of individuals making the inspection or test.
 - f. Designation of the Work and test method.
 - g. Identification of product and Specification Section.
 - h. Complete inspection or test data.
 - i. Test results and an interpretation of test results.
 - j. Ambient conditions at the time of sample taking and testing.
 - k. Comments or professional opinion on whether inspected or tested Work complies with Contract Document requirements.
 - l. Name and signature of laboratory inspector.
 - m. Recommendations on retesting.

1.5 QUALITY ASSURANCE

- A. Qualifications for Service Agencies: Engage inspection and testing service agencies, including independent testing laboratories, that are prequalified as complying with the American Council of Independent Laboratories' "Recommended Requirements for Independent Laboratory Qualification" and that specialize in the types of inspection and tests to be performed.
 1. Each independent inspection and testing agency engaged on the Project shall be authorized by authorities having jurisdiction to operate in the state where the Project is located.

PART 2 - PRODUCTS (Not Applicable)

PART 3 - EXECUTION

3.1 REPAIR AND PROTECTION

- A. General: Upon completion of inspection, testing, sample taking and similar services, repair damaged construction and restore substrates and finishes. Comply with Contract Document requirements for Division 1 Section "Cutting and Patching."
- B. Protect construction exposed by or for quality-control service activities, and protect repaired construction.
- C. Repair and protection is Contractor's responsibility, regardless of the assignment of responsibility for inspection, testing, or similar services.

END OF SECTION 014000

SECTION 014100- REGULATORY REQUIREMENTS

PART I - GENERAL

1.1 SECTION INCLUDES

- A. Safety and Health Regulations.
- B. Housekeeping.
- C. M.S.D.S. Controlled Products.
- D. Emergencies.
- E. Employment Policy.
- F. Environmental Statutes and Regulations.
- G. Miscellaneous Regulations.
- I. Standard of Quality.

1.2 RELATED SECTIONS

- A. General and Supplementary Conditions of the Contract.

1.3 SAFETY AND BEALTH REGULATIONS

- A. These Contract Documents and the joint and several phases of construction hereby contemplated are to be governed, at all times by applicable provisions of the Federal law(s), including but not limited to, the latest amendments of the following:
 - 1. Williams Steiger Occupational Safety and Health Act of 1970, Public Law 91-596,
 - 2. Part 910 - Occupational Safety and Health Standards, Chapter XIII of Title 29, Code of Federal Regulations.
- B. Nothing contained in these Contract Documents for construction shall be construed by the Contractor as relieving him in any way of his responsibility for strict compliance with the rules and regulations contained in the above mentioned Occupational Safety and Health Act.
- C. The use of products containing asbestos will not be permitted.
- D. All work shall be performed in accordance with rules, regulations, procedures and safe practices and/or OSHA and all other Government Agencies having jurisdiction over the project.

- E. Each Contractor shall be responsible for initiating, maintaining and supervising safety precautions and programs in connection with the work. The name of the safety officer for each contractor shall be provided to the Construction Manager.
- F. All Contractors shall comply with the provisions of the Occupational Safety and Health Act and Federal, State and local requirements.
- G. If a Contractor fails to maintain the safety precautions required by law or directed by the Construction Manager, the Construction Manager may take such action necessary and charge the Contractor therefore. The failure of the Construction Manager to take any such action shall not relieve the Contractor of his obligations.
- H. The Contractor individually shall be responsible for the safety, efficiency, and adequacy of his plant, appliances, and methods and for any damage which may result from their failure or their improper construction, maintenance or operation.
- I. Prior to mobilizing to the job, the Contractor shall submit to the Construction Manager in writing, a description of his safety program for review and comment. During the conduct of the work, the Contractor shall immediately notify the Construction Manager in writing of all accidents and shall submit a written report describing in detail the circumstances of each accident within 24 hours of its occurrence.
- J. All Contractors shall notify the Construction Manager of any flammable, combustible and/or toxic materials intended for use on the project and shall furnish the Construction Manager with literature pertinent to the use and control of all materials, including, but not limited to M.S.D.S sheets.
- K. Each Contractor shall delegate one representative who shall be responsible to maintain all safety requirements of the Contractor, and shall attend all project meetings scheduled by the Construction Manager.
- L. The Contractor shall take all reasonable precautions for the safety of, and shall provide all reasonable protection to prevent damage or loss to: -
 - 1. All school personnel, employees on the work site and all other persons who may be affected thereby.
 - 2. All the work and all materials and equipment to be incorporated therein, whether in storage on or off the site, under the care, custody or control of the Contractor or any of his Subcontractors or Sub-Subcontractors.
 - 3. Other property at the site or adjacent thereto, including but not limited to trees, shrubs, lawns, walks, pavements, roadways, structures and utilities not designated for removal, relocation or replacement in the course of construction and underground property.
- M. The Contractor shall give all notices and comply with all applicable laws, ordinances,

rules, regulations and lawful orders of any public authority, including the Owner's requirements bearing on the Safety of persons or property or their protection from damage, injury or loss.

- N. The Contractor shall erect and maintain, as required by existing conditions and progress of the work, all reasonable safeguards for safety and protection, including danger signs and other warnings against hazards. He shall comply with safety regulations and notify the Construction Manager, until he is in compliance.
- O. The Contractor shall promptly remedy all damage or loss to any property caused in whole or in part by the Contractor, his Subcontractors and his Sub-Subcontractors or anyone directly employed by any of them, or by anyone for whose acts any of them be liable.
- P. The Contractor shall not load or permit any part of the work to be loaded so as to endanger its integrity and safety.
- Q. Contractors using a method of blasting to perform work on the project shall use all proper
- R. The use of audio equipment and headsets will not be permitted on the construction site.
- S. All persons entering the project shall wear hard hats in good condition and meet ANSIZ89.1-1981 and ANSI Z89.2-1971. The hats shall be worn in the proper manner.
- T. All persons entering the project shall wear proper work boots, clothing attire including long trousers and shirts.
- U. All job site personnel are expected to strictly adhere to the following rules and regulations:
 - 1. Use of approved eye protection by all company personnel shall be required during all types of percussions and reciprocating work or when owner requirements govern.
 - 2. Approved respiratory equipment shall be worn by all company personnel exposed to hazardous volumes of toxic or noxious dusts, fumes, mists, or gases. Check M.S.D.S. if not sure.
 - 3. Personal protective equipment is to be used under usual conditions, such as high temperature work, handling caustic or corrosive liquids or molten metals.
 - 4. When lifting material, keep back straight, knees bent, and lift with your legs. Get help if the load is too heavy.
 - 5. Work clear of suspended loads. If a load is moved above where you are working or walking, stand clear until it has passed.
 - 6. Unless it is part of your regular work, do not attempt to repair or adjust any electrical equipment.
 - 7. Kill any circuit before attempting to work on it. Even voltages lower than 110 will cause death under certain conditions.
 - 8. Treat all electric wires as live. Do not touch exposed wires; report them immediately to your supervisor.
 - 9. The Contractor is responsible for providing safety training to all of his employees.
 - 10. All shipments to the site shall have the required documentation and labels attached

- and the documentation and labels shall be maintained while the material is on site.
11. As defined in the Occupational Safety & Health Act, safety belts, complete with lanyards or parachute style harness, complete with lanyards, are to be used where there is a danger of falling.

1.4 HOUSEKEEPING

- A. Materials and equipment must be piled up or stored in a safe manner. Aisles must be kept clear.
- B. All drop cables/extension cords shall be elevated above the ground or protected in such a way to allow traffic to pass.
- C. Smoking will only be permitted in designated areas.
- D. Consumption of food and beverages in other than Company designated areas and at specified times are prohibited.
- E. Glass-bottled refreshments will not be allowed in the workplace.
- F. Graffiti will not be tolerated on the job-site.
- G. All compressed gas cylinders must be stored in an upright position and tied off with the cap placed on top.
- H. The cords and connections at temporary panels must be maintained in an orderly fashion at all times to prevent tripping.
- I. Welding stubs and shells from explosive activated tools shall be collected and properly disposed of by the Contractor.
- J. Nails are to be bent over and/or removed from wood,
- K. Aisles and stairwells as well as base areas of ladders are to be kept clear at all times.

1.5 M.S.D.S.-CONTROLLED PRODUCTS

- A. The Contractor is responsible for notifying R.Y. Johnson Construction Management of any controlled products that they bring or cause to have brought onto the site. The Contractor shall provide RY. Johnson Construction Management with a copy of the Material Safety Sheet (M.S.D.S.) for the controlled product and the Contractor shall retain a copy of the M.S.D.S. on site for their own reference. The legal storage, use, and disposal of any controlled product is the responsibility of the Contractor.
- B. The Contractor shall comply with OSHA Communication Standards 29 CFR 1910-1200 for hazardous materials. The Contractor shall maintain a Material Safety Data Sheet on file at the job-site for each chemical brought to the site, M.S.D.S. sheets shall be

submitted to R.Y. Johnson Construction Management for record purposes

- C. Temporary storage of hazardous materials shall be located in containment dikes provided by the Contractor requiring same in area identified by the Construction Manager. All tanks, drums, and containers are to be labeled with appropriate warnings (i.e., flammable, no smoking). Periodic inspections for leakage shall be the responsibility of the Contractor. Final clean-up and removal shall be by the Contractor.

1.6 EMERGENCIES

- A. In any emergency affecting the safety of persons or property, the Contractor shall act, at his discretion, to prevent threatened damage, injury or loss and shall immediately notify the Construction Manager of such emergency conditions. Any claims made by the Contractor for additional compensation or extension of time on account of emergency work shall be processed in accordance with Article 7, of the Supplementary Conditions.

1.7 EMPLOYMENT POLICY

- A. Acceptance of a contract based on these specifications constitutes agreement by the Contractor to comply with State Policy as established by joint Resolution No. 16 of the General Assembly of 1958, which is: That on all public works being paid for in whole or in part with State or other public funds, preference shall be given to available persons who have been residents of Delaware for a period of at least six (6) months immediately prior to availability of positions for employment of laborers, mechanics and others, not including supervisor personnel not to exceed ten percent (10%) of the total working force.
- B. Competent Workmen: No person shall be employed to perform any work under the Contract who is not a competent and first-class workman or mechanic, as applicable. For purposes of this section, no workman or mechanic, as applicable, shall be regarded as competent and first class unless he shall be duly skilled in the applicable branch of labor and shall be paid not less than such rates of wages and for such hours work as shall be established and current rates of wages paid for such hours by employers of organized labor in performance of similar work in the locality where the work is to be performed.
- C. It is understood that the provisions of Title VI of the Civil Rights Act 1964 are hereby included in this contract to the end that no person in the United States shall, on the grounds of race, color, or national origin, be excluded from participation in, be denied the benefits of, or otherwise subjected to discrimination under this Agreement.

The Contractor agrees to make such reports and to maintain and make available, such records as may be required to ensure compliance with ART.38, par. b and c.
- this means permitting access by appropriate State or Federal officials during normal business hours to such facilities, records and other sources of information as may be pertinent to ascertain compliance with the regulations.

- D. All Contractors shall be subject to, and responsible for all costs relating to Contractor licensing ordinances and regulations.

1.8 ENVIRONMENTAL STATUTES AND REGULATIONS

- A. Contractor shall comply with all applicable provisions of federal and state laws dealing with the prevention of environmental pollution and the preservation of natural resources, including but not limited to Act No 247 approved October 26, 1962; the Federal Air Quality Act of 1967; the Clean Air Act; the Clean Water Restoration Act; the Water Pollution Control Act Amendments of 1956; the Water Quality Act of 1965; the Water Quality Improvement Act of 1970; The Water Pollution Control Act Amendments of 1972; The Water Facilities Act (see Consolidated Farmer's Home Administration Act of 1961); the Watershed Protection and Flood Prevention Act; the Pennsylvania Air Pollution Control Act; the Clean Streams Law; the Solid Waste Management Act; the Municipal Waste Planning, Recycling and Waste Reduction Act; A.H.E.R.A.; and all rules and regulations there under, including, but not limited to, those formulated by the United States Environmental Protection Agency, the Pennsylvania Department of Environmental Resources and the Department of Environmental Protection. Nothing contained in the Contract shall be construed as relieving Contractor in anyway of Contractors responsibility for strict compliance with all governmental requirements pertaining to environmental protection.
- B. These Contact Documents and the joint and several phases of construction hereby contemplated are to be governed at all times, by applicable provisions of Federal and State Law(s) dealing with the prevention of environmental pollution and the preservation of public natural resources, including but not limited to the latest amendments of the following:
1. Act No. 247 of the General Assembly of the Commonwealth of Pennsylvania relating to the prevention of environment pollution and the preservation of public natural resources in construction projects, enacted October 26, 1972.
- C. Pursuant to Act No. 247 of the 1972 Pennsylvania General Assembly, all proposals will be subject to all the provisions of all Federal and State statutes dealing with the prevention of pollution and preservation of public natural resources including, but not limited to; the Federal Air Quality Act of 1967; Clean Air Act, as amended; Clean Water Restoration Act; Water Pollution Control Act Amendments of 1956, Water Quality Act of 1965, Water Quality improvement Act of 1970. and Water Pollution Control Act Amendments of 1972; the Water Facilities Act (see Consolidated Farmers Home Administration Act of 1961); the Watershed Protection and Flood Prevention Act; the Pennsylvania Air Pollution Control Act; Clean Streams Law; Solid Waste Management Act; Sewerage Facilities Act; and all rules and regulations there under including, but not limited to, those formulated by the United States Environmental Protection Agency and the Pennsylvania Department of Environmental Resources.
- D. Act No. 247 provides that if the successful bidder must undertake additional work due to enactment of new or the amendment of existing statutes, rules or regulations occurring after the submission of the successful proposal, the Authority shall issue a change order setting for the additional work that must be

undertaken, which shall not invalidate the contract. The cost of such a change order to the Authority shall be determined in accordance with the provisions of the contract for change orders or force accounts, or if n such provision is set forth in the contract, then the cost to the Authority shall be the contractors costs for wages, labor costs other than wages, wage taxes, materials, equipment rentals, insurance and subcontractors attributable to the additional activity plus a reasonable sum for overhead and profit; provided however, that such additional costs to undertake work not specified in the invitation for proposal shall not be approved unless written authorization is given the successful bidder prior to his undertaking such additional activity. In the event of a dispute between the Authority and the successful bidder, arbitration procedures maybe commenced under the applicable terms of the construction contract, or, if the contract contains no such provision for arbitration, the then obtaining rules of the American Arbitration Association. I

- E. Nothing contained in the Contract Documents for construction shall be construed by the Contractor as relieving him in any way of his responsibility for strict compliance with the statutes, rules and regulations contained in the above mentioned Environmental Protection Act.

1.9 MISCELLANEOUS REGULATIONS

- A. Standard of Quality: The various materials and products specified in the specification by name or description are given to establish a standard of quality and of cost for bid purposes. It is not the intent to limit the acceptance to any one material or product specified, but rather to name or describe it as the absolute minimum standard that is desired and acceptable. A material or product of lesser quality would not be acceptable. Where proprietary names are used, whether or not followed by the words Approved equal®, they shall be subject to equals only as approved by the Architect and /or Engineer.

PART 2 -- PRODUCTS (NOT USED)

PART 3- EXECUTION (NOT USED)

END OF SECTION 014100

SECTION 014200 - REFERENCES

PART 1 - GENERAL

1.1 RELATED DOCUMENTS

- A. Drawings and general provisions of the Contract, including General and Supplementary Conditions and other Division 1 Specification Sections, apply to this Section.

1.2 DEFINITIONS

- A. General: Basic Contract definitions are included in the Conditions of the Contract.
- B. "Approved": The term "approved," when used to convey Architect's action on Contractor's submittals, applications, and requests, is limited to Architect's duties and responsibilities as stated in the Conditions of the Contract.
- C. "Directed": Terms such as "directed," "requested," "authorized," "selected," "approved," "required," and "permitted" mean directed by Architect, requested by Architect, and similar phrases.
- D. "Indicated": The term "indicated" refers to graphic representations, notes, or schedules on Drawings or to other paragraphs or schedules in Specifications and similar requirements in the Contract Documents. Terms such as "shown," "noted," "scheduled," and "specified" are used to help the user locate the reference.
- E. "Regulations": The term "regulations" includes laws, ordinances, statutes, and lawful orders issued by authorities having jurisdiction, as well as rules, conventions, and agreements within the construction industry that control performance of the Work.
- F. "Furnish": The term "furnish" means to supply and deliver to Project site, ready for unloading, unpacking, assembly, installation, and similar operations.
- G. "Install": The term "install" describes operations at Project site including unloading, temporarily storing, unpacking, assembling, erecting, placing, anchoring, applying, working to dimension, finishing, curing, and protecting, cleaning, and similar operations.
- H. "Provide": The term "provide" means to furnish and install, complete and ready for the intended use.
- I. "Installer": An installer is the Contractor or another entity engaged by Contractor as an employee, Subcontractor, or Sub-subcontractor, to perform a particular construction operation, including installation, erection, application, and similar operations.
- J. The term "experienced," when used with an entity, means having successfully completed a minimum of five previous projects similar in size and scope to this Project; being familiar with special requirements indicated; and having complied with requirements of authorities having jurisdiction.

1. Using a term such as "carpentry" does not imply that certain construction activities must be performed by accredited or unionized individuals of a corresponding generic name, such as "carpenter." It also does not imply that requirements specified apply exclusively to trades people of the corresponding generic name.

- K. "Project site" is the space available for performing construction activities. The extent of Project site is shown on Drawings and may or may not be identical with the description of the land on which Project is to be built.

1.3 INDUSTRY STANDARDS

- A. Applicability of Standards: Unless the Contract Documents include more stringent requirements, applicable construction industry standards have the same force and effect as if bound or copied directly into the Contract Documents to the extent referenced. Such standards are made a part of the Contract Documents by reference.
- B. Publication Dates: Comply with standards in effect as of date of the Contract Documents, unless otherwise indicated.
- C. Conflicting Requirements: If compliance with two or more standards is specified and the standards establish different or conflicting requirements for minimum quantities or quality levels, comply with the most stringent requirement. Refer uncertainties and requirements that are different, but apparently equal, to Architect for a decision before proceeding.
 1. Minimum Quantity or Quality Levels: The quantity or quality level shown or specified shall be the minimum provided or performed. The actual installation may comply exactly with the minimum quantity or quality specified, or it may exceed the minimum within reasonable limits. To comply with these requirements, indicated numeric values are minimum or maximum, as appropriate, for the context of requirements. Refer uncertainties to Architect for a decision before proceeding.
- D. Copies of Standards: Each entity engaged in construction on Project must be familiar with industry standards applicable to its construction activity. Copies of applicable standards are not bound with the Contract Documents.
 1. Where copies of standards are needed to perform a required construction activity, obtain copies directly from publication source and make them available on request.
- E. Abbreviations and Acronyms for Industry Organizations: Where abbreviations and acronyms are used in Specifications or other Contract Documents, they shall mean the recognized name of the entities indicated in Gale Research's "Encyclopedia of Associations" or in Columbia Books' "National Trade & Professional Associations of the U.S."
- F. Abbreviations and Acronyms for Industry Organizations: Where abbreviations and acronyms are used in Specifications or other Contract Documents, they shall mean the recognized name of the entities in the following list. Names, telephone numbers, and Web site addresses are subject to change and are believed to be accurate and up-to-date as of the date of the Contract Documents.

PRIVATE tbl1@dom1

AA	Aluminum Association, Inc. (The) www.aluminum.org	(202) 862-5100
AAADM	American Association of Automatic Door Manufacturers www.taol.com/aaadm	(216) 241-7333
AABC	Associated Air Balance Council www.aabchq.com	(202) 737-0202
AAMA	American Architectural Manufacturers Association www.aamanet.org	(847) 303-5664
AAN	American Association of Nurserymen (See ANLA)	
AASHTO	American Association of State Highway and Transportation Officials www.aashto.org	(202) 624-5800
AATCC	American Association of Textile Chemists and Colorists (The) www.aatcc.org	(919) 549-8141
ABMA	American Bearing Manufacturers Association www.abma-dc.org	(202) 429-5155
ACI	American Concrete Institute/ACI International www.aci-int.org	(248) 848-3700
ACPA	American Concrete Pipe Association www.concrete-pipe.org	(972) 506-7216
ADC	Air Diffusion Council	(312) 201-0101
AEIC	Association of Edison Illuminating Companies, Inc. (The) www.aeic.org	(205) 257-2530
AFPA	American Forest & Paper Association (See AF&PA)	
AF&PA	American Forest & Paper Association www.afandpa.org	(800) 878-8878 (202) 463-2700
AGA	American Gas Association www.aga.org	(202) 824-7000
AHA	American Hardboard Association www.ahardbd.org	(847) 934-8800
AHAM	Association of Home Appliance Manufacturers www.aham.org	(202) 872-5955

AI	Asphalt Institute www.asphaltinstitute.org	(606) 288-4960
AIA	American Institute of Architects (The) www.aiaonline.org	(202) 626-7300
AISC	American Institute of Steel Construction, Inc. www.aisc.org	(800) 644-2400 (312) 670-2400
AISI	American Iron and Steel Institute www.steel.org	(202) 452-7100
AITC	American Institute of Timber Construction	(303) 792-9559
ALA	American Laminators Association (See LMA)	
ALCA	Associated Landscape Contractors of America www.alca.org	(800) 395-2522 (703) 736-9666
ALSC	American Lumber Standard Committee	(301) 972-1700
AMCA	Air Movement and Control Association International, Inc. www.amca.org	(847) 394-0150
ANLA	American Nursery & Landscape Association (Formerly: AAN - American Association of Nurserymen) www.anla.org	(202) 789-2900
ANSI	American National Standards Institute www.ansi.org	(212) 642-4900
AOSA	Association of Official Seed Analysts www.zia.net.com/AOSA	(402) 476-3852
APA	APA-The Engineered Wood Association www.apawood.org	(253) 565-6600
APA	Architectural Precast Association www.archprecast.org	(941) 454-6989
API	American Petroleum Institute www.api.org	(202) 682-8000
ARI	Air-Conditioning & Refrigeration Institute www.ari.org	(703) 524-8800
ASCA	Architectural Spray Coaters Association www.ascassoc.com	(856) 848-6120

ASCE	American Society of Civil Engineers www.asce.org	(800) 548-2723 (703) 295-6300
ASHRAE	American Society of Heating, Refrigerating and Air-Conditioning Engineers www.ashrae.org	(800) 527-4723 (404) 636-8400
ASME	ASME International (The American Society of Mechanical Engineers International) www.asme.org	(800) 843-2763
ASSE	American Society of Sanitary Engineering www.asse-plumbing.org	(440) 835-3040
ASTM	American Society for Testing and Materials www.astm.org	(610) 832-9585
AWCI	AWCI International (Association of the Wall and Ceiling Industries International) www.awci.org	(703) 534-8300
AWCMA	American Window Covering Manufacturers Association (See WCMA)	
AWI	Architectural Woodwork Institute www.awinet.org	(800) 449-8811 (703) 733-0600
AWPA	American Wood Preservers' Association www.awpa.com	(817) 326-6300
AWS	American Welding Society www.aws.org	(800) 443-9353 (305) 443-9353
AWWA	American Water Works Association www.awwa.org	(800) 926-7337 (303) 794-7711
BHMA	Builders Hardware Manufacturers Association www.buildershardware.com	(212) 661-4261
BIA	Brick Industry Association (The) www.bia.org	(703) 620-0010
BIFMA	BIFMA International (Business and Institutional Furniture Manufacturer's Association International) www.bifma.com	(616) 285-3963

CCC	Carpet Cushion Council www.carpetcushion.org	(203) 637-1312
CCFSS	Center for Cold-Formed Steel Structures www.umn.edu/~ccfss	(573) 341-4471
CDA	Copper Development Association Inc. www.copper.org	(800) 232-3282 (212) 251-7200
CEA	Canadian Electricity Association (The) www.canelect.ca	(613) 230-9263
CFFA	Chemical Fabrics & Film Association, Inc. www.taol.com/cffa	(216) 241-7333
CGA	Compressed Gas Association www.cganet.com	(703) 412-0900
CGSB	Canadian General Standards Board www.pwgsc.gc.ca/cgsb	(819) 956-0425
CIMA	Cellulose Insulation Manufacturers Association www.cellulose.org	(888) 881-2462 (937) 222-2462
CISCA	Ceilings & Interior Systems Construction Association www.cisca.org	(630) 584-1919
CISPI	Cast Iron Soil Pipe Institute www.cispi.org	(423) 892-0137
CLFMI	Chain Link Fence Manufacturers Institute www.chainlinkinfo.com (under construction)	(301) 596-2584
CPA	Composite Panel Association (Formerly: National Particleboard Association) www.pboardf.com	(301) 670-0604
CPPA	Corrugated Polyethylene Pipe Association Division of Plastics Pipe Institute www.cppa-info.org	(800) 510-2772 (419) 241-2221
CRI	Carpet and Rug Institute (The) www.carpet-rug.com	(800) 882-8846 (706) 278-3176
CRSI	Concrete Reinforcing Steel Institute www.crsi.org	(847) 517-1200
CSA	CSA International (Formerly: IAS - International Approval Services) Division of Canadian Standards Association www.iasapprovals.org	(216) 524-4990

CSI	Construction Specifications Institute (The) www.csinet.org	(800) 689-2900 (703) 684-0300
CSSB	Cedar Shake & Shingle Bureau www.cedarbureau.org	(604) 462-8961
CTI	Cooling Tower Institute www.cti.org	(281) 583-4087
DHI	Door and Hardware Institute www.dhi.org	(703) 222-2010
EIA/TIA	Electronic Industries Alliance/Telecommunications Industry Association www.eia.org	(703) 907-7500
EIMA	EIFS Industry Members Association www.eifsfacts.com	(800) 294-3462 (770) 968-7945
EJMA	Expansion Joint Manufacturers Association, Inc. www.ejma.org	(914) 332-0040
FCI	Fluid Controls Institute www.fluidcontrolsinstitute.org	(216) 241-7333
FGMA	Flat Glass Marketing Association (See GANA)	
FM	Factory Mutual System (See FMG)	
FMG	FM Global (Formerly: FM - Factory Mutual System) www.fmglobal.com	(401) 275-3000
GA	Gypsum Association www.gypsum.org	(202) 289-5440
GANA	Glass Association of North America (Formerly: FGMA - Flat Glass Marketing Association) www.glasswebsite.com/gana	(785) 271-0208
GRI	Geosynthetic Research Institute www.drexel.edu/gri	(610) 522-8440
GTA	Glass Tempering Division of Glass Association of North America (See GANA)	

HI	Hydraulic Institute	(888) 786-7744 (973) 267-9700
HI	Hydronics Institute Division of Gas Appliance Manufacturers Association www.gamanet.org	(908) 464-8200
HMMA	Hollow Metal Manufacturers Association Division of National Association of Architectural Metal Manufacturers (See NAAMM)	
HPVA	Hardwood Plywood & Veneer Association www.hpva.org	(703) 435-2900
HPW	H. P. White Laboratory, Inc.	(400) 838-6550
IAS	International Approval Services (See CSA International)	
ICEA	Insulated Cable Engineers Association, Inc. www.icea.net	(508) 394-4424
ICRI	International Concrete Repair Institute www.icri.org	(703) 450-0116
IEC	International Electro technical Commission www.iec.ch	41 22 919 02 11
IEEE	Institute of Electrical and Electronics Engineers, Inc. (The) www.ieee.org	(212) 419-7900
IESNA	Illuminating Engineering Society of North America (The) www.iesna.org	(212) 248-5000
IGCC	Insulating Glass Certification Council www.igcc.org	(315) 938-7444
ILI	Indiana Limestone Institute of America, Inc. www.iliai.com	(812) 275-4426
IRI	HSB Industrial Risk Insurers www.industrialrisk.com	(800) 520-7300 (860) 520-7300
ITS	Intertek Testing Services www.itsglobal.com	(800) 345-3851 (607) 753-6711
IWS	Insect Screening Weavers Association (Now defunct)	

KCMA	Kitchen Cabinet Manufacturers Association www.kcma.org	(703) 264-1690
LGSi	Light Gage Structural Institute www.loseke.com	(972) 625-4560
LMA	Laminating Materials Association (Formerly: ALA - American Laminators Association) www.lma.org	(201) 664-2700
LPI	Lightning Protection Institute www.lightning.org	(800) 488-6864 (847) 577-7200
LSGA	Laminated Safety Glass Association (See GANA)	
MBMA	Metal Building Manufacturers Association www.mbma.com	(216) 241-7333
MFMA	Maple Flooring Manufacturers Association www.maplefloor.org	(847) 480-9138
MFMA	Metal Framing Manufacturers Association	(312) 644-6610
MHIA	Material Handling Industry of America www.mhia.org	(800) 345-1815 (704) 676-1190
MIA	Marble Institute of America www.marble-institute.com	(614) 228-6194
ML/SFA	Metal Lath/Steel Framing Association (See SSMA)	
MSS	Manufacturers Standardization Society of The Valve and Fittings Industry, Inc. www.msshq.com	(703) 281-6613
NAAMM	National Association of Architectural Metal Manufacturers www.naamm.org	(312) 332-0405
NAAMM	North American Association of Mirror Manufacturers (See GANA)	
NACE	NACE International (National Association of Corrosion Engineers International) www.nace.org	(281) 228-6200
NAIMA	North American Insulation Manufacturers Association (The) www.naima.org	(703) 684-0084

NAMI	National Accreditation and Management Institute, Inc.	(304) 258-5100
NAPM	National Association of Photographic Manufacturers (See PIMA)	
NBGQA	National Building Granite Quarries Association, Inc. www.nbgqa.com	(800) 557-2848
NCMA	National Concrete Masonry Association www.ncma.org	(703) 713-1900
NCPI	National Clay Pipe Institute www.ncpi.org	(414) 248-9094
NCTA	National Cable Television Association www.ncta.com	(202) 775-3669
NEBB	National Environmental Balancing Bureau www.nebb.org	(301) 977-3698
NECA	National Electrical Contractors Association www.necanet.org	(301) 657-3110
NeLMA	Northeastern Lumber Manufacturers' Association www.nelma.org	(207) 829-6901
NEMA	National Electrical Manufacturers Association www.nema.org	(703) 841-3200
NETA	International Electrical Testing Association www.electrictest.com/neta	(303) 697-8441
NFPA	National Fire Protection Association www.nfpa.org	(800) 344-3555 (617) 770-3000
NFRC	National Fenestration Rating Council www.nfrc.org	(301) 589-6372
NGA	National Glass Association www.glass.org	(703) 442-4890
NHLA	National Hardwood Lumber Association www.natlhardwood.org	(901) 377-1818
NLGA	National Lumber Grades Authority www.nlga.org	(604) 524-2393
NOFMA	National Oak Flooring Manufacturers Association www.nofma.org	(901) 526-5016

NPA	National Particleboard Association (See CPA)	
NRCA	National Roofing Contractors Association www.nrca.net	(800) 323-9545 (847) 299-9070
NRMCA	National Ready Mixed Concrete Association www.nrmca.org	(301) 587-1400
NSA	National Stone Association www.aggregates.org	(800) 342-1415 (202) 342-1100
NSF	NSF International (National Sanitation Foundation International) www.nsf.org	(800) 673-6275 (734) 769-8010
NTMA	National Terrazzo & Mosaic Association (The) www.ntma.com	(800) 323-9736 (703) 779-1022
NWWDA	National Wood Window and Door Association (See WDMA)	
PCI	Precast/Prestressed Concrete Institute www.pci.org	(312) 786-0300
PDCA	Painting and Decorating Contractors of America www.pdca.com	(800) 332-7322 (703) 359-0826
PDI	Plumbing & Drainage Institute www.pdionline.org	(800) 589-8956 (508) 230-3516
PGI	PVC Geomembrane Institute/Technology Program University of Illinois-Urbana Champaign //pgi-tp.ce.uiuc.edu	(217) 333-3929
PIMA	Photographic & Imaging Manufacturers Association (Formerly: NAPM - National Association of Photographic Manufacturers) www.pima.net	(914) 698-7603
RCSC	Research Council on Structural Connections c/o AISC www.boltcouncil.org	
RFCI	Resilient Floor Covering Institute	(Contact by mail only)
RIS	Redwood Inspection Service Division of the California Redwood Association www.calredwood.org	(888) 225-7339 (415) 382-0662

RMA	Rubber Manufacturers Association www.rma.org	(800) 220-7620 (202) 682-4800
SAE	SAE International www.sae.org	(724) 776-4841 (724) 776-4960 (publications)
SDI	Steel Deck Institute www.sdi.org	(847) 462-1930
SDI	Steel Door Institute www.steeldoor.org	(440) 899-0010
SEFA	Scientific Equipment and Furniture Association www.sefalabfurn.com	(843) 689-6878
SGCC	Safety Glazing Certification Council www.sgcc.org	(315) 938-7444
SIGMA	Sealed Insulating Glass Manufacturers Association www.sigmaonline.org/sigma	(312) 644-6610
SJI	Steel Joist Institute www.steeljoist.org	(843) 626-1995
SMA	Screen Manufacturers Association	(561) 533-0991
SMACNA	Sheet Metal and Air Conditioning Contractors' National Association www.smacna.org	(703) 803-2980
SPI	The Society of the Plastics Industry, Inc. www.plasticindustry.org	(202) 974-5200
SPIB	Southern Pine Inspection Bureau (The) www.spic.org	(850) 434-2611
SPI/SPFD	The Society of the Plastics Industry, Inc. Spray Polyurethane Foam Division (See SPI)	
SPRI	SPRI (Single Ply Roofing Institute) www.spri.org	(781) 444-0242
SSINA	Specialty Steel Industry of North America www.ssina.com	(800) 982-0355 (202) 342-8630
SSMA	Steel Stud Manufacturers Association (Formerly: ML/SFA - Metal Lath/Steel Framing Association) www.ssma.com	(312) 456-5590

SSPC	SSPC: The Society for Protective Coatings www.sspc.org	(800) 837-8303 (412) 281-2331
STI	Steel Tank Institute www.steeltank.com	(847) 438-8265
SWI	Steel Window Institute www.steelwindows.com	(216) 241-7333
SWRI	Sealant, Waterproofing & Restoration Institute www.swrionline.org	(816) 472-7974
TCA	Tile Council of America, Inc. www.tileusa.com	(864) 646-8453
TPI	Truss Plate Institute	(808) 833-5900
TPI	Turfgrass Producers International www.turfgrassod.org	(800) 405-8873 (847) 705-9898
UFAC	Upholstered Furniture Action Council www.ufac.org	(336) 885-5065
UL	Underwriters Laboratories Inc. www.ul.com	(800) 704-4050 (847) 272-8800
UNI	Uni-Bell PVC Pipe Association //members.aol.com/unibell	(972) 243-3902
USG	United States Gypsum Company A Subsidiary of USG Corporation www.usg.com	(800) 874-4968 (312) 606-4000
USITT	United States Institute for Theatre Technology, Inc. www.culturenet.ca/usitt	(800) 938-7488 (315) 463-6463
USP	U.S. Pharmacopeia www.usp.org	(800) 822-8772 (301) 881-0666
WASTEC	Waste Equipment Technology Association www.wastec.org	(800) 424-2869 (202) 244-4700
WCLIB	West Coast Lumber Inspection Bureau www.wclib.org	(800) 283-1486 (503) 639-0651
WCMA	Window Covering Manufacturers Association (Formerly: AWCMA - American Window Covering Manufacturers Association) www.windowcoverings.org	(212) 661-4261

WDMA	Window & Door Manufacturers Association (Formerly: NWWDA - National Wood Window and Door Association) www.wdma.com	(800) 223-2301 (847) 299-5200
WIC	Woodwork Institute of California www.wicnet.org	(916) 372-9943
WMMPA	Wood Molding & Millwork Producers Association www.wmmpa.com	(800) 550-7889 (530) 661-9591
WWPA	Western Wood Products Association www.wwpa.org	(503) 224-3930

- G. Abbreviations and Acronyms for Code Agencies: Where abbreviations and acronyms are used in Specifications or other Contract Documents, they shall mean the recognized name of the entities in the following list. Names, telephone numbers, and Web site addresses are subject to change and are believed to be accurate and up-to-date as of the date of the Contract Documents.

PRIVATE tbl2

BOCA	BOCA International, Inc. www.bocai.org	(708) 799-2300
CABO	Council of American Building Officials (See ICC)	
IAPMO	International Association of Plumbing and Mechanical Officials (The) www.iapmo.org	(909) 595-8449
ICBO	International Conference of Building Officials www.icbo.org	(800) 284-4406 (562) 699-0541
ICC	International Code Council (Formerly: CABO - Council of American Building Officials) www.intlcode.org	(703) 931-4533
SBCCI	Southern Building Code Congress International, Inc. www.sbcci.org	(205) 591-1853

- H. Abbreviations and Acronyms for Federal Government Agencies: Where abbreviations and acronyms are used in Specifications or other Contract Documents, they shall mean the recognized name of the entities in the following list. Names, telephone numbers, and Web site addresses are subject to change and are believed to be accurate and up-to-date as of the date of the Contract Documents.

PRIVATE tbl3@dom1

CE	Army Corps of Engineers CRD Standards	(601) 634-2355
CFR	Code of Federal Regulations www.access.gpo.gov/nara/cfr	(202) 512-1800

CPSC	Consumer Product Safety Commission www.cpsc.gov	(800) 638-2772 (301) 504-0990
DOC	Department of Commerce www.doc.gov	(202) 482-2000
DOD	Department of Defense DOD Specifications and Standards //astimage.daps.dla.mil/online	(215) 697-6257
EPA	Environmental Protection Agency www.epa.gov	(202) 260-2090
FAA	Federal Aviation Administration Department of Transportation www.faa.gov	(202) 366-4000
FCC	Federal Communications Commission www.fcc.gov	(202) 418-0190
FDA	Food and Drug Administration www.fda.gov	(888) 463-6332
FED-STD	Federal Standard (See FS)	
FS	Federal Specification (Available from DOD, GSA, and NIBS)	
FTMS	Federal Test Method Standard (See FS)	
GSA	General Services Administration www.gsa.gov	(202) 708-5082 (202) 619-8925 (Federal Specifications)
HUD	Department of Housing and Urban Development www.hud.gov	(202) 401-0388
LBL	Lawrence Berkeley Laboratory (See LBNL)	
LBNL	Lawrence Berkeley National Laboratory www.lbl.gov	(510) 486-5605
MILSPEC	Military Specification and Standards (See DOD)	
NCHRP	National Cooperative Highway Research Program (See TRB)	

NIST	National Institute of Standards and Technology www.nist.gov	(301) 975-2000
OSHA	Occupational Safety & Health Administration (See CFR 29) www.osha.gov	(202) 219-5000
RUS	Rural Utilities Service (See USDA)	(202) 720-9540
TRB	Transportation Research Board www.nas.edu/trb	(202) 334-2933
USDA	Department of Agriculture www.usda.gov	(202) 720-8732
USPS	Postal Service www.usps.gov	(202) 268-2000

PART 2 - PRODUCTS (Not Used)

PART 3 - EXECUTION (Not Used)

END OF SECTION 014200

SECTION 014219 – REFERENCE STANDARDS

PART 1 – GENERAL

1.1 SECTION INCLUDES

- A. Specification Format.
- B. Specification Language and Form.

1.2 RELATED SECTIONS

- A. The specifications have been arranged in accordance with CSI / CSC “masterformat” master list of titles and numbering system.

1.3 FORMAT

- A. The imperative language of the technical sections of the specifications is directed to the Contractor unless specifically noted otherwise.
- B. Portions of the specifications have been derived from an automated master specification production system and may include minor deviations from traditional writing forms. Such deviations must be recognized as a normal result of this production technique and no other meaning will be implied or permitted.

PART 2 – PRODUCTS (NOT USED)

PART 3 – EXECUTION (NOT USED)

END OF SECTION 014219

SECTION 015000 -TEMPORARY FACILITIES & CONTROLS

PART 1 GENERAL

1.1 RELATED DOCUMENTS

- A. Drawings and general provisions of the Contract, including General and Supplementary Conditions and other Division-0 Specification Sections, apply to this Section.

1.2 SUMMARY

- A. This Section specifies requirements for temporary construction, utilities, facilities, and controls required to support the successful construction of the project and maintain services until the permanent utilities, facilities, and controls are complete. They shall be installed, maintained, and removed subject to the Construction Manager approval.

TABLE OF PARTS

	<u>PART 1 - General</u>
1.3	Quality Assurance
1.4	Project Conditions
1.5	Existing Utilities and Systems
	<u>PART 2 - Products</u>
2.1	Materials
2.2	Equipment
	<u>PART 3 - Execution</u>
3.1	Installation
3.2	Temporary Utility Installation
3.3	Use Charges
3.4	Water Service
3.5	Electrical Power
3.6	Lighting
3.7	Telephones
3.8	Sanitary Facilities
3.9	Storm Sewers
3.10	Dewatering Facilities
3.11	Heating and Ventilation
3.12	Field Offices
3.13	Roads and Parking
3.14	Enclosures
3.15	Lifts and Hoists
3.16	Elevators
3.17	Project Identification
3.18	Waste Disposal and Cleanup
3.19	Construction Aids and Protection
3.20	Fire Safety
3.21	Barricades, Warning Signs, and Lights
3.22	Site Enclosure Fence
3.23	Building Security, Enclosure, and Lockup
3.24	Environmental Protection, NPDES, and PPC

- 3.25 Workday
- 3.26 Lunch Wagon
- 3.27 Erosion Control
- 3.28 Excavation
- 3.29 Blasting
- 3.30 Material Inventories
- 3.31 Deliveries
- 3.32 Operation, Termination, and Removal
- 3.33 Snow Removal

1.3 QUALITY ASSURANCE

- A. Regulations: Comply with industry standards and applicable laws and regulations of authorities having jurisdiction, including but not limited to:
 - Municipal and Labor & Industry Building Code requirements
 - Health and safety regulations
 - Utility company regulations
 - Police, Fire Department and Rescue Squad rules
 - Environmental protection regulations
- B. Inspections: Arrange for authorities, having jurisdiction, to inspect and test each temporary utility before use. Obtain required certifications and permits.

1.4 PROJECT CONDITIONS

- A. Conditions of Use: Keep temporary services and facilities clean and neat in appearance. Operate in a safe and efficient manner. Take necessary fire prevention measures. Do not overload facilities, or permit them to interfere with progress. Do not allow hazardous, dangerous or unsanitary conditions, or public nuisances to develop or persist on the site. They shall be removed, relocated as required by the progress of the work, or directed by the Construction Manager.

1.5 EXISTING UTILITIES AND SYSTEMS

- A. Precaution must be taken to protect existing sanitary sewer, electrical, water and gas lines that cross the site. All existing building utility systems such as electrical, water, gas will be demolished and reconstructed during this project.
- B. Trade Contractors interrupting services due to their construction operations shall provide temporary utility lines, as required, to maintain services.

PART 2 PRODUCTS

2.1 MATERIALS

- A. General: Provide new materials; if acceptable to the Construction Manager, undamaged, previously used materials in serviceable condition may be used. Provide materials suitable for the use intended.
- B. Lumber and Plywood: Comply with requirements in Division-6 Section "Rough Carpentry."
- C. Tarpaulins: Provide waterproof, fire-resistant, UL-labeled tarpaulins with flame-spread rating of 15 or less. For temporary enclosures, provide translucent, nylon-reinforced, laminated polyethylene or polyvinyl chloride fire retardant tarpaulins.
- D. Water: Provide potable water approved by local health authorities.
- E. Open-Mesh Fencing: Provide 11-gauge, galvanized two (2) inch, chain link fabric fencing, six (6) feet high with galvanized steel pipe posts, 1-1/2" I.D. for line posts and 2-1/2" I.D. for corner posts. Drive posts 30" into the ground at no less than 15' spacing.

2.2 EQUIPMENT

- A. General: Provide new equipment; if acceptable to the Construction Manager, undamaged, previously used equipment in serviceable condition may be used. Provide equipment suitable for use intended.
- B. Water Hoses: Provide 3/4" heavy-duty, abrasion-resistant, flexible rubber hoses 100 ft. long, with pressure rating greater than the maximum pressure of the water distribution system; provide adjustable shut-off nozzles at hose discharge.
- C. Electrical Outlets: Provide properly configured NEMA polarized outlets to prevent insertion of 110-120 volt plugs into higher voltage outlets. Provide receptacle outlets equipped with ground-fault circuit interrupters, reset button, and pilot light, for connection of power tools, equipment, and GFI breakers.
- D. Electrical Power Cords: Provide grounded extension cords; use "hard-service" cords where exposed to abrasion and traffic. Provide waterproof connectors to connect separate lengths of electric cords if single lengths will not reach areas where construction activities are in progress.
- E. Electrical Welding Outlets: These will not be provided. Each Trade Contractor will be responsible for his own welding power.
- F. Lamps and Light Fixtures: Provide general service incandescent lamps of wattage required for adequate illumination. Provide guard cages or tempered glass enclosures where exposed to breakage. Provide exterior fixtures where exposed to moisture.

- G. Heating Units: Provide temporary heating units that have been tested and labeled by UL, FM or another recognized trade association related to the type of fuel being consumed.
- H. Temporary Offices: Provide prefabricated or mobile units or similar job-built construction with lockable entrances, operable windows and serviceable finishes. Provide heated and air-conditioned units on foundations adequate for normal loading.
- I. Temporary Toilet Units: Provide self-contained, single-occupant toilet units of the chemical, aerated recirculation, or combustion type, properly vented and fully enclosed with a glass fiber, reinforced polyester shell or similar nonabsorbent material.
- J. First Aid Supplies: Comply with governing regulations.
- K. Fire Extinguishers: Provide hand-carried, portable UL-rated, class "A" fire extinguishers for temporary offices and similar spaces. In other locations, provide hand-carried, portable, UL-rated, class "ABC" dry chemical extinguishers, or a combination of extinguishers of NFPA recommended classes for the exposures.

Comply with NFPA 10 classification, extinguishing agent and size required by location and class of fire exposure.

PART 3 EXECUTIONS

3.1 INSTALLATION

- A. Use qualified personnel for installation of temporary facilities. Locate facilities where they will serve the Project adequately and result in minimum interference with performance of the Work. Relocate and modify facilities as required.
- B. Provide each facility ready for use when needed to avoid delay. Maintain and modify as required. Do not remove until facilities are no longer needed, or are replaced by authorized use of completed permanent facilities.

3.2 TEMPORARY UTILITY INSTALLATION

- A. General: Engage the appropriate local utility company to install temporary service or connect to existing service. Where the company provides only part of the service, provide the remainder with matching, compatible materials and equipment; comply with the company's recommendations.
 - 1. Arrange with the company and existing users for a time when service can be interrupted, where necessary, to make connections for temporary services.
 - 2. Provide adequate capacity at each stage of construction. Prior to temporary utility availability, provide trucked-in services.
 - 3. Obtain easements to bring temporary utilities to the site, where the Owner's easements cannot be used for that purpose.

3.3 USE CHARGES

- A. Cost for temporary facilities are to be paid by the Trade Contractor requiring or providing the temporary facility unless noted otherwise.
- B. Owner will pay utility consumption costs during construction.

3.4 WATER SERVICE

- A. The Plumbing Contractor shall install water service and distribution piping of sizes and pressures adequate for construction. As a minimum, provide a manifold pipe with two 3/4" hose bibs at the building water riser point of entrance until portions of the permanent piping system can be used to support construction activities. Water service may be run from a temporary or permanent source. Coordinate needs with Construction Manager.
 - 1. Sterilization: Sterilize temporary water piping prior to use.
 - 2. Protect system from freezing.
 - 3. Utilize City water pressure.

3.5 ELECTRICAL POWER

- A. After start of work at project site, when requested by the Construction Manager, the Electrical Contractor shall provide a temporary electrical power distribution system sufficient to accommodate temporary lighting and construction operations, including the use of power tools, and start-up of specified building equipment which must be tested, started or placed into use prior to completion of its permanent power connections. Provide weatherproof, grounded wiring with overload protection; with direct wired connections, where feasible, and for voltages up to 220/208 volts. Locate multiple outlets for 120 volt power, not less than 4 gang, at each story of construction, spaced so that the entire area of construction can be reached by power tools on a single extension cord of 100' maximum length. Maximum 20 Amp circuit breaker, four (4) receptacles per circuit breaker.
- B. The Electrical Trade Contractor shall provide and pay for all maintenance, servicing, operation, and supervision of lines installed.
- C. Provide service with ground fault circuit interrupter feature, as per NEC and OSHA requirements. The Electrical Trade Contractor shall have a cord inspection program in place. He shall maintain the inspection records on site.
- D. As permanent power distribution system is accepted as substantially complete, either entire system or usable portions thereof, the Electrical Trade Contractor shall make suitable provisions for temporary use thereof, and remove unused portions of temporary system.
- E. If required, provide meters for electrical power.
- F. When temporary electrical lines are no longer required, they shall be removed by the Electrical Trade Contractor and any part, or parts, of the grounds or buildings disturbed or damaged shall be brought back to their original condition.
- G. Electricity from existing lines may be used at no charge to the Trade Contractor, except for heating units, temporary offices, or storage. Each trade shall provide extension cords from the existing facilities, as required, for the execution of the Work. Electrical power for welding equipment will not be available.

- H. The Electrical Trade Contractor shall maintain and operate permanent electrical supply and distribution system until time of final acceptance and transfer of operation to Owner's personnel.
- I. The Electrical Trade Contractor shall install switching controls for all lighting which will enable turning off temporary lighting during off-construction hours. The Electrical Trade Contractor shall provide manpower to control light switching and be responsible for it.
- J. Temporary power supplies to the Construction Manager's Office Conference/Office Complex shall be installed with service connection by the Electrical Trade Contractor.
- K. The Electrical Trade Contractor will provide power for oil or gas fired temporary heaters, if required by the Construction Manager. It will be connected so that it can remain "live" when the lighting has been turned off.
- L. The Electrical Trade Contractor will provide 24-hour temporary power to any heat tape (installed by others) on temporary water and/or fire line. All temporary heat work will comply with existing OSHA requirements.
- M. Construction circuits shall be separate and independent from temporary lighting.
- N. The Electrical Trade Contractor will extend a temporary electrical service and provide a termination box in the Trade Contractor's office trailer area for hook-up of the Trade Contractor's trailers. Cost for individual Trade Contractor trailer hook-up will be born by the Trade Contractor requiring this service. Use of electric heaters in those trailers and shanties will not be permitted.

3.6 LIGHTING

- A. Whenever overhead floor or roof deck has been installed, the Electrical Trade Contractor shall provide temporary lighting with local switching.
The Electrical Trade Contractor shall provide sufficient temporary lighting to ensure proper workmanship everywhere; by combined use of daylight and general lighting as stated below:
 - 1. Provide uniformly spaced general lighting utilizing one (1) 150 watt incandescent lamp equivalent to 1.0 watts/sq. ft. of floor areas, and one (1) 100 watt lamp per 50' of corridor or per flight of stairs. General lighting to have a minimum of 5' candles measured at floor level.
 - 2. Limit lighting installations to intensities which will accommodate normal access and workmanship requirements, recognizing that each entity performing work requiring higher intensity lighting will provide supplementary plug in temporary lighting and localized areas where such work is in progress.
 - 3. As permanent lighting system is substantially complete for each story or usable portion thereof, the Electrical Trade Contractor shall make suitable provisions for temporary use thereof and remove unused portions of temporary lighting system.
 - 4. The Electrical Trade Contractor shall maintain and operate permanent lighting system until time of final acceptance and transfer of operation to Owner's

personnel, including turning off lighting during off-construction hours.

5. The Electrical Trade Contractor shall replace bulbs that are burned out or substantially dimmed by substantial hours of use.
6. Special lighting required for construction activities shall be provided by contractor requiring it.
7. The Electrical Trade Contractor shall provide safety lighting in the stairways, hallways, and exterior security lighting on a 24-hour basis.
8. Furnish and install dusk to dawn type security lights on poles as shown on the site construction staging plan.
9. If more lighting is necessary to install finishes, drywall, painting, etc., the contractor needing the extra lighting will provide.

3.7 TELEPHONES

- A. The Construction Manager shall be responsible to provide telephone service to a demarcation point in the Trade Contractor office trailer area. Temporary phone service must support 10 office trailers that require phone and/or fax service. Cost for individual hook ups, telephones, and use fees, shall be the responsibility of each Trade Contractor.
- B. The Construction Manager shall make arrangements for one (1) public telephone to be installed on the site and include monthly service cost for the duration of the project.

3.8 SANITARY FACILITIES

- A. The Construction Manager shall provide temporary toilets. Comply with regulations and health codes for the type, number, location, operation and maintenance of fixtures and facilities. Install where facilities will best serve the Project's needs.

Provide toilet tissue for each facility.

- B. Toilets. Install self-contained toilet units. Shield toilets to ensure privacy. Use of pit-type privies will not be permitted. Provide means of locking facilities when construction is not in progress.

Provide one unit for use of Construction Manager=s office/conference meeting complex.

- C. Drinking Water Facilities: Each trade contractor shall provide drinking water for it=s own personnel.

3.9 STORM SEWERS

- A. If storm sewers are available, the Sitework Trade Contractor shall provide temporary connections to remove effluent that can be discharged lawfully. If sewers are not available, or cannot be used, the Sitework Trade Contractor shall provide drainage ditches, dry wells, stabilization ponds and similar facilities. If neither sewers nor drainage facilities can be lawfully used for discharge of effluent, provide containers to remove and dispose of

effluent off the site in a lawful manner.

- B. Filter out excessive amounts of soil, construction debris, chemicals, oils and similar contaminants that might clog sewers or pollute waterways before discharge.
- C. Comply with the soil erosion and sedimentation control plan and local authorities having jurisdiction.

3.10 DEWATERING FACILITIES

- A. For temporary drainage and dewatering facilities, and operations not directly associated with construction activities included under individual Sections, comply with dewatering requirements of applicable Division-2 Sections. Where feasible, utilize the same facilities. The Sitework Trade Contractor shall be responsible to maintain the site, excavations and construction free of water.
- B. In the event that storm drain piping is not completed when needed for roof drain tie in, then the Plumbing Trade Contractor shall provide temporary storm water drainage from the building, and the Sitework Trade Contractor shall control roof drainage from building onto the site.
- C. Sitework Trade Contractor shall be responsible to drain or pump water and remove debris from the site so as not to delay his continuous work or progress. This shall include operating pumps during second shift in order to facilitate next-day continuation of work.
- D. Sitework Trade Contractor shall excavate in a manner that prevents all surface water from flowing into the building area. Sitework Trade Contractor shall be responsible to remove any runoff water or debris which enters the building area.
- E. Sitework Trade Contractor shall continue to drain site and remove debris until designed grades are obtained.
- F. Once building excavation grades are complete, the Concrete Work Contractor shall be responsible to remove all water and debris to install and backfill the building foundations.
- G. Upon completion of building foundations, each Trade Contractor shall be responsible to remove water and debris required to complete his work.

3.11 HEATING AND VENTILATION

- A. Temporary heating shall be provided and maintained by the Trade Contractor performing the work if the outside temperature falls below 40E F at anytime during the day or night for all exterior work or work performed prior to the building being enclosed by walls and roof.
- B. The Trade Contractor shall furnish temporary heat by acceptable means to provide sufficient heat to maintain a temperature of 55E F, 24 hours a day throughout the entire area of the work for which the Trade Contractor is responsible prior to the building being enclosed by walls and roof.
- C. Except where use of the permanent system is authorized, provide vented, self-contained LP gas or fuel oil heaters with individual space thermostatic control. Use of gasoline-burning

space heaters, open flame, or salamander type heating units is prohibited. Temporary heating may not be provided using electrical heating equipment if using electrical power supplied by the Owner.

- D. As soon as the building, or portions thereof, is generally enclosed with walls and roof and temporary heat is required for scheduled work, or required to facilitate proper workmanship, and permanent heating system is not yet operable or authorized for use, the HVAC Contractor shall arrange and provide temporary heat service for every entity authorized to do work at the project site. The HVAC Contractor shall maintain temperatures as indicated by other Specification Sections for each type of work to be performed. The Construction Manager shall be the sole arbiter of when the building is considered generally enclosed.
- E. Refer to paragraph 3.14 in section 01500 for responsibilities to install, maintain, and remove temporary enclosure of windows and doors until the permanent materials are in place.
- F. After the conditions of construction require continuous 24 hour heat in the building, the HVAC Contractor shall provide, operate, and maintain temporary radiation or unit heaters to provide required temperatures (minimum 55E F) for the conduct of work. This service shall be continued until the permanent heating system has been completely installed and is in operation. The HVAC Contractor shall furnish and pay for all fuel as required for providing temporary heat after the building is generally enclosed.
- G. As permanent heating/cooling system is substantially complete and operational for each story or usable portion thereof, the HVAC Trade Contractor shall make suitable provisions for use thereof in temporary heating and cooling. The HVAC Trade Contractor shall maintain and operate permanent system for temporary heating/cooling purposes, including service to occupied areas, if any, until time of final acceptance or transfer of operation to Owner's personnel, for major parts of system if not for entire heating system and air conditioning. The Owner shall pay for all fuel costs incurred by the permanent HVAC systems after acceptance of systems.
- H. Warranty: The warranty as required by the contract specifications will not begin until final acceptance of the system has been given by the architect for all or part of a system. The warranty period does not start with the use of the equipment for temporary heating and cooling.
- I. All permanent heating and air conditioning equipment used to supply temporary heat and air conditioning shall be completely cleaned and reconditioned by the HVAC Trade Contractor prior to final acceptance. Radiator traps and valves used in the heating system during the period of its operation to supply temporary heat shall not be reinstalled in the permanent system. Install new disposable filters and clean non-disposable filters prior to final acceptance. Replace significantly worn parts and parts that have been subject to unusual operating conditions.
- J. PARAGRAPH OMITTED
- K. Temporary Ventilation: A Trade Contractor requiring ventilation for work shall provide fans or other necessary equipment to condition air, provided prior approval has been obtained from the Construction Manager.

- L. Humidification: Where control of ambient humidity is required for proper performance of the work, or for curing/drying of installed work or for protection of installed work from deterioration due to variations in ambient conditions, each Trade Contractor shall provide his own temporary humidification or dehumidification equipment to maintain the required conditions. Coordinate the use of the equipment with temporary heating to produce the required conditions with a minimum overall use of energy.
- M. Permanent electrical power needed to operate permanent heating system must be provided by the Electrical Trade Contractor in conjunction with building enclosure, or the Electrical Trade Contractor shall furnish adequate temporary power to operate permanent heating system.
- N. In the event of permanent installed equipment failure, repairs or alternate equipment must be in place within 24 hours of failure or the Construction Manager will take action necessary to restore the heat to the design temperature and will deduct any and all charges from the HVAC Contractor.
- O. If additional heating above 55 degrees F or cooling below 80 degrees F is required by a Contractor to properly install and maintain his work, he shall be responsible to provide the additional heating and cooling.
- P. Connections for temporary electric to the temporary heat will be provided by the Electrical Contractor.

3.12 FIELD OFFICES

- A. Trade Contractors shall provide offices for their own personnel. All type and location of jobsite offices and equipment will be approved by the Construction Manager.
- B. Storage and Fabrication Sheds: Each Trade Contractor shall provide storage and fabrication sheds, sized, furnished and equipped to accommodate materials and equipment involved, including temporary utility service. Sheds may be open shelters or fully enclosed spaces. All steps and platforms connected to shelters must be per OSHA regulations.
- C. All offices and sheds must have the Trade Contractor's identification on them.

3.13 ROADS AND PARKING

- A. Sitework Trade Contractor shall construct and maintain temporary roads, construction parking and paving to adequately support the indicated loading and to withstand exposure to traffic during the construction period, in conjunction with the site logistics plan bound into this specification. Locate temporary paving for roads, storage areas and parking where the same permanent facilities will be located.
- B. Sitework Trade Contractor shall be responsible for providing stable parking area for all construction personnel on the jobsite by use of crushed stone/binder paving, including permanent parking areas.
- C. The Sitework Trade Contractor shall maintain truck tire wash facility at the construction

entrance.

- D. Snow removal will be performed by the Sitework Contractor.

3.14 ENCLOSURES

- A. All temporary enclosures required for protection of exterior construction in progress and completed from exposure, bad weather, other construction operations, and similar activities and to maintain the progress schedule, shall be provided by each contractor as necessary to protect their work.
- B. General Trades Contractor shall provide temporary building enclosure for protection of construction in progress, and completed, from exposure, foul weather, other construction operations, and similar activities. The extent of temporary enclosures will be as necessary to maintain the progress schedule.
- C. Where heat is needed and the permanent building enclosure is not complete, the General Trades Contractor shall provide temporary enclosures where there is no other provision for containment of heat. Coordinate enclosure with ventilating and material drying or curing requirements to avoid dangerous conditions and effects.

The Aluminum, Storefront, Windows, Canopies, Glass and Glazing Trade Contractor shall be responsible to remove the temporary entrance enclosures and install the permanent entrances or reinstall parts of the temporary enclosures in such a manner that the building security is maintained at the end of each workday shift.

The Aluminum, Storefront, Windows, Canopies, Glass and Glazing Trade Contractor shall be responsible to provide temporary window enclosures, in the event that aluminum window rough openings are fully prepared to receive finish window installation and the finish materials are not ready for prompt installation to maintain the construction schedule.

The General Trade Contractor shall furnish and install temporary entrance doors and maintain them until such time the permanent entrances are installed.

- D. Install tarpaulins securely with noncombustible wood framing and other materials. Close openings of 25 sq. ft. or less with plywood or similar materials.
- E. Dust partitions and enclosures if indicated on the drawings shall be constructed, maintained, and removed by the General Trades Contractor.
- F. Each Trade Contractor is required to construct, maintain, and remove dust partitions required to prevent dust from entering occupied areas due to the performance of his work.

3.15 LIFTS AND HOISTS

- A. Lifting and hoisting of all materials and equipment will be the responsibility of each Trade Contractor.
- B. Truck cranes and similar devices used for hoisting materials are considered "tools and equipment" and shall be provided by contractor requiring same.

- C. Each Trade Contractor shall be responsible to provide all site and subsurface modification preparation and replacement required to use his lifting and hoisting equipment.

3.16 ELEVATORS

- A. Existing Elevator to be demolished.

3.17 PROJECT IDENTIFICATION

- A. The Construction Manager shall prepare project identification and other signs, as approved by the Owner, of the size indicated; install signs where indicated to inform the public and persons seeking entrance to the Project. Support on posts or framing of preservative treated wood or steel. See attached sketches at end of this section.
- B. The Construction Manager shall provide one (1) sign erected on the site, where directed, to identify the project. Sign shall include Project name, Owner's name, Architect's name, and Construction Manager's name. Size shall be 4' x 8'; color and lettering style shall be as designed by the Architect. See attached sketches at end of this section.
- C. Engage an experienced sign painter to apply graphics.
- D. Temporary Signs: The Construction Manager shall prepare signs to provide directional information to construction personnel and visitors as required by the Construction Manager. See attached sketches at end of this section.
- E. No other signs allowed on site unless approved by the Construction Manager.

3.18 WASTE DISPOSAL AND CLEANUP

- A. The construction manager shall provide trash collection containers for construction debris, exclusive of roofing tear off debris, rock, earth, site work demolition waste, masonry and concrete debris and pay for all debris disposal cost for them. Each trade contractor on the project will be required to clean up and deposit in the dumpster, all debris generated by his trade contract work on a daily basis. Roofing contractor, Site work contractor, Masonry contractor and Concrete contractor must pay their own solid waste removal costs. All other contractors will be provided with collection containers for their use at no cost to the contractor.

This requirement shall be enforced by the Construction Manager and will result in cost assessment against a Trade Contractor who fails to perform daily clean-up within 48 hours of verbal or written notice from the Construction Manager. Each Trade Contractor will be responsible for flattening or crushing all trash as necessary when placed into the dumpster. Hazardous material shall not be placed in the collection container.

- B. Contractors may be required to place salvageable and recyclable materials and debris in separate designated dumpsters or dispose of properly for their own salvage value.
- C. All Contractors are to participate in a monthly eight (8) hour general clean up which will be

coordinated by the Construction Manager. Each Contractor shall provide a minimum of one (1) clean-up person for every 15 or less people on the Contractor's average work force for the month with the appropriate brooms, shovels, and wheel barrows. Clean up will be supervised by the Construction Manager.

- D. The Trades Contractors shall be responsible for weekly broom cleaning of all floor surfaces, for dust, dirt and general trash.
- E. The Construction Manager will be responsible for providing trash receptacles, "55 gallon capacity". Emptying them with weekly cleanup or when filled to capacity, shall be done by the Contractors performing the work in that area.
- F. The General Trades Contractor shall determine with the Construction Manager, a location for an enclosed trash chute to control dust for debris from second floor levels to the dumpster container. General Trades Contractor shall also erect a dimensional lumber guard railing around the trash chute to prevent jobsite personnel from exposure to falling debris.

3.19 CONSTRUCTION AIDS AND PROTECTION

- A. The General Trades Contractor shall provide wood handrails and barricades on all stairs and landings, according to OSHA regulations. Provide barricades at all elevator shafts.
- B. The Steel Work Trades Contractor shall furnish, install and remove at completion, all perimeter guard rails for elevated surfaces.
- C. The General Trades Contractor shall install safety coverings, handrail around all recessed areas and openings on all floors. Building perimeters, roof, wall, or shaft openings shall have perimeter protection as required by OSHA. This work shall comply with all OSHA requirements and remain in place until permanent construction fills those openings.
- D. The Roofing Trades Contractor shall install roof edge perimeter protections and guard rails or coverings, at all roof openings.
- E. Each Trade Contractor, upon working in any of the areas named in the above paragraph, shall remove the safety covering and handrail to perform his work. Upon completion of his work for the day, lunch, or breaks, or any time when the individual Trade Contractor is not working in that opening, the safety covering and handrail must be replaced by the Trade Contractor removing it. At the end of each day, the General Trades Contractor will inspect the site and install all safety coverings and handrails. He shall report to the Construction Manager if coverings and handrails are not being reinstalled by other contractors.

At the end of the project, or in order to install permanent construction, the General Trades Contractor shall remove all coverings and handrails.

- F. The Trade Contractors requiring access to above grade work are responsible for providing ladders, scaffolding and appropriate methods to access their work. Trade Contractor desiring use of in place above grade work platforms must arrange directly with the party that owns the equipment and make all rental and insurance arrangements directly with that party.
- G. All work platforms, scaffolding, etc., on the project shall be available for access by the

Owner, Architect, Municipal Authority, Testing Agency and/or Construction Manager.

3.20 FIRE SAFETY

- A. Existing fire protection shall be maintained in place until permanent sprinklered fire protection system is available for use. The Sprinkler System Trades Contractor shall provide the permanent sprinkler fire protection system for use at the earliest possible date after building enclosure and 55° F temperatures are maintained to protect the building structure.
- B. The Construction Manager shall provide fire extinguishers, as required by OSHA standards or other codes.
- C. Each Contractor shall store combustible materials in containers in fire-safe locations.
- D. Each Contractor shall maintain unobstructed access to fire extinguishers, fire hydrants, temporary fire protection facilities, stairways and other access routes for fighting fires. Prohibit smoking in hazardous fire exposure areas.
- E. Each Contractor shall provide supervision of welding operations, combustion type temporary heating units, and similar sources of fire ignition.
- F. The Construction Manager shall provide the local fire company with a set of site and floor plans. He shall invite the local fire company to visit the project site and plan emergency response.

3.21 BARRICADES, WARNING SIGNS AND LIGHTS

- A. All trade contractors requiring barricades, warning signs and lights shall comply with standards and code requirements for erection of structurally adequate barricades. Paint with appropriate colors, graphics, and warning signs to inform personnel and the public of the hazard being protected against.

3.22 SITE ENCLOSURE FENCE

- A. The Construction Manager shall perform all temporary fencing work as indicated on the site logistics drawing. This work shall be done immediately upon mobilizing for Work at the beginning of the Project.
- B. The Sitework Contractor shall maintain permanent chain link fencing and fabric fencing throughout the duration of the Project, particularly maintaining security function of gate devices.

3.23 BUILDING SECURITY, ENCLOSURE, AND LOCKUP

- A. The General Trades Contractor shall install substantial temporary enclosure of partially completed areas of construction. Provide and maintain locking entrances to prevent unauthorized entrance, vandalism, theft and similar violations of security.
- B. Each Trade Contractor is responsible for the secure storage of their own material and equipment on and off the site.

3.24 ENVIRONMENTAL PROTECTION, NPDES, AND PPC

- A. To the fullest extent permitted by law, the Trade Contractor shall indemnify and hold harmless the Owner and Construction Manager, their employees and agents, from claims, losses, damage, and expenses including, but not limited to, attorney's fees arising out of performance of the work as it relates to any type of pollution related situations. This would apply to bodily injury, sickness, disease or death, or to damages or destruction or contamination of tangible property arising out of the acts or omission of the Trade Contractor or the joint negligent acts of the Owner or Construction Manager, or anyone for whose acts the Trade Contractor may be liable.

- B. Each Trade Contractor, prior to construction, must comply with the National Pollution Discharge Elimination System (NPDES) and submit and State and Local Preparedness, Prevention and Contingency Plans (PPC) to the Construction Manager before the start of work.

Each Trade Contractor must construct, operate and maintain storage of materials to provide protection for each individual worker, as well as the protection of property or real estate of the construction site and environment.

- C. Each Trade Contractor shall provide protection, operate temporary facilities, and conduct construction in ways and methods that comply with all environmental regulations, and minimize the possibility that air, water, and soil from becoming contaminated or polluted as a result of work or storage of supplies and materials, or equipment usage.
- D. Each Trade Contractor will designate and train a responsible employee in environmental contamination procedures, including, but not limited to, emergency responses, material and waste inventories, spills and leak precautions and responses, inspections, housekeeping, security, and external factors.
- E. Open burning will not be permitted.

3.25 WORKDAY

- A. The workdays for the project are defined as 7:00 a.m. to 3:30 p.m., Monday through Friday, with lunch period from 12:00B12:30 p.m. The progress schedule may require contractors to perform work other than the normal workday and in addition to the normal workday to meet milestones in the progress schedule for the project, or to make up time previously lost to regain the progress schedule requirements or to prevent interruption of the Owner's ongoing operations at no additional cost to the Owner.
- B. Working times other than the normal workday or in addition to the normal work day, must be arranged in advance with the Construction Manager.
- C. Trade Contractors who require additional workday hours to regain work time previously lost to meet the requirements of the project schedule shall be assessed for all costs including Construction Manager Supervision and other Trade Contractor cost necessary for the performance of their work.

3.26 LUNCH WAGON

- A. Lunch wagons, catered events or other non-construction related functions shall not be permitted on the project site, except by the written permission of the Owner and Construction Manager.
- B. No alcoholic beverages or controlled substances shall be allowed on the project at any time.

3.27 EROSION CONTROL

- A. The Sitework Trade Contractor shall employ all methods required to comply with local regulatory authorities requirements to control erosion from the project site, including drainage control ditches, sediment basins, straw bale dikes, silt fencing and whatever procedure necessary to comply with requirements.
- B. The Sitework Trade Contractor shall maintain these controls throughout the duration of the project.

3.28 EXCAVATION

- A. Any Trade Contractor performing excavation shall protect all excavated materials from moisture, freezing and drying, so that the same materials excavated can be utilized for backfill.
- B. Any Trade Contractor performing excavation shall have an OSHA trained person on site during all excavation operations. This person shall evaluate soil types and conditions to determine the required shoring and excavation methods.

3.29 BLASTING

- A. Blasting is not permitted.

3.30 MATERIAL INVENTORIES

- A. Contractors shall coordinate the delivery and storage on the jobsite of all significant materials.
- B. Each Trade Contractor shall be responsible for the proper location, secure, and weather resistant storage as required of all materials. This includes placement of materials not to obstruct passage on site or within building structures or in any way which causes impediment or obstruction to other Trade Contractors.
- C. All material inventories must be stored by the Trade Contractor to avoid excessive loads on building structure.
- D. When directed by the Construction Manager, a Trade Contractor shall remove or relocate material inventories as required for the progress of the project.

3.31 DELIVERIES

- A. All contractors are required to properly instruct material suppliers and vendors to address deliveries to them specifically by named responsible party at the jobsite and require

advance notice.

- B. All deliveries addressed to the project in general, the Owner, Architect or Construction Manager, will be refused and returned to shipper.
- C. The Owner will not be responsible for receipt, handling, or loss of any materials which are shipped to the Owner in error and received unknowing of relationship to the project.
- D. Contractor receiving materials at the jobsite shall be responsible for prevention of any mud or other deposits on public roadways or other areas outside project limit lines, which may result due to methods of material delivery. Trade Contractor shall instruct delivery conveyor to take appropriate measures to prevent depositing mud or other construction deposits outside of contract limit lines. Total responsibility of cleanup of mud or other construction deposit outside of contract limit lines will be the responsibility of the Trade Contractor receiving the delivery.
- E. Each Contractor shall provide his superintendent with a telephone pager to enable locating the superintendent on and off site.

3.32 OPERATION, TERMINATION AND REMOVAL

- A. Supervision: Enforce strict discipline in use of temporary facilities. Limit availability of temporary facilities to essential and intended uses to minimize waste and abuse.
- B. Maintenance: Maintain facilities in good operating condition until removal. Protect from damage by freezing temperatures and similar elements.
 - 1. Maintain operation of temporary enclosures, heating, cooling, humidity control, ventilation and similar facilities on a 24-hour day basis where required to achieve indicated results and to avoid possibility of damage.
 - 2. Protection: Prevent water filled piping from freezing. Maintain markers for underground lines. Protect from damage during excavation operations.
- C. Termination and Removal: Unless the Construction Manager requests that it be maintained longer, remove each temporary facility when the need has ended, or when replaced by authorized use of a permanent facility, or not later than Substantial Completion. Complete or, if necessary restore, permanent construction that may have been delayed because of interference with the temporary facility. Repair damaged work, clean exposed surfaces, and replace construction that cannot be satisfactorily repaired.
 - 1. Materials and facilities that constitute temporary facilities are property of the Trade Contractor. The Owner reserves the right to take possession of Project identification signs.
 - 2. The Sitework Trade Contractor shall remove temporary paving that is not intended for or acceptable for integration into permanent paving. Where the area is intended for landscape development, remove soil and aggregate fill that does not comply with requirements for fill or subsoil in the area. Remove materials contaminated with road oil, asphalt, and other petrochemical compounds, and other substances which might impair growth of plant materials or lawns. Repair or replace street

paving, curbs and sidewalks at the temporary entrances, as required by the governing authority.

3.33 SNOW REMOVAL

- A. Snow removal for roads, building exterior, contractor parking, contractor office, staging, and Construction Manager's office area access will be performed by the Sitework Contractor.
- B. The General Trades Contractor shall be responsible for snow removal from within the building, maintaining safe walkway, stair traffic areas and building corridors, using anti-skid methods for snow, mud and/or ice removal, to provide safe usage.
- C. All snow and ice removal required to perform contractor specific tasks on floors, roof, work stages, etc., shall be performed by each Contractor.

END OF SECTION 015000

NOT FOR BIDDING

SECTION 016000 - PRODUCT REQUIREMENTS

PART 1 - GENERAL

1.1 RELATED DOCUMENTS

- A. Drawings and general provisions of the Contract, including General and Supplementary Conditions and other Division 1 Specification Sections, apply to this Section.

1.2 SUMMARY

- A. This Section includes administrative and procedural requirements governing the Contractor's selection of products for use in the Project.
 - 1. Multiple Prime Contracts: Provisions of this Section apply to the construction activities of each prime contractor.
- B. Related Sections: The following Sections contain requirements that relate to this Section:
 - 1. Division 1 Section "Reference Standards and Definitions" specifies the applicability of industry standards to products specified.
 - 2. Division 1 Section "Submittals" specifies requirements for submittal of the Contractor's Construction Schedule and the Submittal Schedule.
 - 3. Division 1 Section "Substitutions" specifies administrative procedures for handling requests for substitutions made after award of the Contract.

1.3 DEFINITIONS

- A. Definitions used in this Article are not intended to change the meaning of other terms used in the Contract Documents, such as "specialties," "systems," "structure," "finishes," "accessories," and similar terms. Such terms are self-explanatory and have well-recognized meanings in the construction industry.
 - 1. "Products" are items purchased for incorporation in the Work, whether purchased for the Project or taken from previously purchased stock. The term "product" includes the terms "material," "equipment," "system," and terms of similar intent.
 - a. "Named Products" are items identified by the manufacturer's product name, including make or model number or other designation, shown or listed in the manufacturer's published product literature, which is current as of the date of the Contract Documents.
 - b. "Foreign Products," as distinguished from "domestic products," are items substantially manufactured (50 percent or more of value) outside the United States and its possessions. Products produced or supplied by entities substantially owned (more than 50 percent) by persons who are not citizens of, nor living within, the United States and its possessions are also considered to be foreign products.
 - 2. "Materials" are products substantially shaped, cut, worked, mixed, finished, refined or otherwise fabricated, processed, or installed to form a part of the Work.

3. "Equipment" is a product with operational parts, whether motorized or manually operated, that requires service connections, such as wiring or piping.

1.4 SUBMITTALS

- A. Product List: A list of products required is included at the end of this Section. Prepare a schedule in tabular form showing each product listed. Include the manufacturer's name and proprietary product names for each item listed.
- B. Product List: Prepare a list showing products specified in tabular form acceptable to the Architect. Include generic names of products required. Include the manufacturer's name and proprietary product names for each item listed.
 1. Coordinate product list with the Contractor's Construction Schedule and the Schedule of Submittals.
 2. Form: Prepare product list with information on each item tabulated under the following column headings:
 - a. Related Specification Section number.
 - b. Generic name used in Contract Documents.
 - c. Proprietary name, model number, and similar designations.
 - d. Manufacturer's name and address.
 - e. Supplier's name and address.
 - f. Installer's name and address.
 - g. Projected delivery date or time span of delivery period.
 3. Initial Submittal: Within 30 days after date of commencement of the Work, submit 3 copies of an initial product list. Provide a written explanation for omissions of data and for known variations from Contract requirements.
 - a. At the Contractor's option, the initial submittal may be limited to product selections and designations that must be established early in the Contract period.
 4. Completed List: Within 60 days after date of commencement of the Work, submit 3 copies of the completed product list. Provide a written explanation for omissions of data and for known variations from Contract requirements.
 5. Architect's Action: The Architect will respond in writing to Contractor within 2 weeks of receipt of the completed product list. No response within this period constitutes no objection to listed manufacturers or products but does not constitute a waiver of the requirement that products comply with Contract Documents. The Architect's response will include a list of unacceptable product selections, containing a brief explanation of reasons for this action.

1.5 QUALITY ASSURANCE

- A. Source Limitations: To the fullest extent possible, provide products of the same kind from a single

source.

1. When specified products are available only from sources that do not, or cannot, produce a quantity adequate to complete project requirements in a timely manner, consult with the Architect to determine the most important product qualities before proceeding. Qualities may include attributes, such as visual appearance, strength, durability, or compatibility. When a determination has been made, select products from sources producing products that possess these qualities, to the fullest extent possible.
- B. Compatibility of Options: When the Contractor is given the option of selecting between 2 or more products for use on the Project, the product selected shall be compatible with products previously selected, even if previously selected products were also options.
 1. Each prime contractor is responsible for providing products and construction methods that are compatible with products and construction methods of other prime or separate contractors.
 2. If a dispute arises between prime contractors over concurrently selectable, but incompatible products, the Architect will determine which products shall be retained and which are incompatible and must be replaced.
- C. Foreign Product Limitations: Except under one or more of the following conditions, provide domestic products, not foreign products, for inclusion in the Work.
 1. No available domestic product complies with the Contract Documents.
 2. Domestic products that comply with the Contract Documents are available only at prices or terms substantially higher than foreign products that comply with the Contract Documents.
- D. Nameplates: Except for required labels and operating data, do not attach or imprint manufacturer's or producer's nameplates or trademarks on exposed surfaces of products that will be exposed to view in occupied spaces or on the exterior.
 1. Labels: Locate required product labels and stamps on concealed surfaces or, where required for observation after installation, on accessible surfaces that are not conspicuous.
 2. Equipment Nameplates: Provide a permanent nameplate on each item of service-connected or power-operated equipment. Locate on an easily accessible surface that is inconspicuous in occupied spaces. The nameplate shall contain the following information and other essential operating data:
 - a. Name of product and manufacturer.
 - b. Model and serial number.
 - c. Capacity.
 - d. Speed.
 - e. Ratings.

1.6 PRODUCT DELIVERY, STORAGE, AND HANDLING

- A. Deliver, store, and handle products according to the manufacturer's recommendations, using means and methods that will prevent damage, deterioration, and loss, including theft.
 1. Schedule delivery to minimize long-term storage at the site and to prevent overcrowding of construction spaces.
 2. Coordinate delivery with installation time to assure minimum holding time for items that are

- flammable, hazardous, easily damaged, or sensitive to deterioration, theft, and other losses.
3. Deliver products to the site in an undamaged condition in the manufacturer's original sealed container or other packaging system, complete with labels and instructions for handling, storing, unpacking, protecting, and installing.
 4. Inspect products upon delivery to ensure compliance with the Contract Documents and to ensure that products are undamaged and properly protected.
 5. Store products at the site in a manner that will facilitate inspection and measurement of quantity or counting of units.
 6. Store heavy materials away from the Project structure in a manner that will not endanger the supporting construction.
 7. Store products subject to damage by the elements above ground, under cover in a weather tight enclosure, with ventilation adequate to prevent condensation. Maintain temperature and humidity within range required by manufacturer's instructions.

PART 2 - PRODUCTS

2.1 PRODUCT SELECTION

- A. General Product Requirements: Provide products that comply with the Contract Documents, that are undamaged and, unless otherwise indicated, new at the time of installation.
1. Provide products complete with accessories, trim, finish, safety guards, and other devices and details needed for a complete installation and the intended use and effect.
 2. Standard Products: Where available, provide standard products of types that have been produced and used successfully in similar situations on other projects.
- B. Product Selection Procedures: The Contract Documents and governing regulations govern product selection. Procedures governing product selection include the following:
1. Proprietary Specification Requirements: Where Specifications name only a single product or manufacturer, provide the product indicated. No substitutions will be permitted.
 2. Semi proprietary Specification Requirements: Where Specifications name 2 or more products or manufacturers, provide 1 of the products indicated. No substitutions will be permitted.
 - a. Where Specifications specify products or manufacturers by name, accompanied by the term "or equal" or "or approved equal," comply with the Contract Document provisions concerning "substitutions" to obtain approval for use of an unnamed product.
 3. Nonproprietary Specifications: When Specifications list products or manufacturers that are available and may be incorporated in the Work, but do not restrict the Contractor to use of these products only, the Contractor may propose any available product that complies with Contract requirements. Comply with Contract Document provisions concerning "substitutions" to obtain approval for use of an unnamed product.
 4. Descriptive Specification Requirements: Where Specifications describe a product or assembly, listing exact characteristics required, with or without use of a brand or trade name, provide a product or assembly that provides the characteristics and otherwise complies with Contract requirements.
 5. Performance Specification Requirements: Where Specifications require compliance with performance requirements, provide products that comply with these requirements and are recommended by the manufacturer for the application indicated.
 - a. Manufacturer's recommendations may be contained in published product literature or by the

manufacturer's certification of performance.

6. Compliance with Standards, Codes, and Regulations: Where Specifications only require compliance with an imposed code, standard, or regulation, select a product that complies with the standards, codes, or regulations specified.
7. Visual Matching: Where Specifications require matching an established Sample, the Architect's decision will be final on whether a proposed product matches satisfactorily.
 - a. Where no product available within the specified category matches satisfactorily and complies with other specified requirements, comply with provisions of the Contract Documents concerning "substitutions" for selection of a matching product in another product category.
8. Visual Selection: Where specified product requirements include the phrase "... as selected from manufacturer's standard colors, patterns, textures ..." or a similar phrase, select a product and manufacturer that complies with other specified requirements. The Architect will select the color, pattern, and texture from the product line selected.
9. Allowances: Refer to individual Specification Sections and "Allowance" provisions in Division 1 for allowances that control product selection and for procedures required for processing such selections.

PART 3 - EXECUTION

3.1 INSTALLATION OF PRODUCTS

- A. Comply with manufacturer's instructions and recommendations for installation of products in the applications indicated. Anchor each product securely in place, accurately located and aligned with other Work.
 1. Clean exposed surfaces and protect as necessary to ensure freedom from damage and deterioration at time of Substantial Completion.

END OF SECTION 016000

SECTION 017000 – EXECUTION AND CLOSEOUT REQUIREMENTS

1.1 RELATED SECTIONS

- A. General and Supplementary Conditions.
- B. Section 013300 - Submittal Procedures for closeout documents submittals.
- C. Section 015000 - Construction Facilities and Temporary Controls: Progress cleaning.
- D. Section 017500 - Starting of Systems: System start-up, testing, adjusting, and balancing.

1.2 CLOSEOUT PROCEDURES

- A. Completion of the Work specified herein is a condition precedent to issuance of the Final Certificate of Payment by Construction Manager and Architect.
- B. Submit written certification that Contract Documents have been reviewed, Work has been inspected, and that Work is complete in accordance with Contract Documents and ready for Architect review.
- C. Provide submittals to Architect through Construction Manager that is required by governing or other authorities.
- D. Submit final Application for Payment identifying total adjusted Contract Sum, previous payments, and sum remaining due.
- E. Owner will occupy portions of the site as specified in Section 013100.

1.3 HAZARDOUS-FREE MATERIALS CERTIFICATION

- A. Upon completion of this project, the Contractor shall deliver to the Architect three (3) copies of a notarized letter addressed to the Owner certifying that to the best of the Contractor's knowledge all products provided by them for incorporation into this project do not contain any hazardous materials exceeding current EPA guidelines.
- B. It is the responsibility of the Contractor to review "Manufacturer's Safety Data Sheets" (MSDS) on all products to ascertain compliance with EPA guidelines prior to shop drawing submission to the Architect. Incorporation of products into the project without the submission of shop drawings or samples to the Architect will indicate that the Contractor has ascertained that the products meet EPA limits.
- C. It is the responsibility of the Contractor to notify the Architect in writing of the lack of compliance of a product with EPA guidelines prior to ordering or incorporating any products into this project.

1.4 OPERATION AND MAINTENANCE DATA

- A. Submit data on 8-1/2 x 11 inch text pages, bound in three D side ring binders with durable plastic covers.
- B. Prepare binder cover with printed title "OPERATION AND MAINTENANCE INSTRUCTIONS" and title of Project.

- C. Internally subdivide the binder contents with permanent page dividers, logically organized as described below; with tab titling clearly printed under reinforced laminated plastic tabs.
- D. Contents: Prepare a Table of Contents for each volume, with each Product or system description identified, typed on white paper, in three parts as follows:
1. Part 1: Directory, listing names, addresses, and telephone numbers of Architect/Engineer, Contractor, Subcontractors, and major equipment suppliers. Include for all mechanical and electrical equipment a compilation of the nameplate data for equipment; name, address and phone number of nearest distributor; name, address and phone number of nearest service organization.
 2. Part 2: Operation and maintenance instructions arranged by system and subdivided by specification section. For each category, identify names, addresses, and telephone numbers of Subcontractors and suppliers. Identify the following:
 - a. Significant design criteria.
 - b. List of equipment.
 - c. Parts list for each component.
 - d. Operating instructions.
 - e. Maintenance instructions for equipment and systems.
 - f. Maintenance instructions for finishes, including recommended cleaning methods and materials, and special precautions identifying detrimental agents. Include videotapes of training sessions.
 - g. (1) 8x10 photograph of each piece of equipment.
 - h. Name and telephone number of service representative.
 - i. Test result /reports.
 - j. Certified performance curves.
 - k. Re-order information.
 - l. Catalog, model, serial number.
 - m. Wiring diagrams.
 - n. Assembly drawings.
 - o. Schedule
 - p. Charts
 - q. Nameplate data.
 3. Part 3: Project documents and certificates, including the following:
 - a. Shop drawings and product data.
 - b. Air and water balance reports.
 - c. Certificates.
 - d. Photocopies of warranties and bonds.
- E. Submit 1 draft copy of completed volumes 15 days prior to final inspection. This copy will be reviewed and returned after final inspection, with Architect/Engineer comments. Revise content of all document sets as required prior to final submission.
- F. Submit three copies of revised final volumes, within 10 days after final inspection.

1.5 WARRANTIES

- A. Provide triplicate notarized copies.
- B. Execute and assemble transferable warranty documents from Subcontractors, suppliers, and manufacturers.
- C. Provide Table of Contents and assemble in three D side ring binder with durable plastic cover.
- D. Submit prior to final Application for Payment.
- E. For items of Work delayed beyond date of Substantial Completion, provide updated submittal within 10 days after acceptance, listing date of acceptance as start of warranty period.

1.6 FINAL SUBMISSIONS

- A. Submit Consent of Surety to Final Payment.
- B. Submit evidence of final, continuing insurance coverage complying with insurance requirements.
- C. Submit a certified copy of the Architect's final inspection list of items to be completed or corrected, stating that each item has been completed or otherwise resolved for acceptance and the list has been endorsed and dated by the Architect.
- D. Affidavit of payment of all claims against the work.

1.7 PROJECT RECORD DOCUMENTS

- A. Trade contractors shall maintain on site, one set of the following record documents; record actual revisions to the Work:
 - 1. Drawings.
 - 2. Specifications.
 - 3. Addenda.
 - 4. Change Orders and other modifications to the Contract.
 - 5. Reviewed Shop Drawings, Product Data, and Samples.
 - 6. Manufacturer's instruction for assembly, installation, and adjusting.
- B. Ensure entries are complete and accurate, enabling future reference by Construction Manager and Owner.
- C. Store record documents separate from documents used for construction.
- D. Record information concurrent with construction progress.
- E. Specifications: Legibly mark and record at each Product section description of actual Products installed, including the following:

1. Manufacturer's name and product model and number.
 2. Product substitutions or alternates utilized.
 3. Changes made by Addenda and modifications.
- F. Record Documents and Shop Drawings: Legibly mark each item to record actual construction including:
1. Measured depths of foundations in relation to finish floor.
 2. Measured horizontal and vertical locations of underground utilities and appurtenances, referenced to permanent surface improvements.
 3. Measured locations of internal utilities and appurtenances concealed in construction, referenced to visible and accessible features of the Work.
 4. Field changes of dimension and detail.
 5. Details not on original Contract Drawings.
- G. Remove Architect seal from all documents.
- H. Submit documents to Architect with final Application for Payment.
- I. Submit a final liquidated damages settlement statement.
- 1.8 SPARE PARTS AND MAINTENANCE MATERIALS
- A. Provide products, spare parts, maintenance and extra materials in quantities specified in individual specification sections.
- B. Deliver to Project site and place in location as directed extra materials and parts as indicated within the respective specification sections; obtain receipt from Owner upon delivery and placement and prior to final payment.

END OF SECTION 017000

SECTION 01 73 29 – CUTTING & PATCHING

PART 1 - GENERAL

1.1 RELATED DOCUMENTS

- A. Drawings and general provisions of the Contract, including General and Supplementary Conditions and other Division 01 Specification Sections, apply to this Section.

1.2 SUMMARY

- A. This Section includes procedural requirements for cutting and patching.
- B. Related Sections include the following:
 - 1. Divisions 02 through 07 Sections for specific requirements and limitations applicable to cutting and patching individual parts of the Work.

1.3 DEFINITIONS

- A. Cutting: Removal of in-place construction necessary to permit installation or performance of other Work.
- B. Patching: Fitting and repair work required to restore surfaces to original conditions after installation of other Work.

1.4 QUALITY ASSURANCE

- A. Structural Elements: Do not cut and patch structural elements in a manner that could change their load-carrying capacity or load-deflection ratio.
- B. Operational Elements: Do not cut and patch operating elements and related components in a manner that results in reducing their capacity to perform as intended or that result in increased maintenance or decreased operational life or safety. Operating elements include the following: List below is an example only. Revise to suit Project's operating systems. With advice of counsel, delete below if Architect's approval is not required. If list is deleted, delete option in paragraph above.
 - 1. Fire-suppression systems.
 - 2. Mechanical systems piping and ducts.
 - 3. Control systems.
 - 4. Communication systems.
 - 5. Conveying systems.
 - 6. Electrical wiring systems.

- C. Visual Requirements: Do not cut and patch construction in a manner that results in visual evidence of cutting and patching. Do not cut and patch construction exposed on the exterior or in occupied spaces in a manner that would, in Architect's opinion, reduce the building's aesthetic qualities. Remove and replace construction that has been cut and patched in a visually unsatisfactory manner.
- D. Cutting and Patching Conference: Before proceeding, meet at Project site with parties involved in cutting and patching, including mechanical and electrical trades. Review areas of potential interference and conflict. Coordinate procedures and resolve potential conflicts before proceeding.

PART 2 - PRODUCTS

2.1 MATERIALS

- A. General: Comply with requirements specified in other Sections.
- B. In-Place Materials: Use materials identical to in-place materials. For exposed surfaces, use materials that visually match in-place adjacent surfaces to the fullest extent possible.
 - 1. If identical materials are unavailable or cannot be used, use materials that, when installed, will match the visual and functional performance of in-place materials.

PART 3 - EXECUTION

3.1 EXAMINATION

- A. Examine surfaces to be cut and patched and conditions under which cutting and patching are to be performed.
 - 1. Compatibility: Before patching, verify compatibility with and suitability of substrates, including compatibility with in-place finishes or primers.
 - 2. Proceed with installation only after unsafe or unsatisfactory conditions have been corrected.

3.2 PREPARATION

- A. Temporary Support: Provide temporary support of Work to be cut.
- B. Protection: Protect in-place construction during cutting and patching to prevent damage. Provide protection from adverse weather conditions for portions of Project that might be exposed during cutting and patching operations.
- C. Adjoining Areas: Avoid interference with use of adjoining areas or interruption of free passage to adjoining areas.

- D. Existing Utility Services and Mechanical/Electrical Systems: Where existing services/systems are required to be removed, relocated, or abandoned, bypass such services/systems before cutting to prevent interruption to occupied areas.

3.3 PERFORMANCE

- A. General: Employ skilled workers to perform cutting and patching. Proceed with cutting and patching at the earliest feasible time, and complete without delay.
 - 1. Cut in-place construction to provide for installation of other components or performance of other construction, and subsequently patch as required to restore surfaces to their original condition.
- B. Cutting: Cut in-place construction by sawing, drilling, breaking, chipping, grinding, and similar operations, including excavation, using methods least likely to damage elements retained or adjoining construction. If possible, review proposed procedures with original Installer; comply with original Installer's written recommendations.
 - 1. In general, use hand or small power tools designed for sawing and grinding, not hammering and chopping. Cut holes and slots as small as possible, neatly to size required, and with minimum disturbance of adjacent surfaces. Temporarily cover openings when not in use.
 - 2. Finished Surfaces: Cut or drill from the exposed or finished side into concealed surfaces.
 - 3. Concrete or Masonry: Cut using a cutting machine, such as an abrasive saw or a diamond-core drill.
 - 4. Mechanical and Electrical Services: Cut off pipe or conduit in walls or partitions to be removed. Cap, valve, or plug and seal remaining portion of pipe or conduit to prevent entrance of moisture or other foreign matter after cutting.
 - 5. Proceed with patching after construction operations requiring cutting are complete.
- C. Patching: Patch construction by filling, repairing, refinishing, closing up, and similar operations following performance of other Work. Patch with durable seams that are as invisible as possible. Provide materials and comply with installation requirements specified in other Sections.
 - 1. Inspection: Where feasible, test and inspect patched areas after completion to demonstrate integrity of installation.
 - 2. Exposed Finishes: Restore exposed finishes of patched areas and extend finish restoration into retained adjoining construction in a manner that will eliminate evidence of patching and refinishing.
 - a. Clean piping, conduit, and similar features before applying paint or other finishing materials.
 - b. Restore damaged pipe covering to its original condition.
 - 3. Floors and Walls: Where walls or partitions that are removed extend one finished area into another, patch and repair floor and wall surfaces in the new space. Provide an even surface of uniform finish, color, texture, and appearance. Remove in-place floor and wall coverings and replace with new materials, if necessary, to achieve uniform color and appearance.

- a. Where patching occurs in a painted surface, apply primer and intermediate paint coats over the patch and apply final paint coat over entire unbroken surface containing the patch. Provide additional coats until patch blends with adjacent surfaces.
- 4. Ceilings: Patch, repair, or rehang in-place ceilings as necessary to provide an even-plane surface of uniform appearance.
- 5. Exterior Building Enclosure: Patch components in a manner that restores enclosure to a weathertight condition.
- D. Cleaning: Clean areas and spaces where cutting and patching are performed. Completely remove paint, mortar, oils, putty, and similar materials.

END OF SECTION 01 73 29

NOT FOR BIDDING

#

SECTION 01 74 19 – CONSTRUCTION WASTE MANAGEMENT AND DISPOSAL

PART 1 – GENERAL

1.1 SUMMARY

- A. Section includes: Administrative and procedural requirements for construction waste management activities.

1.2 DEFINITIONS

- A. Construction, Demolition, and Land clearing (CDL) Waste: Includes all non-hazardous solid wastes resulting from construction, remodeling, alterations, repair, demolition and land clearing. Includes material that is recycled, reused, salvaged or disposed as garbage.
- B. Salvage: Recovery of materials for on-site reuse, sale or donation to a third party.
- C. Reuse: Making use of a material without altering its form. Materials can be reused on-site or reused on other projects off-site. Examples include, but are not limited to the following: Crushing or grinding of concrete for use as sub-base material. Chipping of land clearing debris for use as mulch.
- D. Recycling: The process of sorting, cleaning, treating, and reconstituting materials for the purpose of using the material in the manufacture of a new product.
- E. Source-Separated CDL Recycling: The process of separating recyclable materials in separate containers as they are generated on the job-site. The separated materials are hauled directly to a recycling facility or transfer station.
- F. Co-mingled CDL Recycling: The process of collecting mixed recyclable materials in one container on-site. The container is taken to a material recovery facility where materials are separated for recycling.
- G. Approved Recycling Facility: Any of the following:
 - 1. A facility that can legally accept CDL waste materials for the purpose of processing the materials into an altered form for the manufacture of a new product.
 - 2. Material Recovery Facility: A general term used to describe a waste-sorting facility. Mechanical, hand-separation, or a combination of both procedures, are used to recover recyclable materials.

1.3 SUBMITTALS

- A. Contractor shall develop a Waste Management Plan: Submit 3 copies of plan within 14 days of date established for the **Notice to Proceed**.
- B. Contractor shall provide Waste Management Report: Concurrent with each Application for Payment, submit 3 copies of report.

#

1.4 PERFORMANCE REQUIREMENTS

- A. General: Divert a minimum of **75%** CDL waste, by weight, from the landfill by one, or a combination of the following activities:
1. Salvage
 2. Reuse
 3. Source-Separated CDL Recycling
 4. Co-mingled CDL Recycling
- B. CDL waste materials that can be salvaged, reused or recycled include, but are not limited to, the following:
1. Acoustical ceiling tiles
 2. Asphalt
 3. Asphalt shingles
 4. Cardboard packaging
 5. Carpet and carpet pad
 6. Concrete
 7. Drywall
 8. Fluorescent lights and ballasts
 9. Land clearing debris (vegetation, stumpage, dirt)
 10. Metals
 11. Paint (through hazardous waste outlets)
 12. Wood
 13. Plastic film (sheeting, shrink wrap, packaging)
 14. Window glass
 15. Wood
 16. Field office waste, including office paper, aluminum cans, glass, plastic, and office cardboard.

1.4 QUALITY ASSURANCE

- A. Waste Management Coordinator Qualifications: Experienced firm, with a record of successful waste management coordination of projects with similar requirements, that employs a LEED Accredited Professional, certified by the USGBC as waste management coordinator.
- B. Regulatory Requirements: Conduct construction waste management activities in accordance with hauling and disposal regulations of all authorities having jurisdiction and all other applicable laws and ordinances.
- C. Preconstruction Conference: Schedule and conduct meeting at Project site prior to construction activities.
1. Attendees: Inform the following individuals, whose presence is required, of date and time of meeting.
 - a. Owner
 - b. Architect

#

- c. Contractor's superintendent
 - d. Major subcontractors
 - e. Waste Management Coordinator
 - f. Other concerned parties.
 - 2. Agenda Items: Review methods and procedures related to waste management including, but not limited to, the following:
 - a. Review and discuss waste management plan including responsibilities of Waste Management Coordinator.
 - b. Review requirements for documenting quantities of each type of waste and its disposition.
 - c. Review and finalize procedures for materials separation and verify availability of containers and bins needed to avoid delays.
 - d. Review procedures for periodic waste collection and transportation to recycling and disposal facilities.
 - e. Review waste management requirements for each trade.
 - 3. Minutes: Record discussion. Distribute meeting minutes to all participants.
Note: If there is a Project Architect, they will perform this role.
- 1.5 WASTE MANAGEMENT PLAN – Contractor shall develop and document the following:
- A. Develop a plan to meet the requirements listed in this section at a minimum. Plan shall consist of waste identification, waste reduction plan and cost/revenue analysis. Distinguish between demolition and construction waste. Indicate quantities by weight throughout the plan.
 - B. Indicate anticipated types and quantities of demolition, site-cleaning and construction waste generated by the project. List all assumptions made for the quantities estimates.
 - C. List each type of waste and whether it will be salvaged, recycled, or disposed of in an landfill. The plan should included the following information:
 - 1. Types and estimated quantities, by weight, of CDL waste expected to be generated during demolition and construction.
 - 2. Proposed methods for CDL waste salvage, reuse, recycling and disposal during demolition including, but not limited to, one or more of the following:
 - a. Contracting with a deconstruction specialist to salvage materials generated,
 - b. Selective salvage as part of demolition contractor's work,
 - c. Reuse of materials on-site or sale or donation to a third party.
 - 3. Proposed methods for salvage, reuse, recycling and disposal during construction including, but not limited to, one or more of the following:
 - a. Requiring subcontractors to take their CDL waste to a recycling facility;
 - b. Contracting with a recycling hauler to haul recyclable CDL waste to an approved recycling or material recovery facility;
 - c. Processing and reusing materials on-site;

#

- d. Self-hauling to a recycling or material recovery facility.
4. Name of recycling or material recovery facility receiving the CDL wastes.
5. Handling and Transportation Procedures: Include method that will be used for separating recyclable waste including sizes of containers, container labeling, and designated location on project site where materials separation will be located.
- D. Cost/Revenue Analysis: Indicate total cost of waste disposal as if there was no waste management plan and net additional cost or net savings resulting from implementing waste management plan. Include the following:
 1. Total quantity of waste.
 2. Estimated cost of disposal (cost per unit). Include hauling and tipping fees and cost of collection containers for each type of waste.
 3. Total cost of disposal (with no waste management).
 4. Revenue from salvaged materials.
 5. Revenue from recycled materials.
 6. Savings in hauling and tipping fees by donating materials.
 7. Savings in hauling and tipping fees that are avoided.
 8. Handling and transportation costs. Including cost of collection containers for each type of waste.
 9. Net additional cost or net savings from waste management plan.

PART 2 - PRODUCTS (Not Used)

PART 3 – EXECUTION

3.1 CONSTRUCTION WASTE MANAGEMENT, GENERAL

- A. Provide containers for CDL waste that is to be recycled clearly labeled as such with a list of acceptable and unacceptable materials. The list of acceptable materials must be the same as the materials recycled at the receiving material recovery facility or recycling processor.
- B. The collection containers for recyclable CDL waste must contain no more than 10% non-recyclable material, by volume.
- C. Provide containers for CDL waste that is disposed in a landfill clearly labeled as such.
- D. Use detailed material estimates to reduce risk of unplanned and potentially wasteful cuts.
- E. To the greatest extent possible, include in material purchasing agreements a waste reduction provision requesting that materials and equipment be delivered in packaging made of recyclable material, that they reduce the amount of packaging, that packaging be taken back for reuse or recycling, and to take back all unused product. Insure that subcontractors require the same provisions in their purchase agreements.
- F. Conduct regular visual inspections of dumpsters and recycling bins to remove contaminants.

3.2 SOURCE SEPARATION

- A. General: Contractor shall separate recyclable materials from CDL waste to the maximum

#

extent possible.

Separate recyclable materials by type.

1. Provide containers, clearly labeled, by type of separated materials or provide other storage method for managing recyclable materials until they are removed from Project site.
2. Stockpile processed materials on-site without intermixing with other materials. Place, grade, and shape stockpiles to drain surface water and to minimize pest attraction. Cover to prevent windblown dust.
3. Stockpile materials away from demolition area. Do not store within drip line of remaining trees.
4. Store components off the ground and protect from weather.

3.3 CO-MINGLED RECYCLING

- A. General: Do not put CDL waste that will be disposed in a landfill into a co-mingled CDL waste recycling container.

REMOVAL OF CONSTRUCTION WASTE MATERIALS

- A. Remove CDL waste materials from project site on a regular basis. Do not allow CDL waste to accumulate on-site.
- B. Transport CDL waste materials off Owner's property and legally dispose of them.
- C. Burning of CDL waste is not permitted.

END OF SECTION

#

WASTE MANAGEMENT PROGRESS REPORT				
MATERIAL CATEGORY	DISPOSED IN MUNICIPAL SOLID WASTE LANDFILL	DIVERTED FROM LANDFILL BY RECYCLING, SALVAGE OR REUSE		
		Recycled	Salvaged	Reused
1. Acoustical Ceiling Tiles				
2. Asphalt				
3. Asphalt Shingles				
4. Cardboard Packaging				
5. Carpet and Carpet Pad				
6. Concrete				
7. Drywall				
8. Fluorescent Lights and Ballasts				
9. Land Clearing Debris (vegetation, stumpage, dirt)				
10. Metals				
11. Paint (through hazardous waste outlets)				
12. Wood				
13. Plastic Film (sheeting, shrink wrap, packaging)				
14. Window Glass				
15. Field Office Waste (office paper, aluminum cans, glass, plastic, and coffee cardboard)				
16. Other (insert description)				
17. Other (insert description)				
Total (In Weight)		(TOTAL OF ALL ABOVE VALUES – IN WEIGHT)		
		Percentage of Waste Diverted	(TOTAL WASTE DIVIDED BY TOTAL DIVERTED)	

SECTION 017700 - CLOSEOUT PROCEDURES

PART 1 - GENERAL

1.1 RELATED DOCUMENTS

- A. Drawings and general provisions of the Contract, including General and Supplementary Conditions and other Division 1 Specification Sections, apply to this Section.

1.2 SUMMARY

- A. This Section includes administrative and procedural requirements for contract closeout, including, but not limited to, the following:
 - 1. Inspection procedures.
 - 2. Project Record Documents.
 - 3. Operation and maintenance manuals.
 - 4. Warranties.
 - 5. Instruction of Owner's personnel.
 - 6. Final cleaning.
- B. Related Sections include the following:
 - 1. Division 1 Section "Payment Procedures" for requirements for Applications for Payment for Substantial and Final Completion.
 - 2. Division 1 Section "Execution Requirements" for progress cleaning of Project site.
 - 3. Divisions 2 through 33 Sections for specific closeout and special cleaning requirements for products of those Sections.

1.3 SUBSTANTIAL COMPLETION

- A. Preliminary Procedure: Before requesting inspection for determining date of Substantial Completion, complete the following. List items below that are incomplete in request.
 - 1. Prepare a list of items to be completed and corrected (punch list), the value of items on the list, and reasons why the Work is not complete.
 - 2. Advise Owner of pending insurance changeover requirements.
 - 3. Submit specific warranties, workmanship bonds, maintenance service agreements, final certifications, and similar documents.
 - 4. Obtain and submit releases permitting Owner unrestricted use of the Work and access to services and utilities. Include occupancy permits, operating certificates, and similar releases.
 - 5. Deliver tools, spare parts, extra materials, and similar items to location designated by Owner. Label with manufacturer's name and model number where applicable.
 - 6. Make final changeover of permanent locks and deliver keys to Owner. Advise Owner's personnel of changeover in security provisions.
 - 7. Complete startup testing of systems.
 - 8. Submit test/adjust/balance records.
 - 9. Terminate and remove temporary facilities from Project site, along with mockups, construction tools, and similar elements.
 - 10. Advise Owner of changeover in heat and other utilities.

11. Submit changeover information related to Owner's occupancy, use, operation, and maintenance.
12. Complete final cleaning requirements, including touchup painting.
13. Touch up and otherwise repair and restore marred exposed finishes to eliminate visual defects.

B. Inspection: Submit a written request for inspection for Substantial Completion. On receipt of request, Architect will either proceed with inspection or notify Contractor of unfulfilled requirements. Architect will prepare the Certificate of Substantial Completion after inspection or will notify Contractor of items, either on Contractor's list or on additional items identified by Architect, that must be completed or corrected before certificate will be issued.

1. Reinspection: Request reinspection when the Work identified in previous inspections as incomplete is completed or corrected.
2. Results of completed inspection will form the basis of requirements for Final Completion.

1.4 FINAL COMPLETION

A. Preliminary Procedures: Before requesting final inspection for determining date of Final Completion, complete the following:

1. Submit a final Application for Payment according to Division 1 Section "Payment Procedures."
2. Submit certified copy of Architect's Substantial Completion inspection list of items to be completed or corrected (punch list), endorsed and dated by Architect. The certified copy of the list shall state that each item has been completed or otherwise resolved for acceptance.
3. Submit evidence of final, continuing insurance coverage complying with insurance requirements.
4. Submit pest-control final inspection report and warranty.
5. Instruct Owner's personnel in operation, adjustment, and maintenance of products, equipment, and systems.

B. Inspection: Submit a written request for final inspection for acceptance. On receipt of request, Architect will either proceed with inspection or notify Contractor of unfulfilled requirements. Architect will prepare a final Certificate for Payment after inspection or will notify Contractor of construction that must be completed or corrected before certificate will be issued.

1. Reinspection: Request reinspection when the Work identified in previous inspections as incomplete is completed or corrected.

1.5 LIST OF INCOMPLETE ITEMS (PUNCH LIST)

A. Preparation: Submit three copies of list. Include name and identification of each space and area affected by construction operations for incomplete items and items needing correction including, if necessary, areas disturbed by Contractor that are outside the limits of construction.

1. Organize list of spaces in sequential order, starting with exterior areas first and proceeding from lowest floor to highest floor.

2. Organize items applying to each space by major element, including categories for ceiling, individual walls, floors, equipment, and building systems.
3. Include the following information at the top of each page:
 - a. Project name.
 - b. Date.
 - c. Name of Architect.
 - d. Name of Contractor.
 - e. Page number.
4. Include space for sign off and acceptance of each item.

1.6 PROJECT RECORD DOCUMENTS

- A. General: Do not use Project Record Documents for construction purposes. Protect Project Record Documents from deterioration and loss. Provide access to Project Record Documents for Architect and Owner's reference during normal working hours.
- B. Record Drawings: Maintain and submit one set of blue- or black-line white prints of Contract Drawings and Shop Drawings.
 1. Mark Record Prints to show the actual installation where installation varies from that shown originally. Require individual or entity who obtained record data, whether individual or entity is Installer, subcontractor, or similar entity, to prepare the marked-up Record Prints.
 - a. Give particular attention to information on concealed elements that cannot be readily identified and recorded later.
 - b. Accurately record information in an understandable drawing technique.
 - c. Record data as soon as possible after obtaining it. Record and check the markup before enclosing concealed installations.
 - d. Mark Contract Drawings or Shop Drawings, whichever is most capable of showing actual physical conditions, completely and accurately. Where Shop Drawings are marked, show cross-reference on Contract Drawings.
 2. Mark record sets with erasable, red-colored pencil. Use other colors to distinguish between changes for different categories of the Work at the same location.
 3. Mark important additional information that was either shown schematically or omitted from original Drawings.
 4. Note Construction Change Directive numbers, Change Order numbers, alternate numbers, and similar identification where applicable.
 5. Identify and date each Record Drawing; include the designation "PROJECT RECORD DRAWING" in a prominent location. Organize into manageable sets; bind each set with durable paper cover sheets. Include identification on cover sheets.
- C. Record Specifications: Submit one copy of Project's Specifications, including addenda and contract modifications. Mark copy to indicate the actual product installation where installation varies from that indicated in Specifications, addenda, and contract modifications.
 1. Give particular attention to information on concealed products and installations that cannot be readily identified and recorded later.

2. Mark copy with the proprietary name and model number of products, materials, and equipment furnished, including substitutions and product options selected.
 3. Note related Change Orders, Record Drawings, and Product Data, where applicable.
- D. Record Product Data: Submit one copy of each Product Data submittal. Mark one (1) set to indicate the actual product installation where installation varies substantially from that indicated in Product Data.
1. Give particular attention to information on concealed products and installations that cannot be readily identified and recorded later.
 2. Include significant changes in the product delivered to Project site and changes in manufacturer's written instructions for installation.
 3. Note related Change Orders, Record Drawings, and Record Specifications, where applicable.
- E. Miscellaneous Record Submittals: Assemble miscellaneous records required by other Specification Sections for miscellaneous record keeping and submittal in connection with actual performance of the Work. Bind or file miscellaneous records and identify each, ready for continued use and reference.

1.7 OPERATION AND MAINTENANCE MANUALS

- A. Assemble a complete set of operation and maintenance data indicating the operation and maintenance of each system, subsystem, and piece of equipment not part of a system. Include operation and maintenance data required in individual Specification Sections and as follows:
1. Operation Data:
 - a. Emergency instructions and procedures.
 - b. System, subsystem, and equipment descriptions, including operating standards.
 - c. Operating procedures, including startup, shutdown, seasonal, and weekend operation.
 - d. Description of controls and sequence of operations.
 - e. Piping diagrams.
 2. Maintenance Data:
 - a. Manufacturer's information, including list of spare parts.
 - b. Name, address, and telephone number of Installer or supplier.
 - c. Maintenance procedures.
 - d. Maintenance and service schedules for preventive and routine maintenance.
 - e. Maintenance record forms.
 - f. Sources of spare parts and maintenance materials.
 - g. Copies of maintenance service agreements.
 - h. Copies of warranties and bonds.
- B. Organize operation and maintenance manuals into suitable sets of manageable size. Bind and index data in heavy-duty, 3-ring, vinyl-covered, loose-leaf binders, in thickness necessary to accommodate contents, with pocket inside the covers to receive folded oversized sheets. Identify each binder on front and spine with the printed title "OPERATION AND MAINTENANCE MANUAL," Project name, and subject matter of contents.

1.8 WARRANTIES

- A. Submittal Time: Submit written warranties on request of Architect for designated portions of the Work where commencement of warranties other than date of Substantial Completion is indicated.
- B. Partial Occupancy: Submit properly executed warranties within 15 days of completion of designated portions of the Work that are completed and occupied or used by Owner during construction period by separate agreement with Contractor.
- C. Organize warranty documents into an orderly sequence based on the table of contents of the Project Manual.
 - 1. Bind warranties and bonds in heavy-duty, 3-ring, vinyl-covered, loose-leaf binders, thickness as necessary to accommodate contents, and sized to receive 8-1/2-by-11-inch (115-by-280-mm) paper.
 - 2. Provide heavy paper dividers with plastic-covered tabs for each separate warranty. Mark tab to identify the product or installation. Provide a typed description of the product or installation, including the name of the product and the name, address, and telephone number of Installer.
 - 3. Identify each binder on the front and spine with the typed or printed title "WARRANTIES," Project name, and name of Contractor.
- D. Provide additional copies of each warranty to include in operation and maintenance manuals.

PART 2 - PRODUCTS

2.1 MATERIALS

- A. Cleaning Agents: Use cleaning materials and agents recommended by manufacturer or fabricator of the surface to be cleaned. Do not use cleaning agents that are potentially hazardous to health or property or that might damage finished surfaces.

PART 3 - EXECUTION

3.1 DEMONSTRATION AND TRAINING

- A. Instruction: Instruct Owner's personnel to adjust, operate, and maintain systems, subsystems, and equipment not part of a system.
 - 1. Provide instructors experienced in operation and maintenance procedures.
 - 2. Provide instruction at mutually agreed-on times. For equipment that requires seasonal operation, provide similar instruction at the start of each season.
 - 3. Schedule training with Owner, through Architect, with at least seven days' advance notice.
 - 4. Coordinate instructors, including providing notification of dates, times, length of instruction, and course content.

- B. Program Structure: Develop an instruction program that includes individual training modules for each system and equipment not part of a system, as required by individual Specification Sections. For each training module, develop a learning objective and teaching outline. Include instruction for the following:

1. System design and operational philosophy.
2. Review of documentation.
3. Operations.
4. Adjustments.
5. Troubleshooting.
6. Maintenance.
7. Repair.

3.2 FINAL CLEANING

- A. General: Provide final cleaning. Conduct cleaning and waste-removal operations to comply with local laws and ordinances and Federal and local environmental and antipollution regulations.
- B. Cleaning: Employ experienced workers or professional cleaners for final cleaning. Clean each surface or unit to condition expected in an average commercial building cleaning and maintenance program. Comply with manufacturer's written instructions.
1. Complete the following cleaning operations before requesting inspection for certification of Substantial Completion for entire Project or for a portion of Project:
 - a. Clean Project site, yard, and grounds, in areas disturbed by construction activities, including landscape development areas, of rubbish, waste material, litter, and other foreign substances. Cut lawn and field areas.
 - b. Sweep paved areas broom clean. Remove petrochemical spills, stains, and other foreign deposits.
 - c. Rake grounds that are neither planted nor paved to a smooth, even-textured surface.
 - d. Remove tools, construction equipment, machinery, and surplus material from Project site.
 - e. Remove snow and ice to provide safe access to building.
 - f. Clean exposed exterior and interior hard-surfaced finishes to a dirt-free condition, free of stains, films, and similar foreign substances. Avoid disturbing natural weathering of exterior surfaces. Restore reflective surfaces to their original condition.
 - g. Remove debris and surface dust from limited access spaces, including roofs, plenums, shafts, trenches, equipment vaults, manholes, attics, and similar spaces.
 - h. Sweep concrete floors broom clean in unoccupied spaces.
 - i. Vacuum carpet and similar soft surfaces, removing debris and excess nap; shampoo if visible soil or stains remain.
 - j. Clean transparent materials, including mirrors and glass in doors and windows. Remove glazing compounds and other noticeable, vision-obscuring materials. Replace chipped or broken glass and other damaged transparent materials. Polish mirrors and glass, taking care not to scratch surfaces.
 - k. Remove labels that are not permanent.

- l. Touch up and otherwise repair and restore marred, exposed finishes and surfaces. Replace finishes and surfaces that cannot be satisfactorily repaired or restored or that already show evidence of repair or restoration.
 - 1) Do not paint over "UL" and similar labels, including mechanical and electrical nameplates.
 - m. Wipe surfaces of mechanical and electrical equipment, elevator equipment, and similar equipment. Remove excess lubrication, paint and mortar droppings, and other foreign substances.
 - n. Replace parts subject to unusual operating conditions.
 - o. Clean plumbing fixtures to a sanitary condition, free of stains, including stains resulting from water exposure.
 - p. Replace disposable air filters and clean permanent air filters. Clean exposed surfaces of diffusers, registers, and grills.
 - q. Clean ducts, blowers, and coils if units were operated without filters during construction.
 - r. Clean light fixtures, lamps, globes, and reflectors to function with full efficiency. Replace burned-out bulbs, and those noticeably dimmed by hours of use, and defective and noisy starters in fluorescent and mercury vapor fixtures to comply with requirements for new fixtures.
 - s. Leave Project clean and ready for occupancy.
- C. Pest Control: Engage an experienced, licensed exterminator to make a final inspection and rid Project of rodents, insects, and other pests. Prepare a report.
- D. Comply with safety standards for cleaning. Do not burn waste materials. Do not bury debris or excess materials on Owner's property. Do not discharge volatile, harmful, or dangerous materials into drainage systems. Remove waste materials from Project site and dispose of lawfully.

END OF SECTION 017700

SECTION 017836 - WARRANTIES

PART 1 - GENERAL

1.1 RELATED DOCUMENTS

- A. Drawings and general provisions of the Contract, including General and Supplementary Conditions and other Division 1 Specification Sections, apply to this Section.

1.2 SUMMARY

- A. This Section includes administrative and procedural requirements for warranties required by the Contract Documents, including manufacturer's standard warranties on products and special warranties.
 - 1. Refer to the General Conditions for terms of the Contractor's period for correction of the Work.
- B. Related Sections: The following Sections contain requirements that relate to this Section:
 - 1. Division 1 Section "Submittals" specifies procedures for submitting warranties.
 - 2. Division 1 Section "Contract Closeout" specifies contract closeout procedures.
 - 3. Divisions 2 through 16 Sections for specific requirements for warranties on products and installations specified to be warranted.
 - 4. Certifications and other commitments and agreements for continuing services to Owner are specified elsewhere in the Contract Documents.
- C. Disclaimers and Limitations: Manufacturer's disclaimers and limitations on product warranties do not relieve the Contractor of the warranty on the work that incorporates the products. Manufacturer's disclaimers and limitations on product warranties do not relieve suppliers, manufacturers, and subcontractors required to countersign special warranties with the Contractor.
- D. Separate Prime Contracts: Each prime contractor is responsible for warranties related to its own contract.

1.3 DEFINITIONS

- A. Standard product warranties are preprinted written warranties published by individual manufacturers for particular products and are specifically endorsed by the manufacturer to the Owner.
- B. Special warranties are written warranties required by or incorporated in the Contract Documents, either to extend time limits provided by standard warranties or to provide greater rights for the Owner.

1.4 WARRANTY REQUIREMENTS

- A. Related Damages and Losses: When correcting failed or damaged warranted construction, remove and replace construction that has been damaged as a result of such failure or must be removed and replaced to provide access for correction of warranted construction.
- B. Reinstatement of Warranty: When Work covered by a warranty has failed and been corrected by

replacement or rebuilding, reinstate the warranty by written endorsement. The reinstated warranty shall be equal to the original warranty with an equitable adjustment for depreciation.

- C. **Replacement Cost:** Upon determination that Work covered by a warranty has failed, replace or rebuild the Work to an acceptable condition complying with requirements of the Contract Documents. The Contractor is responsible for the cost of replacing or rebuilding defective Work regardless of whether the Owner has benefited from use of the Work through a portion of its anticipated useful service life.
- D. **Owner's Recourse:** Expressed warranties made to the Owner are in addition to implied warranties and shall not limit the duties, obligations, rights, and remedies otherwise available under the law. Expressed warranty periods shall not be interpreted as limitations on the time in which the Owner can enforce such other duties, obligations, rights, or remedies.
 - 1. **Rejection of Warranties:** The Owner reserves the right to reject warranties and to limit selection to products with warranties not in conflict with requirements of the Contract Documents.
- E. Where the Contract Documents require a special warranty, or similar commitment on the Work or part of the Work, the Owner reserves the right to refuse to accept the Work, until the Contractor presents evidence that entities required to countersign such commitments are willing to do so.

1.5 SUBMITTALS

- A. Submit written warranties to the Architect prior to the date certified for Substantial Completion. If the Architect's Certificate of Substantial Completion designates a commencement date for warranties other than the date of Substantial Completion for the Work, or a designated portion of the Work, submit written warranties upon request of the Architect.
 - 1. When a designated portion of the Work is completed and occupied or used by the Owner, by separate agreement with the Contractor during the construction period, submit properly executed warranties to the Architect within 15 days of completion of that designated portion of the Work.
- B. When the Contract Documents require the Contractor, or the Contractor and a subcontractor, supplier or manufacturer to execute a special warranty, prepare a written document that contains appropriate terms and identification, ready for execution by the required parties. Submit a draft to the Owner, through the Architect, for approval prior to final execution.
- C. Forms for special warranties are included at the end of this Section. Prepare a written document utilizing the appropriate form, ready for execution by the Contractor, or by the Contractor, subcontractor, supplier, or manufacturer. Submit a draft to the Owner, through the Architect, for approval prior to final execution.
 - 1. Refer to Divisions 2 through 16 Sections for specific content requirements and particular requirements for submitting special warranties.
- D. **Form of Submittal:** At Final Completion compile 2 copies of each required warranty properly executed by the Contractor, or by the Contractor, subcontractor, supplier, or manufacturer. Organize the warranty documents into an orderly sequence based on the table of contents of the Project

Manual.

- E. Bind warranties and bonds in heavy-duty, commercial-quality, durable 3-ring, vinyl-covered loose-leaf binders, thickness as necessary to accommodate contents, and sized to receive 8-1/2-by-11-inch (115-by-280-mm) paper.
1. Provide heavy paper dividers with celluloid covered tabs for each separate warranty. Mark the tab to identify the product or installation. Provide a typed description of the product or installation, including the name of the product, and the name, address, and telephone number of the Installer.
 2. Identify each binder on the front and spine with the typed or printed title "WARRANTIES," Project title or name, and name of the Contractor.
 3. When warranted construction requires operation and maintenance manuals, provide additional copies of each required warranty, as necessary, for inclusion in each required manual.

PART 2 - PRODUCTS (Not Applicable)

PART 3 - EXECUTION

3.1 LIST OF WARRANTIES

- A. Schedule: Provide warranties on products and installations as specified in individual specification sections.

END OF SECTION 017836

SECTION 02 41 19 - SELECTIVE DEMOLITION

PART 1 - GENERAL

1.1 RELATED DOCUMENTS

- A. Drawings and general provisions of the Contract, including General and Supplementary Conditions and Division 01 Specification Sections, apply to this Section.

1.2 SUMMARY

A. Section Includes:

- 1. Demolition and removal of selected portions of building or structure.
- 2. Demolition and removal of selected site elements.
- 3. Salvage of existing items to be reused or recycled

B. Related Requirements:

- 1. Section 011000 "Summary" for restrictions on the use of the premises, Owner-occupancy requirements, and phasing requirements.
- 2. Section 017300 "Execution" for cutting and patching procedures.
- 3. Section 311000 "Site Clearing" for additional Site Demolition / Work

1.3 DEFINITIONS

- A. Remove: Detach items from existing construction and legally dispose of them off-site unless indicated to be removed and salvaged or removed and reinstalled.
- B. Remove and Salvage: Carefully detach from existing construction, in a manner to prevent damage, and deliver to Owner.
- C. Remove and Reinstall: Detach items from existing construction, prepare for reuse, and reinstall where indicated.
- D. Existing to Remain: Existing items of construction that are not to be permanently removed and that are not otherwise indicated to be removed, removed and salvaged, or removed and reinstalled.

1.4 MATERIALS OWNERSHIP

- A. Unless otherwise indicated, demolition waste becomes property of Contractor.
- B. Historic items, relics, antiques, and similar objects including, but not limited to, cornerstones and their contents, commemorative plaques and tablets, and other items of interest or value to Owner that may be uncovered during demolition remain the property of Owner.

1. Carefully salvage in a manner to prevent damage and promptly return to Owner.

1.5 PREINSTALLATION MEETINGS

- A. Pre-demolition Conference: Conduct conference at Project site.
 1. Inspect and discuss condition of construction to be selectively demolished.
 2. Review structural load limitations of existing structure.
 3. Review and finalize selective demolition schedule and verify availability of materials, demolition personnel, equipment, and facilities needed to make progress and avoid delays.
 4. Review requirements of work performed by other trades that rely on substrates exposed by selective demolition operations.
 5. Review areas where existing construction is to remain and requires protection.

1.6 INFORMATIONAL SUBMITTALS

- A. Qualification Data: For refrigerant recovery technician.
- B. Proposed Protection Measures: Submit report, including drawings, that indicates the measures proposed for protecting individuals and property, for environmental protection, for dust control and , for noise control. Indicate proposed locations and construction of barriers.
- C. Schedule of Selective Demolition Activities: Indicate the following:
 1. Detailed sequence of selective demolition and removal work, with starting and ending dates for each activity. Ensure Owner's on-site operations are uninterrupted.
 2. Interruption of utility services. Indicate how long utility services will be interrupted.
 3. Coordination for shutoff, capping, and continuation of utility services.
 4. Use of elevator and stairs.
 5. Coordination of Owner's continuing occupancy of portions of existing building and of Owner's partial occupancy of completed Work.
- D. Inventory: Submit a list of items to be removed and salvaged and deliver to Owner prior to start of demolition.
- E. Pre-demolition Photographs or Video: Submit before Work begins.
- F. Statement of Refrigerant Recovery: Signed by refrigerant recovery technician responsible for recovering refrigerant, stating that all refrigerant that was present was recovered and that recovery was performed according to EPA regulations. Include name and address of technician and date refrigerant was recovered.
- G. Warranties: Documentation indicated that existing warranties are still in effect after completion of selective demolition.

1.7 CLOSEOUT SUBMITTALS

- A. Inventory: Submit a list of items that have been removed and salvaged.
- B. Landfill Records: Indicate receipt and acceptance of hazardous wastes by a landfill facility licensed to accept hazardous wastes.

1.8 QUALITY ASSURANCE

- A. Refrigerant Recovery Technician Qualifications: Certified by an EPA-approved certification program.

1.9 FIELD CONDITIONS

- A. Conditions existing at time of inspection for bidding purpose will be maintained by Owner as far as practical.
 - 1. Before selective demolition, Owner will remove the following items:
 - a. Furniture and Equipment.
- B. Notify Architect of discrepancies between existing conditions and Drawings before proceeding with selective demolition.
- C. Hazardous Materials: It is not expected that hazardous materials will be encountered in the Work.
 - 1. Hazardous materials will be removed by Owner before start of the Work.
 - 2. If suspected hazardous materials are encountered, do not disturb; immediately notify Architect and Owner. Hazardous materials will be removed by Owner under a separate contract.
- D. Storage or sale of removed items or materials on-site is not permitted.
- E. Utility Service: Maintain existing utilities indicated to remain in service and protect them against damage during selective demolition operations.
 - 1. Maintain fire-protection facilities in service during selective demolition operations.

1.10 WARRANTY

- A. Existing Warranties: Remove, replace, patch, and repair materials and surfaces cut or damaged during selective demolition, by methods and with materials so as not to void existing warranties. Notify warrantor before proceeding
- B. Notify warrantor on completion of selective demolition, and obtain documentation verifying that existing system has been inspected and warranty remains in effect. Submit documentation at Project closeout.

PART 2 - PRODUCTS

2.1 PEFORMANCE REQUIREMENTS

- A. Regulatory Requirements: Comply with governing EPA notification regulations before beginning selective demolition. Comply with hauling and disposal regulations of authorities having jurisdiction.
- B. Standards: Comply with ANSI/ASSE A10.6 and NFPA 241.

PART 3 - EXECUTION

3.1 EXAMINATION

- A. Verify that utilities have been disconnected and capped before starting selective demolition operations.
- B. Review record documents of existing construction provided by Owner. Owner does not guarantee that existing conditions are same as those indicated in record documents.
- C. Survey existing conditions and correlate with requirements indicated to determine extent of selective demolition required.
- D. When unanticipated mechanical, electrical, or structural elements that conflict with intended function or design are encountered, investigate and measure the nature and extent of conflict. Promptly submit a written report to Architect.
- E. Survey of Existing Conditions: Record existing conditions by use of measured drawing.
 - 1. Comply with requirements specified in Section 013233 "Photographic Documentation."
 - 2. Inventory and record the condition of items to be removed and salvaged. Provide photographs of conditions that might be misconstrued as damage caused by salvage operations.
 - 3. Before selective demolition or removal of existing building elements that will be reproduced or duplicated in final Work, make permanent record of measurements, materials, and construction details required to make exact reproduction.

3.2 UTILITY SERVICES AND MECHANICAL/ELECTRICAL SYSTEMS

- A. Existing Services/Systems to Remain: Maintain services/systems indicated to remain and protect them against damage.
 - 1. Comply with requirements for existing services/systems interruptions specified in Section 011000 "Summary."
- B. Existing Services/Systems to Be Removed, Relocated, or Abandoned: Locate, identify, disconnect, and seal or cap off indicated utility services and mechanical/electrical systems serving areas to be selectively demolished.

1. Owner will arrange to shut off indicated services/systems when requested by Contractor.
2. If services/systems are required to be removed, relocated, or abandoned, provide temporary services/systems that bypass area of selective demolition and that maintain continuity of services/systems to other parts of building.
3. Disconnect, demolish, and remove fire-suppression systems, plumbing, and HVAC systems, equipment, and components indicated to be removed.
 - a. Piping to Be Removed: Remove portion of piping indicated to be removed and cap or plug remaining piping with same or compatible piping material.
 - b. Piping to Be Abandoned in Place: Drain piping and cap or plug piping with same or compatible piping material.
 - c. Equipment to Be Removed: Disconnect and cap services and remove equipment.
 - d. Equipment to Be Removed and Reinstalled: Disconnect and cap services and remove, clean, and store equipment; when appropriate, reinstall, reconnect, and make equipment operational.
 - e. Equipment to Be Removed and Salvaged: Disconnect and cap services and remove equipment and deliver to Owner.
 - f. Ducts to Be Removed: Remove portion of ducts indicated to be removed and plug remaining ducts with same or compatible ductwork material.
 - g. Ducts to Be Abandoned in Place: Cap or plug ducts with same or compatible ductwork material.
- C. Refrigerant: Remove refrigerant from mechanical equipment to be selectively demolished according to 40 CFR 82 and regulations of authorities having jurisdiction.

3.3 PREPARATION

- A. Site Access and Temporary Controls: Conduct selective demolition and debris-removal operations to ensure minimum interference with roads, streets, walks, walkways, and other adjacent occupied and used facilities.
 1. Comply with requirements for access and protection specified in Section 015000 "Temporary Facilities and Controls."
- B. Temporary Facilities: Provide temporary barricades and other protection required to prevent injury to people and damage to adjacent buildings and facilities to remain.
 1. Provide protection to ensure safe passage of people around selective demolition area and to and from occupied portions of building.
 2. Provide temporary weather protection, during interval between selective demolition of existing construction on exterior surfaces and new construction, to prevent water leakage and damage to structure and interior areas.
 3. Protect walls, ceilings, floors, and other existing finish work that are to remain or that are exposed during selective demolition operations.
 4. Cover and protect furniture, furnishings, and equipment that have not been removed.
 5. Comply with requirements for temporary enclosures, dust control, heating, and cooling specified in Section 015000 "Temporary Facilities and Controls."
- C. Temporary Shoring: Provide and maintain shoring, bracing, and structural supports as required to preserve stability and prevent movement, settlement, or collapse of construction and finishes

to remain, and to prevent unexpected or uncontrolled movement or collapse of construction being demolished.

1. Strengthen or add new supports when required during progress of selective demolition.

3.4 SELECTIVE DEMOLITION, GENERAL

- A. General: Demolish and remove existing construction only to the extent required by new construction and as indicated. Use methods required to complete the Work within limitations of governing regulations and as follows:

1. Proceed with selective demolition systematically, from higher to lower level. Complete selective demolition operations above each floor or tier before disturbing supporting members on the next lower level.
2. Neatly cut openings and holes plumb, square, and true to dimensions required. Use cutting methods least likely to damage construction to remain or adjoining construction. Use hand tools or small power tools designed for sawing or grinding, not hammering and chopping, to minimize disturbance of adjacent surfaces. Temporarily cover openings to remain.
3. Cut or drill from the exposed or finished side into concealed surfaces to avoid marring existing finished surfaces.
4. Do not use cutting torches until work area is cleared of flammable materials. At concealed spaces, such as duct and pipe interiors, verify condition and contents of hidden space before starting flame-cutting operations. Maintain fire watch and portable fire-suppression devices during flame-cutting operations.
5. Maintain adequate ventilation when using cutting torches.
6. Remove decayed, vermin infested, or otherwise dangerous or unsuitable materials and promptly dispose of off site.
7. Remove structural framing members and lower to ground by method suitable to avoid free fall and to prevent ground impact or dust generation.
8. Locate selective demolition equipment and remove debris and materials so as not to impose excessive loads on supporting walls, floors, or framing.
9. Dispose of demolished items and materials promptly. Comply with requirements in Section 02 41 19 "Construction Waste Management and Disposal."

- B. Removed and Reinstalled Items:

1. Clean and repair items to functional condition adequate for intended reuse.
2. Pack or crate items after cleaning and repairing. Identify contents of containers.
3. Protect items from damage during transport and storage.
4. Reinstall items in locations indicated. Comply with installation requirements for new materials and equipment. Provide connections, supports, and miscellaneous materials necessary to make item functional for use indicated.

- C. Existing Items to Remain: Protect construction indicated to remain against damage and soiling during selective demolition. When permitted by Architect, items may be removed to a suitable, protected storage location during selective demolition and reinstalled in their original locations after selective demolition operations are complete.

3.5 SELECTIVE DEMOLITION PROCEDURES FOR SPECIFIC MATERIALS

- A. Concrete: Demolish in small sections. Using power-driven saw, cut concrete to a depth of at least 3/4 inch (19 mm) at junctures with construction to remain. Dislodge concrete from reinforcement at perimeter of areas being demolished, cut reinforcement, and then remove remainder of concrete. Neatly trim openings to dimensions indicated.
- B. Masonry: Demolish in small sections. Cut masonry at junctures with construction to remain, using power-driven saw, then remove masonry between saw cuts.
- C. Concrete Slabs-on-Grade: Saw-cut perimeter of area to be demolished, then break up and remove.
- D. Resilient Floor Coverings: Remove floor coverings and adhesive according to recommendations in RFCI's "Recommended Work Practices for the Removal of Resilient Floor Coverings."
- E. Carpet

3.6 DISPOSAL OF DEMOLISHED MATERIALS

- A. General: Except for items or materials indicated to be recycled, reused, salvaged, reinstalled, or otherwise indicated to remain Owner's property, remove demolished materials from Project site and legally dispose of them in an EPA-approved landfill.
 - 1. Do not allow demolished materials to accumulate on-site.
 - 2. Remove and transport debris in a manner that will prevent spillage on adjacent surfaces and areas.
 - 3. Remove debris from elevated portions of building by chute, hoist, or other device that will convey debris to grade level in a controlled descent.
 - 4. Comply with requirements specified in Section 017419 "Construction Waste Management and Disposal."
- B. Burning: Do not burn demolished materials.
- C. Disposal: Transport demolished materials and dispose of at designated spoil areas on Owner's property.
- D. Disposal: Transport demolished materials off Owner's property and legally dispose of them.

3.7 CLEANING

- A. Clean adjacent structures and improvements of dust, dirt, and debris caused by selective demolition operations. Return adjacent areas to condition existing before selective demolition operations began.

END OF SECTION 02 41 19

SECTION 033000 - CAST-IN-PLACE CONCRETE

1.1 QUALITY ASSURANCE

- A. Quality Standard: ACI 301.
- B. Mockups to demonstrate typical joints, surface finish, texture, tolerances, floor treatments, and standard of workmanship.

1.2 PRODUCTS

- A. Form facing materials.
- B. Steel Reinforcement:
 - 1. Recycled Content of Steel Products: Postconsumer recycled content plus one-half of preconsumer recycled content not less than **[25]** **[60]** **<Insert number>** percent.
 - 2. Reinforcing Bars: **[Deformed]** **[Low-alloy]** **[Galvanized]** **[Epoxy coated]** **[Stainless steel]** **[Steel bar mats]**.
 - 3. Welded Wire Reinforcement: **[Plain]** **[Deformed]** **[Galvanized]** **[Epoxy coated]**.
- C. Concrete Materials:
 - 1. Portland Cement: ASTM C 150, Type **[I]** **[II]** **[III]** **[V]**, **[gray]** **[white]**, **[supplement with]** **[fly ash]** **[ground granulated blast-furnace slag]**.
 - 2. Blended Hydraulic Cement: ASTM C 595, Type **[IS]** **[IP]** **[I (PM)]** **[I (SM)]**.
 - 3. Silica fume.
 - 4. Aggregate: **[Normal weight]** **[Lightweight]**.
 - 5. Water.
- D. Mixing: **[Ready mixed]** **[Project site]**.

1.3 CONCRETE MIXTURES

- A. Portland Cement Replacement: Use fly ash, ground granulated blast-furnace slag, and silica fume to reduce portland cement by 40 percent.
- B. Compressive Strength (28 Days):
 - 1. Footings: **[5000 psi (34.5 MPa)]** **[4500 psi (31 MPa)]** **[4000 psi (27.6 MPa)]** **[3500 psi (24.1 MPa)]** **[3000 psi (20.7 MPa)]**.
 - 2. Foundation Walls: **[5000 psi (34.5 MPa)]** **[4500 psi (31 MPa)]** **[4000 psi (27.6 MPa)]** **[3500 psi (24.1 MPa)]** **[3000 psi (20.7 MPa)]**.
 - 3. Slabs-on-Grade: **[5000 psi (34.5 MPa)]** **[4500 psi (31 MPa)]** **[4000 psi (27.6 MPa)]** **[3500 psi (24.1 MPa)]** **[3000 psi (20.7 MPa)]**.
 - 4. Suspended Slabs: **[Normal-weight]** **[Lightweight]** concrete: **[5000 psi (34.5 MPa)]** **[4500 psi (31 MPa)]** **[4000 psi (27.6 MPa)]** **[3500 psi (24.1 MPa)]** **[3000 psi (20.7 MPa)]**.
 - 5. Concrete Toppings: **[5000 psi (34.5 MPa)]** **[4500 psi (31 MPa)]** **[4000 psi (27.6 MPa)]** **[3500 psi (24.1 MPa)]** **[3000 psi (20.7 MPa)]**.
 - 6. Building Frame Members: **[5000 psi (34.5 MPa)]** **[4500 psi (31 MPa)]** **[4000 psi (27.6 MPa)]** **[3500 psi (24.1 MPa)]** **[3000 psi (20.7 MPa)]**.

7. Building Walls: [5000 psi (34.5 MPa)] [4500 psi (31 MPa)] [4000 psi (27.6 MPa)] [3500 psi (24.1 MPa)] [3000 psi (20.7 MPa)].

1.4 INSTALLATION

- A. Formed Finishes: [Rough] [Smooth] [Rubbed].

- B. Floor and Slab Finishes:

1. Scratch: Surfaces to receive [concrete floor toppings] [mortar setting beds for bonded cementitious floor finishes].
2. Float: Surfaces to receive trowel finish and surfaces to be covered with [fluid-applied or sheet waterproofing] [built-up or membrane roofing] [sand-bed terrazzo].
3. Trowel: Surfaces exposed to view or to be covered with [resilient flooring] [carpet] [ceramic or quarry tile set over a cleavage membrane] [paint] [thin-film-finish coating system].
4. Trowel and Fine-Broom: Surfaces to be covered with ceramic or quarry tile to be installed by either thickset or thin-set method.
5. Broom: Exterior concrete [platforms] [steps] [ramps].
6. Slip-Resistive Finish: Concrete [stair treads] [platforms] [ramps].
7. Dry-Shake Floor Hardener: <Insert locations>.
8. Polished Concrete: <Insert locations>.

1.5 FIELD QUALITY CONTROL

- A. Testing: By [Owner-engaged] [Contractor-engaged] agency.
- B. Special Inspections: By Owner-engaged special inspector.

END OF SECTION 033000

SECTION 04 20 00 - UNIT MASONRY ASSEMBLIES

PART 1 - GENERAL

1.1 RELATED DOCUMENTS

- A. Drawings and general provisions of the Contract, including General and Supplementary Conditions and Division 1 Specification Sections, apply to this Section.

1.2 SUMMARY

- A. This Section includes unit masonry assemblies consisting of the following:
 - 1. Concrete masonry units (CMUs).
 - 2. Concrete brick.
 - 3. Face brick.
 - 4. Mortar and grout.
 - 5. Reinforcing steel.
 - 6. Masonry joint reinforcement.
 - 7. Ties and anchors.
 - 8. Embedded flashing.
 - 9. Miscellaneous masonry accessories.
- B. Related Sections include the following:
 - 1. Division 2 Section "Unit Pavers" for exterior unit masonry paving.
 - 2. Division 4 Section "Cast Stone".
 - 3. Division 7 Section "Sheet Metal Flashing and Trim" for exposed sheet metal flashing.
 - 4. Division 7 Section "Joint Sealants" for sealing control and expansion joints in unit masonry.
- C. Products installed, but not furnished, under this Section include the following:
 - 1. Steel lintels and shelf angles for unit masonry, furnished under Division 5 Section "Metal Fabrications."

1.3 DEFINITIONS

- A. Reinforced Masonry: Masonry containing reinforcing steel in grouted cells.

1.4 SUBMITTALS

- A. Product Data: For each type of product indicated.
- B. Shop Drawings: For the following:

1. Masonry Units: Show sizes, profiles, coursing, and locations of special shapes.
 2. Reinforcing Steel: Detail bending and placement of unit masonry reinforcing bars. Comply with ACI 315, "Details and Detailing of Concrete Reinforcement." Show elevations of reinforced walls.
 3. Fabricated Flashing: Detail corner units, end-dam units, and other special applications.
- C. Samples for Initial Selection: For the following:
1. Face brick, in the form of straps of five or more bricks indicating the full color range of each brick selection.
 2. Weep holes/vents.
- D. Samples for Verification: For each type and color of the following:
1. Pre-faced concrete masonry units.
 2. Face brick, in the form of straps of five or more bricks.
 3. Weep holes/vents.
 4. Accessories embedded in masonry.
- E. List of Materials Used in Constructing Mockups: List generic product names together with manufacturers, manufacturers' product names, model numbers, lot numbers, batch numbers, source of supply, and other information as required to identify materials used. Include mix proportions for mortar and grout and source of aggregates.
1. Submittal is for information only. Neither receipt of list nor approval of mockup constitutes approval of deviations from the Contract Documents unless such deviations are specifically brought to the attention of Architect and approved in writing.
- F. Material Certificates: Include statements of material properties indicating compliance with requirements including compliance with standards and type designations within standards. Provide for each type and size of the following:
1. Masonry units.
 - a. Include material test reports substantiating compliance with requirements.
 - b. For bricks, include size-variation data verifying that actual range of sizes falls within specified tolerances.
 - c. For exposed brick, include material test report for efflorescence according to ASTM C 67.
 2. Cementitious materials. Include brand, type, and name of manufacturer.
 3. Grout mixes. Include description of type and proportions of ingredients.
 4. Reinforcing bars.
 5. Joint reinforcement.
 6. Anchors, ties, and metal accessories.
- G. Mix Designs: For each type of mortar and grout. Include description of type and proportions of ingredients.

1. Include test reports, per ASTM C 780, for mortar mixes required to comply with property specification.
 2. Include test reports, per ASTM C 1019, for grout mixes required to comply with compressive strength requirement.
- H. Cold-Weather Procedures: Detailed description of methods, materials, and equipment to be used to comply with cold-weather requirements.

1.5 QUALITY ASSURANCE

- A. Testing Agency Qualifications: An independent agency qualified according to ASTM C 1093 for testing indicated, as documented according to ASTM E 548.
- B. Source Limitations for Masonry Units: Obtain exposed masonry units of a uniform texture and color, or a uniform blend within the ranges accepted for these characteristics, through one source and production run from a single manufacturer for each product required.
- C. Source Limitations for Mortar Materials: Obtain mortar ingredients of a uniform quality, including color for exposed masonry, from a single manufacturer and production run for each cementitious component and from one source or producer for each aggregate.
- D. Fire-Resistance Ratings: Where indicated, provide materials and construction identical to those of assemblies with fire-resistance ratings determined per ASTM E 119 by a testing and inspecting agency, by equivalent concrete masonry thickness, or by other means, as acceptable to authorities having jurisdiction.
- E. Sample Panels: Build sample panels to verify selections made under sample submittals and to demonstrate aesthetic effects. Comply with requirements in Division 1 Section "Quality Requirements" for mockups. Locate mockup as directed by Architect with finish face to have southern exposure. Protect during construction and do not remove until authorized by Architect.
 1. Build sample panels for each type and color of exposed unit masonry construction in sizes approximately 48 inches long by 48 inches high.
 2. Sample panels to include concealed-wall flashings with separate drip edges, mortar filters, and weeps.
 3. Clean one half of exposed faces of panels with masonry cleaner indicated.
 4. Protect approved sample panels from the elements with weather-resistant membrane.
 5. Approval of sample panels is for color, texture, and blending of masonry units; relationship of mortar and sealant colors to masonry unit colors; tooling of joints; aesthetic qualities of workmanship; and other material and construction qualities specifically approved by Architect in writing. Approval of sample panels or demonstration mock up does not constitute approval of deviations from the Contract Documents contained in sample panels unless such deviations are specifically approved by Architect in writing.
- F. Preinstallation Conference: Conduct conference at Project site to comply with requirements in Division 1 Section "Project Management and Coordination."

1.6 DELIVERY, STORAGE, AND HANDLING

- A. Store masonry units on elevated platforms in a dry location. If units are not stored in an enclosed location, cover tops and sides of stacks with waterproof sheeting, securely tied. If units become wet, do not install until they are dry.
- B. Store cementitious materials on elevated platforms, under cover, and in a dry location. Do not use cementitious materials that have become damp.
- C. Store aggregates where grading and other required characteristics can be maintained and contamination avoided.
- D. Deliver preblended, dry mortar mix in moisture-resistant containers designed for lifting and emptying into dispensing silo. Store preblended, dry mortar mix in delivery containers on elevated platforms, under cover, and in a dry location or in a metal dispensing silo with weatherproof cover.
- E. Store masonry accessories, including metal items, to prevent corrosion and accumulation of dirt and oil.

1.7 PROJECT CONDITIONS

- A. Protection of Masonry: During construction, cover tops of walls, projections, and sills with waterproof sheeting at end of each day's work. Cover partially completed masonry when construction is not in progress.
 - 1. Extend cover a minimum of 24 inches down both sides and hold cover securely in place.
 - 2. Where 1 wythe of multiwythe masonry walls is completed in advance of other wythes, secure cover a minimum of 24 inches down face next to unconstructed wythe and hold cover in place.
- B. Do not apply uniform floor or roof loads for at least 12 hours and concentrated loads for at least 3 days after building masonry walls or columns.
- C. Stain Prevention: Prevent grout, mortar, and soil from staining the face of masonry to be left exposed or painted. Immediately remove grout, mortar, and soil that come in contact with such masonry.
 - 1. Protect base of walls from rain-splashed mud and from mortar splatter by spreading coverings on ground and over wall surface.
 - 2. Protect sills, ledges, and projections from mortar droppings.
 - 3. Protect surfaces of window and door frames, as well as similar products with painted and integral finishes, from mortar droppings.
 - 4. Turn scaffold boards near the wall on edge at the end of each day to prevent rain from splashing mortar and dirt onto completed masonry.
- D. Cold-Weather Requirements: Do not use frozen materials or materials mixed or coated with ice or frost. Do not build on frozen substrates. Remove and replace unit masonry damaged by frost or by freezing conditions. Comply with cold-weather construction requirements contained in ACI 530.1/ASCE 6/TMS 602.
 - 1. Cold-Weather Cleaning: Use liquid cleaning methods only when air temperature is 40 deg F (4 deg C) and above and will remain so until masonry has dried, but not less than 7 days after completing cleaning.

- E. Hot-Weather Requirements: Comply with hot-weather construction requirements contained in ACI 530.1/ASCE 6/TMS 602.

PART 2 - PRODUCTS

2.1 MANUFACTURERS

- A. In other Part 2 articles where titles below introduce lists, the following requirements apply to product selection:
1. Available Products: Subject to compliance with requirements, products that may be incorporated into the Work include, but are not limited to, products specified.
 2. Products: Subject to compliance with requirements, provide one of the products specified.
 3. Available Manufacturers: Subject to compliance with requirements, manufacturers offering products that may be incorporated into the Work include, but are not limited to, manufacturers specified.
 4. Manufacturers: Subject to compliance with requirements, provide products by one of the manufacturers specified.
 5. Basis-of-Design Product: The design for the product identified is based on the product names. The use of a trade name and/or supplier's name and address in the specifications is to indicate a possible source of the product and a standard of quality. Products of the same type from other sources shall not be excluded, provided they possess like physical and functional and aesthetic characteristics.

2.2 MASONRY UNITS, GENERAL

- A. Defective Units: Referenced masonry unit standards may allow a certain percentage of units to exceed tolerances and to contain chips, cracks, or other defects exceeding limits stated in the standard. Do not use units where such defects, including dimensions that vary from specified dimensions by more than stated tolerances, will be exposed in the completed Work or will impair the quality of completed masonry.

2.3 CONCRETE MASONRY UNITS (CMUs)

Shapes: Provide shapes where for lintels, corners, jambs, sashes, movement joints, headers, bonding, and other special conditions.

- A. Concrete Masonry Units: ASTM C 90.
1. Unit Compressive Strength: Provide units with minimum average net-area compressive strength of 1900 psi (13.1 MPa).
 2. Weight Classification: Normal weight, unless otherwise indicated.
 3. Size (Width): Manufactured to dimensions 3/8 inch less than nominal dimensions.

4. Exposed Faces: Provide color and texture matching the range represented by Architect's sample.

2.4 BRICK

A. General: Provide shapes indicated and as follows:

1. For ends of sills and caps and for similar applications that would otherwise expose unfinished brick surfaces, provide units without cores or frogs and with exposed surfaces finished.
2. Provide special shapes for applications where stretcher units cannot accommodate special conditions, including those at corners and jambs.
3. Provide special shapes for applications requiring brick of size, form, color, and texture on exposed surfaces that cannot be produced by sawing.
4. Provide special shapes for applications where shapes produced by sawing would result in sawed surfaces being exposed to view.

B. Face Brick: ASTM C 216, Grade SW, Type FBS.

1. Unit Compressive Strength: Provide units with minimum average net-area compressive strength of 3000 psi.
2. Initial Rate of Absorption: Less than 30 g/30 sq. in. (30 g/194 sq. cm) per minute when tested per ASTM C 67.
3. Efflorescence: Provide brick that has been tested according to ASTM C 67 and is rated "not effloresced."
4. Size (Actual dimensions): Standard Modular Brick, 3-5/8 inches wide by 2-1/4 inches tall by 7-5/8 inches long.
5. Color and Texture: As selected by Architect to match existing adjacent structure
6. All face brick shall come from a single source. Each color brick including special shapes shall be from the same production run.
7. Contractor may provide brick from one of the following manufacturers subject to compliance with the stated performance criteria and approved color and finish samples.

2.5 MORTAR AND GROUT MATERIALS

A. Mortar: Dry, preblended mortar mix containing portland cement, hydrated lime, and dried masonry sand available in standard or custom colors.

1. Basis of Design: Portland Lime & Sand Mortar by Spec Mix, Eagan, MN.
2. Products by other manufacturers are acceptable subject to the requirements of this Section.

B. Aggregate for Grout: ASTM C 404.

C. Cold-Weather Admixture: Not permitted.

D. Water: Potable.

2.6 REINFORCEMENT

- A. Uncoated Steel Reinforcing Bars: ASTM A 615/A 615M or ASTM A 996/A 996M, Grade 60 (Grade 420).
- B. Masonry Joint Reinforcement, General: ASTM A 951.
 - 1. Interior Walls: Hot-dip galvanized, carbon steel.
 - 2. Exterior Walls: Hot-dip galvanized, carbon steel.
 - 3. Wire Size for Side Rods: W2.8 or 0.188-inch diameter.
 - 4. Wire Size for Cross Rods: W2.8 or 0.188-inch diameter.
 - 5. Wire Size for Veneer Ties: W2.8 or 0.188-inch diameter.
 - 6. Spacing of Cross Rods, Tabs, and Cross Ties: Not more than 16 inches o.c.
 - 7. Provide in lengths of not less than 10 feet , with prefabricated corner and tee units.
- C. Masonry Joint Reinforcement for Single-Wythe Masonry: Either ladder or truss type with single pair of side rods.

2.7 TIES AND ANCHORS

- A. Materials: Provide ties and anchors specified in subsequent paragraphs that are made from materials that comply with eight subparagraphs below, unless otherwise indicated.
 - 1. Hot-Dip Galvanized, Carbon-Steel Wire: ASTM A 82; with ASTM A 153/A 153M, Class B-2 coating.
 - 2. Steel Sheet, Galvanized after Fabrication: ASTM A 1008/A 1008M, Commercial Steel, hot-dip galvanized after fabrication to comply with ASTM A 153/A 153M.
 - 3. Steel Plates, Shapes, and Bars: ASTM A 36/A 36M.
- B. Wire Ties, General: Unless otherwise indicated, size wire ties to extend at least halfway through veneer but with at least 5/8-inch cover on outside face. Outer ends of wires are bent 90 degrees and extend 2 inches parallel to face of veneer.
- C. Individual Wire Ties: Rectangular units with closed ends and not less than 4 inches wide.
 - 1. Z-shaped ties with ends bent 90 degrees to provide hooks not less than 2 inches long may be used for masonry constructed from solid units or hollow units laid with cells horizontal.
 - 2. Where wythes do not align or are of different materials, use adjustable ties with pintle-and-eye connections having a maximum adjustment of 1-1/4 inches.
 - 3. Wire: Fabricate from 3/16-inch- diameter, hot-dip galvanized steel wire.
- D. Adjustable Anchors for Connecting to Structure: Provide anchors that allow vertical or horizontal adjustment but resist tension and compression forces perpendicular to plane of wall.
 - 1. Anchor Section for Welding to Steel Frame: Crimped 1/4-inch-diameter, hot-dip galvanized steel wire.
 - 2. Tie Section for Steel Frame: Triangular-shaped wire tie, sized to extend within 1 inch of masonry face, made from 0.188-inch- diameter, hot-dip galvanized steel wire.

- E. Partition Top anchors: 0.097-inch- thick metal plate with 3/8-inch- diameter metal rod 6 inches long welded to plate and with closed-end plastic tube fitted over rod that allows rod to move in and out of tube. Fabricate from steel, hot-dip galvanized after fabrication.
- F. Rigid Anchors: Fabricate from steel bars 1-1/2 inches wide by 1/4 inch thick by 24 inches long, with ends turned up 2 inches or with cross pins, unless otherwise indicated.
 - 1. Corrosion Protection: Hot-dip galvanized to comply with ASTM A 153/A 153M.
- G. Adjustable Masonry-Veneer Anchors
 - 1. General: Provide anchors that allow vertical adjustment but resist tension and compression forces perpendicular to plane of wall, for attachment over sheathing to wood or metal studs, and as follows:
 - a. Structural Performance Characteristics: Capable of withstanding a 100-lbf (445-N) load in both tension and compression without deforming or developing play in excess of 0.05 inch.
 - 2. Screw-Attached, Masonry-Veneer Anchors: Units consisting of a wire tie and a metal anchor section.
 - a. Anchor Section: Sheet metal plate, 1-1/4 inches (32 mm) wide by 9 inches (225 mm) long, with screw holes top and bottom and with raised rib-stiffened strap, 5/8 inch (16 mm) wide by 5-1/2 inches (140 mm) long, stamped into center to provide a slot between strap and plate for inserting wire tie.
 - b. Screws to be type 410 stainless steel self drilling self tapping #10-16 x 1 1/2".
 - c. Fabricate sheet metal anchor sections and other sheet metal parts from 0.097-inch-thick, steel sheet, galvanized after fabrication
 - d. Wire Ties: Triangular-, rectangular-, or T-shaped wire ties fabricated from 0.188-inch- diameter, hot-dip galvanized steel wire.
 - e. Basis of Design Hohmann & Barnard, Inc.; **DW-10X**. Products by other manufacturer's meeting the design intent and basis of design include, but are not limited to:
 - 1) Dayton Superior Corporation, Dur-O-Wal Division;
 - 2) Heckmann Building Products Inc
 - 3) Wire-Bond

2.8 MISCELLANEOUS ANCHORS

- A. Dovetail Slots in Concrete: Furnish dovetail slots with filler strips, of slot size indicated, fabricated from 0.034-inch, galvanized steel sheet.
- B. Anchor Bolts: L-shaped steel bolts complying with ASTM A 307, Grade A (ASTM F 568M, Property Class 4.6); with ASTM A 563 (ASTM A 563M) hex nuts and, where indicated, flat washers; hot-dip galvanized to comply with ASTM A 153/A 153M, Class C; of dimensions indicated.
- C. Post installed Anchors where required: Provide chemical or torque-controlled expansion anchors, with capability to sustain, without failure, a load equal to six times the load imposed when installed in solid or grouted unit masonry and equal to four times the load imposed when

installed in concrete, as determined by testing per ASTM E 488 conducted by a qualified independent testing agency.

1. Corrosion Protection: Carbon-steel components zinc plated to comply with ASTM B 633, Class Fe/Zn 5 (5 microns) for Class SC 1 service condition (mild).

2.9 EMBEDDED FLASHING MATERIALS

- A. Flexible flashing: For flashing not exposed to the exterior.
 1. Products of manufacturers listed below meeting indicated standards and specified manufacturer's product data characteristics, except as modified below, are acceptable for use, subject to compliance with specified requirements.
 - a. York Manufacturing, Inc.; Multi-Flash SS 316.
 - b. Prosoco, Inc.; R-Guard SS ThruWall 316.
 - c. STS Coatings, Inc.; Wall Guardian 316 Stainless Steel FWF.
 - d. Other products meeting the requirements of this Section.
 2. Characteristics
 - a. Type: Stainless steel core with polymer fabric laminated to the bottom stainless steel face with non-asphalt adhesive. The top face (exposed side) must not be covered with a polymer fabric.
 - b. Stainless steel: Type 316, ASTM A240. Domestically sourced per DFARS 252.225-7008 and/or DFARS 252.225-7009.
 - c. Fabric: Polymer fabric; laminated back face (non-exposed side) of stainless steel core.
 - d. Size: Manufacturer's standard width rolls.
- B. Provide width as necessary to extend vertically 8" finishing behind waterproof membrane and ½" from face of exterior finish wall surface with 3" stainless steel drip plate.
- C. Adhesives, Primers, and Seam Tapes for Flashings: Flashing manufacturer's standard products or products recommended by flashing manufacturer for bonding flashing sheets to each other and to substrates.

2.10 MISCELLANEOUS MASONRY ACCESSORIES

- A. Compressible Filler: Premolded filler strips complying with ASTM D 1056, Grade 2A1; compressible up to 35 percent; of width and thickness indicated; formulated from neoprene.
- B. Preformed Control-Joint Gaskets: Made from styrene-butadiene-rubber compound, complying with ASTM D 2000, Designation M2AA-805 and designed to fit standard sash block and to maintain lateral stability in masonry wall; size and configuration as indicated.
- C. Bond-Breaker Strips: Asphalt-saturated, organic roofing felt complying with ASTM D 226, Type I (No. 15 asphalt felt).
- D. Weep/Vent Products: Mesh Weep/Vent full height and width of head joint and depth 1/8 inch less than depth of outer wythe.
 1. Basis of design: Hohmann & Barnard Mortar trap Weep vent. Products by other manufacturer's meeting the design intent and basis of design may be used

- a. 100% recycled polyester non-woven plastic treated with flame retardant and UV inhibitors
 - b. Color as selected from manufacturer's full standard line
- E. Cavity Drainage Material
 - 1. Basis of design: Hohmann & Barnard Mortar Trap.
 - 2. Products by other Manufacturers meeting the requirements of this Section may be used.
 - a. Free-draining 90 percent open mesh, made from polymer strands that will not degrade within the wall cavity.
 - b. Strips, full-depth of cavity and 10 inches wide, with dovetail shaped notches 7 inches deep that prevent mesh from being clogged with mortar droppings.

2.11 MASONRY CLEANERS

- A. Proprietary Acidic Masonry Cleaner: Manufacturer's standard-strength cleaner designed for removing mortar/grout stains, efflorescence, and other new construction stains from new masonry without discoloring or damaging masonry surfaces. Use product expressly approved for intended use by cleaner manufacturer and manufacturer of masonry units being cleaned.
 - 1. Manufacturers:
 - a. Diedrich Technologies, Inc.
 - b. EaCo Chem, Inc.
 - c. ProSoCo, Inc.

2.12 MORTAR AND GROUT MIXES

- A. General: Do not use admixtures, including pigments, air-entraining agents, accelerators, retarders, water-repellent agents, and freeze compounds, or other admixtures, unless otherwise indicated.
 - 1. For masonry below grade or in contact with earth, use Type S.
 - 2. For reinforced and non-reinforced CMU masonry, use Type S.
 - 3. For exterior, above-grade, non-load-bearing walls and parapet walls; and for other applications where another type is not indicated, use Type N
 - 4. Do not use calcium chloride in mortar or grout.
 - 5. Limit cementitious materials in mortar to portland cement, mortar cement, and lime.
- B. Preblended, Dry Mortar Mix: Furnish dry mortar ingredients in form of a preblended mix. Measure quantities by weight to ensure accurate proportions, and thoroughly blend ingredients before delivering to Project site.
- C. Mortar for Unit Masonry: Comply with ASTM C 270 and BIA Technical Notes 8A, Proportion Specification. Provide the following types of mortar for applications stated unless another type is indicated or needed to provide required compressive strength of masonry
- D. Colored Mortar for exposed brick
 - 1. Colored Cement Product: Packaged blend made from portland cement and lime and mortar pigments, all complying with specified requirements, and containing no other ingredients.

2. Formulate blend as required to produce color indicated or, if not indicated, as selected from manufacturer's available colors.
 3. Pigments shall not exceed 10 percent of portland cement by weight.
 4. Available Products:
 5. Colored Portland Cement-Lime Mix:
 6. Capital Materials Corporation; Riverton Portland Cement Lime Custom Color.
 7. Holcim (US) Inc.; Rainbow Mortamix Custom Color Cement/Lime.
 8. Lafarge North America Inc.; Eaglebond.
 9. Lehigh Cement Company; Lehigh Custom Color Portland/Lime Cement.
 10. Portland Cement: ASTM C 150, Type I or II, except Type III may be used for cold-weather construction. Provide natural color or white cement as required to produce mortar color indicated.
- E. Hydrated Lime: ASTM C 207, Type S.
- F. Portland Cement-Lime Mix: Packaged blend of portland cement and hydrated lime containing no other ingredients.
- G. Masonry Cement: ASTM C 91.
- H. Aggregate for Mortar: ASTM C 144.
- I. For mortar that is exposed to view, use washed aggregate consisting of natural sand or crushed stone.
- J. For joints less than 1/4 inch thick, use aggregate graded with 100 percent passing the No. 16 sieve.
- K. Cold-Weather Admixture: Nonchloride, noncorrosive accelerating admixture complying with ASTM C 494/C 494M, Type C, and recommended by manufacturer for use in masonry mortar of composition indicated.
1. Products: Subject to compliance with requirements, provide one of the following:
 2. Euclid Chemical Company (The) Accelguard 80.
 3. Grace Construction Products, W. R. Grace & Co. - Conn.; Morset.
 4. Sonneborn Products, BASF Aktiengesellschaft; Trimix-NCA.
- L. Water: Potable.
- a.
- M. Grout for Unit Masonry: Comply with ASTM C 476.
1. Use grout of type indicated or, if not otherwise indicated, of type (fine or coarse) that will comply with Table 1.15.1 in ACI 530.1/ASCE 6/TMS 602 for dimensions of grout spaces and pour height.
 2. Provide grout with a slump of 8 to 11 inches as measured according to ASTM C 143/C 143M.
 3. Aggregate for Grout: ASTM C 404

PART 3 - EXECUTION

3.1 EXAMINATION

- A. Examine conditions, with Installer present, for compliance with requirements for installation tolerances and other conditions affecting performance of work.

1. For the record, prepare written report, endorsed by Installer, listing conditions detrimental to performance of work.
 2. Verify that foundations are within tolerances specified.
 3. Verify that reinforcing dowels are properly placed.
- B. Before installation, examine rough-in and built-in construction for piping systems to verify actual locations of piping connections.
- C. Proceed with installation only after unsatisfactory conditions have been corrected.

3.2 INSTALLATION, GENERAL

- A. Thickness: Build cavity and composite walls and other masonry construction to full thickness shown. Build single-wythe walls to actual widths of masonry units, using units of widths indicated.
- B. Build chases and recesses to accommodate items specified in this and other Sections.
- C. Leave openings for equipment to be installed before completing masonry. After installing equipment, complete masonry to match the construction immediately adjacent to opening.
- D. Use full-size units without cutting if possible. If cutting is required to provide a continuous pattern or to fit adjoining construction, cut units with motor-driven saws; provide clean, sharp, unchipped edges. Allow units to dry before laying unless wetting of units is specified. Install cut units with cut surfaces and, where possible, cut edges concealed.
- E. Select and arrange units for exposed unit masonry to produce a uniform blend of colors and textures.
1. Mix units from several pallets or cubes as they are placed.
- F. Wetting of Brick: Wet brick before laying if initial rate of absorption exceeds 30 g/30 sq. in. per minute when tested per ASTM C 67. Allow units to absorb water so they are damp but not wet at time of laying.
- G. Comply with construction tolerances in ACI 530.1/ASCE 6/TMS 602 and with the following:
1. For conspicuous vertical lines, such as external corners, door jambs, reveals, and expansion and control joints, do not vary from plumb by more than 1/8 inch in 10 feet, 1/4 inch in 20 feet, or 1/2 inch maximum.
 2. For vertical alignment of exposed head joints, do not vary from plumb by more than 1/4 inch in 10 feet, or 1/2 inch maximum.
 3. For conspicuous horizontal lines, such as lintels, sills, parapets, and reveals, do not vary from level by more than 1/8 inch in 10 feet, 1/4 inch in 20 feet, or 1/2 inch maximum.
 4. For exposed bed joints, do not vary from thickness indicated by more than plus or minus 1/8 inch, with a maximum thickness limited to 1/2 inch. Do not vary from bed-joint thickness of adjacent courses by more than 1/8 inch.
 5. For exposed head joints, do not vary from thickness indicated by more than plus or minus 1/8 inch. Do not vary from adjacent bed-joint and head-joint thicknesses by more than 1/8 inch.
 6. For faces of adjacent exposed masonry units, do not vary from flush alignment by more than 1/16 inch except due to warpage of masonry units within tolerances specified for warpage of units.
 7. For exposed bed joints and head joints of stacked bond, do not vary from a straight line by more than 1/16 inch from one masonry unit to the next.

3.3 LAYING MASONRY WALLS

- A. Lay out walls in advance for accurate spacing of surface bond patterns with uniform joint thicknesses and for accurate location of openings, movement-type joints, returns, and offsets. Avoid using less-than-half-size units, particularly at corners, jambs, and, where possible, at other locations.
- B. Bond Pattern for Exposed Masonry: Unless otherwise indicated, lay exposed masonry in running bond; do not use units with less than nominal 4-inch horizontal face dimensions at corners or jambs.
- C. Lay concealed masonry with all units in a wythe in running bond or bonded by lapping not less than 4-inches. Bond and interlock each course of each wythe at corners. Do not use units with less than nominal 4-inch horizontal face dimensions at corners or jambs.
- D. Stopping and Resuming Work: Stop work by racking back units in each course from those in course below; do not tooth. When resuming work, clean masonry surfaces that are to receive mortar, remove loose masonry units and mortar, and wet brick if required before laying fresh masonry.
- E. Built-in Work: As construction progresses, build in items specified in this and other Sections. Fill in solidly with masonry around built-in items.
- F. Fill space between steel frames and masonry solidly with mortar, unless otherwise indicated.
- G. Where built-in items are to be embedded in cores of hollow masonry units, place a layer of metal lath, wire mesh, or plastic mesh in the joint below and rod mortar or grout into core.
- H. Fill cores in hollow concrete masonry units with grout 24 inches under bearing plates, beams, lintels, posts, and similar items, unless otherwise indicated.

3.4 MORTAR BEDDING AND JOINTING

- A. Lay hollow brick and concrete masonry units as follows:
 - 1. With face shells fully bedded in mortar and with head joints of depth equal to bed joints.
 - 2. With webs fully bedded in mortar in all courses of piers, columns, and pilasters.
 - 3. With webs fully bedded in mortar in grouted masonry, including starting course on footings.
 - 4. With entire units, including areas under cells, fully bedded in mortar at starting course on footings where cells are not grouted.
- B. Lay solid masonry units with completely filled bed and head joints; butter ends with sufficient mortar to fill head joints and shove into place. Do not deeply furrow bed joints or slush head joints.

3.5 MASONRY JOINT REINFORCEMENT

- A. General: Install entire length of longitudinal side rods in mortar with a minimum cover of 5/8 inch on exterior side of walls, 1/2 inch elsewhere. Lap reinforcement a minimum of 6 inches.
 - 1. Space reinforcement not more than 16 inches (406 mm) o.c.
 - 2. Space reinforcement not more than 8 inches (203 mm) o.c. in foundation walls and parapet walls.

3. Provide reinforcement not more than 8 inches (203 mm) above and below wall openings and extending 12 inches (305 mm) beyond openings.
 - a. Reinforcement above is in addition to continuous reinforcement.
- B. Interrupt joint reinforcement at control and expansion joints, unless otherwise indicated.
- C. Provide continuity at wall intersections by using prefabricated T-shaped units.
- D. Provide continuity at corners by using prefabricated L-shaped units.
- E. Cut and bend reinforcing units as directed by manufacturer for continuity at corners, returns, offsets, column fireproofing, pipe enclosures, and other special conditions.

3.6 ANCHORING MASONRY VENEERS

- A. Anchor masonry veneers to wall framing with masonry-veneer anchors to comply with the following requirements:
 1. Fasten screw-attached anchors through sheathing to wall framing and to masonry backup with metal fasteners of type indicated. Use two fasteners unless anchor design only uses one fastener.
 2. Insert slip-in anchors in metal studs as sheathing is installed. Provide one anchor at each stud in each horizontal joint between sheathing boards.
 3. Embed tie sections connector sections and continuous wire in masonry joints. Provide not less than 1 1/2 inches of air space between back of masonry veneer and face of sheathing.
 4. Locate anchor sections to allow maximum vertical differential movement of ties up and down.
 5. Space anchors as indicated, but not more than 16 inches o.c. vertically and 16 inches o.c. horizontally with not less than 1 anchor for each 1.87 sq. ft. of wall area. Install additional anchors within 8 inches of openings and at intervals, not exceeding 12 inches, around perimeter.

3.7 CONTROL AND EXPANSION JOINTS

- A. General: Install control and expansion joint materials in unit masonry as masonry progresses. Do not allow materials to span control and expansion joints without provision to allow for in-plane wall or partition movement.
- B. Form control joints in concrete masonry and install preformed control-joint gaskets designed to fit standard sash block.
- C. Form expansion joints in brick made and form open joint full depth of brick wythe and of width indicated, but not less than 1/2 inch for installation of sealant and backer rod specified in Division 7 Section "Joint Sealants."

3.8 LINTELS

- A. Install steel lintels where indicated.
- B. Provide minimum bearing of 8 inches at each jamb, unless otherwise indicated.

3.9 FLASHING, WEEP HOLES, CAVITY DRAINAGE, AND VENTS

- A. General: Install embedded flashing and weep holes in masonry at shelf angles, lintels, ledges, other obstructions to downward flow of water in wall, and where indicated.
- B. Install flashing as follows, unless otherwise indicated:
 - 1. Prepare masonry surfaces so they are smooth and free from projections that could puncture flashing. Where flashing is within mortar joint, place through-wall flashing on sloping bed of mortar and cover with mortar. Before covering with mortar, seal penetrations in flashing with adhesive, sealant, or tape as recommended by flashing manufacturer.
 - 2. At masonry-veneer walls, extend flashing through veneer, across air space behind veneer, and up face of sheathing at least 8 inches; with upper edge tucked under building paper or building wrap, lapping at least 4 inches. Stop flexible flashing 1/2 inch back from outside face of wall.
 - 3. At lintels and shelf angles, extend flashing a minimum of 6 inches into masonry at each end. At heads and sills, extend flashing 6 inches at ends and turn up not less than 2 inches to form end dams.
- C. Install reglets and nailers for flashing and other related construction where they are shown to be built into masonry.
- D. Install weep holes in head joints in exterior wythes of first course of masonry immediately above embedded flashing and as follows:
 - 1. Use specified weep/vent products.
 - 2. Space weep holes 24 inches o.c., unless otherwise indicated.
- E. Place cavity drainage material in cavities to comply with configuration requirements for cavity drainage material in Part 2 "Miscellaneous Masonry Accessories" Article.

3.10 REINFORCED UNIT MASONRY INSTALLATION

- A. Temporary Formwork and Shores: Construct formwork and shores as needed to support reinforced masonry elements during construction.
 - 1. Construct formwork to provide shape, line, and dimensions of completed masonry as indicated. Make forms sufficiently tight to prevent leakage of mortar and grout. Brace, tie, and support forms to maintain position and shape during construction and curing of reinforced masonry.
 - 2. Do not remove forms and shores until reinforced masonry members have hardened sufficiently to carry their own weight and other temporary loads that may be placed on them during construction.
- B. Placing Reinforcement: Comply with requirements in ACI 530.1/ASCE 6/TMS 602
- C. Grouting: Do not place grout until entire height of masonry to be grouted has attained enough strength to resist grout pressure.

1. Comply with requirements in ACI 530.1/ASCE 6/TMS 602 for cleanouts and for grout placement, including minimum grout space and maximum pour height.
2. Limit height of vertical grout pours to not more than 60 inches, unless otherwise noted.

3.11 REPAIRING, POINTING, AND CLEANING

- A. Remove and replace masonry units that are loose, chipped, broken, stained, or otherwise damaged or that do not match adjoining units. Install new units to match adjoining units; install in fresh mortar, pointed to eliminate evidence of replacement.
- B. Pointing: During the tooling of joints, enlarge voids and holes, except weep holes, and completely fill with mortar. Point up joints, including corners, openings, and adjacent construction, to provide a neat, uniform appearance. Prepare joints for sealant application, where indicated.
- C. In-Progress Cleaning: Clean unit masonry as work progresses by dry brushing to remove mortar fins and smears before tooling joints.
- D. Final Cleaning: After mortar is thoroughly set and cured, clean exposed masonry as follows:
 1. Remove large mortar particles by hand with wooden paddles and nonmetallic scrape hoes or chisels.
 2. Test cleaning methods on sample wall panel; leave one-half of panel uncleaned for comparison purposes. Obtain Architect's approval of sample cleaning before proceeding with cleaning of masonry.
 3. Protect adjacent stone and non-masonry surfaces from contact with cleaner by covering them with liquid strippable masking agent or polyethylene film and waterproof masking tape.
 4. Wet wall surfaces with water before applying cleaners; remove cleaners promptly by rinsing surfaces thoroughly with clear water.
 5. Clean brick by bucket-and-brush hand-cleaning method described in BIA Technical Notes 20.
 6. Clean masonry with a proprietary acidic cleaner applied according to manufacturer's written instructions.
 7. Clean concrete masonry by cleaning method indicated in NCMA TEK 8-2A applicable to type of stain on exposed surfaces.

3.12 MASONRY WASTE DISPOSAL

- A. Salvageable Materials: Unless otherwise indicated, excess masonry materials are Contractor's property. At completion of unit masonry work, remove from Project site.

END OF SECTION 04 20 00

SECTION 054000 - COLD-FORMED METAL FRAMING

1.1 PERFORMANCE REQUIREMENTS

A. Structural Performance:

1. Dead Loads: <Insert applicable loads>.
2. Live Loads: <Insert applicable loads>.
3. Roof Loads: <Insert applicable loads>.
4. Snow Loads: <Insert applicable loads>.
5. Wind Loads: <Insert applicable loads or wind-loading criteria>.
6. Seismic Loads: <Insert applicable design data>.
7. Deflection Limits: [1/240] [1/360] <Insert deflection limits>.

B. Engineering design of cold-formed metal framing by Contractor.

C. Design Standards: AISI S100 and AISI S200.

1.2 MATERIALS

A. Recycled Content of Steel: Postconsumer recycled content plus one-half of preconsumer recycled content not less than [25] <Insert number> percent.

B. Steel Sheet: ASTM A 1003/A 1003M, Structural Grade, metallic coated.

C. Load-Bearing Wall Framing: Standard C-shaped, punched steel studs[, **steel box or back-to-back headers,**] and U-shaped, unpunched track.

1. Minimum Steel Thickness: [0.0329 inch (0.84 mm)] [0.0428 inch (1.09 mm)] [0.0538 inch (1.37 mm)] [0.0677 inch (1.72 mm)] [0.0966 inch (2.45 mm)].

D. Exterior Non-Load-Bearing Wall Framing: Standard C-shaped, punched steel studs and U-shaped, unpunched track.

1. Minimum Steel Thickness: [0.0329 inch (0.84 mm)] [0.0428 inch (1.09 mm)] [0.0538 inch (1.37 mm)] [0.0677 inch (1.72 mm)] [0.0966 inch (2.45 mm)].
2. [Vertical deflection clips] [Single deflection track] [Double deflection track] [Drift clips].

E. Floor Joist Framing: Standard C-shaped, [unpunched] [punched] steel joists and U-shaped, unpunched joist track.

1. Minimum Steel Thickness: [0.0329 inch (0.84 mm)] [0.0428 inch (1.09 mm)] [0.0538 inch (1.37 mm)] [0.0677 inch (1.72 mm)] [0.0966 inch (2.45 mm)].

F. Roof Rafter Framing: Standard C-shaped steel sections.

1. Minimum Steel Thickness: [0.0329 inch (0.84 mm)] [0.0428 inch (1.09 mm)] [0.0538 inch (1.37 mm)] [0.0677 inch (1.72 mm)] [0.0966 inch (2.45 mm)].

G. Ceiling Joist Framing: Standard C-shaped, unpunched steel sections.

1. Minimum Steel Thickness: [0.0329 inch (0.84 mm)] [0.0428 inch (1.09 mm)] [0.0538 inch (1.37 mm)] [0.0677 inch (1.72 mm)] [0.0966 inch (2.45 mm)].

H. Soffit Framing: Standard C-shaped, unpunched steel sections.

1. Minimum Steel Thickness: [0.0329 inch (0.84 mm)] [0.0428 inch (1.09 mm)] [0.0538 inch (1.37 mm)] [0.0677 inch (1.72 mm)] [0.0966 inch (2.45 mm)].

I. Framing Accessories: [Supplementary framing] [bracing, bridging, and solid blocking] [web stiffeners] [anchor clips] [end clips] [foundation clips] [gusset plates] [stud kickers and knee braces] [joist hangers and end closures] [hole reinforcing plates] [and] [backer plates].

1.3 INSTALLATION

A. Fasten framing by [welding] [or] [screw fastening].

1. Load-Bearing Wall Stud Spacing: [12 inches (305 mm)] [16 inches (406 mm)] [19.2 inches (488 mm)] [24 inches (610 mm)] [300 mm] [400 mm] [480 mm] [600 mm].
2. Exterior Non-Load-Bearing Wall Stud Spacing: [12 inches (305 mm)] [16 inches (406 mm)] [19.2 inches (488 mm)] [24 inches (610 mm)] [300 mm] [400 mm] [480 mm] [600 mm].
3. Joist Spacing: [12 inches (305 mm)] [16 inches (406 mm)] [19.2 inches (488 mm)] [24 inches (610 mm)] [300 mm] [400 mm] [480 mm] [600 mm].

1.4 FIELD QUALITY CONTROL

A. Testing: By Owner-engaged agency.

END OF SECTION 054000

SECTION 055000 - METAL FABRICATIONS

1.1 PRODUCTS

- A. Materials: **[Steel plates, shapes, and bars]** **[Stainless-steel plates, shapes, and bars]** **[Steel tubing]** **[Steel pipe]** **[Slotted channel framing]** **[Iron castings]** **[Aluminum]** **[Bronze]** **[Nickel silver]**.
1. Recycled Content of Steel: Postconsumer recycled content plus one-half of preconsumer recycled content not less than **[25]** **<Insert number>** percent.
 2. Low-Emitting Primer: Primer complies with LEED for Schools Credit IEQ 4.2.
- B. Miscellaneous Framing and Supports: **[Galvanized where indicated]** **[Primed using zinc-rich primer where indicated]**.
1. Steel framing and supports for **[ceiling-hung toilet compartments]** **[operable partitions]** **[overhead doors]** **[overhead grilles]** **[countertops]** **[low partitions]** **[mechanical and electrical equipment]** **[applications where framing and supports are not specified in other Sections]**.
 2. Elevator machine beams[, **hoist beams,**] **[and]** **[divider beams]**.
 3. Steel shapes for supporting elevator door sills.
 4. Steel **[girders]** **[and]** **[pipe columns]** for supporting wood frame construction.
- C. Prefabricated Building Columns: **[4]** **[3]** **[2]**-hour fire-resistance rating.
- D. Shelf angles[, **galvanized**] [, **primed using zinc-rich primer**] at exterior walls.
- E. Metal Ladders ~~[Including Elevator Pit Ladders]:~~ **[Aluminum]** **[Steel]**.
1. Galvanized **[exterior]** ladders.
 2. Primed **[exterior]** ladders using zinc-rich primer.
- F. Ladder Safety Cages: **[Aluminum]** **[Steel]**.
1. Galvanized.
 2. Primed using zinc-rich primer.
- G. Alternating Tread Devices: **[Steel]** **[Stainless steel]** **[Aluminum]**.
1. Galvanized **[exterior]** alternating tread devices.
 2. Primed **[exterior]** alternating tread devices using zinc-rich primer.
- H. Metal **[Ships' Ladders]** **[and]** **[Pipe Crossovers]**: **[Steel]** **[Stainless steel]** **[Aluminum]**.
1. Galvanized **[exterior]** **[ships' ladders]** **[and]** **[pipe crossovers]**.
 2. Primed **[exterior]** **[ships' ladders]** **[and]** **[pipe crossovers]** using zinc-rich primer.
- I. Metal Floor Plate: **[Steel]** **[Stainless steel]** **[Aluminum alloy]** **[Abrasive-surface steel]**.
- J. Elevator pit sump covers.

- K. Structural-Steel Door Frames:
1. Galvanized [**exterior**] frames.
 2. Primed [**exterior**] frames using zinc-rich primer.
- L. Miscellaneous Steel Trim: [**Steel angle corner guards**] [**steel edgings**] [**and**] [**loading-dock edge angles**].
1. Galvanized [**exterior**] trim .
 2. Primed [**exterior**] trim using zinc-rich primer.
- M. Metal Bollards: [**Schedule 40 steel pipe**] [**Schedule 80 steel pipe**] [**Rectangular steel tubing**] [**Steel shapes, as indicated**].
1. Primed using zinc-rich primer.
- N. Wire rope parking garage guards.
- O. [**Pipe**] [**Downspout**] guards.
1. Galvanized.
 2. Primed using zinc-rich primer.
- P. Abrasive Metal [**Nosings**] [**Treads**] [**and**] [**Thresholds**]: [**Cast iron**] [**Cast aluminum**] [**Cast bronze**] [**Cast nickel silver**] [**Extruded aluminum**] [**Extruded bronze**].
- Q. Cast-iron wheel guards[, **primed using zinc-rich primer**].
- R. Metal Downspout Boots: Cast [**iron**] [**aluminum**] [, **primed using zinc-rich primer**].
- S. Loose bearing and leveling plates[, **galvanized**] [, **primed using zinc-rich primer**].
- T. Loose steel lintels[, **galvanized at exterior walls**] [, **primed using zinc-rich primer at exterior walls**].
- U. Anchor bolts, steel pipe sleeves, slotted-channel inserts, and wedge-type inserts cast into concrete or built into unit masonry.
- V. Steel weld plates and angles not specified in other Sections, for casting into concrete.

END OF SECTION 055000

SECTION 06 10 53 - MISCELLANEOUS CARPENTRY

PART 1 - GENERAL

1.1 RELATED DOCUMENTS

- A. Drawings and general provisions of the Contract, including General and Supplementary Conditions and Division 1 Specification Sections, apply to this Section.

1.2 SUMMARY

- A. This Section includes the following:
 - 1. Shelving and support brackets
 - 2. Interior wood blocking and nailers.
- B. Blocking shall be provided, but not limited to, at the following locations:
 - 1. Casework and shelving.
 - 2. Tackboards and marker boards
 - 3. Wall mounted door hardware
 - 4. Fire Extinguisher Cabinets
 - 5. Wall mounted equipment
 - 6. As noted on drawings
- C. Related Sections include the following:
 - 1. Division 6 Section "Rough Carpentry"
 - 2. Division 6 Section "Interior Architectural Woodwork."

1.3 DEFINITIONS

- A. Dimension Lumber: Lumber of 2 inches nominal or greater but less than 5 inches nominal in least dimension.
- B. Lumber grading agencies, and the abbreviations used to reference them, include the following:
 - 1. NeLMA: Northeastern Lumber Manufacturers' Association.
 - 2. NHLA: National Hardwood Lumber Association.
 - 3. NLGA: National Lumber Grades Authority.
 - 4. SPIB: The Southern Pine Inspection Bureau.
 - 5. WCLIB: West Coast Lumber Inspection Bureau.
 - 6. WWPA: Western Wood Products Association.

1.4 QUALITY ASSURANCE

- A. Fabricator/Installer: A firm which has successfully produced work similar to the quality specified and in the quantity shown for a period of not less than 5 years.

- B. Reference Standards: Comply with the applicable provisions for grading and workmanship of the "Architectural Woodwork Quality Standards", Version 2.0 (2005), published by the Architectural Woodwork Institute (AWI) (herein referred to as Standards), except as otherwise specified.
- C. Structural Performance: Design, manufacture and install handrails to resist a 200 pound concentrated force applied in any direction at any point and a uniform force of 50 pounds per linear foot applied in any direction without distortion or failure.

1.5 SUBMITTALS

- A. Product Data: For each type of process and factory-fabricated product. Indicate component materials and dimensions and include construction and application details.
 - 1. Include data for wood-preservative treatment from chemical treatment manufacturer and certification by treating plant that treated materials comply with requirements. Indicate type of preservative used and net amount of preservative retained.
 - 2. Include data for fire-retardant treatment from chemical treatment manufacturer and certification by treating plant that treated materials comply with requirements. Include physical properties of treated materials based on testing by a qualified independent testing agency.
 - 3. For products receiving a waterborne treatment, include statement that moisture content of treated materials was reduced to level specified before shipment to Project site.
 - 4. Include copies of warranties from chemical treatment manufacturers for each type of treatment.

1.6 DELIVERY, STORAGE, AND HANDLING

- A. Stack lumber flat with spacers between each bundle to provide air circulation. Provide for air circulation around stacks and under coverings.
- B. Deliver interior wood materials that are to be exposed to view only after building is enclosed and weatherproof, wet work other than painting is dry, and HVAC system is operating and maintaining temperature and humidity at occupancy levels.

PART 2 - PRODUCTS

2.1 WOOD PRODUCTS, GENERAL

- A. Lumber: DOC PS 20 and applicable rules of grading agencies indicated. If no grading agency is indicated, provide lumber that complies with the applicable rules of any rules-writing agency certified by the ALSC Board of Review. Provide lumber graded by an agency certified by the ALSC Board of Review to inspect and grade lumber under the rules indicated.
 - 1. Factory mark each piece of lumber with grade stamp of grading agency.
 - 2. Where nominal sizes are indicated, provide actual sizes required by DOC PS 20 for moisture content specified. Where actual sizes are indicated, they are minimum dressed sizes for dry lumber.

3. Provide dressed lumber, S4S, unless otherwise indicated.

2.2 FIRE-RETARDANT-TREATED MATERIALS

- A. General: Comply with performance requirements in AWPA C20 (lumber) and AWPA C27 (plywood).
 1. Use treatment that does not promote corrosion of metal fasteners.
 2. Use Exterior type for exterior locations and where indicated.
 3. Use Interior Type A, unless otherwise indicated.
- B. Identify fire-retardant-treated wood with appropriate classification marking of testing and inspecting agency acceptable to authorities having jurisdiction.
- C. Application: Treat items indicated on Drawings, and the following:
 1. Concealed blocking.
 2. Plywood backing panels.
 3. Plywood Sheathing complying with C31 and C27.

2.3 MISCELLANEOUS LUMBER

- A. General: Provide miscellaneous lumber indicated and lumber for support or attachment of other construction, including but not limited to the following:
 1. Blocking.
 2. Nailers.
- B. For items of dimension lumber size, provide Construction or No. 2 grade lumber with 19 percent maximum moisture content of any species.
- C. For concealed boards, provide lumber with 19 percent maximum moisture content and any of the following species and grades:
 1. Mixed southern pine, No. 2 grade; SPIB.
 2. Hem-fir or hem-fir (north), Construction or 2 Common grade; NLGA, WCLIB, or WWPA.
 3. Spruce-pine-fir (south) or spruce-pine-fir, Construction or 2 Common grade; NeLMA, NLGA, WCLIB, or WWPA.
- D. For blocking not used for attachment of other construction Utility, Stud, or No. 3 grade lumber of any species may be used provided that it is cut and selected to eliminate defects that will interfere with its attachment and purpose.
- E. For blocking and nailers used for attachment of other construction, select and cut lumber to eliminate knots and other defects that will interfere with attachment of other work.
- F. For furring strips for installing plywood or hardboard paneling, select boards with no knots capable of producing bent-over nails and damage to paneling.

2.4 FASTENERS

- A. General: Provide fasteners of size and type indicated that comply with requirements specified in this Article for material and manufacture.
 - 1. Where carpentry is exposed to weather, in ground contact, pressure-preservative treated, or in area of high relative humidity, provide fasteners of Type 304 stainless steel.
- B. Nails, Brads, and Staples: ASTM F 1667.
- C. Power-Driven Fasteners: NES NER-272.
- D. Wood Screws: ASME B18.6.1.
- E. Screws for Fastening to Cold-Formed Metal Framing: ASTM C 954, except with wafer heads and reamer wings, length as recommended by screw manufacturer for material being fastened.
- F. Lag Bolts: ASME B18.2.1.
- G. Bolts: Steel bolts complying with ASTM A 307, Grade A; with ASTM A 563 hex nuts and, where indicated, flat washers.
- H. Stainless-Steel Bolts and Nuts: Regular hexagon head annealed stainless-steel bolts, nuts and, where indicated, flat washers; ASTM F 593 (ASTM F 738M) for bolts and ASTM F 594 (ASTM F 836M) for nuts, Alloy Group 1 (A1).
- I. Expansion Anchors: Anchor bolt and sleeve assembly of material indicated below with capability to sustain, without failure, a load equal to 5 times the load imposed when installed in unit masonry assemblies and equal to 4 times the load imposed when installed in concrete as determined by testing per ASTM E 488 conducted by a qualified independent testing and inspecting agency.
 - 1. Material: Carbon-steel components, zinc plated to comply with ASTM B 633, Class Fe/Zn 5.
 - 2. Material: Stainless steel with bolts and nuts complying with ASTM F 593 and ASTM F 594, Alloy Group 1 or 2.

2.5 MISCELLANEOUS MATERIALS

- A. Adhesives for Gluing Sleepers to Concrete or Masonry: Formulation complying with ASTM D 3498 that is approved for use indicated by adhesive manufacturer.
- B. Separator sheet: 15# Building felt or 15 mil "underslab" vapor barrier.

PART 3 - EXECUTION

3.1 INSTALLATION, GENERAL

- A. Set rough carpentry to required levels and lines, with members plumb, true to line, cut, and fitted. Fit carpentry to other construction; scribe and cope as needed for accurate fit. Locate nailers,

blocking, grounds, and similar supports to comply with requirements for attaching other construction.

- B. Provide blocking and framing as indicated and as required to support facing materials, fixtures, specialty items, and trim.
 - 1. Provide metal clips for fastening gypsum board or lath at corners and intersections where framing or blocking does not provide a surface for fastening edges of panels. Space clips not more than 16 inches OC.
- C. Sort and select lumber so that natural characteristics will not interfere with installation or with fastening other materials to lumber. Do not use materials with defects that interfere with function of member or pieces that are too small to use with minimum number of joints or optimum joint arrangement.
- D. Comply with AWP A M4 for applying field treatment to cut surfaces of preservative-treated lumber.
 - 1. Use inorganic boron for items that are continuously protected from liquid water.
 - 2. Use copper naphthenate for items not continuously protected from liquid water.
- E. Securely attach carpentry work to substrate by anchoring and fastening as indicated, complying with the following:
 - 1. NES NER-272 for power-driven fasteners.
 - 2. Table 2304.9.1, "Fastening Schedule," in ICC's International Building Code.
- F. Use common wire nails, unless otherwise indicated. Select fasteners of size that will not fully penetrate members where opposite side will be exposed to view or will receive finish materials. Make tight connections between members. Install fasteners without splitting wood; do not countersink nail heads, unless otherwise indicated.

3.2 WOOD SLEEPER, BLOCKING, AND NAILER INSTALLATION

- A. Install where indicated and where required for attaching other work. Form to shapes indicated and cut as required for true line and level of attached work. Coordinate locations with other work involved. Secure all pressure treated lumber with stainless steel or epoxy coated anchorage.
- B. Attach items to substrates to support applied loading. Recess bolts and nuts flush with surfaces, unless otherwise indicated.
- C. Provide separator sheet between all pressure treated wood blocking and metal deck, steel studs, copings, curbs, and other steel or aluminum components.

3.3 PROTECTION

- A. Protect wood that has been treated with inorganic boron (SBX) from weather. If, despite protection, inorganic boron-treated wood becomes wet, apply EPA-registered borate treatment. Apply borate solution by spraying to comply with EPA-registered label.

- B. Protect rough carpentry from weather. If, despite protection, rough carpentry becomes wet, apply EPA-registered borate treatment. Apply borate solution by spraying to comply with EPA-registered label.

END OF SECTION 06 10 53

NOT FOR BIDDING

SECTION 06 16 00 - SHEATHING

PART 1 - GENERAL

1.1 RELATED DOCUMENTS

- A. Drawings and general provisions of the Contract, including General and Supplementary Conditions and Division 01 Specification Sections, apply to this Section.

1.2 SUMMARY

A. Section Includes:

1. Wall sheathing.
2. Roof sheathing

B. Related Requirements:

1. Section 061053 "Miscellaneous Rough Carpentry"
2. Section 072500 "Weather Barriers"

1.3 ACTION SUBMITTALS

- A. Product Data: For each type of process and factory-fabricated product. Indicate component materials and dimensions and include construction and application details.

1. Include data for wood preservative treatment from chemical treatment manufacturer and certification by treating plant that treated plywood complies with requirements. Indicate type of preservative used and net amount of preservative retained.
2. Include data for fire-retardant treatment from chemical treatment manufacturer and certification by treating plant that treated plywood complies with requirements. Include physical properties of treated materials.
3. For fire-retardant treatments, include physical properties of treated plywood both before and after exposure to elevated temperatures, based on testing by a qualified independent testing agency according to ASTM D 5516.
4. For products receiving a water-borne treatment, include statement that moisture content of treated materials was reduced to levels specified before shipment to Project site.
5. Include copies of warranties from chemical treatment manufacturers for each type of treatment.

1.4 INFORMATIONAL SUBMITTALS

- A. Evaluation Reports: For following products, from ICC-ES:

1. Preservative-treated plywood.
2. Fire-retardant-treated plywood.
3. Foam-plastic sheathing.

1.5 QUALITY ASSURANCE

- A. Testing Agency Qualifications: For testing agency providing classification marking for fire-retardant-treated material, an inspection agency acceptable to authorities having jurisdiction that periodically performs inspections to verify that the material bearing the classification marking is representative of the material tested.

1.6 DELIVERY, STORAGE, AND HANDLING

- A. Stack panels flat with spacers beneath and between each bundle to provide air circulation. Protect sheathing from weather by covering with waterproof sheeting, securely anchored. Provide for air circulation around stacks and under coverings.

PART 2 - PRODUCTS

2.1 PERFORMANCE REQUIREMENTS

- A. Fire-Test-Response Characteristics: For assemblies with fire-resistance ratings, provide materials and construction identical to those of assemblies tested for fire resistance per ASTM E 119 by a testing and inspecting agency acceptable to authorities having jurisdiction.

- 1. Fire-Resistance Ratings: Indicated by design designations from UL's "**Fire Resistance Directory.**"

2.2 WALL SHEATHING

- A. Glass-Mat Gypsum Wall Sheathing: ASTM C 1177/1177M.

- 1. Products: Subject to compliance with requirements, available products that may be incorporated into the Work include, but are not limited to, the following:

- a. CertainTeed Corporation; GlasRoc.
 - b. G-P Gypsum Corporation; Dens-Glass Gold.
 - c. National Gypsum Company; Gold Bond e(2)XP.
 - d. Temple-Inland Inc.; GreenGlass
 - e. United States Gypsum Co.; Securock.

- 2. Type and Thickness: Type X, 5/8 inch (15.9 mm) thick.
 - 3. Size: 48 by 96 inches (1219 by 2438 mm) for vertical installation.

- B. Roof sheathing

- 1. Fire treated cdx plywood thickness as noted on the drawings
 - 2. Span rating 32

2.3 FASTENERS

- A. General: Provide fasteners of size and type indicated that comply with requirements specified in this article for material and manufacture.
- B. Nails, Brads, and Staples: ASTM F 1667.
- C. Power-Driven Fasteners: NES NER-272.
- D. Screws for Fastening Gypsum Sheathing to Cold-Formed Metal Framing: Steel drill screws, in length recommended by sheathing manufacturer for thickness of sheathing to be attached, with organic-polymer or other corrosion-protective coating having a salt-spray resistance of more than 800 hours according to ASTM B 117.
 - 1. For steel framing less than 0.0329 inch (0.835 mm) thick, use screws that comply with ASTM C 1002.
 - 2. For steel framing from 0.033 to 0.112 inch (0.84 to 2.84 mm) thick, use screws that comply with ASTM C 954.

2.4 SHEATHING JOINT-AND-PENETRATION TREATMENT MATERIALS

- A. Sealant for Glass-Mat Gypsum Sheathing: Elastomeric, medium-modulus, neutral-curing silicone joint sealant compatible with joint substrates formed by gypsum sheathing and other materials, recommended by sheathing manufacturer for application indicated and complying with requirements for elastomeric sealants specified in Section 079200 "Joint Sealants."
- B. Sealant for Glass-Mat Gypsum Sheathing: Silicone emulsion sealant complying with ASTM C 834, compatible with sheathing tape and sheathing and recommended by tape and sheathing manufacturers for use with glass-fiber sheathing tape and for covering exposed fasteners.
 - 1. Sheathing Tape: Self-adhering glass-fiber tape, minimum 2 inches (50 mm) wide, 10 by 10 or 10 by 20 threads/inch (390 by 390 or 390 by 780 threads/m), of type recommended by sheathing and tape manufacturers for use with silicone emulsion sealant in sealing joints in glass-mat gypsum sheathing and with a history of successful in-service use.

PART 3 - EXECUTION

3.1 INSTALLATION, GENERAL

- A. Do not use materials with defects that impair quality of sheathing or pieces that are too small to use with minimum number of joints or optimum joint arrangement. Arrange joints so that pieces do not span between fewer than three support members.
- B. Cut panels at penetrations, edges, and other obstructions of work; fit tightly against abutting construction unless otherwise indicated.
- C. Securely attach to substrate by fastening as indicated, complying with the following:

1. NES NER-272 for power-driven fasteners.
 2. Table 2304.9.1, "Fastening Schedule," in ICC's "International Building Code."
 3. Table R602.3(1), "Fastener Schedule for Structural Members," and Table R602.3(2), "Alternate Attachments," in ICC's "International Residential Code for One- and Two-Family Dwellings."
- D. Use common wire nails unless otherwise indicated. Select fasteners of size that will not fully penetrate members where opposite side will be exposed to view or will receive finish materials. Make tight connections. Install fasteners without splitting wood.
- E. Coordinate wall sheathing installation with flashing and joint-sealant installation so these materials are installed in sequence and manner that prevent exterior moisture from passing through completed assembly.
- F. **Do not bridge building expansion joints**; cut and space edges of panels to match spacing of structural support elements.
- G. Coordinate sheathing installation with installation of materials installed over sheathing so sheathing is not exposed to precipitation or left exposed at end of the workday when rain is forecast.

3.2 GYPSUM SHEATHING INSTALLATION

- A. Comply with GA-253 and with manufacturer's written instructions.
1. Fasten gypsum sheathing to wood framing with [nails] [or] [screws].
 2. Fasten gypsum sheathing to cold-formed metal framing with screws.
 3. Install boards with a 3/8-inch (9.5-mm) gap where non-load-bearing construction abuts structural elements.
 4. Install boards with a 1/4-inch (6.4-mm) gap where they abut masonry or similar materials that might retain moisture, to prevent wicking.
- B. Apply fasteners so heads bear tightly against face of sheathing, but do not cut into facing.
- C. Horizontal Installation: Install sheathing with V-grooved edge down and tongue edge up. Interlock tongue with groove to bring long edges in contact with edges of adjacent boards without forcing. Abut ends of boards over centers of studs, and stagger end joints of adjacent boards not less than one stud spacing. Attach boards at perimeter and within field of board to each steel stud.
1. Space fasteners approximately 8 inches (200 mm) OC and set back a minimum of 3/8 inch (9.5 mm) from edges and ends of boards.
 2. For sheathing under stucco cladding, boards may be initially tacked in place with screws if overlying self-furring metal lath is screw-attached through sheathing to studs immediately after sheathing is installed.
- D. Vertical Installation: Install board vertical edges centered over studs. Abut ends and edges of each board with those of adjacent boards. Attach boards at perimeter and within field of board to each stud.

1. Space fasteners approximately 8 inches (200 mm) OC and set back a minimum of 3/8 inch (9.5 mm) from edges and ends of boards.
 2. For sheathing under stucco cladding, boards may be initially tacked in place with screws if overlying self-furring metal lath is screw-attached through sheathing to studs immediately after sheathing is installed.
- E. Seal sheathing joints according to sheathing manufacturer's written instructions.
1. Apply elastomeric sealant to joints and fasteners and trowel flat. Apply sufficient amount of sealant to completely cover joints and fasteners after troweling. Seal other penetrations and openings.
 2. Apply glass-fiber sheathing tape to glass-mat gypsum sheathing joints and apply and trowel silicone emulsion sealant to embed entire face of tape in sealant. Apply sealant to exposed fasteners with a trowel so fasteners are completely covered. Seal other penetrations and openings.

END OF SECTION 06 16 00

NOT FOR BIDDING

SECTION 06 40 23 - INTERIOR ARCHITECTURAL WOODWORK

PART 1 - GENERAL

1.1 RELATED DOCUMENTS

- A. Drawings and general provisions of the Contract, including General and Supplementary Conditions and Division 01 Specification Sections, apply to this Section.
- B. Division 01, Section 017419 – Construction Waste Management.
- C. Division 12, Section 123200 – Modular Wood Casework

1.2 SUMMARY

- A. This Section includes the following:
 - 1. Plastic-laminate cabinets.
 - 2. Plastic-laminate countertops.
 - 3. Solid-surfacing-material countertops.
- B. Related Sections include the following:
 - 1. Division 06 Section "Rough Carpentry" for wood furring, blocking, shims, and hanging strips required for installing woodwork and concealed within other construction before woodwork installation.

1.3 DEFINITIONS

- A. Interior architectural woodwork includes wood furring, blocking, shims, and hanging strips for installing woodwork items unless concealed within other construction before woodwork installation.

1.4 SUBMITTALS

- A. Product Data: For each type of product indicated, including cabinet hardware and accessories and finishing materials and processes.
 - 1. Include data for fire-retardant treatment from chemical treatment manufacturer and certification by treating plant that treated materials comply with requirements.
- B. Shop Drawings: Show location of each item, dimensioned plans and elevations, large-scale details, attachment devices, and other components.
 - 1. Show locations and sizes of furring, blocking, and hanging strips, including concealed blocking and reinforcement specified in other Sections.
 - 2. Show locations and sizes of cutouts and holes for plumbing fixtures, faucets and other items installed in architectural woodwork.
 - 3. Show veneer leaves with dimensions, grain direction, exposed face, and identification numbers indicating the flitch and sequence within the flitch for each leaf.

4. Apply WI-certified compliance label to first page of Shop Drawings.
- C. Samples for Initial Selection:
 1. Plastic laminates.
 2. PVC edge material.
 3. Solid-surfacing materials.
- D. Samples for Verification:
 1. Plastic laminates, 8 by 10 inches (200 by 250 mm), for each type, color, pattern, and surface finish, with 1 sample applied to core material and specified edge material applied to 1 edge.
 2. Thermoset decorative-panels, 8 by 10 inches (200 by 250 mm), for each type, color, pattern, and surface finish, with edge banding on 1 edge.
 3. Solid-surfacing materials, 6 inches (150 mm) square.
 4. Corner pieces as follows:
 - a. Cabinet-front frame joints between stiles and rails, as well as exposed end pieces, 18 inches (450 mm) high by 18 inches (450 mm) wide by 6 inches (150 mm) deep.
 - b. Miter joints for standing trim.
- E. Product Certificates: For each type of product, signed by product manufacturer.
- F. Woodwork Quality Standard Compliance Certificates: WI-certified compliance certificates.
- G. Qualification Data: For fabricator.

1.5 QUALITY ASSURANCE

- A. Fabricator Qualifications: Shop that employs skilled workers who custom-fabricate products similar to those required for this Project and whose products have a record of successful in-service performance. Shop is a licensee of WI's Certified Compliance Program.
- B. Source Limitations: Engage a qualified woodworking firm to assume undivided responsibility for production of interior architectural woodwork with sequence-matched wood veneers Quality Standard: Unless otherwise indicated, comply with AWI's "Architectural Woodwork Quality Standards" for grades of interior architectural woodwork indicated for construction, finishes, installation, and other requirements.
 1. Provide AWI Quality Certification Program labels indicating that woodwork, including installation, complies with requirements of grades specified.
- C. Quality Standard: Unless otherwise indicated, comply with WI's "Manual of Millwork" for grades of interior architectural woodwork indicated for construction, finishes, installation, and other requirements.
 1. Provide WI-certified compliance labels indicating that woodwork complies with requirements of grades specified.
 2. The Contract Documents contain selections chosen from options in the quality standard and additional requirements beyond those of the quality standard. Comply with such selections and requirements in addition to the quality standard.

- D. Fire-Test-Response Characteristics: Where fire-retardant materials or products are indicated, provide materials and products with specified fire-test-response characteristics as determined by testing identical products per test method indicated by UL, ITS, or another testing and inspecting agency acceptable to authorities having jurisdiction. Identify with appropriate markings of applicable testing and inspecting agency in the form of separable paper label or, where required by authorities having jurisdiction, imprint on surfaces of materials that will be concealed from view after installation.
- E. Preinstallation Conference: Conduct conference at Project site to comply with requirements in Division 01 Section "Project Management and Coordination."

1.6 DELIVERY, STORAGE, AND HANDLING

- A. Do not deliver woodwork until painting and similar operations that could damage woodwork have been completed in installation areas. If woodwork must be stored in other than installation areas, store only in areas where environmental conditions comply with requirements specified in "Project Conditions" Article.

1.7 PROJECT CONDITIONS

- A. Environmental Limitations: Do not deliver or install woodwork until building is enclosed, wet work is complete, and HVAC system is operating and maintaining temperature between 60 and 90 deg F (16 and 32 deg C) and relative humidity between 25 and 55 percent during the remainder of the construction period.
- B. Field Measurements: Where woodwork is indicated to fit to other construction, verify dimensions of other construction by field measurements before fabrication, and indicate measurements on Shop Drawings. Coordinate fabrication schedule with construction progress to avoid delaying the Work.
 - 1. Locate concealed framing, blocking, and reinforcements that support woodwork by field measurements before being enclosed, and indicate measurements on Shop Drawings.
 - 2. Established Dimensions: Where field measurements cannot be made without delaying the Work, establish dimensions and proceed with fabricating woodwork without field measurements. Provide allowance for trimming at site, and coordinate construction to ensure that actual dimensions correspond to established dimensions.

1.8 COORDINATION

- A. Coordinate sizes and locations of framing, blocking, furring, reinforcements, and other related units of Work specified in other Sections to ensure that interior architectural woodwork can be supported and installed as indicated.
- B. Hardware Coordination: Distribute copies of approved hardware schedule specified in Division 08 Section "Door Hardware (Scheduled by Describing Products)" to fabricator of architectural woodwork; coordinate Shop Drawings and fabrication with hardware requirements.

PART 2 - PRODUCTS

2.1 WOODWORK FABRICATORS

- A. Available Fabricators: Subject to compliance with requirements, fabricators offering interior architectural woodwork that may be incorporated into the Work include, but are not limited to, the following: T.B.D.

2.2 MATERIALS

- A. General: Provide materials that comply with requirements of WI's quality standard for each type of woodwork and quality grade specified, unless otherwise indicated.
- B. Wood Species and Cut for Transparent Finish: Maple match door finish.
- C. Wood Species for Opaque Finish: Any closed-grain hardwood.
- D. Wood Products: Comply with the following:
 - 1. Recycled Content of Medium-Density Fiberboard and Particleboard: Provide products with an average recycled content so post-consumer recycled content plus one-half of pre-consumer recycled content is not less than 20 percent.
 - 2. Hardboard: AHA A135.4.
 - 3. Medium-Density Fiberboard: ANSI A208.2, Grade MD, made with binder containing no urea formaldehyde.
 - 4. Particleboard: ANSI A208.1, Grade M-2-Exterior Glue.
 - 5. Softwood Plywood: DOC PS 1.
 - 6. Veneer-Faced Panel Products (Hardwood Plywood): HPVA HP-1, made with adhesive containing no urea formaldehyde.
- E. Thermoset Decorative Panels: Particleboard or medium-density fiberboard finished with thermally fused, melamine-impregnated decorative paper complying with LMA SAT-1.
 - 1. Provide PVC or polyester edge banding complying with LMA EDG-1 on components with exposed or semi-exposed edges.
- F. High-Pressure Decorative Laminate: NEMA LD 3, grades as indicated or, if not indicated, as required by woodwork quality standard.
 - 1. Manufacturer: Subject to compliance with requirements, provide high-pressure decorative laminates by one of the following:
 - a. Refer to Finish Legend.
- G. Solid-Surfacing Material: Homogeneous solid sheets of filled plastic resin complying with ISSFA-2.
 - 1. Manufacturers: Subject to compliance with requirements, provide products by one of the following:
 - a. Refer to Finish Legend.
 - 2. Type: Standard type, unless Special Purpose type is indicated.

3. Colors and Patterns: As indicated by manufacturer's designations.
4. Ltd.; Medite Div.

2.3 CABINET HARDWARE AND ACCESSORIES

- A. General: Provide cabinet hardware and accessory materials associated with architectural cabinets, except for items specified in Division 08 Section "Door Hardware (Scheduled by Describing Products)."
- B. Butt Hinges: 2-3/4-inch (70-mm), 5-knuckle steel hinges made from 0.095-inch- (2.4-mm-) thick metal, and as follows:
 1. Semi-concealed Hinges for Overlay Doors: BHMA A156.9, B01521.
- C. Back-Mounted Pulls: BHMA A156.9, B02011.
- D. Wire Pulls: Back mounted, solid metal, 5 inches (127 mm) long, 2-1/2 inches (63.5 mm) deep, and 5/16 inch (8 mm) in diameter.
- E. Catches: Magnetic catches, BHMA A156.9, B03141.
- F. Adjustable Shelf Standards and Supports: BHMA A156.9, B04071; with shelf rests, B04081.
- G. Shelf Rests: BHMA A156.9, B04013; metal, two-pin type with shelf hold-down clip.
- H. Drawer Slides: BHMA A156.9, B05091
 1. Standard Duty (Grade 1, Grade 2, and Grade 3): Side mounted and extending under bottom edge of drawer; full-extension type; zinc-plated steel with polymer rollers.
 2. Box Drawer Slides: Grade 1; for drawers not more than 6 inches (150 mm) high and 24 inches (600 mm) wide.
 3. File Drawer Slides: Grade 1HD-100; for drawers more than 6 inches (150 mm) high or 24 inches (600 mm) wide.
 4. Pencil Drawer Slides: Grade 2 for drawers not more than 3 inches (75 mm) high and 24 inches (600 mm) wide.
 5. Keyboard Slides: Grade 1; for computer keyboard shelves.
- I. Door Locks: BHMA A156.11, E07121.
- J. Drawer Locks: BHMA A156.11, E07041.
- K. Grommets for Cable Passage through Countertops: **2-inch (51-mm) OD**, black, molded-plastic grommets and matching plastic caps with slot for wire passage.
 1. Product: Subject to compliance with requirements, provide "SG series" by Doug Mockett & Company, Inc.
- L. Exposed Hardware Finishes: For exposed hardware, provide finish that complies with BHMA A156.18 for BHMA finish number indicated.
 1. Satin Stainless Steel: BHMA 630.

- M. For concealed hardware, provide manufacturer's standard finish that complies with product class requirements in BHMA A156.9.

2.4 MISCELLANEOUS MATERIALS

- A. Furring, Blocking, Shims, and Hanging Strips: Softwood or hardwood lumber, kiln dried to less than 15 percent moisture content.
- B. Furring, Blocking, Shims, and Hanging Strips: Fire-retardant-treated softwood lumber, kiln dried to less than 15 percent moisture content.
- C. Anchors: Select material, type, size, and finish required for each substrate for secure anchorage. Provide nonferrous-metal or hot-dip galvanized anchors and inserts on inside face of exterior walls and elsewhere as required for corrosion resistance. Provide toothed-steel or lead expansion sleeves for drilled-in-place anchors.
- D. Adhesives, General: Do not use adhesives that contain urea formaldehyde.
- E. VOC Limits for Installation Adhesives and Glues: Use installation adhesives that comply with the following limits for VOC content when calculated according to 40 CFR 59, Subpart D (EPA Method 24):
 - 1. Wood Glues: 30 g/L.
 - 2. Contact Adhesive: 250 g/L.
- F. Adhesive for Bonding Plastic Laminate: Unpigmented contact cement.
 - 1. Adhesive for Bonding Edges: Hot-melt adhesive or adhesive specified above for faces.

2.5 FABRICATION, GENERAL

- A. Interior Woodwork Grade: Unless otherwise indicated, provide Premium-grade interior woodwork complying with referenced quality standard.
- B. Wood Moisture Content: Comply with requirements of referenced quality standard for wood moisture content in relation to ambient relative humidity during fabrication and in installation areas.
- C. Sand fire-retardant-treated wood lightly to remove raised grain on exposed surfaces before fabrication.
- D. Fabricate woodwork to dimensions, profiles, and details indicated. Ease edges to radius indicated for the following:
 - 1. Corners of Cabinets and Edges of Solid-Wood (Lumber) Members 3/4 Inch (19 mm) Thick or Less: 1/16 inch (1.5 mm).
 - 2. Edges of Rails and Similar Members More Than 3/4 Inch (19 mm) Thick: 1/8 inch (3 mm).
 - 3. Corners of Cabinets and Edges of Solid-Wood (Lumber) Members and Rails: 1/16 inch (1.5 mm).

- E. Complete fabrication, including assembly, finishing, and hardware application, to maximum extent possible before shipment to Project site. Disassemble components only as necessary for shipment and installation. Where necessary for fitting at site, provide ample allowance for scribing, trimming, and fitting.
 - 1. Notify Architect seven days in advance of the dates and times woodwork fabrication will be complete.
 - 2. Trial fit assemblies at fabrication shop that cannot be shipped completely assembled. Install dowels, screws, bolted connectors, and other fastening devices that can be removed after trial fitting. Verify that various parts fit as intended and check measurements of assemblies against field measurements indicated on Shop Drawings before disassembling for shipment.
- F. Shop-cut openings to maximum extent possible to receive hardware, appliances, plumbing fixtures, electrical work, and similar items. Locate openings accurately and use templates or roughing-in diagrams to produce accurately sized and shaped openings. Sand edges of cutouts to remove splinters and burrs.
 - 1. Seal edges of openings in countertops with a coat of varnish.
- G. Install glass to comply with applicable requirements in Division 08 Section "Glazing" and in GANA's "Glazing Manual." For glass in wood frames, secure glass with removable stops.

2.6 INTERIOR STANDING AND RUNNING TRIM FOR TRANSPARENT FINISH

- A. Grade: Premium.
- B. Wood Species and Cut: Maple, match wood door finish.
 - 1. Provide split species on trim that faces areas with different wood species, matching each face of woodwork to species and cut of finish wood surfaces in areas finished.
- C. For trim items wider than available lumber, use veneered construction. Do not glue for width.
- D. For rails wider or thicker than available lumber, use veneered construction. Do not glue for width or thickness.
- E. Backout or groove backs of flat trim members and kerf backs of other wide, flat members, except for members with ends exposed in finished work.
- F. Assemble casings in plant except where limitations of access to place of installation require field assembly.
- G. Assemble moldings in plant to maximum extent possible. Miter corners in plant and prepare for field assembly with bolted fittings designed to pull connections together.

2.7 INTERIOR STANDING AND RUNNING TRIM FOR OPAQUE FINISH

- A. Grade: Custom.
- B. Wood Species: Any closed-grain hardwood.
- C. Backout or groove backs of flat trim members and kerf backs of other wide, flat members, except for members with ends exposed in finished work.
- D. Assemble casings in plant except where limitations of access to place of installation require field assembly.
- E. Assemble moldings in plant to maximum extent possible. Miter corners in plant and prepare for field assembly with bolted fittings designed to pull connections together.

2.8 PLASTIC-LAMINATE CABINETS

- A. Grade: Premium.
- B. AWI Type of Cabinet Construction: Flush overlay.
- C. WI Construction Style: Style A, Frameless.
- D. WI Construction Type: Type I, multiple self-supporting units rigidly joined together.
- E. WI Door and Drawer Front Style: Flush overlay.
- F. Reveal Dimension: As indicated.
- G. Laminate Cladding for Exposed Surfaces: High-pressure decorative laminate complying with the following requirements:
 - 1. Horizontal Surfaces Other Than Tops: Grade HGS.
 - 2. Postformed Surfaces: Grade HGP.
 - 3. Vertical Surfaces: Grade HGS.
 - 4. Edges: PVC edge banding, 0.12 inch (3 mm) thick, matching laminate in color, pattern, and finish.
- H. Materials for Semi-exposed Surfaces:
 - 1. Surfaces Other Than Drawer Bodies: Thermoset decorative panels.
 - a. Edges of Plastic-Laminate Shelves: PVC edge banding, 0.12 inch (3 mm) thick, matching laminate in color, pattern, and finish.
 - b. For semi-exposed backs of panels with exposed plastic-laminate surfaces, provide surface of high-pressure decorative laminate, Grade VGS.
 - 2. Drawer Sides and Backs: Thermoset decorative panels.
 - 3. Drawer Bottoms: Thermoset decorative panels.

- I. Concealed Backs of Panels with Exposed Plastic Laminate Surfaces: High-pressure decorative laminate, Grade BKL.
- J. Colors, Patterns, and Finishes: Provide materials and products that result in colors and textures of exposed laminate surfaces complying with the following requirements:
 - 1. As indicated by laminate manufacturer's designations.
- K. Provide dust panels of 1/4-inch (6.4-mm) plywood or tempered hardboard above compartments and drawers, unless located directly under tops.

2.9 PLASTIC-LAMINATE COUNTERTOPS

- A. Grade: Premium.
- B. High-Pressure Decorative Laminate Grade: HGS.
- C. Colors, Patterns, and Finishes: Provide materials and products that result in colors and textures of exposed laminate surfaces complying with the following requirements:
 - 1. As indicated by manufacturer's designations.
- D. Edge Treatment: Same as laminate cladding on horizontal surfaces.
- E. Backer Sheet: Provide plastic-laminate backer sheet, Grade BKL, on underside of countertop substrate.
- F. Paper Backing: Provide paper backing on underside of countertop substrate.

2.10 SOLID-SURFACING-MATERIAL COUNTERTOPS

- A. Grade: Premium.
- B. Solid-Surfacing-Material Thickness: 3/4 inch (19 mm).
 - 1. Basis of Design Manufacturer: Corian as manufactured DuPont
- C. Colors, Patterns, and Finishes: Provide materials and products that result in colors of solid-surfacing material complying with the following requirements:
 - 1. As indicated on Finish Legend.
- D. Fabricate tops in one piece, unless otherwise indicated. Comply with solid-surfacing-material manufacturer's written recommendations for adhesives, sealers, fabrication, and finishing.
 - 1. Fabricate tops with shop-applied edges of materials and configuration indicated.
 - 2. Fabricate tops with shop-applied backsplashes.
- E. Install integral sink bowls in countertops in shop.

- F. Drill holes in countertops for plumbing fittings and soap dispensers in shop.

2.11 SHOP FINISHING

- A. Grade: Provide finishes of same grades as items to be finished.
- B. General: Finish architectural woodwork at fabrication shop as specified in this Section. Defer only final touchup, cleaning, and polishing until after installation.
- C. General: Shop finish transparent-finished interior architectural woodwork at fabrication shop as specified in this Section. Refer to Division 09 painting Sections for finishing opaque-finished architectural woodwork.
- D. General: Drawings indicate items that are required to be shop finished. Finish such items at fabrication shop as specified in this Section. Refer to Division 09 painting Sections for finishing architectural woodwork not indicated to be shop finished.
- E. Shop Priming: Shop apply the prime coat including backpriming, if any, for transparent-finished items specified to be field finished. Refer to Division 09 painting Sections for material and application requirements.
- F. Preparation for Finishing: Comply with referenced quality standard for sanding, filling countersunk fasteners, sealing concealed surfaces, and similar preparations for finishing architectural woodwork, as applicable to each unit of work.
 - 1. Back-priming: Apply one coat of sealer or primer, compatible with finish coats, to concealed surfaces of woodwork. Apply two coats to back of paneling and to end-grain surfaces. Concealed surfaces of plastic-laminate-clad woodwork do not require back-priming when surfaced with plastic laminate, backing paper, or thermoset decorative panels.
- G. Opaque Finish:
 - 1. Grade: Custom
 - 2. Color: As selected by Architect from manufacturer's full range.
 - 3. Sheen: Satin, 31-45 gloss units measured on 60-degree gloss meter per ASTM D 523.

PART 3 - EXECUTION

3.1 PREPARATION

- A. Before installation, condition woodwork to average prevailing humidity conditions in installation areas.
- B. Before installing architectural woodwork, examine shop-fabricated work for completion and complete work as required, including removal of packing and back-priming.

3.2 INSTALLATION

- A. Grade: Install woodwork to comply with requirements for the same grade specified in Part 2 for fabrication of type of woodwork involved.
- B. Assemble woodwork and complete fabrication at Project site to comply with requirements for fabrication in Part 2, to extent that it was not completed in the shop.
- C. Install woodwork level, plumb, true, and straight. Shim as required with concealed shims. Install level and plumb (including tops) to a tolerance of 1/8 inch in 96 inches (3 mm in 2400 mm).
- D. Scribe and cut woodwork to fit adjoining work, refinish cut surfaces, and repair damaged finish at cuts.
- E. Fire-Retardant-Treated Wood: Handle, store, and install fire-retardant-treated wood to comply with chemical treatment manufacturer's written instructions, including those for adhesives used to install woodwork.
- F. Anchor woodwork to anchors or blocking built in or directly attached to substrates. Secure with countersunk, concealed fasteners and blind nailing as required for complete installation. Use fine finishing nails or finishing screws for exposed fastening, countersunk and filled flush with woodwork and matching final finish if transparent finish is indicated.
- G. Standing and Running Trim: Install with minimum number of joints possible, using full-length pieces (from maximum length of lumber available to greatest extent possible. Do not use pieces less than **96 inches (2400 mm)** long, except where shorter single-length pieces are necessary. Scarf running joints and stagger in adjacent and related members.
 - 1. Fill gaps, if any, between top of base and wall with plastic wood filler, sand smooth, and finish same as wood base if finished.
 - 2. Install wall railings on indicated metal brackets securely fastened to wall framing.
 - 3. Install standing and running trim with no more variation from a straight line than 1/8 inch in 96 inches (3 mm in 2400 mm).
- H. Cabinets: Install without distortion so doors and drawers fit openings properly and are accurately aligned. Adjust hardware to center doors and drawers in openings and to provide unencumbered operation. Complete installation of hardware and accessory items as indicated.
 - 1. Install cabinets with no more than 1/8 inch in 96-inch (3 mm in 2400-mm) sag, bow, or other variation from a straight line.
 - 2. Maintain veneer sequence matching of cabinets with transparent finish.
 - 3. Fasten wall cabinets through back, near top and bottom, at ends and not more than 16 inches (400 mm) OC with No. 10 wafer-head screws sized for 1-inch (25-mm) penetration into wood framing, blocking, or hanging strips.
- I. Countertops: Anchor securely by screwing through corner blocks of base cabinets or other supports into underside of countertop.
 - 1. Align adjacent solid-surfacing-material countertops and form seams to comply with manufacturer's written recommendations using adhesive in color to match countertop. Carefully dress joints smooth, remove surface scratches, and clean entire surface.

2. Install countertops with no more than 1/8 inch in 96-inch (3 mm in 2400-mm) sag, bow, or other variation from a straight line.
 3. Secure backsplashes to tops with concealed metal brackets at 16 inches (400 mm) OC and to walls with adhesive.
 4. Calk space between backsplash and wall with sealant specified in Division 07 Section "Joint Sealants."
- J. Touch up finishing work specified in this Section after installation of woodwork. Fill nail holes with matching filler where exposed.
- K. Refer to Division 09 Sections for final finishing of installed architectural woodwork not indicated to be shop finished.

3.3 ADJUSTING AND CLEANING

- A. Repair damaged and defective woodwork, where possible, to eliminate functional and visual defects; where not possible to repair, replace woodwork. Adjust joinery for uniform appearance.
- B. Clean, lubricate, and adjust hardware.
- C. Clean woodwork on exposed and semi-exposed surfaces. Touch up shop-applied finishes to restore damaged or soiled areas.

END OF SECTION 06 40 23

SECTION 07 21 00 – THERMAL INSULATION

PART 1 - GENERAL

1.1 RELATED DOCUMENTS

- A. Drawings and general provisions of the Contract, including General and Supplementary Conditions and Division 1 Specification Sections, apply to this Section.

1.2 SUMMARY

- A. This Section includes the following:
 - 1. Perimeter insulation under slabs-on-grade and foundation walls.
 - 2. Concealed building insulation.
- B. Related Sections include the following:
 - 1. Division 01 Section 017419 – Construction Waste Management..
 - 2. Division 9 Section "Gypsum Board Assemblies" for installation of sound attenuation blankets in interior partitions.
 - 3. Division 23 Section "Mechanical Insulation."

1.3 DEFINITIONS

- A. Mineral-Fiber Insulation: Insulation composed of rock-wool fibers, slag-wool fibers, or glass fibers; produced in boards and blanket with latter formed into batts (flat-cut lengths) or rolls.

1.4 SUBMITTALS

- A. Product Data: For each type of product indicated.
- B. Samples for Verification: Upon request provide full-size units for each type of exposed insulation indicated.
- C. Product Test Reports: Upon request provide based on evaluation of comprehensive tests performed by a qualified testing agency for insulation products.

1.5 QUALITY ASSURANCE

- A. Source Limitations: Obtain each type of building insulation through one source from a single manufacturer.
- B. Fire-Test-Response Characteristics: Provide insulation and related materials with the fire-test-response characteristics indicated, as determined by testing identical products per test method indicated below by UL or another testing and inspecting agency acceptable to authorities having

jurisdiction. Identify materials with appropriate markings of applicable testing and inspecting agency.

1. Surface-Burning Characteristics: ASTM E 84.
2. Fire-Resistance Ratings: ASTM E 119.
3. Combustion Characteristics: ASTM E 136.

1.6 DELIVERY, STORAGE, AND HANDLING

- A. Protect insulation materials from physical damage and from deterioration by moisture, soiling, and other sources. Store inside and in a dry location. Comply with manufacturer's written instructions for handling, storing, and protecting during installation.
- B. Protect plastic insulation as follows:
 1. Do not expose to sunlight, except to extent necessary for period of installation and concealment.
 2. Protect against ignition at all times. Do not deliver plastic insulating materials to Project site before installation time.
 3. Complete installation and concealment of plastic materials as rapidly as possible in each area of construction.

PART 2 - PRODUCTS

2.1 MANUFACTURERS

- A. Extruded-Polystyrene Board Insulation: ASTM C 578, of type and density indicated below, with maximum flame-spread and smoke-developed indexes of 75 and 450, respectively: Faced, Glass-Fiber Blanket Insulation: ASTM C 665, Type III (blankets with reflective membrane facing), Class A (membrane-faced surface with a flame-spread index of 25 or less); Category 1 (membrane is a vapor barrier), faced with foil-scrim-kraft, vapor-retarder membrane on 1 face. – Provide where batt insulation is semi-exposed above ceilings and other semi-concealed locations

2.2 FOAM-PLASTIC BOARD INSULATION

- A. Extruded-Polystyrene Board Insulation: ASTM C 578, of type and density indicated below, with maximum flame-spread and smoke-developed indexes of 75 and 450, respectively:
 1. Available Manufacturers:
 - a. DiversiFoam Products.
 - b. Dow Chemical Company.
 - c. Owens Corning.
 - d. Pactiv Building Products Division.
 2. 2" Thickness, to achieve Minimum R-7.5 unless otherwise indicated.
 3. Type VII, 2.20 lb/cu. ft. (40 psi compressive strength).

4. Maximum flame-spread and smoke-developed indexes of 75 and 450, respectively
- 2.3 BLANKET (BATT) INSULATION (interior and) exterior walls
- A. Mineral-fiber insulation
 1. Basis of design Rockwool “comfort batts”. Products by other manufactures meeting the design intent and specifications of the basis of design products include but are not limited to:
 - a. CertainTeed Corporation.
 - b. Guardian Fiberglass, Inc.
 - c. Johns Manville.
 - d. Knauf Fiber Glass.
 - e. Owens Corning.
 - B. Semi-rigid Formaldehyde free stone /wool insulation,
 1. Complying with astm C612 type 1
 2. Density: > 2 lbs/ft³ (>32 kg/m³) nominal.
 3. Surface Burning Characteristics: Tested in accordance with ASTM E84
 - a. Unfaced: Flame Spread 0 and Smoke Developed 0
 4. Moisture Resistance: Absorption of less than 0.03 percent by volume, when tested in accordance with ASTM C1104.
 5. Corrosion Resistance: Non-corrosive/Passed, when tested in accordance with ASTM C665 for Steel & ASTM C795 for Stress Corrosion Cracking Tendency of Austenitic Stainless Steel.
 6. Fungi resistance: Zero mold growth to ASTM C1338
 7. Recyclability: Material to be capable of being fully recyclable at end of life with the intention of sending zero waste to landfill.
 8. Environmental Product Declaration (EPD): Material must be included on a UL Certified EPD in accordance with EN 15804 and ISO 14025.
 - C. Thickness and/or R-value as noted on drawings
- 2.4 SPRAY INSULATION (attic area)
- A. Spray applied acoustic-thermal insulation
 1. Basis of Design international Cellulose K-13. Products by other manufacturers meeting the design intent and specifications of the basis of design products include but are not limited
 - a. United Spray
 - b. Retrotherm
 - B. Spray applied cellulose insulation
 1. Bond strength shall be greater than 150 psf per ASTM E 736
 2. Product shall be Class 1 Class A per ASTM E 84/ UL 723
 3. Non-corrosive per ASTM C 1149
 4. Bond Deflection per ASTM E 759: 6” Deflection in 10’ Span – No Spalling or Delamination
 5. R-Value to be 3.70 per inch per ASTM C 518
 6. Meet ASTM C 1149
 7. Product must have a publicly available Health Product Declaration (HPD) to 100 PPM

8. Product must have a third-party verified, publicly available, product-specific Environmental Product Declaration per ISO 14025
9. Manufacturer's written certification that product contains no asbestos, fiberglass or other man-made mineral fibers
10. Minimum Fiber Recycled Content to be 80%.
11. Cannot contain any added Urea-Formaldehyde Resins

- C. Thickness and/or "R" value as noted on drawing

2.5 AUXILIARY INSULATING MATERIALS

- A. Adhesive for Bonding Insulation: Product with demonstrated capability to bond insulation securely to substrates indicated without damaging insulation and substrates.

PART 3 - EXECUTION

3.1 EXAMINATION

- A. Examine substrates and conditions, with Installer present, for compliance with requirements of Sections in which substrates and related work are specified and for other conditions affecting performance.
1. Proceed with installation only after unsatisfactory conditions have been corrected.

3.2 PREPARATION

- A. Clean substrates of substances harmful to insulation or vapor retarders, including removing projections capable of puncturing vapor retarders or of interfering with insulation attachment.

3.3 INSTALLATION, GENERAL

- A. Comply with insulation manufacturer's written instructions applicable to products and application indicated.
- B. Install insulation that is undamaged, dry, and unsoiled and that has not been left exposed at any time to ice, rain, and snow.
- C. Extend insulation in thickness indicated to envelop entire area to be insulated. Cut and fit tightly around obstructions and fill voids with insulation. Remove projections that interfere with placement. Secure thermal insulation as necessary when located within framing of a larger thickness than the thickness of insulation indicated, to prevent insulation from falling over.
- D. Water-Piping Coordination: If water piping is located within insulated exterior walls, coordinate location of piping to ensure that it is placed on warm side of insulation and insulation encapsulates piping.

- E. For preformed insulating units, provide sizes to fit applications indicated and selected from manufacturer's standard thicknesses, widths, and lengths. Apply single layer of insulation units to produce thickness indicated unless multiple layers are otherwise shown or required to make up total thickness.

3.4 INSTALLATION OF PERIMETER AND UNDER-SLAB INSULATION

- A. On vertical surfaces, set insulation units in adhesive applied according to manufacturer's written instructions. Use adhesive recommended by insulation manufacturer.
 - 1. If not otherwise indicated, extend insulation a minimum of 24 inches (610 mm) below exterior grade line.
- B. On horizontal surfaces, loosely lay insulation units according to manufacturer's written instructions. Stagger end joints and tightly abut insulation units.
- C. Protect below-grade insulation on vertical surfaces from damage during backfilling by applying protection course with joints butted. Set in adhesive according to insulation manufacturer's written instructions.

3.5 INSTALLATION OF GENERAL BUILDING INSULATION

- A. Apply insulation units to substrates by method indicated, complying with manufacturer's written instructions. If no specific method is indicated, bond units to substrate with adhesive or use mechanical anchorage to provide permanent placement and support of units.
- B. Install fiber insulation in cavities formed by framing members according to the following requirements:
 - 1. Use insulation widths and lengths that fill the cavities formed by framing members. If more than one length is required to fill cavity, provide lengths that will produce a snug fit between ends.
 - 2. Place insulation in cavities formed by framing members to produce a friction fit between edges of insulation and adjoining framing members.
 - 3. Maintain 3-inch clearance of insulation around recessed lighting fixtures.
 - 4. For metal-framed wall cavities where cavity heights exceed 96 inches (2438 mm), support unfaced blankets mechanically and support faced blankets by taping flanges of insulation to flanges of metal studs.
- C. Where conditions do not permit friction fit, provide wire retainers or adhesively attached, spindle-type insulation anchors as fastened to concrete substrates with insulation anchor adhesive according to anchor manufacturer's written instructions. Space ties or anchors according to insulation manufacturer's written instructions for insulation type, thickness, and application indicated where insulation will not be covered by other building materials, apply capped washers to tips of spindles.
- D. Stuff glass-fiber loose-fill insulation into miscellaneous voids and cavity spaces where shown. Compact to approximately 40 percent of normal maximum volume equaling a density of approximately 2.5 lb/cu. ft.

- E. Spray-Applied Insulation: Apply spray-applied insulation according to manufacturer's written instructions.
1. Do not apply at temperature below manufacturer's recommendations. Do not apply when temperature will drop below 35°F during cueing period
 2. Prime substrate as recommended by manufacturer to assure proper adhesion.
 3. Allow to cure prior to erection.
 4. After insulation has cured, trim only as required to allow panel erection by using method recommended by insulation manufacturer.

3.6 PROTECTION

- A. Protect installed insulation and vapor retarders from damage due to harmful weather exposures, physical abuse, and other causes. Provide temporary coverings or enclosures where insulation is subject to abuse and cannot be concealed and protected by permanent construction immediately after installation.

END OF SECTION 07 21 00

SECTION 07 25 00 - WEATHER BARRIERS (AIR INFILTRATION BARRIERS)

PART 1 - GENERAL

1.1 RELATED DOCUMENTS

- A. Drawings and general provisions of the Contract, including General and Supplementary Conditions and Division 01 Specification Sections, apply to this Section.

1.2 SUMMARY

- A. Section Includes:
 - 1. Weather resistive barrier.
 - 2. Flexible flashing.
- B. Related Requirements:
 - 1. Division 2: Section 02419 SELECTIVE DEMOLITION
- C. Quality Assurance
 - 1. Obtain air barrier, flashings, sealants, primers, mastics, and adhesives from a single Air Barrier Manufacturer regularly engaged in the manufacturing and supply of the specified products
 - 2. Perform Work in accordance with Air Barrier Manufacturer published literature and as specified in this section
- D. Mockup
 - 1. A location will be established within the project area to install a sample panel complete with sealants, air water vapor barrier, furring and panel.
 - 2. Approval of mockups does not constitute approval of deviations from the Contract Documents contained in mockups unless Architect specifically approves such deviations in writing.
 - 3. Subject to compliance with requirements, approved mockups may become part of the completed Work if undisturbed at time of Substantial Completion

1.3 ACTION SUBMITTALS

- A. Product Data: For each type of product.
 - 1. For building wrap, include data on air and water-vapor permeance based on testing according to referenced standards.

1.4 INFORMATIONAL SUBMITTALS

- A. Evaluation Reports: For water-resistive barrier and flexible flashing, from ICC-ES.

PART 2 - PRODUCTS

2.1 WATER-RESISTIVE BARRIER

- A. Self-adhered water resistive air barrier membrane comprised of rubberized asphalt integrally laminated to a blue engineered thermoplastic film surface; having the following typical physical properties:
1. Basis of design: Henry Blueskin SA Self-Adhered Water Resistive Air Barrier
 - a. Products meeting project requirements and specifications may be provided
 2. Thickness, nominal: 40 mils (1.0 mm)
 3. Water Vapor Permeance (ASTM E96 Method B): 0.08 Perms
 4. Air Permeance (ASTM E2178): <0.0002 cfm/ft² (0.0011 L/s.m.²)
 5. Air leakage:
 - a. Assembly (ASTM E2357): Pass
 - b. Air Leakage Rate (CAN/ULC-S742) Classification A1
 6. Nail Sealability (AAMA 711, ASTM D1970 modified): Pass
- B. Silicone Tape
1. Basis of Design: Pecora "Sil Span"
 - a. Manufacturers offering products meeting the project specifications and requirements may include, but are not limited to:
 - b. Tremco
 - c. GE Silicones

2.2 Adhesives/Primers:

- A. Standard VOC adhesive:
1. Synthetic rubber based quick setting adhesive; having the following typical physical properties:
 - a. Basis of design: Henry Blueskin Adhesive
 - b. Primers supplied or recommended by water resistive barrier manufacturer

2.3 MISCELLANEOUS MATERIALS

- A. Flexible Flashing: Self-adhered water resistive air barrier membrane comprised of rubberized asphalt and integrally laminated to a blue engineered thermoplastic film surface; having the following typical physical properties
1. Basis of design: Basis of design: Henry Blueskin SA Self-Adhered Water Resistive Air Barrier
 2. Primer for Flexible Flashing: Product recommended by manufacturer of flexible flashing for substrate.

PART 3 - EXECUTION

3.1 EXAMINATION

- A. It is the installing Subcontractor's responsibility to verify the substrate is in accordance with Air Barrier Manufacturer requirements and as specified in this Section prior to installation of air bar-

rier. Commencement of the Work or any parts thereof, indicates installer acceptance of the substrate.

1. Verify surfaces are sound, clean and free of frost, oil, grease, dirt, excess mortar or other contaminants.
2. Substrate must be continuous and secure.
3. Top and backside of substrate walls must be protected against bulk water during and after application of air barrier.
4. Curing compounds must be resin based without oil, wax or pigments. Substrates must be free of form release agents.
5. Do not install air barrier over substrates that are wet to touch.
6. Do not apply air barrier assembly components until substrate and environmental conditions are in accordance with Air Barrier Manufacturer's published information

B. Notify Contractor in writing of any conditions that are not acceptable.

A. Install water-resistive barrier as follows:

1. Cut back barrier 1/2 inch (13 mm) on each side of the break in supporting members at expansion- or control-joint locations.
2. Apply barrier to cover vertical flashing with a minimum 4-inch (100-mm) overlap unless otherwise indicated.

3.2 FLEXIBLE FLASHING INSTALLATION

A. Apply flexible flashing where indicated to comply with manufacturer's written instructions.

1. Prime substrates as recommended by flashing manufacturer.
2. Lap seams and junctions with other materials at least 4 inches (100 mm) except that at flashing flanges of other construction, laps need not exceed flange width.
3. Lap flashing over water-resistive barrier at bottom and sides of openings.
4. Lap water resistive barrier over flashing at heads of openings.
5. After flashing has been applied, roll surfaces with a hard rubber or metal roller to ensure that flashing is completely adhered to substrates.

END OF SECTION 07 25 00

SECTION 074113.16 - STANDING-SEAM METAL ROOF PANELS

PART 1 - GENERAL

1.1 RELATED DOCUMENTS

- A. Drawings and general provisions of the Contract, including General and Supplementary Conditions and Division 01 Specification Sections, apply to this Section.

1.2 SUMMARY

- A. Section includes:
 - 1. Pre-finished standing-seam metal roof panels.
 - 2. Associated underlayment, metal trim, accessories, fasteners, insulation, and sealants
 - 3. Snow Gaurds
- B. Related Sections:
 - 1. Division 7, Section 072100 "Thermal Insulation"
 - 2. Division 7, Section 074213.53 "Metal Soffit Panels" for metal panels used in horizontal soffit applications.
 - 3. Division 7, Section 07600 "Sheet Metal Flashing and Trim".

1.3 DEFINITIONS

- A. Metal Roof Panel Assembly: Metal roof panels, attachment system components, miscellaneous metal framing, and accessories necessary for a complete weathertight roofing system.
- B. References:
 - 1. American Society for Testing and Materials (ASTM)
 - a. ASTM A 653: Steel Sheet, Zinc Coated by the Hot Dip Process
 - b. ASTM A 792: Steel Sheet, Aluminum-Zinc Alloy Coated by the Hot Dip Process
 - c. ASTM B 209: Aluminum and Aluminum Alloy Sheet and Plate
 - d. ASTM B370 Standard Specification for Copper Sheet and Strip for Building Construction
 - 2. Sheet Metal and Air Conditioning Contractors National Association (SMACNA)
 - a. SMACNA Architectural Sheet Metal Manual, latest edition.
 - 3. American Iron and Steel Institute (AISI)
 - a. AISI Cold Formed Steel Design Manual, latest edition.
 - 4. Aluminum Association
 - a. Aluminum Design Manual, latest edition.
 - 5. Metal Construction Association
 - a. Preformed Metal Wall Guidelines, latest edition.
 - 6. Code References
 - a. ASCE, Minimum Loads for Buildings and Other Structures

1.4 ACTION SUBMITTALS

- A. Product Data: For each type of product.
 - 1. Include construction details, material descriptions, dimensions of individual components and profiles, and finishes for each type of panel and accessory.
 - 2. Include a submittal for Snow Guard product.
- B. Shop Drawings:
 - 1. Include fabrication and installation layouts of metal panels; details of edge conditions, joints, panel profiles, corners, anchorages, snow guards, attachment system, trim, flashings, closures, and accessories; and special details.
 - 2. Distinguish between factory and field-assembled work.
 - 3. Accessories: Include details of the flashing, trim, and anchorage systems, at a scale of not less than 1-1/2 inches per 12 inches (1:10).
 - 4. Coordination Drawings: Roof Plans, drawn to scale, on which of the following are shown and coordinated with each other, based on input from installer of the items involved:
 - a. Roof Panels and attachments
 - b. Trusses, bracing and supports
 - c. Roof-mounted items including snow guards
- C. Samples for Initial Selection: For each type of metal panel indicated with factory-applied color finishes.
 - 1. Provide manufacturer color cards. Photocopy or electronic copies are not permitted.
- D. Samples for Verification: For each type of exposed finish required, prepared on Samples of size indicated below.
 - 1. Metal Panels: 24 inches (610 mm) long by actual panel width. Include clips, fasteners, closures, and other metal panel accessories.
 - 2. Provide manufacturer color cards. Photocopy or electronic copies are not permitted.

1.5 INFORMATIONAL SUBMITTALS

- A. Qualification Data: For Installer.
- B. Product Test Reports: For each product, for tests performed by a qualified testing agency.
- C. Field quality-control reports.
- D. Sample Warranties: For special warranties.

1.6 CLOSEOUT SUBMITTALS

- A. Maintenance Data: For metal panels to include in maintenance manuals.

1.7 QUALITY ASSURANCE

- A. Installer Qualifications: An entity that employs installers and supervisors who are trained and approved by manufacturer.
- B. UL-Certified, Portable Roll-Forming Equipment: UL-certified, portable roll-forming equipment capable of producing metal panels warranted by manufacturer to be the same as factory-formed products. Maintain UL certification of portable roll-forming equipment for duration of work.

1.8 DELIVERY, STORAGE, AND HANDLING

- A. Deliver components, metal panels, and other manufactured items so as not to be damaged or deformed. Package metal panels for protection during transportation and handling.
- B. Unload, store, and erect metal panels in a manner to prevent bending, warping, twisting, and surface damage.
- C. Stack metal panels horizontally on platforms or pallets, covered with suitable weathertight and ventilated covering. Store metal panels to ensure dryness, with positive slope for drainage of water. Do not store metal panels in contact with other materials that might cause staining, denting, or other surface damage.
- D. Retain strippable protective covering on metal panels during installation.

1.9 FIELD CONDITIONS

- A. Weather Limitations: Proceed with installation only when existing and forecasted weather conditions permit assembly of metal panels to be performed according to manufacturers' written instructions and warranty requirements.
- B. Field Measurements: Verify dimensions of construction contiguous with metal roof panels by field measurements before fabrication.

1.10 COORDINATION

- A. Coordinate sizes and locations of roof penetrations with actual equipment provided.
- B. Coordinate metal panel installation with rain drainage work, flashing, trim, construction of soffits, and other adjoining work to provide a leakproof, secure, and noncorrosive installation.

1.11 WARRANTY

- A. Special Warranty: Manufacturer's standard form in which manufacturer agrees to repair or replace components of metal panel systems that fail in materials or workmanship within specified warranty period.

- 1. Failures include, but are not limited to, the following:

- a. Structural failures including rupturing, cracking, or puncturing.
 - b. Deterioration of metals and other materials beyond normal weathering.
2. Warranty Period: 2 years from date of Substantial Completion.
- B. Special Warranty on Panel Finishes: Manufacturer's standard form in which manufacturer agrees to repair finish or replace metal panels that show evidence of deterioration of factory-applied finishes within specified warranty period.
 1. Exposed Panel Finish: Deterioration includes, but is not limited to, the following:
 - a. Color fading more than 5 Hunter units when tested according to ASTM D 2244.
 - b. Chalking in excess of a No. 8 rating when tested according to ASTM D 4214.
 - c. Cracking, checking, peeling, or failure of paint to adhere to bare metal.
 2. Finish Warranty Period: 20 years from date of Substantial Completion.
- C. Special Weathertightness Warranty: Manufacturer's standard form in which manufacturer agrees to repair or replace standing-seam metal roof panel assemblies that fail to remain weathertight, including leaks, within specified warranty period.
 1. Warranty Period: 20 years from date of Substantial Completion.

PART 2 - PRODUCTS

2.1 PERFORMANCE REQUIREMENTS

- A. Energy Performance: Provide roof panels according to one of the following when tested according to CRRC-1:
 1. Three-year, aged solar reflectance of not less than 0.55 and emissivity of not less than 0.75
 2. Three-year, aged Solar Reflectance Index of not less than 64 when calculated according to ASTM E 1980.
- B. Structural Performance: Provide metal panel systems capable of withstanding the effects of the following loads, based on testing according to ASTM E 1592:
 1. Wind Loads: As indicated on Drawings.
 2. Other Design Loads: As indicated on Drawings.
 3. Deflection Limits: For wind loads, no greater than $[1/180]$ $[1/240]$ <Insert deflection> of the span.
- C. Air Infiltration: Air leakage of not more than 0.06 cfm/sq. ft. (0.3 L/s per sq. m) when tested according to ASTM E 1680 or ASTM E 283 at the following test-pressure difference:
 1. Test-Pressure Difference: 6.24 lbf/sq. ft. (300 Pa).
- D. Water Penetration under Static Pressure: No water penetration when tested according to ASTM E 1646 or ASTM E 331 at the following test-pressure difference:

1. Test-Pressure Difference: 6.24 lbf/sq. ft. (300 Pa).
 - E. Hydrostatic-Head Resistance: No water penetration when tested according to ASTM E 2140.
 - F. Wind-Uplift Resistance: Provide metal roof panel assemblies that comply with UL 580 for wind-uplift-resistance class indicated.
 1. Uplift Rating: UL 90.
 - G. FM Global Listing: Provide metal roof panels and component materials that comply with requirements in FM Global 4471 as part of a panel roofing system and that are listed in FM Global's "Approval Guide" for Class 1 or noncombustible construction, as applicable. Identify materials with FM Global markings.
 1. Fire/Windstorm Classification: Class 1A-120.
 2. Hail Resistance: MH
 - H. Thermal Movements: Allow for thermal movements from ambient and surface temperature changes by preventing buckling, opening of joints, overstressing of components, failure of joint sealants, failure of connections, and other detrimental effects. Base calculations on surface temperatures of materials due to both solar heat gain and nighttime-sky heat loss.
 1. Temperature Change (Range): 120 deg F (67 deg C), ambient; 180 deg F (100 deg C), material surfaces
- 2.2 STANDING-SEAM METAL ROOF PANELS
- A. General: Provide factory-formed metal roof panels designed to be installed by lapping and/or snapping interconnecting raised side edges of adjacent panels with joint type indicated and mechanically attaching panels to supports using concealed clips inside laps. Include clips, cleats, pressure plates, and accessories required for weathertight installation.
 1. Aluminum Panel Systems: Unless more stringent requirements are indicated, comply with ASTM E 1637.
 - B. Vertical-Rib, Snap-Joint, Standing-Seam Metal Roof Panels: Formed with vertical ribs at panel edges and a flat pan between ribs; designed for sequential installation by mechanically attaching panels to supports using concealed clips located under one side of panels, engaging opposite edge of adjacent panels, and snapping panels together.
 1. Basis-of-Design Product: Subject to compliance with requirements, provide Petersen Aluminum Corporation, PAC-Clad, Snap-On Standing Seam Metal Roofing Panels, or comparable product by one of the following:
 - a. Advanced Architectural Products.
 - b. Architectural Building Components.
 - c. Architectural Metal Systems; a Nucor company.
 - d. CENTRIA Architectural Systems.
 - e. Dimensional Metals, Inc.
 - f. Garland Company, Inc. (The)
 - g. McElroy Metal, Inc.
 - h. Morin; a Kingspan Group company.

2. Aluminum Sheet: Coil-coated sheet, ASTM B 209 (ASTM B 209M), alloy as standard with manufacturer, with temper as required to suit forming operations and structural performance required.
 - a. Thickness: 0.032 inch (0.81 mm)
 - b. Surface: Smooth, flat finish.
 - c. Exterior Finish: Three-coat.
 - d. Color: As selected by Architect from manufacturer's full range.

2.3 UNDERLAYMENT MATERIALS

- A. Self-Adhering, High-Temperature Underlayment: Provide self-adhering, cold-applied, sheet underlayment, a minimum of 30 mils (0.76 mm) thick, consisting of slip-resistant, polyethylene-film top surface laminated to a layer of butyl or SBS-modified asphalt adhesive, with release-paper backing. Provide primer when recommended by underlayment manufacturer.
 1. Thermal Stability: Stable after testing at 240 deg F (116 deg C); ASTM D 1970.
 2. Low-Temperature Flexibility: Passes after testing at minus 20 deg F (29 deg C); ASTM D 1970.
 3. Thickness: Minimum 40 mil.
 4. Surface Texture: Smooth, non-granular.
 1. Basis-of-Design Product: Subject to compliance with requirements, provide Carlisle WIP 300 HT High Temperature Protection Self Adhering Roofing Underlayment, or comparable product by one of the following:
 - a. Grace Construction Products, a unit of W. R. Grace & Co.; Grace Ice and Water Shield HT
 - b. Interwrap; Titanium PSU 30
 - c. Tamko; TW Tile and Metal Underlayment
 - d. Henry Company; Blueskin PE200 HT.
 - e. Kirsch Building Products, LLC; Sharkskin Ultra SA.
 - f. Metal-Fab Manufacturing, LLC; MetShield.
 - g. Owens Corning; WeatherLock Metal High Temperature Underlayment.
- B. Slip Sheet: Manufacturer's recommended slip sheet, of type required for application.

2.4 MISCELLANEOUS MATERIALS

- A. Miscellaneous Metal Subframing and Furring: ASTM C 645; cold-formed, metallic-coated steel sheet, ASTM A 653/A 653M, G90 (Z275 hot-dip galvanized) coating designation or ASTM A 792/A 792M, Class AZ50 (Class AZM150) coating designation unless otherwise indicated. Provide manufacturer's standard sections as required for support and alignment of metal panel system.
- B. Panel Accessories: Provide components required for a complete, weathertight panel system including trim, copings, fasciae, mullions, sills, corner units, clips, flashings, sealants, gaskets, fillers, closure strips, and similar items. Match material and finish of metal panels unless otherwise indicated.

1. Closures: Provide closures at eaves and ridges, fabricated of same metal as metal panels.
 2. Backing Plates: Provide metal backing plates at panel end splices, fabricated from material recommended by manufacturer.
 3. Closure Strips: Closed-cell, expanded, cellular, rubber or crosslinked, polyolefin-foam or closed-cell laminated polyethylene; minimum 1-inch- (25-mm-) thick, flexible closure strips; cut or premolded to match metal panel profile. Provide closure strips where indicated or necessary to ensure weathertight construction.
- C. Flashing and Trim: Provide flashing and trim formed from same material as metal panels as required to seal against weather and to provide finished appearance. Locations include, but are not limited to, eaves, rakes, corners, bases, framed openings, ridges, fasciae, and fillers. Finish flashing and trim with same finish system as adjacent metal panels.
- D. Roof Edge Fascia:
1. Basis of Design Product: PAC-Clad Snap-On Fascia
 2. Material: Aluminum
 3. Thickness: 0.050"
- E. Gutters: Formed from same material as roof panels, complete with end pieces, outlet tubes, and other special pieces as required. Fabricate in minimum 96-inch (2400-mm-) long sections, of size and metal thickness according to SMACNA's "Architectural Sheet Metal Manual." Furnish gutter supports spaced a maximum of 36 inches (914 mm) o.c., fabricated from same metal as gutters. Provide wire ball strainers of compatible metal at outlets. Finish gutters to match metal roof panels.
- F. Downspouts: Formed from same material as roof panels. Fabricate in 10-foot- (3-m-) long sections, complete with formed elbows and offsets, of size and metal thickness according to SMACNA's "Architectural Sheet Metal Manual." Finish downspouts to match gutters.
- G. Snow Guards:
1. Provide Basis of Design Product: Sno Gem Inc "Original Polycarbonate" Snow Guard
 2. Material: Lexan 143R Resin (UV-Stabilized Polycarbonate)
 3. Dimensions: 5"W x 5"D x 3 1/4"H
 4. Color: As selected by architect from manufacturer's standard range.
 5. Spacing as shown in Drawings.
- H. Panel Fasteners: Self-tapping screws designed to withstand design loads. Place fasteners as indicated in manufacturer's standards.
- I. Panel Sealants: Provide sealant type recommended by manufacturer that are compatible with panel materials, are nonstaining, and do not damage panel finish.
1. Sealant Tape: Pressure-sensitive, 100 percent solids, gray polyisobutylene compound sealant tape with release-paper backing. Provide permanently elastic, nonsag, nontoxic, nonstaining tape 1/2 inch (13 mm) wide and 1/8 inch (3 mm) thick.
 2. Joint Sealant: ASTM C 920; elastomeric polyurethane or silicone sealant; of type, grade, class, and use classifications required to seal joints in metal panels and remain weathertight; and as recommended in writing by metal panel manufacturer.
 3. Butyl-Rubber-Based, Solvent-Release Sealant: ASTM C 1311.

2.5 FABRICATION

- A. General: Fabricate and finish metal panels and accessories at the factory, by manufacturer's standard procedures and processes, as necessary to fulfill indicated performance requirements demonstrated by laboratory testing. Comply with indicated profiles and with dimensional and structural requirements.
- B. Provide panel profile, including major ribs and intermediate stiffening ribs, if any, for full length of panel.
- C. Fabricate metal panel joints with factory-installed captive gaskets or separator strips that provide a weathertight seal and prevent metal-to-metal contact, and that minimize noise from movements.
- D. Sheet Metal Flashing and Trim: Fabricate flashing and trim to comply with manufacturer's recommendations and recommendations in SMACNA's "Architectural Sheet Metal Manual" that apply to design, dimensions, metal, and other characteristics of item indicated.
 - 1. Form exposed sheet metal accessories that are without excessive oil canning, buckling, and tool marks and that are true to line and levels indicated, with exposed edges folded back to form hems.
 - 2. Seams for Aluminum: Fabricate nonmoving seams with flat-lock seams. Form seams and seal with epoxy seam sealer. Rivet joints for additional strength.
 - 3. Sealed Joints: Form nonexpansion, but movable, joints in metal to accommodate sealant and to comply with SMACNA standards.
 - 4. Conceal fasteners and expansion provisions where possible. Exposed fasteners are not allowed on faces of accessories exposed to view.
 - 5. Fabricate cleats and attachment devices from same material as accessory being anchored or from compatible, noncomposite metal recommended in writing by metal panel manufacturer.
 - a. Size: As recommended by SMACNA's "Architectural Sheet Metal Manual" or metal panel manufacturer for application, but not less than thickness of metal being secured.

2.6 FINISHES

- A. Protect mechanical and painted finishes on exposed surfaces from damage by applying a strippable, temporary protective covering before shipping.
- B. Appearance of Finished Work: Variations in appearance of abutting or adjacent pieces are acceptable if they are within one-half of the range of approved Samples. Noticeable variations in same piece are unacceptable. Variations in appearance of other components are acceptable if they are within the range of approved Samples and are assembled or installed to minimize contrast.
- C. Aluminum Panels and Accessories:
 - 1. Two-Coat Fluoropolymer: AAMA 620. Fluoropolymer finish containing not less than 70 percent PVDF resin by weight in color coat. Prepare, pretreat, and apply coating to exposed metal surfaces to comply with coating and resin manufacturers' written instructions.

PART 3 - EXECUTION

3.1 EXAMINATION

- A. Examine substrates, areas, and conditions, with Installer present, for compliance with requirements for installation tolerances, metal panel supports, and other conditions affecting performance of the Work.
 - 1. Examine primary and secondary roof framing to verify that rafters, purlins, angles, channels, and other structural panel support members and anchorages have been installed within alignment tolerances required by metal roof panel manufacturer.
 - 2. Examine solid roof sheathing to verify that sheathing joints are supported by framing or blocking and that installation is within flatness tolerances required by metal roof panel manufacturer.
 - a. Verify that air- or water-resistive barriers have been installed over sheathing or backing substrate to prevent air infiltration or water penetration.
- B. Examine roughing-in for components and systems penetrating metal panels to verify actual locations of penetrations relative to seam locations of metal panels before installation.
- C. Proceed with installation only after unsatisfactory conditions have been corrected.

3.2 PREPARATION

- A. Miscellaneous Supports: Install subframing, furring, and other miscellaneous panel support members and anchorages according to ASTM C 754 and metal panel manufacturer's written recommendation.

3.3 UNDERLAYMENT INSTALLATION

- A. Self-Adhering Sheet Underlayment: Apply primer if required by manufacturer. Comply with temperature restrictions of underlayment manufacturer for installation. Apply at locations indicated [below] [on Drawings], wrinkle free, in shingle fashion to shed water, and with end laps of not less than 6 inches (152 mm) staggered 24 inches (610 mm) between courses. Overlap side edges not less than 3-1/2 inches (90 mm).[Extend underlayment into gutter trough.] Roll laps with roller. Cover underlayment within 14 days.
 - 1. Apply over the entire roof surface.
 - 2. Apply over the roof area indicated below:
 - a. Roof perimeter for a distance up from eaves of 24 inches beyond interior wall line.
 - b. Valleys, from lowest point to highest point, for a distance on each side of 12 inches. Overlap ends of sheets not less than 6 inches (152 mm).

- c. Rake edges for a distance of 18 inches.
 - d. Hips and ridges for a distance on each side of 12 inches.
 - e. Roof-to-wall intersections for a distance from wall of 18 inches
- B. Slip Sheet: Apply slip sheet over underlayment before installing metal roof panels.
- C. Flashings: Install flashings to cover underlayment to comply with requirements specified in Section 076200 "Sheet Metal Flashing and Trim."

3.4 METAL PANEL INSTALLATION

- A. General: Install metal panels according to manufacturer's written instructions in orientation, sizes, and locations indicated. Install panels perpendicular to supports unless otherwise indicated. Anchor metal panels and other components of the Work securely in place, with provisions for thermal and structural movement.
 - 1. Shim or otherwise plumb substrates receiving metal panels
 - 2. Flash and seal metal panels at perimeter of all openings. Fasten with self-tapping screws. Do not begin installation until air- or water-resistive barriers and flashings that will be concealed by metal panels are installed.
 - 3. Install screw fasteners in predrilled holes.
 - 4. Locate and space fastenings in uniform vertical and horizontal alignment.
 - 5. Install flashing and trim as metal panel work proceeds.
 - 6. Locate panel splices over, but not attached to, structural supports. Stagger panel splices and end laps to avoid a four-panel lap splice condition.
 - 7. Align bottoms of metal panels and fasten with blind rivets, bolts, or self-tapping screws. Fasten flashings and trim around openings and similar elements with self-tapping screws.
 - 8. Provide weathertight escutcheons for pipe- and conduit-penetrating panels.
- B. Fasteners:
 - 1. Aluminum Panels: Use aluminum or stainless-steel fasteners for surfaces exposed to the exterior; use aluminum or galvanized-steel fasteners for surfaces exposed to the interior.
- C. Anchor Clips: Anchor metal roof panels and other components of the Work securely in place, using manufacturer's approved fasteners according to manufacturers' written instructions.
- D. Metal Protection: Where dissimilar metals contact each other or corrosive substrates, protect against galvanic action as recommended in writing by metal panel manufacturer.
- E. Standing-Seam Metal Roof Panel Installation: Fasten metal roof panels to supports with concealed clips at each standing-seam joint at location, spacing, and with fasteners recommended in writing by manufacturer.
 - 1. Install clips to supports with self-tapping fasteners.
 - 2. Install pressure plates at locations indicated in manufacturer's written installation instructions.
 - 3. Snap Joint: Nest standing seams and fasten together by interlocking and completely engaging factory-applied sealant.
 - 4. Watertight Installation:

- a. Apply a continuous ribbon of sealant or tape to seal joints of metal panels, using sealant or tape as recommend in writing by manufacturer as needed to make panels watertight.
 - b. Provide sealant or tape between panels and protruding equipment, vents, and accessories.
 - c. At panel splices, nest panels with minimum 6-inch (152-mm) end lap, sealed with sealant and fastened together by interlocking clamping plates.
- F. Accessory Installation: Install accessories with positive anchorage to building and weathertight mounting, and provide for thermal expansion. Coordinate installation with flashings and other components.
 1. Install components required for a complete metal panel system including trim, copings, corners, seam covers, flashings, sealants, gaskets, fillers, closure strips, and similar items. Provide types indicated by metal roof panel manufacturers; or, if not indicated, types recommended by metal roof panel manufacturer.
 2. Snow Gaurds:
 - a. Inspect the roof system in it's entirety to verify proper attachment, completion and the ability of the building structure to withstand additional loading applied by the snow retention system. Install the snow retention system in accordance with the architect's layout and shop drawings, installation instructions and approved submittals.
- G. Flashing and Trim: Comply with performance requirements, manufacturer's written installation instructions, and SMACNA's "Architectural Sheet Metal Manual." Provide concealed fasteners where possible, and set units true to line and level as indicated. Install work with laps, joints, and seams that will be permanently watertight and weather resistant.
 1. Install exposed flashing and trim that is without buckling and tool marks, and that is true to line and levels indicated with exposed edges folded back to form hems. Install sheet metal flashing and trim to fit substrates and achieve waterproof and weather-resistant performance.
 2. Expansion Provisions: Provide for thermal expansion of exposed flashing and trim. Space movement joints at a maximum of 10 feet (3 m) with no joints allowed within 24 inches (610 mm) of corner or intersection. Where lapped expansion provisions cannot be used or would not be sufficiently weather resistant and waterproof, form expansion joints of intermeshing hooked flanges, not less than 1 inch (25 mm) deep, filled with mastic sealant (concealed within joints).
- H. Gutters: Join sections with riveted and soldered or lapped and sealed joints. Attach gutters to eave with gutter hangers spaced not more than 36 inches (914 mm) o.c. using manufacturer's standard fasteners. Provide end closures and seal watertight with sealant. Provide for thermal expansion.
- I. Downspouts: Join sections with telescoping joints. Provide fasteners designed to hold downspouts securely 1 inch (25 mm) away from walls; locate fasteners at top and bottom and at approximately 60 inches (1524 mm) o.c. in between.
 1. Provide elbows at base of downspouts to direct water away from building.
 2. Connect downspouts to underground drainage system indicated.

- J. Pipe Flashing: Form flashing around pipe penetration and metal roof panels. Fasten and seal to metal roof panels as recommended by manufacturer.

3.5 ERECTION TOLERANCES

- A. Installation Tolerances: Shim and align metal panel units within installed tolerance of 1/4 inch in 20 feet (6 mm in 6 m) on slope and location lines as indicated and within 1/8-inch (3-mm) offset of adjoining faces and of alignment of matching profiles.

3.6 FIELD QUALITY CONTROL

- A. Manufacturer's Field Service: Engage a factory-authorized service representative to test and inspect metal roof panel installation, including accessories. Report results in writing.
- B. Remove and replace applications of metal roof panels where tests and inspections indicate that they do not comply with specified requirements.
- C. Additional tests and inspections, at Contractor's expense, are performed to determine compliance of replaced or additional work with specified requirements.
- D. Prepare test and inspection reports.

3.7 CLEANING AND PROTECTION

- A. Remove temporary protective coverings and strippable films, if any, as metal panels are installed, unless otherwise indicated in manufacturer's written installation instructions. On completion of metal panel installation, clean finished surfaces as recommended by metal panel manufacturer. Maintain in a clean condition during construction.
- B. Replace metal panels that have been damaged or have deteriorated beyond successful repair by finish touchup or similar minor repair procedures.

END OF SECTION 074113.16

SECTION 076200 – SHEET METAL FLASHING AND TRIM

PART 1 - GENERAL

1.1 RELATED DOCUMENTS

- A. Drawings and general provisions of the Contract, including General and Supplementary Conditions and Division 1 Specification Sections, apply to this Section.

1.2 SUMMARY

- A. This Section includes the following manufactured roof specialties:
 - 1. Flashings, edge drips and vented edge drips.
 - 2. Formed equipment support flashing.
- B. Related Sections include the following:
 - 1. Division 01 Section 017419 – Construction Waste Management.
 - 2. Division 4 Section "Unit Masonry" for reglets and thru-wall flashing.
 - 3. Division 6 Section "Miscellaneous Carpentry" for wood nailers, curbs, and blocking.
 - 4. Division 7 Section "Roof Accessories" for set-on-type curbs, equipment supports, roof hatches, vents, roof expansion joint covers and other manufactured roof accessory units.
 - 5. Division 7 Section "Metal Wall Panels"
 - 6. Division 7 Section "Joint Sealants" for field-applied sealants.

1.3 PERFORMANCE REQUIREMENTS

- A. General: Manufacture and install manufactured roof specialties to resist thermally induced movement and exposure to weather without failing, rattling, leaking, and fastener disengagement.
- B. Manufacture and install roof edge flashings tested according to SPRI ES-1 and capable of resisting the following design pressures:
 - 1. Design Pressure: 50 PSF Typical; 60 PSF pressure at building corners.
- C. Thermal Movements: Provide manufactured roof specialties that allow for thermal movements resulting from the following maximum change (range) in ambient and surface temperatures by preventing buckling, opening of joints, hole elongation, overstressing of components, failure of joint sealants, failure of connections, and other detrimental effects. Provide clips that resist rotation and avoid shear stress as a result of thermal movements. Base engineering calculation on surface temperatures of materials due to both solar heat gain and nighttime-sky heat loss.
 - 1. Temperature Change (Range): 100 deg F, ambient; 150 deg F material surfaces.

- D. Water Infiltration: Provide manufactured roof specialties that do not allow water infiltration to building interior.
- E. Shop Drawings: For sheet metal flashing and trim.
 - 1. Include plans, elevations, sections, and attachment details.
 - 2. Detail fabrication and installation layouts, expansion-joint locations, and keyed details. Distinguish between shop- and field-assembled work.
 - 3. Include identification of material, thickness, weight, and finish for each item and location in Project.
 - 4. Include details for forming, including profiles, shapes, seams, and dimensions.
 - 5. Include details for joining, supporting, and securing, including layout and spacing of fasteners, cleats, clips, and other attachments. Include pattern of seams.
 - 6. Include details of termination points and assemblies.
 - 7. Include details of expansion joints and expansion-joint covers, including showing direction of expansion and contraction from fixed points.
 - 8. Include details of roof-penetration flashing.
 - 9. Include details of edge conditions, including eaves, ridges, valleys, rakes, crickets, and counter-flashings as applicable.
 - 10. Include details of special conditions.
 - 11. Include details of connections to adjoining work.
 - 12. Detail formed flashing and trim at scale of not less than 3 inches per 12 inches (1:5)
- F. Samples for Initial Selection: For each type of sheet metal and accessory indicated with factory-applied finishes.
- G. Samples for Verification: For each type of exposed finish.
 - 1. Sheet Metal Flashing: 12 inches (300 mm) long by actual width of unit, including finished seam and in required profile. Include fasteners, cleats, clips, closures, and other attachments.
 - 2. Trim, Metal Closures, Expansion Joints, Joint Intersections, and Miscellaneous Fabrications: 12 inches (300 mm) long and in required profile. Include fasteners and other exposed accessories.
 - 3. Unit-Type Accessories and Miscellaneous Materials: Full-size Sample.
 - 4. Anodized Aluminum Samples: Samples to show full range to be expected for each color required.

1.4 INFORMATIONAL SUBMITTALS

- A. Qualification Data: For fabricator.
- B. Sample Warranty: For special warranty.

1.5 CLOSEOUT SUBMITTALS

- A. Maintenance Data: For sheet metal flashing and trim, and its accessories, to include in maintenance manuals.

1.6 QUALITY ASSURANCE

- A. Fabricator Qualifications: Employs skilled workers who custom fabricate sheet metal flashing and trim similar to that required for this Project and whose products have a record of successful in-service performance.
- B. Mockups: Build mockups to verify selections made under Sample submittals, to demonstrate aesthetic effects, and to set quality standards for fabrication and installation.
 - 1. Build mockup of:
 - a. Typical integral welded roof corner, minimum 6'-0" long in both directions, including supporting construction cleats, seams, attachments, underlayment, and accessories.
 - 2. Approval of mockups does not constitute approval of deviations from the Contract Documents contained in mockups unless Architect specifically approves such deviations in writing.
 - 3. Subject to compliance with requirements, approved mockups may become part of the completed Work if undisturbed at time of Substantial Completion.

1.7 DELIVERY, STORAGE, AND HANDLING

- A. Do not store sheet metal flashing and trim materials in contact with other materials that might cause staining, denting, or other surface damage. Store sheet metal flashing and trim materials away from uncured concrete and masonry.
- B. Protect strippable protective covering on sheet metal flashing and trim from exposure to sunlight and high humidity, except to extent necessary for period of sheet metal flashing and trim installation.

1.8 WARRANTY

- A. Special Warranty on Finishes: Manufacturer agrees to repair finish or replace sheet metal flashing and trim that shows evidence of deterioration of factory-applied finishes within specified warranty period.
 - 1. Exposed Panel Finish: Deterioration includes, but is not limited to, the following:
 - a. Color fading more than 5 Hunter units when tested according to ASTM D 2244.
 - b. Chalking in excess of a No. 8 rating when tested according to ASTM D 4214.
 - c. Cracking, checking, peeling, or failure of paint to adhere to bare metal.
 - 2. Finish Warranty Period: **20** years from date of Substantial Completion.

PART 2 - PRODUCTS

2.1 MANUFACTURERS

- A. In other Part 2 articles where titles below introduce lists, the following requirements apply to product selection:

1. Available Products: Subject to compliance with requirements, products that may be incorporated into the Work include, but are not limited to, products specified.
2. Basis-of-Design Product: The design for the product(s) identified is based on the product named. The use of a trade name and/or suppliers name and address in the specifications is to indicate a possible source of the product and a standard of quality. Products of the same type from other sources shall not be excluded, provided they possess like physical and functional and aesthetic characteristics. Refer to Division 1, "Product Requirements" for process to obtain approval of other products.

2.2 EXPOSED METALS

- A. Aluminum Sheet: ASTM B 209 (ASTM B 209M), alloy and temper recommended by manufacturer for use and finish indicated, finished as follows:
 1. Surface: Smooth, flat finish.
 2. High-Performance Organic Finish: AA-C12C42R1x (Chemical Finish: cleaned with inhibited chemicals; Chemical Finish: acid-chromate-fluoride-phosphate conversion coating; Organic Coating: as specified below). Prepare, pretreat, and apply coating to exposed metal surfaces to comply with coating and resin manufacturers' written instructions.
 - a. Two-Coat Fluoropolymer: AAMA 620. Fluoropolymer finish containing not less than 70 percent PVDF resin by weight in color coat. Prepare, pretreat, and apply coating to exposed metal surfaces to comply with coating and resin manufacturers' written instructions.
- B. Aluminum Extrusions: ASTM B 221 (ASTM B 221M), alloy and temper recommended by manufacturer for type of use and finish indicated, finished as follows:
 1. High-Performance Organic Finish: AA-C12C42R1x (Chemical Finish: cleaned with inhibited chemicals; Chemical Finish: acid-chromate-fluoride-phosphate conversion coating; Organic Coating: as specified below). Prepare, pretreat, and apply coating to exposed metal surfaces to comply with coating and resin manufacturers' written instructions.
 - a. Two-Coat Fluoropolymer: AAMA 620. Fluoropolymer finish containing not less than 70 percent PVDF resin by weight in color coat. Prepare, pretreat, and apply coating to exposed metal surfaces to comply with coating and resin manufacturers' written instructions.
- C. Stainless-Steel Sheet: ASTM A 240/A 240M, Type 304, No. 2B (bright, reflective) finish, with hem edges.
 1. Provide stainless steel flashing where metal flashing is indicated on drawings at exterior walls where used in conjunction with membrane flashing.
 2. Other locations on the drawing where not part of manufactured (aluminum) roof flashing systems.

2.3 CONCEALED METALS

- A. Stainless-Steel Sheet: ASTM A 240/A 240M, Type 304, with hem edges typical.

2.4 MISCELLANEOUS MATERIALS

- A. General: Provide materials and types of fasteners, protective coatings, separators, sealants, and other miscellaneous items required by manufacturer for a complete installation.
- B. Fasteners: Manufacturer's recommended fasteners, suitable for application and designed to withstand design loads.
 - 1. Exposed Penetrating Fasteners: Gasketed screws with hex washer heads matching color of sheet metal.
 - 2. Provide stainless steel screws, bolts and fasteners where attached or anchored to treated lumber blocking.
- C. Sealing Tape: Pressure-sensitive, 100 percent solids, polyisobutylene compound sealing tape with release-paper backing. Provide permanently elastic, nonsag, nontoxic, nonstaining tape.
- D. Elastomeric Sealant: ASTM C 920, elastomeric silicone polymer sealant; of type, grade, class, and use classifications required to seal joints in sheet metal flashing and trim and remain watertight.
- E. Butyl Sealant: ASTM C 1311, single component, solvent-release butyl rubber sealant, polyisobutylene plasticized, heavy bodied for hooked-type expansion joints with limited movement.
- F. Bituminous Coating: Cold-applied asphalt mastic, SSPC-Paint 12, compounded for 15-mil (0.4-mm) dry film thickness per coat. Provide inert-type noncorrosive compound free of asbestos fibers, sulfur components, and other deleterious impurities.
- G. Asphalt Roofing Cement: ASTM D 4586, asbestos free, of consistency required for application.
- H. Polyethylene Sheet: 6-mil- (0.15-mm-) thick polyethylene sheets complying with ASTM D 4397.
- I. Felt: ASTM D 226, Type II (No. 30), asphalt-saturated organic felt, nonperforated.
 - 1. Slip Sheet: Rosin-sized paper, minimum 3 lb/100 sq. ft. (0.16 kg/sq. m).

2.5 FINISHES

- A. Comply with NAAMM's "Metal Finishes Manual for Architectural and Metal Products" for recommendations for applying and designating finishes.
- B. Protect mechanical and painted finishes on exposed surfaces from damage by applying a strippable, temporary protective covering before shipping.

- C. Appearance of Finished Work: Variations in appearance of abutting or adjacent pieces are acceptable if they are within one-half of the range of approved Samples. Noticeable variations in the same piece are not acceptable. Variations in appearance of other components are acceptable if they are within the range of approved Samples and are assembled or installed to minimize contrast.

PART 3 - EXECUTION

3.1 EXAMINATION

- A. Examine substrates, areas, and conditions, with Installer present, to verify actual locations, dimensions, and other conditions affecting performance of work.
 - 1. Examine walls, roof edges, and parapets for suitable conditions for manufactured roof specialties.
 - 2. Verify that substrate is sound, dry, smooth, clean, sloped for drainage, and securely anchored.
 - 3. Proceed with installation only after unsatisfactory conditions have been corrected.

3.2 INSTALLATION

- A. General: Install manufactured roof specialties according to manufacturer's written instructions. Anchor manufactured roof specialties securely in place and capable of resisting forces specified in performance requirements. Use fasteners, separators, sealants, and other miscellaneous items as required to complete manufactured roof specialty systems.
 - 1. Install manufactured roof specialties with provisions for thermal and structural movement.
 - 2. Torch cutting of manufactured roof specialties is not permitted.
- B. Metal Protection: Where dissimilar metals will contact each other or corrosive substrates, protect against galvanic action by painting contact surfaces with bituminous coating or by other permanent separation as recommended by manufacturer.
 - 1. Coat concealed side of aluminum manufactured roof specialties with bituminous coating where in contact with wood, ferrous metal, or cementitious construction.
 - 2. Underlayment: Where installing exposed-to-view components of manufactured roof specialties directly on cementitious or wood substrates, install a course of felt underlayment and cover with a slip sheet, or install a course of polyethylene underlayment.
 - 3. Bed flanges in thick coat of asphalt roofing cement where required by manufacturers of roof specialties for waterproof performance.
- C. Install manufactured roof specialties level, plumb, true to line and elevation, and without warping, jogs in alignment, excessive oil-canning, buckling, or tool marks.
- D. Install manufactured roof specialties to fit substrates and to result in watertight performance. Verify shapes and dimensions of surfaces to be covered before manufacture.

- E. Expansion Provisions: Provide for thermal expansion of exposed manufactured roof specialties. Space movement joints at a maximum of 12 feet (3.6 m) with no unplanned joints within 18 inches of corners or intersections.
- F. Fasteners: Use fasteners of type and size recommended by manufacturer but of sizes that will penetrate substrate not less than 1-1/4 inches (32 mm) for nails and not less than 3/4 inch (19 mm) for wood screws.
- G. Seal joints with elastomeric sealant as required by manufacturer of roofing specialties.

3.3 EXPOSED FLASHING INSTALLATION

- A. Counterflashings: Coordinate installation of exposed flashing, and brick caps with installation of adjacent finish materials. Insert minimum 4 inches behind metal panels and bed with sealant.

3.4 CLEANING AND PROTECTION

- A. Clean exposed metal surfaces of substances that interfere with uniform oxidation and weathering.
- B. Clean and neutralize flux materials. Clean off excess solder and sealants.
- C. Remove temporary protective coverings and shippable films as manufactured roof specialties are installed. On completion of installation, clean finished surfaces, including removing unused fasteners, metal filings, pop rivet stems, and pieces of flashing. Maintain in a clean condition during construction.
- D. Replace manufactured roof specialties that have been damaged or that cannot be successfully repaired by finish touchup or similar minor repair procedures.

END OF SECTION 07 62 00

SECTION 07 84 00
FIRESTOPPING

PART 1 GENERAL

1.01 SECTION INCLUDES

- A. Firestopping systems.
- B. Firestopping of all joints and penetrations in fire resistance rated and smoke resistant assemblies, whether indicated on drawings or not, and other openings indicated.

1.02 RELATED REQUIREMENTS

- A. Section 07 05 53 - Fire and Smoke Assembly Identification.
- B. Section 09 21 16 - Gypsum Board Assemblies: Gypsum wallboard fireproofing.

1.03 REFERENCE STANDARDS

- A. ASTM E119 - Standard Test Methods for Fire Tests of Building Construction and Materials 2020.
- B. ASTM E814 - Standard Test Method for Fire Tests of Penetration Firestop Systems 2013a (Re-approved 2017).
- C. ASTM E1966 - Standard Test Method for Fire-Resistive Joint Systems 2015 (Reapproved 2019).
- D. ASTM E2174 - Standard Practice for On-Site Inspection of Installed Firestop Systems 2020a.
- E. ASTM E2393 - Standard Practice for On-Site Inspection of Installed Fire Resistive Joint Systems and Perimeter Fire Barriers 2020a.
- F. ASTM E2307 - Standard Test Method for Determining Fire Resistance of Perimeter Fire Barriers Using Intermediate-Scale, Multi-story Test Apparatus 2020.
- G. ASTM E2837 - Standard Test Method for Determining the Fire Resistance of Continuity Head-of-Wall Joint Systems Installed Between Rated Wall Assemblies and Nonrated Horizontal Assemblies 2013 (Reapproved 2017).
- H. ASTM G21 - Standard Practice for Determining Resistance of Synthetic Polymeric Materials to Fungi 2015.
- I. ITS (DIR) - Directory of Listed Products current edition.
- J. FM (AG) - FM Approval Guide current edition.
- K. UL 1479 - Standard for Fire Tests of Penetration Firestops Current Edition, Including All Revisions.
- L. UL 2079 - Standard for Tests for Fire Resistance of Building Joint Systems Current Edition, Including All Revisions.
- M. UL (DIR) - Online Certifications Directory Current Edition.
- N. UL (FRD) - Fire Resistance Directory Current Edition.

1.04 SUBMITTALS

- A. See Section 01 30 00 - Administrative Requirements, for submittal procedures.

- B. Schedule of Firestopping: List each type of penetration, fire rating of the penetrated assembly, and firestopping test or design number.
- C. Product Data: Provide data on product characteristics, performance ratings, and limitations.
- D. Manufacturer's Installation Instructions: Indicate preparation and installation instructions.
- E. Manufacturer's Certificate: Certify that products meet or exceed specified requirements.

1.05 QUALITY ASSURANCE

- A. Fire Testing: Provide firestopping assemblies of designs that provide the scheduled fire ratings when tested in accordance with methods indicated.
 - 1. Listing in UL (FRD) or FM (AG) will be considered as constituting an acceptable test report.
 - 2. Valid evaluation report published by ICC Evaluation Service, Inc. (ICC-ES) at www.icc-es.org will be considered as constituting an acceptable test report.
- B. Manufacturer Qualifications: Company specializing in manufacturing the products specified in this section with minimum three years documented experience.
- C. Installer Qualifications: Company specializing in performing the work of this section and:
 - 1. Trained by manufacturer.
 - 2. Verification of minimum three years documented experience installing work of this type.

1.06 FIELD CONDITIONS

- A. Comply with firestopping manufacturer's recommendations for temperature and conditions during and after installation; maintain minimum temperature before, during, and for three days after installation of materials.

PART 2 PRODUCTS

2.01 MANUFACTURERS

- A. Firestopping Manufacturers:

- 1. 3M Fire Protection Products: www.3m.com/firestop.
- 2. Hilti, Inc.: www.us.hilti.com/#sle.
- 3. Nelson FireStop Products: www.nelsonfirestop.com.
- 4. Specified Technologies Inc: www.stifirestop.com/#sle.
- 5. International Fireproof Technology, Inc. ; www.painttoprotect.com/.
- 6. Substitutions: See Section 01 60 00 - Product Requirements.

2.02 MATERIALS

- A. Firestopping Materials: Any materials meeting requirements.
- B. Mold and Mildew Resistance: Provide firestopping materials with mold and mildew resistance rating of zero(0) in accordance with ASTM G21.
- C. Primers, Sleeves, Forms, Insulation, Packing, Stuffing, and Accessories: Provide type of materials as required for tested firestopping assembly.

D. Fire Ratings: Refer to drawings for required systems and ratings.

2.03 FIRESTOPPING ASSEMBLY REQUIREMENTS

A. General:

1. Provide firestopping composed of components that are compatible with each other, the substrates forming openings, and the items, if any, penetrating the firestopping under conditions of service and application, as demonstrated by the firestopping manufacturer based on testing and field experience.
2. Provide components for each firestopping system that are needed to install fill material. Use only components specified by the firestopping manufacturer and approved by the qualified testing agency for the designated fire-resistance-rated systems.

B. Perimeter Fire Containment Firestopping: Use system that has been tested according to ASTM E2307 to have fire resistance F Rating equal to required fire rating of floor assembly.

1. Where floor assembly is not required to have a fire rating, provide systems that have been tested to show L Rating as indicated.

C. Head-of-Wall Joint System Firestopping at Joints Between Fire-Rated Wall Assemblies and Non-Rated Horizontal Assemblies: Use system that has been tested according to ASTM E2837 to have fire resistance F Rating equal to required fire rating of floor or wall, whichever is greater.

1. Movement: Provide systems that have been tested to show movement capability as indicated.

D. Floor-to-Floor, Wall-to-Wall, and Wall-to-Floor Joints, Except Perimeter, Where Both Are Fire-Rated: Use system that has been tested according to ASTM E1966 or UL 2079 to have fire resistance F Rating equal to required fire rating of the assembly in which the joint occurs.

1. Listing by FM (AG), ITS (DIR), UL (DIR), or UL (FRD) in their certification directories will be considered evidence of successful testing.

E. Through Penetration Firestopping: Use system that has been tested according to ASTM E814 to have fire resistance F Rating equal to required fire rating of penetrated assembly.

1. Temperature Rise: Where penetration is not contained in a wall cavity, provide systems that have been tested to show T Rating equal to F Rating, where required by code.
2. Listing by FM (AG), ITS (DIR), UL (DIR), or UL (FRD) in their certification directories will be considered evidence of successful testing.

2.04 FIRESTOPPING SYSTEMS

A. Firestopping: Any material meeting requirements.

1. Fire Ratings: Use system that is listed by FM (AG), ITS (DIR), or UL (FRD) and tested in accordance with ASTM E814, ASTM E119, or UL 1479 with F Rating equal to fire rating of penetrated assembly and minimum T Rating Equal to F Rating and in compliance with other specified requirements.

PART 3 EXECUTION

3.01 EXAMINATION

- A. Verify openings are ready to receive the work of this section.

3.02 PREPARATION

- A. Clean substrate surfaces of dirt, dust, grease, oil, loose material, or other materials that could adversely affect bond of firestopping material.
- B. Remove incompatible materials that could adversely affect bond.
- C. Install backing materials to prevent liquid material from leakage.

3.03 COORDINATION

- A. Coordinate construction of openings, penetrations and construction joints to ensure that the fire stop systems are installed according to specified requirements.
- B. Coordinate sizing of sleeves, openings, core-drilled holes, or cut openings to accommodate through-penetration fire stop systems. Coordinate construction and sizing of joints to ensure that fire-resistive joint systems are installed according to specified requirements.
- C. Coordinate fire stopping with other trades so that obstructions are not placed in the way prior to the installation of the fire stop systems.
- D. Consult with mechanical engineer, project manager, and damper manufacturer prior to installation of UL firestop systems that might hamper the performance of fire dampers as it pertains to duct work.

3.04 INSTALLATION

- A. Install materials in manner described in fire test report and in accordance with manufacturer's instructions, completely closing openings.
- B. Do not cover installed firestopping until inspected by authorities having jurisdiction.
- C. Install labeling required by code.

3.05 FIELD QUALITY CONTROL

- A. Independent Testing Agency: Inspection agency employed and paid by Owner, will examine penetration firestopping in accordance with ASTM E2174, and ASTM E2393.
- B. Repair or replace penetration firestopping and joints at locations where inspection results indicate firestopping or joints do not meet specified requirements.

3.06 CLEANING

- A. Clean adjacent surfaces of firestopping materials.

3.07 PROTECTION

A. Protect adjacent surfaces from damage by material installation.

END OF SECTION

NOT FOR BIDDING

SECTION 07 92 00 - JOINT SEALANTS

PART 1 - GENERAL

1.1 SUMMARY

A. Section Includes:

1. Silicone joint sealants.
2. Urethane joint sealants.
3. Latex joint sealants.
4. Preformed joint sealants.
5. Acoustical joint sealants.

B. Related Sections:

1. Division 01 Section 01 74 19 – Construction Waste Management.

1.2 SUBMITTALS

A. Product Data: For each joint-sealant product indicated.

B. Samples: For each kind and color of joint sealant required.

C. Joint-Sealant Schedule: Include the following information:

1. Joint-sealant application, joint location, and designation.
2. Joint-sealant manufacturer and product name.
3. Joint-sealant formulation.
4. Joint-sealant color.

D. Product test reports.

E. Field-adhesion test reports.

F. Warranties.

1.3 QUALITY ASSURANCE

A. Testing Agency Qualifications: Qualified according to ASTM C 1021 to conduct the testing indicated.

B. Preinstallation Conference: Conduct conference at Project site.

1.4 WARRANTY

- A. Special Installer's Warranty: Manufacturer's standard form in which Installer agrees to repair or replace joint sealants that do not comply with performance and other requirements specified in this Section within specified warranty period.
 - 1. Warranty Period: Two years from date of Substantial Completion.
- B. Special Manufacturer's Warranty: Manufacturer's standard form in which joint-sealant manufacturer agrees to furnish joint sealants to repair or replace those that do not comply with performance and other requirements specified in this Section within specified warranty period.
 - 1. Warranty Period: Two years from date of Substantial Completion.

PART 2 - PRODUCTS

2.1 MATERIALS, GENERAL

- A. VOC Content of Interior Sealants: Provide sealants and sealant primers for use inside the weatherproofing system that comply with the following limits for VOC content when calculated according to 40 CFR 59, Part 59, Subpart D (EPA Method 24):
 - 1. Architectural Sealants: 250 g/L.
 - 2. Sealant Primers for Nonporous Substrates: 250 g/L.
 - 3. Sealant Primers for Porous Substrates: 775 g/L.
- B. Liquid-Applied Joint Sealants: Comply with ASTM C 920 and other requirements indicated for each liquid-applied joint sealant specified, including those referencing ASTM C 920 classifications for type, grade, class, and uses related to exposure and joint substrates.
 - 1. Suitability for Immersion in Liquids: Where sealants are indicated for Use I for joints that will be continuously immersed in liquids, provide products that have undergone testing according to ASTM C 1247. Liquid used for testing sealants is deionized water, unless otherwise indicated.
- C. Stain-Test-Response Characteristics: Where sealants are specified to be nonstaining to porous substrates, provide products that have undergone testing according to ASTM C 1248 and have not stained porous joint substrates indicated for Project.
- D. Suitability for Contact with Food: Where sealants are indicated for joints that will come in repeated contact with food, provide products that comply with 21 CFR 177.2600.

2.2 SILICONE JOINT SEALANTS

- A. Neutral-Curing Silicone Joint Sealant: ASTM C 920.

1. Manufacturers: Subject to compliance with requirements, available manufacturers offering products that may be incorporated into the Work include, but are not limited to, the following:
 - a. BASF Building Systems.
 - b. Dow Corning Corporation.
 - c. GE Advanced Materials - Silicones.
 - d. May National Associates, Inc.
 - e. Pecora Corporation.
 - f. Polymeric Systems, Inc.
 - g. Schnee-Morehead, Inc.
 - h. Sika Corporation; Construction Products Division.
 - i. Tremco Incorporated.
2. Type: single component (S).
3. Grade: nonsag (NS).
4. Class: 100/50.
5. Uses Related to Exposure: Nontraffic (NT) typically, Traffic (T) at floor / walkway conditions

2.3 LATEX JOINT SEALANTS

- A. Latex Joint Sealant (interior applications requiring painted finishes): Acrylic latex or siliconized acrylic latex, ASTM C 834, Type GP, Grade NF.
 1. Manufacturers: Subject to compliance with requirements, available manufacturers offering products that may be incorporated into the Work include, but are not limited to, the following]:
 - a. BASF Building Systems.
 - b. Bostik, Inc.
 - c. May National Associates, Inc.
 - d. Pecora Corporation.
 - e. Schnee-Morehead, Inc.
 - f. Tremco Incorporated.

2.4 PREFORMED JOINT SEALANTS

- A. Preformed Foam Joint Sealant (For Limited Use – Existing Joint Repair): Manufacturer's standard preformed, precompressed, open-cell foam sealant manufactured from urethane foam with minimum density of 10 lb/cu. ft. (160 kg/cu. m) and impregnated with a nondrying, water-repellent agent. Factory produce in precompressed sizes in roll or stick form to fit joint widths indicated; coated on one side with a pressure-sensitive adhesive and covered with protective wrapping.
 1. Manufacturers: Subject to compliance with requirements, available manufacturers offering products that may be incorporated into the Work include, but are not limited to, the following]:

- a. Dayton Superior Specialty Chemicals.
- b. EMSEAL Joint Systems, Ltd.
- c. Sandell Manufacturing Co.
- d. Schul International, Inc.
- e. Willseal USA, LLC.

2.5 ACOUSTICAL JOINT SEALANTS

- A. Acoustical Joint Sealant : Manufacturer's standard nonsag, paintable, nonstaining latex sealant complying with ASTM C 834. Product effectively reduces airborne sound transmission through perimeter joints and openings in building construction as demonstrated by testing representative assemblies according to ASTM E 90.
 1. Manufacturers: Subject to compliance with requirements, available manufacturers offering products that may be incorporated into the Work include, but are not limited to, the following:
 - a. Pecora Corporation.
 - b. USG Corporation.

2.6 JOINT SEALANT BACKING

- A. Cylindrical Sealant Backings: ASTM C 1330, Type C (closed-cell material with a surface skin), and of size and density to control sealant depth and otherwise contribute to producing optimum sealant performance.
- B. Bond-Breaker Tape: Polyethylene tape or other plastic tape recommended by sealant manufacturer.

2.7 MISCELLANEOUS MATERIALS

- A. Primer: Material recommended by joint-sealant manufacturer where required for adhesion of sealant to joint substrates indicated, as determined from preconstruction joint-sealant-substrate tests and field tests.
- B. Cleaners for Nonporous Surfaces: Chemical cleaners acceptable to manufacturers of sealants and sealant backing materials.
- C. Masking Tape: Nonstaining, nonabsorbent material compatible with joint sealants and surfaces adjacent to joints.

2.8 PRECURED SILICONE EXTRUSIONS

- A. Precured, Preformed Silicone Extrusion:
 1. Description: Precured elastomeric, nonstaining, silicone joint sealant, flat extrusion, for bonding to substrates.
 2. Compliance: ASTM C 920, Type S, Grade NS, Class 200/50, Use NT.

3. Performance:
 - a. Dynamic Movement Capability: Plus 200 percent and minus 50 percent per ASTM C 1523.
 - b. Service Temperature Range: Minus 60 degrees F to 300 degrees F (minus 51 degrees C to 149 degrees F).
4. Extrusion Width: as indicated on drawings.
5. Surface Treatment: Smooth
6. Color: Custom; match Architect's sample
7. Product: Sil-Span Preformed Silicone Profiles.

PART 3 - EXECUTION

3.1 PREPARATION

- A. Surface Cleaning of Joints: Clean out joints immediately before installing joint sealants to comply with joint-sealant manufacturer's written instructions.
 1. Remove laitance and form-release agents from concrete.
 2. Clean nonporous joint substrate surfaces with chemical cleaners or other means that do not stain, harm substrates, or leave residues capable of interfering with adhesion of joint sealants.
- B. Joint Priming: Prime joint substrates where recommended by joint-sealant manufacturer or as indicated by preconstruction joint-sealant-substrate tests or prior experience. Apply primer to comply with joint-sealant manufacturer's written instructions. Confine primers to areas of joint-sealant bond; do not allow spillage or migration onto adjoining surfaces.
- C. Masking Tape: Use masking tape where required to prevent contact of sealant or primer with adjoining surfaces that otherwise would be permanently stained or damaged by such contact or by cleaning methods required to remove sealant smears. Remove tape immediately after tooling without disturbing joint seal.

3.2 INSTALLATION

- A. Sealant Installation Standard: Comply with recommendations in ASTM C 1193 for use of joint sealants as applicable to materials, applications, and conditions indicated.
- B. Install sealant backings of kind indicated to support sealants during application and at position required to produce cross-sectional shapes and depths of installed sealants relative to joint widths that allow optimum sealant movement capability.
 1. Do not leave gaps between ends of sealant backings.
 2. Do not stretch, twist, puncture, or tear sealant backings.
 3. Remove absorbent sealant backings that have become wet before sealant application and replace them with dry materials.
- C. Install bond-breaker tape behind sealants where sealant backings are not used between sealants and backs of joints.

- D. Install sealants using proven techniques that comply with the following and at the same time backings are installed:
 - 1. Place sealants so they directly contact and fully wet joint substrates.
 - 2. Completely fill recesses in each joint configuration.
 - 3. Produce uniform, cross-sectional shapes and depths relative to joint widths that allow optimum sealant movement capability.
- E. Tooling of Nonsag Sealants: Immediately after sealant application and before skinning or curing begins, tool sealants according to requirements specified in subparagraphs below to form smooth, uniform beads of configuration indicated; to eliminate air pockets; and to ensure contact and adhesion of sealant with sides of joint.
 - 1. Remove excess sealant from surfaces adjacent to joints.
 - 2. Use tooling agents that are approved in writing by sealant manufacturer and that do not discolor sealants or adjacent surfaces.
 - 3. Provide concave joint profile per Figure 8A in ASTM C 1193, unless otherwise indicated.
- F. Acoustical Sealant Installation: Comply with ASTM C 919 and with manufacturer's written recommendations.
- G. Clean off excess sealant or sealant smears adjacent to joints as the Work progresses by methods and with cleaning materials approved in writing by manufacturers of joint sealants and of products in which joints occur.

3.3 FIELD QUALITY CONTROL

- A. Field-Adhesion Testing: Field test joint-sealant adhesion to joint substrates as follows:
 - 1. Extent of Testing: Test completed and cured sealant joints as follows:
 - a. Perform 1 test for each 1000 feet (300 m) of joint length thereafter or 1 test per each floor per elevation.
 - 2. Test Method: Test joint sealants according to Method A, Field-Applied Sealant Joint Hand Pull Tab, in Appendix X1 in ASTM C 1193 or Method A, Tail Procedure, in ASTM C 1521.
- B. Evaluation of Field-Adhesion Test Results: Sealants not evidencing adhesive failure from testing or noncompliance with other indicated requirements will be considered satisfactory. Remove sealants that fail to adhere to joint substrates during testing or to comply with other requirements. Retest failed applications until test results prove sealants comply with indicated requirements.

3.4 ELASTOMERIC JOINT-SEALANT SCHEDULE

- A. Low-Modulus Nonacid-Curing Silicone Sealant:

1. Where joint sealants of this type are indicated, provide one of the following:
 - a. 790; Dow Corning.
 - b. UltraPruf SCS2300; GE Silicones.
 - c. 890; Pecora Corporation.
 - d. Omniseal; Sonneborn Building Products Div., ChemRex Inc.
2. Type and Grade: S (single component) and NS (nonsag).
3. Class: 25.
4. Use Related to Exposure: NT (nontraffic).
5. Uses Related to Joint Substrates: M, G, A, and, as applicable to joint substrates indicated, O.
 - a. Use O Joint Substrates: Coated glass, aluminum coated with a high-performance coating, , brick, granite, limestone, and ceramic tile.
6. Applications: Exposed joints within aluminum glazed curtain wall system and / or storefront system.
7. Color as selected by Architect and Owner.

B. Multicomponent Pourable Urethane Sealant:

1. Where joint sealants of this type are indicated, provide one of the following:
 - a. Chem-Calk 550; Bostik Inc.
 - b. NR-300 Urexpan, Type M; Pecora Corporation.
 - c. SL 2; Sonneborn Building Products Div., ChemRex Inc.
 - d. THC-901; Tremco.
2. Type and Grade: M (multicomponent) and P (pourable).
3. Class: 25.
4. Use Related to Exposure: T (traffic)
5. Uses Related to Joint Substrates: M, A, and as applicable to joint substrates indicated, O.
 - a. Use O Joint Substrates: granite, limestone, marble, and ceramic tile
6. Applications: Floors as indicated on drawings
7. Color as selected by Architect and Owner.

3.5 LATEX JOINT-SEALANT SCHEDULE

A. Latex Sealant:

1. Where joint sealants of this type are indicated, provide one of the following:
 - a. Chem-Calk 600; Bostik Inc.
 - b. AC-20; Pecora Corporation
 - c. Sonolac; Sonneborn Building Products Div., ChemRex, Inc.
 - d. Tremflex 834; Tremco

2. Applications: Interior joints in vertical and overhead surfaces of gypsum drywall assemblies; hollow metal door frames; all other interior joints between similar materials, and joints between dissimilar materials.
3. Color as selected by Architect and Owner.

3.6 ACOUSTICAL JOINT-SEALANT SCHEDULE

A. Acoustical Sealant for Exposed and Concealed Joints:

1. Where joint sealants of this type are indicated, provide one of the following:
 - a. AC-20 FTR Acoustical and Insulation Sealant; Pecora Corporation.
 - b. SHEETROCK Acoustical Sealant; USG Corp., United States Gypsum Co.
2. Applications: Interior joints requiring sound isolation
3. Color as selected by Architect and Owner

3.7 PREFORMED JOINT-SEALANT SCHEDULE

A. Preformed Foam Sealant:

1. Where joint sealants of this type are indicated, provide one of the following:
 - a. Emseal Greyflex; Emseal Joint Systems, Ltd.
 - b. Polytite B; Polytite Manufacturing Corporation.
2. Applications: Exterior vertical wall expansion joint assemblies
3. Color as selected by Architect and Owner.

END OF SECTION 07 92 00

SECTION 06 16 00 - SHEATHING

PART 1 - GENERAL

1.1 SUMMARY

- A. Section Includes: Work under this section comprises of furnishing hollow metal doors and frames, including transom frames, sidelight and window frames with provision for glazed, paneled or louvered openings, fire labeled and non-labeled, as scheduled.
1. Flush Steel Doors.
 2. Temperature Rise Doors.
 3. Steel Frames.
 4. Hollow Metal Framing Systems.
- B. Related Sections: Related documents, drawings and general provisions of contract, including General and Supplementary Conditions and Division 1 specification sections apply to this section. The latest published edition of each reference applies.
1. Section 06 10 00 - Rough Carpentry
 2. Section 08 14 00 - Wood Doors
 3. Section 08 71 00 - Door Hardware
 4. Section 08 80 00 - Glazing
 5. Section 09 90 00 - Painting and Coating
- C. References: The intent of this document is that all hollow metal and its application will comply or exceed the standards identified below. The latest published edition of each reference applies.
1. ANSI – American National Standards Institute - ansi.org
 2. NFPA – National Fire Protection Association
 - a. NFPA 80 – Standard for Fire Doors and Other Opening Protectives
 - b. NFPA 101 – Life Safety Code
 - c. NFPA 105 – Standard Smoke Door Assemblies and Other Opening Protectives
 - d. NFPA 252 – Standard Method of Fire Tests of Door Assemblies
 3. DHI – Door and Hardware Institute – Door Security + Safety Professionals
 - a. Installation Guide for Doors and Hardware
 - b. Recommended Locations for Architectural Hardware for Standard Steel Doors and Frames
 - c. Recommended Locations for Builders' Hardware for Custom Steel Doors and Frames
 4. SDI – Steel Door Institute
 - a. SDI-105 – Recommended Erection Instructions for Steel Frames
 - b. SDI-107 – Hardware on Steel Doors (Reinforcement - Application)

- c. SDI-111 – Recommended Details for Standard Steel Doors, Frames, Accessories, and Related Components
 - d. SDI-117 – Manufacturing Tolerances Standard Steel Doors and Frames
 - e. SDI -118 – Basic Fire Door Requirements
 - f. SDI A250.3 – Test Procedure and Acceptance Criteria for Factory Applied Finish Coatings for Steel Doors and Frames
 - g. SDI A250.4 – Test Procedure and Acceptance Criteria for Physical Endurance for Steel Doors, Frames, and Frame Anchors
 - h. SDI A250.6 – Recommended Practice for Hardware Reinforcing on Standard Steel Doors and Frames
 - i. SDI A250.8 – SDI-100 Specifications for Standard Steel Doors and Frames
 - j. SDI A250.10 – Test Procedure and Acceptance Criteria for Prime Painted Steel Surfaces for Steel Doors and Frames
 - k. SDI A250.11 – Recommended Erection Instructions for Steel Frames
5. BHMA – Builders Hardware Manufacturers Association
- a. BHMA A156.115 – Hardware Preparations in Standard Steel Doors and Frames
 - b. BHMA A156.7 – Hinge Template Dimensions
6. ASTM – American Society for Testing Materials
- a. ASTM A568/A568M-19a Standard Specification for Steel, Sheet, Carbon, Structural, and High-Strength, Low-Alloy, Hot-Rolled and Cold-Rolled, General Requirements
 - b. ASTM A879/A879M-12(2017) Standard Specification for Steel Sheet, Zinc Coated by the Electrolytic Process for Applications Requiring Designation of the Coating Mass on Each Surface
 - c. ASTM A653/A653M-19a Standard Specification for Steel Sheet, Zinc-Coated (Galvanized) or Zinc-Iron Alloy-Coated (Galvannealed) by the Hot-Dip Process
 - d. ASTM A924/A924M-19 Standard Specification for General Requirements for Steel Sheet, Metallic-Coated by the Hot-Dip Process
 - e. ASTM A1008/A1008M-18 Standard Specification for Steel, Sheet, Cold-Rolled, Carbon, Structural, High-Strength Low-Alloy, High-Strength Low-Alloy with Improved Formability, Solution Hardened, and Bake Hardenable
7. ICC – International Code Council
- a. ICC A117.1 – Accessible and Usable Building and Facilities
 - b. ICC Standard for the Design and Construction of Storm Shelters
8. UL – Building Materials Directory; Underwriters Laboratories Inc.
- a. UL 10B – Standard for Neutral Pressure Fire Tests of Door Assemblies
 - b. UL 10C – Standard for Positive Pressure Fire Tests of Door Assemblies
 - c. UL 1784 – Air Leakage Test of Door Assemblies
 - d. UL 752 – Standard for Bullet-Resisting Equipment
9. NAAMM/HMMA – National Association of Architectural Metal Manufacturers/Hollow Metal Manufacturers Association

- a. NAAMM/HMMA 840 – Guide Specification for Receipt, Storage, and Installation of Hollow Metal Doors and Frames

10. WH – Certification Listings; Warnock Hersey International, Inc.

1.2 SUBSTITUTIONS:

- A. All substitution requests must be submitted within the procedures and time frame as outlined in Division 1, General Requirements. Approval of products is at the discretion of the architect and their consultant.

1.3 SUBMITTALS

- A. Submittals to comply with provisions of Division 01, Submittal Procedures.
- B. Product Data: Manufacturer's standard details and catalog data indicating compliance with referenced standards and manufacturer's installation instructions.
- C. Shop Drawings: Provide a schedule of doors and frames using same reference numbers for details and door openings as those on the contract documents. Shop drawings should include the following information to ensure doors and frames are properly prepared and coordinated to receive hardware.
 1. Elevations of each door and frame type.
 2. Details for door core.
 3. Details of doors, including vertical- and horizontal-edge details and metal thicknesses.
 4. Locations of cutouts for glass and louvers.
 5. Frame details for each frame type including dimensioned profiles and metal thicknesses.
 6. Mounting locations for hardware.
 7. Thickness of reinforcement/preparations for hardware.
 8. Details of anchorages, joints, field splices, and connections.
 9. Details of accessories.
 10. Details of moldings, removable stops, and glazing.
 11. Fire ratings.
 12. Finishes.
- D. Samples: 12 by 12 inches (304 mm by 304 mm) cut away sample door with provisions for lockset, hinge and corner section of frame welded and prepped for specified hardware. Sample should be furnished with submittals for Owner approval. After approval return sample to door/frame supplier as confirmation of approved construction.
- E. Closeout Submittals to comply with Division 1, Closeout Submittals procedures.
- F. Furnish copies of manufacturer's warranty information and maintenance instructions.

1.4 QUALITY ASSURANCE

- A. Hollow Metal Distributor is to be a direct account of the manufacturer of the products furnished. In addition, that distributor must have in their regular employment an Architectural Hardware Consultant (AHC), Certified Door Consultant (CDC), an Architectural Openings Consultant (AOC), a Door & Hardware Consultant (DHC) or equivalent door and hardware industry experience who will be available to consult with the Architect and Contractor regarding any matters affecting the door and frame opening.

- B. Manufacturer Qualifications: Certified Member of the Steel Door Institute in good standing.
- C. Installer: Minimum five years documented experience installing products specified this Section.
- D. Certificates
 - 1. Manufacturer's certification that products comply with referenced standards.
 - 2. Hollow Metal Manufacturer must provide documentation that they are an SDI Certified Manufacturer.
- E. Fire Rated Doors and Frames: Underwriters' Laboratories, Intertek Testing Services/Warnock Hersey, and Factory Mutual labeled fire doors and frames:
 - 1. Provide labeled fire doors and frames in accordance with Underwriters Laboratories standard UL10C Positive Pressure Fire Tests of Door Assemblies.
 - 2. Construct and install doors and frames to comply with current issue of NFPA 80.
 - 3. Manufacturer Underwriters' Laboratories labeled doors and frames in strict compliance to UL procedures, and provide the degree of fire protection, heat transmission and panic loading capability indicated by the opening class.
 - 4. Manufacturer Intertek Testing Services /Warnock Hersey labeled doors and frames in strict compliance to ITS/WH procedures and provide the degree of fire protection capability indicated by the opening class.
 - 5. Affix a physical label or approved marking to each fire door and/or fire door frame, at an authorized facility as evidence of compliance with procedures of the labeling agency.
 - 6. Conform to applicable codes for fire ratings. It is the intent of this specification that doors, frames, hardware and their application comply or exceed the standards for labeled openings. In case of conflict between types required for fire protection, furnish type required by NFPA and UL.
 - 7. Provide Temperature Rise Fire Door Assemblies in exit enclosures and exit passageway with maximum transmitted temperature end point rating of not more than 250 degrees F (121 degrees C) above ambient at the end of 30 minutes of the standard fire test exposure.
 - 8. For openings required to be fire rated exceeding limitations of labeled assemblies, submit manufacturer's certification that each door and frame assembly has been constructed to conform to design, materials and construction equivalent to requirements for labeled construction.

1.5 DELIVERY, STORAGE, AND HANDLING

- A. Packaging and Shipping
 - 1. The use of non-vented plastic or canvas shelters that can create a humidity chamber shall be avoided to prevent rust or damage.
 - 2. Provide cardboard wrapped or crated product to provide protection during transit and job site storage.
 - 3. Should wrappers become wet, remove immediately.
- B. Delivery and Site Acceptance
 - 1. The supplier shall deliver all materials to the project site; direct factory shipments are not allowed unless agreed upon beforehand. Supplier shall coordinate delivery times and schedules with the contractor.

2. Deliver doors cardboard wrapped or crated to provide protection during transit and job site storage. Provide additional protection to prevent damage to any factory-finished doors. Mark all doors and frames with architects opening numbers as shown on the contract documents and shop drawings on the center hinge preparation location.
3. Upon delivery, check in doors and frames jointly with supplier. Inspect doors and frames upon delivery for damage, correct quantities or shortages. Minor damages may be repaired provided refinished items are equal in all respects to new work and acceptable to the architect. Otherwise, remove and replace damaged goods as directed. Note shortages and replace immediately.

C. Storage and Protection

1. Handle, store and protect products in accordance with the manufacturers printed instructions, ANSI/SDI A250.8 – Specifications for Standard Steel Doors and Frames, A250.10 - Test Procedure and Acceptance Criteria for Prime Painted Steel Surfaces for Steel Doors and Frames, or ANSI/SDI A250.3 - Test Procedure and Acceptance Criteria for Factory Applied Finish Coatings for Steel Doors and Frames and NAAMM/HMMA 840 – Guide Specification for Receipt, Storage, and Installation of Hollow Metal Doors and Frames.
2. Store all materials in a dry area. All hollow metal material shall be stored so that it does not come in contact with water or moisture. Protect units from adverse weather elements.
3. Place units on 4 inch (102 mm) high wood skids to prevent rust and damage.
4. Store doors vertically under a properly vented cover, five units maximum in a stack with a 1/4" space between doors to permit air circulation.
5. Store frames in an upright position with heads uppermost under cover.
6. Store assembled frames five units maximum in a stack with 2-inch (51 mm) space between frames to permit air circulation.

1.6 COORDINATION

- A. Coordinate work with other directly affected sections involving manufacture or fabrication of internal cutouts and reinforcement for door hardware, electric devices and recessed items.
- B. Coordinate work with frame opening construction, door and hardware installation.
- C. Sequence installation to accommodate required door hardware.
- D. Verify field dimensions for factory assembled frames prior to fabrication.

1.7 WARRANTY

- A. Comply with Division 01 Closeout Submittals.
- B. All doors and frames shall be warranted in writing by the manufacturer against defects in materials and workmanship for a period of one (1) year commencing on the date of manufacture.

PART 2 - PRODUCTS

2.1 MANUFACTURERS

A. Following Code Compliance, provide the following basis of design, or approved equal:

1. Basis-of-Design – MESKER a dormakaba Brand, Web: <http://meskerdoor.com>
 - a. Acceptable Manufacturer – Curries an ASSA Abloy Company
 - b. Acceptable Manufacturer – Steelcraft an Allegion Company

B. Provide all steel doors and frames from a single SDI certified manufacturer.

2.2 GENERAL

A. Physical performance: Units shall comply with the 1 million cycles swing test requirement per ANSI A250.4 - Level A.

B. Finishing:

1. Prime Gray to meet SDI A250.10

C. Electrical Requirements: Coordinate all electrical requirements for doors and frames. Make provisions for installation of electrical items so that wiring can be readily removed and replaced.

1. Provide cutouts and reinforcements required for metal doors and frames to accept electric components.
2. Frame with Electrical Hinges: Junction box welded over center hinge reinforcing. Top or bottom hinge locations are not permitted.
3. Coordinate with Section 08 71 00 (or Division 28) for electrified hardware items.

2.3 DOORS

A. General: Construct exterior/interior doors to the following designs and gauges:

1. Exterior Doors: Zinc-Iron Alloy-Coated galvanized steel (A40) (A60) or Zinc-Coated Galvanized steel (G90) that conforms to ASTM A653/A653M:
 - a. Thickness: 16 gauge.
 - b. Provide flush top/closed top channel for exterior swing-out doors to eliminate moisture penetration. Galvanized steel top caps are permitted.
2. Interior Doors: Cold-rolled steel, ASTM A 1008/A 1008M:
 - a. Thickness: 18 gauge.
3. Door Thickness: 1-3/4 inches.
4. Vertical edge seams: Provide doors with continuous vertical mechanical inter-locking joints at lock and hinge edges. Finish edges as follows:

- a. Welded Vertical Edges: Continuous vertical weld and pressed smooth with no putty or filler.
5. Bevel hinge and lock door edges 1/8 inch (3 mm) in 2 inches (50 mm). Square edges on hinge and/or lock stiles are acceptable.
6. Reinforce top and bottom of doors with galvanized 16 gauge minimum, welded to both panels.
7. Fire Rating: Supply door units bearing Labels for fire ratings indicated in Door Schedule for the locations indicated.
8. Core Adhesion System – Basis of design - Moisture Cure Polyurethane Hot Melt:
 - a. Adhesives are to cure completely, meaning once set, they cannot be re-melted and will not soften or freeze and lose adhesion.
 - b. Adhesive system will have an enhanced resistance to flame spread in its cured state designed to pass UL 10C, Positive Pressure Fire Tests of Door Assemblies.
 - c. Bonded assemblies will withstand prolonged exposure from -35°F (-37°C) to 200°F (93°C) temperatures without exhibiting any signs of bond failure.
 - d. Cured adhesive film will remain flexible to allow for differences in thermal expansion and contraction of various substrates without sacrificing bond performance.
9. Core
 - a. HDP – High Density Polystyrene.
10. Glass moldings and stops:
 - a. Fabricate from 18 gauge minimum steel.
 - b. Install trim into the door as a four-sided welded assembly with mitered, reinforced and welded corners.
 - c. Trim: identical on both sides of the door.
 - d. Labeled and non-labeled doors: use the same trim to match aesthetics.
 - e. Channeling requirements:
 - 1) Cutouts larger than 36" in height require 18 gauge perimeter channelings in the cutout of the door prior to installation of the lite kit or louver.
11. Hardware Reinforcements:
 - a. Doors shall be mortised and adequately reinforced per the manufacturers guidelines for all hardware. Required mortise hardware reinforcements shall be drilled and tapped at the factory. Surface applied hardware shall be field drilled by hardware installer.
 - b. Hinge reinforcements for full mortise hinges: minimum 7 gauge with an extra long, high frequency top hinge reinforcement as a standard feature.
 - c. Lock reinforcements: minimum 16 gauge.
 - d. Closer reinforcements: minimum 14 gauge steel.
 - e. Projection welded hinge and lock reinforcements to the edge of the door.
 - f. Provided adequate reinforcements for other hardware as required.

B. Full Flush Doors:

1. Basis-of-Design: MESKER N-Series.

C. Temperature Rise Doors:

1. Basis-of-Design: MESKER NF-Series Doors.
2. Mineral Fiber Core: Full 1-3/4 inches (45mm) mineral fiber core material designed to comply with the 250 degrees F (121 degrees C) maximum temperature rise rating.

2.4 DOOR FRAMES

A. General: Construct exterior/interior metal door frames to the following designs and gauges:

1. Exterior Frames: Zinc-Iron Alloy-Coated galvanized steel (A40) (A60) or Zinc-Coated Galvanized steel (G90) that conforms to ASTM A 653/A653M:
 - a. Thickness: 14 gauge.
2. Interior Frames in Masonry: Zinc-Iron Alloy-Coated galvanized steel (A40) (A60) or Zinc-Coated Galvanized steel (G90) that conforms to ASTM A 653/A653M:
 - a. Thickness: 16 gauge.
3. Interior Frames in stud wall construction: cold rolled steel, ASTM A 1008/A 1008M.
 - a. Thickness: 16 gauge.

B. Flush Steel Frames:

1. Basis-of-Design: MESKER F-Series.
2. Profile:
 - a. Face:
 - 1) 2 inches face dimension and types and throat dimensions indicated on the Door Schedule.
 - 2) Custom special face dimension and types and throat dimensions indicated on the Door Schedule.
3. Provide reinforcements and accessories for specified hardware per SDI 250.6.
4. Anchors: Locate adjustable anchors in each jamb 6 inches from the top of the door opening to hold frame in rigid alignment.
 - a. Strap anchors welded to frame.
5. Fire Rating: Supply frame units bearing Labels for fire ratings indicated in Door Schedule for the locations indicated

2.5 HOLLOW METAL FRAMING SYSTEM

A. Hollow Metal Framing System:

1. Basis of Design: MESKER S-Series, M-Series

2. Components: Construct architectural stick frame assemblies of standard frame components, fabricated as specified.
 - a. Exterior Frame Material: Zinc-Iron Alloy-Coated galvanized steel (A40) (A60) or Zinc-Coated Galvanized steel (G90) that conforms to ASTM A 653/A653M, 14 gauge galvanized steel.
 - b. Interior Frames in Masonry: Zinc-Iron Alloy-Coated galvanized steel (A40) (A60) or Zinc-Coated Galvanized steel (G90) that conforms to ASTM A 653/A653M, 16 gauge galvanized steel.
 - c. Interior Frames in stud wall construction: 16 gauge cold rolled steel, ASTM A 1008/A 1008M steel.
 - d. Include galvanized components and internal reinforcements with galvanized frames.
3. Frame component requirements:
 - a. Prepare required sticks at door openings and frame assemblies for hardware as specified in Section 087100.
 - b. Fabricate frame assemblies from three basic components:
 - 1) Open Sections (perimeter members) identical in configuration to standard frames.
 - 2) Closed sections (intermediate members) with identical jamb depth, face dimensions, and stops as open sections.
 - 3) Sill sections: To be flush with both faces of adjacent vertical members. Cut individual components to length and notched to assure square joints and corners.
 - c. Externally welded face joints at meeting mullions or between mullions and other frame members on the face surfaces only. Grind and finish face joints smooth.
 - d. Fabricate frame assemblies for shipment to the jobsite completely welded.
 - 1) Field joints permissible only when the size of the total assembly exceeds shipping limitations.
 - 2) Fabricate oversized frames in sections designated for splicing in the field..
 - e. Pierce and dimpled glazing beads for use with manufacturers' standard fasteners.
 - f. Provide necessary anchors for jambs, heads, and sills of assemblies.
 - g. Verify field dimensions as required. Do not begin fabrication until these dimensions have been verified and approved.
4. Accessories:
 - a. Glazing Bead: Formed steel sheet; screw-attached.
 - b. Steel Panels:
 - 1) 1/2-inch – 1 inch thick and manufactured from 18 gauge or 16 gauge thick non-galvanized or galvanized steel faces with a polystyrene core.
 - 2) 1-3/4 inches thick and manufactured from 18 gauge or 16 gauge thick non-galvanized or galvanized steel faces with a steel stiffened core for fire rated openings.

5. Fire Rating: Provide factory assembled welded units bearing Labels for fire ratings indicated on the Drawings.

2.6 ACCESSORIES

- A. Anchors: Manufacturer's standard framing anchors, specified in manufacturer's printed installation instructions for project conditions.
- B. Astragals for pairs of doors: Manufacturer's standard for labeled and non-labeled openings.
- C. Plaster Guards: Same material as door frame, minimum 24 gauge (0.5 mm) minimum; provide for all strike boxes. Plaster guards not mandatory on interior after set frames.
- D. Silencers: Resilient rubber, Inserted type, three per strike jamb for single openings. Stick-on silencers shall not be permitted except on hollow metal framing systems.
- E. Glazing: Specified in Section 088000.

2.7 FABRICATION

- A. Steel Frames:
 1. Fabricate steel door and frame units to be rigid, neat in appearance, and free from defects, warp, or buckle. Where practical, fit and assemble units in manufacturer's plant. Clearly identify work that cannot be permanently factory assembled before shipment, to assure proper assembly at Project site. Comply with ANSI/SDI 100 requirements.
 - a. Clearances shall comply with the requirements of NFPA 80..
 2. Factory-welded frames: Head and jamb intersecting corners mitered at 45 degrees, with back welded joints ground smooth.
 - a. Continuous face weld the joint between the head and jamb faces along their length either internally or externally. Grind, prime paint, and finish smooth face joints with no visible face seams.
 3. Provide temporary steel spreaders (welded to the jambs at each rabbet of door openings) on welded frames during shipment. Remove temporary steel spreaders prior to installation of the frame.
- B. Tolerances shall comply with SDI-117 "Manufacturing Tolerances for Standard Steel Doors and Frames".
- C. Fabricate concealed stiffeners, reinforcement, edge channels, louvers, and moldings from either cold-rolled or hot-rolled steel sheet.
- D. Unless otherwise indicated, provide exposed fasteners with countersunk flat or oval heads for exposed screws and bolts.
- E. Prepare doors and frames to receive mortised and concealed hardware per final door hardware schedule and templates provided by hardware supplier. Comply with applicable requirements of SDI-107 and ANSI-A115 Series specifications for door and frame preparation for hardware.
- F. Reinforce doors and frames to receive surface-applied hardware per SDI A250.6. Drilling and tapping for surface-applied hardware shall be done at Project site. Provide internal reinforcements for all doors to receive door closers and exit devices where scheduled.

- G. Locate hardware as indicated on Shop Drawings or, if not indicated, per the Door and Hardware Institute's (DHI) "Recommended Locations for Architectural Hardware for Standard Steel Doors and Frames".

2.8 FINISHES

- A. Chemical Treatment: Treat steel surfaces to promote paint adhesion.
- B. Exposed door and frame surfaces to be cleaned and treated then coated with rust inhibitive primer. Water-based primer and color paint finishes to be free of Hazardous Air Pollutants (HAPS) and Volatile Organic Compounds (VOCs). Paint to comply with ANSI A250.3 and A250.10.

PART 3 - EXECUTION

3.1 EXAMINATION

- A. Verify that project conditions are acceptable before beginning installation of frames.
 - 1. Verify that completed openings to receive knock-down wrap-around frames are of correct size and thickness.
 - 2. Verify that completed concrete or masonry openings to receive butt type frames are of correct size.
- B. Do not begin installation until conditions have been properly prepared.
- C. Correct unacceptable conditions before proceeding with installation.

3.2 INSTALLATION

- A. Install doors and frames in accordance with manufacturer's printed installation instructions and with Steel Door Institute's recommended erection instructions for steel frames SDI A250.11 and NAAMM/HMM A 84.
- B. DHI – Door and Hardware Institute – Door Security + Safety Professionals – Installation Guide for Doors and Hardware.
- C. Fire Doors and Frames: Install in accordance with SDI A 250.11 and NFPA 80.
 - 1. To ensure compliance with Positive Pressure criteria as required by UBC7-2, UL10C, NFPA5000 and all applicable Local, State and National Code Jurisdictions, all Doors and Frames should be checked for accurate installation per Manufacturers installation instructions to provide proper fire and Smoke Gasketing as tested and listed.
 - 2. Fit hollow-metal doors accurately in frames, within clearances specified in SDI A 250.11 and SDI 100. Install fire rated doors with clearances specified in NFPA 80.
- D. Comply with provisions of SDI-105, "Recommended Erection Instructions for Steel Door Frames," unless otherwise indicated. Set frames accurately in position, plumbed, aligned, and braced securely until permanent anchors are set.
 - 1. Except for frames located in existing concrete, masonry, or gypsum board assembly construction, place frames before constructing enclosing walls and ceilings.

2. In masonry construction, install at least 3 wall anchors per jamb adjacent to hinge location on hinge jamb and at corresponding heights on strike jamb. Acceptable anchors include masonry wire anchors and masonry T-shaped anchors. Use additional anchors as required for height per manufacturers' installation instructions.
 3. At existing concrete or masonry construction, install at least 3 completed opening anchors per jamb adjacent to hinge location on hinge jamb and at corresponding heights on strike jamb. Set frames and secure to adjacent construction with bolts and masonry anchorage devices. Use additional anchors as required for height per manufacturers' installation instructions.
 4. In metal-stud partitions, install at least 3 wall anchors per jamb at hinge and strike levels. In steel-stud partitions, attach wall anchors to studs with screws. Secure Sill Anchors to floor. Use additional anchors as required for height per manufacturers' installation instructions.
 5. Drywall series frames are designed for installation in interior applications after construction of wood or metal stud and drywall applications. Drywall series frames are provided with adjustable jamb lock anchors for secure installation. Install frames per manufacturers' installation instructions. Adjust anchors and secure sill and baseboard anchors as provided.
- E. Remove temporary steel spreaders prior to installation of frames.
- F. Set frames accurately in position; plumb, align and brace until permanent anchors are set. After wall construction is complete, remove temporary wood spreaders.
1. Field splice only at approved locations indicated on the shop drawings.
 2. Weld, grind, and finish as required to conceal evidence of splicing on exposed faces.
- G. Provide full height 3/8 inch (9.5 mm) to 1-1/2 inch (38 mm) thick strip of polystyrene foam blocking at frames requiring grooving. Apply the strip to the back of the frame to facilitate field drilling or tapping.
- H. Glaze and seal exterior transoms, sidelight and window frames in accordance with HMMA-820 TN03.
- I. Apply hardware in accordance with hardware manufacturers' instructions and Section 087100 of these Specifications. Install hardware with only factory-provided fasteners. Install silencers. Adjust door installation to provide 1/8" at head and 1/8" at strike and hinge jamb with door undercut to meet fire ratings and floor conditions to achieve maximum operational effectiveness and appearance.

3.3 FIELD QUALITY CONTROL

A. Fire-Rated Door Assembly Testing:

1. Upon completion of the installation, test each fire door assembly to confirm proper operation of its closing device and verify that it meets all criteria of a fire door assembly per NFPA 80.
2. Perform inspections by individuals with documented knowledge and understanding of the operation components of the type of door being tested per NFPA 80 and NFPA 101.
3. Provide a written record to the Owner with copies available to the Authorities Having Jurisdiction (AHJ).
4. Record shall list the fire door assembly and include the door number with an itemized list of hardware set components for each door opening and location in the facility.

3.4 ADJUST AND CLEAN

- A. Adjust doors for proper operation, free from binding or other defects.
- B. Clean and restore soiled surfaces. Remove scraps and debris and leave site in a clean condition.
- C. Prime Coat Touch-Up: Immediately after erection, sand smooth rusted or damaged areas of prime coat, and apply touch-up of compatible air-drying primer.
- D. Properly clean and apply paint to doors and frames in accordance with HMMA-840 TN01 and ANSI A250.8 appendix B along with Manufactures recommended surface preparation for painting.

3.5 PROTECTION

- A. Protect installed products and finished surfaces from damage during construction.

END OF SECTION 08 11 13

NOT FOR BIDDING

SECTION 08 14 16 - FLUSH WOOD DOORS

PART 1 - GENERAL

1.1 RELATED DOCUMENTS

- A. Drawings and general provisions of the Contract, including General and Supplementary Conditions and Division 1 Specification Sections, apply to this Section.

1.2 SUMMARY

A. Section Includes:

1. Solid core doors with wood veneer faces.
2. Factory finishing wood doors.
3. Factory fitting wood doors to frames and factory machining for hardware.
4. Light frames and glazing installed in wood doors

B. Related Sections:

1. Division 06 Section "Interior Architectural Woodwork" for requirements for veneers from the same flitches for both wood doors and wood paneling.
2. Division 08 Section "Hollow Metal Doors and Frames" for wood doors in steel frames.
3. Division 08 Section "Glazing" for glass view panels in wood doors.
4. Division 08 Sections "Door Hardware" for door hardware for flush wood doors and wood frames.
5. Division 28 Section "Access Control" for access control devices installed at door openings and provided as part of a security access system.

C. Standards and References: Comply with the version year adopted by the Authority Having Jurisdiction.

1. ANSI A208.1 - Particleboard.
2. Intertek Testing Service (ITS Warnock Hersey) - Certification Listings for Fire Doors.
3. NFPA 80 - Standard for Fire Doors and Fire Windows; National Fire Protection Association.
4. NFPA 252 - Standard Methods of Fire Tests of Door Assemblies; National Fire Protection Association.
5. UL 10C - Positive Pressure Fire Tests of Door Assemblies; UL 1784 - Standard for Air Leakage Tests of Door Assemblies.
6. United States Green Building Council (USGBC).
7. Window and Door Manufacturers Association - WDMA I.S.1-A Architectural Wood Flush Doors.
8. Window and Door Manufacturers Association - WDMA I.S. 10 Industry Standard for Testing Cellulosic Composite Materials for Use in Fenestration Products.

1.3 SUBMITTALS

- A. Product Data: For each type of door indicated. Include details of core and edge construction, louvers, trim for openings, and WDMA I.S.1-A or AWS classifications. Include factory finishing specifications.
- B. Door hardware supplier is to furnish templates, template reference number and/or physical hardware to the wood door supplier in order to prepare the doors and frames to receive the finish hardware items.
- C. Shop Drawings: Indicate location, size, and hand of each door; elevation of each kind of door; construction details not covered in Product Data; location and extent of hardware blocking; and other pertinent data.
 - 1. Indicate dimensions and locations of mortises and holes for hardware.
 - 2. Indicate dimensions and locations of cutouts.
 - 3. Indicate requirements for veneer matching.
 - 4. Indicate doors to be factory finished and finish requirements.
 - 5. Indicate fire protection ratings for fire rated doors.
- D. Samples for Initial Selection: For factory finished doors.
 - 1. Factory finishes applied to actual door face materials, approximately 8 by 10 inches, for each material and finish. For each wood species and transparent finish, provide set of three samples showing typical range of color and grain to be expected in the finished work.
 - 2. Corner sections of doors, 6 by 10 inches, with door faces and edges representing actual materials to be used.
 - a. Provide samples for each species of veneer and solid lumber required.
 - b. Finish veneer faced door samples with same materials proposed for factory finished doors.
 - 3. Frames for light openings, 6 inches long, for each material, type, and finish required.
- E. Warranty: Sample of special warranties.

1.4 QUALITY ASSURANCE

- A. Source Limitations: Obtain flush wood doors through one source from a single manufacturer wherever possible.
- B. Quality Standard: In addition to requirements specified, comply with WDMA I.S.1-A, latest edition, "Industry Standard for Architectural Wood Flush Doors."
- C. Pre-Submittal Conference: Conduct conference in compliance with requirements in Division 01 Section "Project Meetings" with attendance by representatives of Supplier, Installer, and Contractor to review proper methods and procedures for receiving, handling, and installing flush wood doors.

1.5 DELIVERY, STORAGE, AND HANDLING

- A. Comply with requirements of referenced standard and manufacturer's written instructions.
- B. Package pre-finished doors individually in plastic bags or cardboard cartons and wrap bundles of doors in plastic sheeting.
- C. Mark each door on top rail with opening number used on Shop Drawings.

1.6 PROJECT CONDITIONS

- A. Environmental Limitations: Do not deliver or install doors until spaces are enclosed and weather tight, wet work in spaces is complete and dry, and HVAC system is operating and maintaining ambient temperature and humidity conditions at occupancy levels during the remainder of the construction period.

1.7 WARRANTY

- A. Special Warranty: Manufacturer's standard form in which manufacturer agrees to repair or replace doors that fail in materials or workmanship within specified warranty period.
 - 1. Failures include, but are not limited to, the following:
 - a. Warping (bow, cup, or twist) more than 1/4 inch in a 42-by-84-inch section.
 - b. Telegraphing of core construction in wood face veneers exceeding 0.01 inch in a 3-inch span.
 - c. Telegraphing of core construction and delaminating of face in decorative laminate-faced doors.
 - 2. Warranty includes installation and finishing that may be required due to repair or replacement of defective doors.
 - 3. Warranty Period for Solid Core Interior Doors: Life of installation according to manufacturer's written warranty.

PART 2 - PRODUCTS

2.1 DOOR CONSTRUCTION – GENERAL

- A. WDMA I.S.1-A Performance Grade: Extra Heavy Duty; Aesthetic Grade: Premium.
- B. Environmentally Responsible Doors: Provide where specified doors manufactured with the following environmentally responsible components:
 - 1. Particleboard Core:

- a. Certified Wood: Interior wood flush doors (including fire rated doors) to be manufactured in accordance with FSC principles and criteria for wood building component and have FSC Chain of Custody certification.
 - b. Recycled Content: Interior wood flush doors to contain a minimum of 20% recycled content.
 - c. Low Emitting Materials: Interior wood flush doors must contain no added urea-formaldehyde resins.
2. Engineered Composite Lumber Core:
- a. Certified Wood: Interior wood flush doors (including fire rated doors) to be manufactured in accordance with FSC principles and criteria for wood building component and have FSC Chain of Custody certification.
 - b. Low Emitting Materials: Interior wood flush doors must contain no added urea-formaldehyde resins.
 - c. Stiles and Rails: No added urea formaldehyde.

2.2 CORE CONSTRUCTION

A. Engineered Composite Core Wood Doors:

1. Structural Composite Lumber: Engineered hardwood composite wood products tested in accordance with WDMA I.S.1A, Testing Cellulosic Composite Materials for Use in Fenestration Products containing no added Urea Formaldehyde. Comply with minimum performance levels below:
 - a. Screw Withdrawal, Face: 700 lbf (3100 N).
 - b. Screw Withdrawal, Edge: 550 lbf (2440 N).
2. Acceptable Manufacturers:
 - a. Algoma Hardwoods, Inc
 - b. Ampco
 - c. Graham Wood Doors
 - d. Marshfield: DCL
 - e. Mohawk Doors; a Masonite Company.
 - f. Vancouver Door Company
 - g. VT Industries, Inc

B. Particleboard Core Doors:

1. Particleboard: Wood fiber based materials complying with ANSI A208.1 Particleboard standard. Grade LD-2.
2. Adhesive: Fully bonded construction using Polyurethane (PUR) glue.
3. Blocking: When through-bolted hardware is not used, provide wood blocking in particleboard core doors as follows:
 - a. 5-inch (125-mm) top-rail blocking, in doors indicated to have closers.
 - b. 5-inch (125-mm) mid-rail blocking, in doors indicated to have exit devices.

- 1) Optional Cores for Blocking: Provide doors with either glued-wood-stave or structural-composite-lumber core instead of particleboard core for doors indicated to receive closers and exit devices.

4. Acceptable Manufacturers:

- a. Algoma Hardwoods, Inc
- b. Ampco
- c. Graham Wood Doors
- d. Marshfield Door Systems, Inc
- e. Mohawk Doors; a Masonite Company
- f. Vancouver Door Company
- g. VT Industries, Inc

2.3 VENEERED DOORS FOR TRANSPARENT FINISH

A. Manufacturers: Subject to compliance with requirements, provide products by one of the following:

1. Algoma Hardwoods, Inc
2. Ampco
3. Graham Wood Doors
4. Marshfield Door Systems, Inc.
5. Mohawk Doors; a Masonite Company
6. Vancouver Door Company
7. VT Industries, Inc.

B. Interior Solid Core Doors:

1. Grade and Faces: Face grades as note below; veneer minimum 1/50-inch (0.5mm) thickness at moisture content of 12% or less.
 - a. Plain Sliced Select White Maple, A grade faces.
2. Match between Veneer Leaves:
 - a. Book match.
3. Assembly of Veneer Leaves on Door Faces:
 - a. Running Match.
4. Pair and Set Match: Provide for doors hung in same opening or separated only by mullions.
5. Room Match: Match door faces within each separate room or area of building. Corridor door faces do not need to match where they are separated by 10 feet or more.
6. Transom Match: Continuous match.
7. Vertical Edges: Matching same species as faces. Wood or composite material, one piece, laminated, or veneered. Minimum requirements per WDMA section P-1, Performance Standards for Architectural Wood Flush Doors.

8. Horizontal Edges: Solid wood or structural composite material meeting the minimum requirements per WDMA section P-1, Performance Standards for Architectural Wood Flush Doors
9. Construction: Five plies. Stiles and rails are bonded to core, then entire unit sanded before applying face veneers.
10. At doors over 40% of the face cut-out for lights and or louvers, furnish engineered composite lumber core.

2.4 LIGHT FRAMES AND GLAZING

- A. Wood Beads for Light Openings in Wood Doors up to and including 20-minute rating:
 1. Wood Species: Same species as door faces.
 2. Profile: Manufacturer's standard lipped profile. At wood core doors with 20-minute fire protection ratings, provide wood beads and metal glazing clips approved for such use.
- B. Metal Frames for Light Openings in Fire Rated Doors over 20-minute rating: Manufacturer's standard frame formed of 0.048-inch-thick, cold rolled steel sheet; with baked enamel or powder coated finish; and approved for use in doors of fire protection rating indicated.
- C. Glazing: Comply with installation requirements in Division 08 Section "Glazing" and with the flush wood door manufacturer's written instructions.
 1. Factory Glazing: Factory install glazing in doors as indicated. Doors with factory installed glass to include all of the required glazing material.

2.5 FABRICATION

- A. Factory fit doors to suit frame opening sizes indicated. Comply with clearance requirements of referenced quality standard for fitting unless otherwise indicated.
 1. Comply with requirements in NFPA 80 for fire rated doors.
- B. Factory machine doors for hardware that is not surface applied. Comply with final hardware schedules, door frame Shop Drawings, DHI A115-W series standards, and hardware templates.
 1. Coordinate with hardware mortises in metal frames to verify dimensions and alignment before factory machining.
 2. Metal Astragals: Factory machine astragals and formed steel edges for hardware for pairs of fire rated doors.
- C. Transom and Side Panels: Fabricate matching panels with same construction, exposed surfaces, and finish as specified for associated doors. Finish bottom edges of transoms and top edges of rabbeted doors same as door stiles.
- D. Openings: Cut and trim openings through doors in factory.
 1. Light Openings: Trim openings with moldings of material and profile indicated.
 2. Glazing: Comply with applicable requirements in Division 08 Section "Glazing."

3. Louvers: Factory install louvers in prepared openings.

- E. Electrical Raceways: Provide flush wood doors receiving electrified hardware with concealed wiring harness and standardized Molex™ plug connectors on both ends to accommodate up to twelve wires. Coordinate connectors on end of the wiring harness to plug directly into the electrified hardware and the through wire transfer hardware or wiring harness specified in hardware sets in Division 08 "Door Hardware". Wire nut connections are not acceptable.

2.6 FACTORY FINISHING

- A. General: Comply with referenced quality standard for factory finishing. Complete fabrication, including fitting doors for openings and machining for hardware that is not surface applied, before finishing.
1. Finish faces, all four edges, edges of cutouts, and mortises. Stains and fillers may be omitted on top and bottom edges, edges of cutouts, and mortises.
- B. Transparent Finish: Provide a clear protective coating over the wood veneer allowing the natural color and grain of the selected wood species to provide the appearance specified. Stain is applied to the wood surface underneath the transparent finish to add color and design flexibility.
1. Grade: Premium.
 2. Finish: Meet or exceed WDMA I.S. 1A-1K5 Catalyzed Polyurethane finish performance requirements.
 3. Staining: As selected by Architect from manufacturer's full range.
 4. Sheen: Satin.

PART 3 - EXECUTION

3.1 EXAMINATION

- A. Examine doors and installed door frames before hanging doors.
1. Verify that frames comply with indicated requirements for type, size, location, and swing characteristics and have been installed with level heads and plumb jambs.
 2. Reject doors with defects.
- B. Proceed with installation only after unsatisfactory conditions have been corrected.

3.2 INSTALLATION

- A. Hardware: For installation, see Division 8 Section "Door Hardware."
- B. Installation Instructions: Install doors to comply with manufacturer's written instructions and the referenced quality standard, and as indicated.
1. Install fire rated doors in corresponding fire rated frames according to NFPA 80.

- C. Factory Fitted Doors: Align in frames for uniform clearance at each edge.
- D. Factory Finished Doors: Restore finish before installation if fitting or machining is required at Project site.

3.3 ADJUSTING

- A. Operation: Re-hang or replace doors that do not swing or operate freely.
- B. Finished Doors: Replace doors that do not comply with requirements. Doors may be repaired or refinished if work complies with requirements and shows no evidence of repair or refinishing.

END OF SECTION 08 14 16

NOT FOR BIDDING

SECTION 08 41 13 - ALUMINUM-FRAMED ENTRANCES / STOREFRONTS & DOORS

PART 1 - GENERAL

1.1 RELATED DOCUMENTS

- A. Drawings and general provisions of the Contract, including General and Supplementary Conditions and Division 1 Specification Sections, apply to this Section.

1.2 SUMMARY

- A. Section Includes:
 - 1. Exterior storefront framing
 - 2. Operable Vent
 - 3. Steel elements clip angles, brackets, and reinforcing for storefront and securing same to abutting construction
- B. Related Sections:
 - 1. Division 7, Section "Sealants"
 - 2. Division 8, Section 088000 - "Glazing" for glass and glazing materials

1.3 PERFORMANCE REQUIREMENTS

- A. General Performance: Aluminum-framed systems shall withstand the effects of the following performance requirements without exceeding performance criteria or failure due to defective manufacture, fabrication, installation, or other defects in construction:
 - 1. Movements of supporting structure indicated on Drawings including, but not limited to, story drift and deflection from uniformly distributed and concentrated live loads.
 - 2. Dimensional tolerances of building frame and other adjacent construction.
 - 3. Failure includes the following:
 - a. Deflection exceeding specified limits.
 - b. Thermal stresses transferring to building structure.
 - c. Framing members transferring stresses, including those caused by thermal and structural movements to glazing.
 - d. Noise or vibration created by wind and by thermal and structural movements.
 - e. Loosening or weakening of fasteners, attachments, and other components.
 - f. Sealant failure.
 - g. Failure of operating units.

B. Structural Loads:

1. Wind Loads:

- a. Basic Wind Speed: 90 mph.
- b. Importance Factor: 1.15.
- c. Exposure Category: B.

2. Design Wind Pressure: System shall be designed to withstand the following loads normal to the plane of the wall:

- a. Pressure (Positive and negative) of not less than 35 PSF at non-corner zones.
- b. Pressure (Positive and negative) of not less than 35 PSF at corner zones.

C. Deflection of Framing Members:

1. Deflection Normal to Wall Plane: Limited to 1/175 of clear span for spans up to 13 feet 6 inches (4.1 m) and to 1/240 of clear span plus 1/4 inch (6.35 mm) for spans greater than 13 feet 6 inches (4.1 m) or an amount that restricts edge deflection of individual glazing lites to 3/4 inch (19 mm), whichever is less.
2. Deflection Parallel to Glazing Plane: Limited to L/300 of clear span or 1/8 inch (3.2 mm), whichever is smaller.

D. Structural-Test Performance: Provide aluminum-framed systems tested according to ASTM E 330 as follows:

1. When tested at positive and negative wind-load design pressures, systems do not evidence deflection exceeding specified limits.
2. When tested at 150 percent of positive and negative wind-load design pressures, systems, including anchorage, do not evidence material failures, structural distress, and permanent deformation of main framing members exceeding 0.2 percent of span.
3. Test Duration: As required by design wind velocity, but not fewer than 10 seconds.

E. Air Infiltration: Provide aluminum-framed systems with maximum air leakage through fixed glazing and framing areas of 0.06 cfm/sq. ft. (0.03 L/s per sq. m) of fixed wall area when tested according to ASTM E 283 at a minimum static-air-pressure difference of 6.24 lbf/sq. ft. (300 Pa).

F. Water Penetration under Static Pressure: Provide aluminum-framed systems that do not evidence water penetration through fixed glazing and framing areas when tested according to ASTM E 331 at a minimum static-air-pressure difference of 20 percent of positive wind-load design pressure, but not less than 6.24 lbf/sq. ft. (300 Pa).

1. Maximum Water Leakage: No uncontrolled water penetrating aluminum-framed systems or water appearing on systems' normally exposed interior surfaces from sources other than condensation. Water leakage does not include water controlled by flashing and gutters that is drained to exterior and water that cannot damage adjacent materials or finishes.

- G. Thermal Movements: Provide aluminum-framed systems that allow for thermal movements resulting from the following maximum change (range) in ambient and surface temperatures. Base engineering calculation on surface temperatures of materials due to both solar heat gain and nighttime-sky heat loss.
1. Temperature Change (Range): 120 deg F (67 deg C), ambient; 180 deg F (100 deg C), material surfaces.
 2. Test Performance: No buckling; stress on glass; sealant failure; excess stress on framing, anchors, and fasteners; or reduction of performance when tested according to AAMA 501.5.
 - a. High Exterior Ambient-Air Temperature: That which produces an exterior metal-surface temperature of 180 deg F (82 deg C).
 - b. Low Exterior Ambient-Air Temperature: 0 deg F (minus 18 deg C).
 3. Interior Ambient-Air Temperature: 75 deg F (24 deg C).
- H. Condensation Resistance: Provide aluminum-framed systems with fixed glazing and framing areas having condensation-resistance factor (CRF) of not less than .58 when tested according to AAMA 1503.
- I. Thermal Conductance: Provide aluminum-framed systems with fixed glazing and framing areas having an average U-factor of not more than 0.58 Btu/sq. ft. x h x deg F when tested according to AAMA 1503.

1.4 SUBMITTALS

- A. Product Data: For each type of product indicated. Include construction details, material descriptions, dimensions of individual components and profiles, and finishes for aluminum-framed systems.
- B. Shop Drawings: For aluminum-framed systems. Include plans, elevations, sections, details, and attachments to other work.
1. Include details of provisions for system expansion and contraction and for drainage of moisture in the system to the exterior.
- C. Engineering Analysis: Provide data indicating compliance with all performance requirements and design criteria indicated.
1. Provide load analysis, design calculations and/or manufacturers design tables, fully demonstrating compliance with lateral design loads as well as gravity loading as applicable. Indicate reinforcing, anchorage and bracing and other supports and engineering analysis.
- D. Samples for Verification: For each type of exposed finish required, in manufacturer's standard sizes.
- E. Submit a set of two (2) samples of required aluminum finish, showing extremes of color and appearance, on minimum 4" long extrusions of the alloys to be used for the Work.

1. The right is reserved to require samples of typical fabricated sections, showing joints, exposed fastenings (if any), quality of workmanship, hardware and accessory items, before fabrication of the Work proceeds.
 - F. Other Action Submittals:
 1. Door Hardware Schedule: Prepared by or under the supervision of supplier, detailing fabrication and assembly of entrance door hardware, as well as procedures and diagrams. Coordinate final entrance door hardware schedule with doors, frames, and related work to ensure proper size, thickness, hand, function, and finish of entrance door hardware.
 - G. Qualification Data: For qualified Installer.
 - H. Welding certificates.
 - I. Product Test Reports: Based on evaluation of comprehensive tests performed by a qualified testing agency, for aluminum-framed systems, indicating compliance with performance requirements.
 - J. Maintenance Data: For aluminum-framed systems to include in maintenance manuals.
 - K. Warranties: Sample of special warranties.
- 1.5 QUALITY ASSURANCE
- A. Installer Qualifications: Manufacturer's authorized representative who is trained and approved for installation of units required for this Project.
 - B. Testing Agency Qualifications: Qualified according to ASTM E 699 for testing indicated.
 - C. Product Options: Information on Drawings and in Specifications establishes requirements for systems' aesthetic effects and performance characteristics. Aesthetic effects are indicated by dimensions, arrangements, alignment, and profiles of components and assemblies as they relate to sightlines, to one another, and to adjoining construction. Performance characteristics are indicated by criteria subject to verification by one or more methods including preconstruction testing, field testing, and in-service performance.
 1. Do not revise intended aesthetic effects, as judged solely by Architect, except with Architect's approval. If revisions are proposed, submit comprehensive explanatory data to Architect for review.
 - D. Accessible Entrances: Comply with applicable provisions in the U.S. Architectural & Transportation Barriers Compliance Board's ADA-ABA Accessibility Guidelines and ICC/ANSI A117.1.
 - E. Source Limitations for Aluminum-Framed Systems: Obtain from single source from single manufacturer.
 - F. Welding Qualifications: Qualify procedures and personnel according to AWS D1.2, "Structural Welding Code - Aluminum."

1.6 PROJECT CONDITIONS

- A. Field Measurements: Verify actual locations of structural supports for aluminum-framed systems by field measurements before fabrication and indicate measurements on Shop Drawings.

1.7 WARRANTY

- A. Special Warranty: Manufacturer's standard form in which manufacturer agrees to repair or replace components of aluminum-framed systems that do not comply with requirements or that fail in materials or workmanship within specified warranty period.

1. Failures include, but are not limited to, the following:
 - a. Structural failures including, but not limited to, excessive deflection.
 - b. Noise or vibration caused by thermal movements.
 - c. Deterioration of metals, metal finishes, and other materials beyond normal weathering.
 - d. Adhesive or cohesive sealant failures.
 - e. Water leakage through fixed glazing and framing areas.
 - f. Failure of operating components.
2. Warranty Period: 10 years from date of Substantial Completion.

PART 2 - PRODUCTS

2.1 MANUFACTURERS

- A. Aluminum Framed Storefront Systems: Basis-of-Design Product and Subject to compliance with requirements, provide Kawneer North America; Series 450 and 451T, center set outside glazed, Storefront Framing, or comparable product by one of the following:
1. EFCO Corporation 433T
 2. Tubelite Inc.
 3. United States Aluminum.
 4. Vistawall Architectural Products
 5. YKK
- B. Operable vent
1. By storefront manufacturer matching color and finish

2.2 MATERIALS

- A. Aluminum: Alloy and temper recommended by manufacturer for type of use and finish indicated.
1. Sheet and Plate: ASTM B 209 (ASTM B 209M).

2. Extruded Bars, Rods, Profiles, and Tubes: ASTM B 221 (ASTM B 221M).
 3. Extruded Structural Pipe and Tubes: ASTM B 429.
 4. Structural Profiles: ASTM B 308/B 308M.
 5. Welding Rods and Bare Electrodes: AWS A5.10/A5.10M.
- B. Steel Reinforcement: Manufacturer's standard zinc-rich, corrosion-resistant primer, complying with SSPC-PS Guide No. 12.00; applied immediately after surface preparation and pretreatment. Select surface preparation methods according to recommendations in SSPC-SP COM and prepare surfaces according to applicable SSPC standard.
1. Structural Shapes, Plates, and Bars: ASTM A 36/A 36M.
 2. Cold-Rolled Sheet and Strip: ASTM A 1008/A 1008M.
 3. Hot-Rolled Sheet and Strip: ASTM A 1011/A 1011M.

2.3 FRAMING SYSTEMS

- A. Framing Members: Manufacturer's standard extruded-aluminum framing members of thickness required and reinforced as required to support imposed loads.
1. Construction:
 - a. Exterior Storefront: Thermally improved.
 2. Glazing System: Retained mechanically with gaskets on four sides.
- B. Brackets and Reinforcements: Manufacturer's standard high-strength aluminum with nonstaining, nonferrous shims for aligning system components. Provide reinforcing as required to achieve design loading indicated.
- C. Fasteners and Accessories: Manufacturer's standard corrosion-resistant, nonstaining, nonbleeding fasteners and accessories compatible with adjacent materials.
1. Use self-locking devices where fasteners are subject to loosening or turning out from thermal and structural movements, wind loads, or vibration.
 2. Reinforce members as required to receive fastener threads.
 3. Use exposed fasteners with countersunk Phillips screw heads, finished to match framing system.
- D. Attachments, Supports and Bracing: All work and components required for proper installation - but not indicated - shall be the responsibility of the window wall systems installer. Installer shall provide all components, materials and equipment necessary for the complete and operational installation of products and materials described here. Any work, including supports, brackets, anchorage, miscellaneous steel, not indicated on the drawings to be provided by others, shall be the responsibility of the installer.
- E. Concrete and Masonry Inserts: Hot-dip galvanized cast-iron, malleable-iron, or steel inserts, complying with ASTM A 123/A 123M or ASTM A 153/A 153M.
- F. Flashing: Manufacturer's standard corrosion-resistant, nonstaining, nonbleeding flashing compatible with adjacent materials.

- G. Framing System Gaskets and Sealants: Manufacturer's standard, recommended by manufacturer for joint type.

2.4 GLAZING SYSTEMS

- A. Glazing: As specified in Division 8 Section "Glazing."
- B. Glazing Gaskets: Manufacturer's standard compression types; replaceable, molded or extruded, of profile and hardness required to maintain watertight seal.
- C. Spacers and Setting Blocks: Manufacturer's standard elastomeric type.
- D. Bond-Breaker Tape: Manufacturer's standard TFE-fluorocarbon or polyethylene material to which sealants will not develop adhesion.
 - a. Provide sealants for use inside of the weatherproofing system that have a VOC content of 250 g/L or less when calculated according to 40 CFR 59, Subpart D (EPA Method 24).
 - b. Color: Matching structural sealant.

2.5 OPEERABLE VENT

- A. Basis of design Kawneer "Glass-vent" operable vent to be by storefront manufacture to match color, finish and operation of basis of design
- 1. Performance Requirements: Provide aluminum windows of performance indicated that comply with AAMA/WDMA/CSA 101/I.S.2/A440 (NAFS).
 - a. Performance Class and Grade: (P-HC40 – P-HC70) Project-Out Window
 - b. Air Infiltration: The test specimen shall be tested in accordance with ASTM E283 at a minimum size of 60" x 36" (1524 mm x 915 mm) Project-Out or 36" x 60" (915 x 1524) Casement Outswing. Air infiltration rate shall not exceed 0.10 cfm/ft² at a static air pressure differential of 6.24 psf (300 Pa).
 - c. Water Resistance: The test specimen shall be tested in accordance with ASTM E547 and ASTM E331 at a minimum size of 60" x 36" (1524 mm x 915 mm) Project-Out or 36" x 60" (915 mm x 1524 mm) Casement Outswing. There shall be no leakage as defined in the test method at a static air pressure differential of 15 psf (720 Pa).
 - d. Uniform Load Deflection: A minimum static air pressure difference of (40 psf (1915 Pa)(2 Locks)) or (70 psf (3352 Pa)(3 Locks)) shall be applied in the positive and negative direction in accordance with ASTM E330. There shall be no deflection in excess of L/175 of the span of any framing member.
 - e. Uniform Load Structural: A minimum static air pressure difference of (60 psf (2873 Pa)(2 Locks)) or (105 psf (5027)(3 Locks)) shall be applied in the positive and negative direction in accordance with ASTM E330. The unit shall be evaluated after each load with permanent set not to exceed 0.2% of span length.
 - f. Component Testing: Window components shall be tested in accordance with procedures described in AAMA/WDMA/CSA 101/I.S.2/A440 and AAMA 910.
 - g. Thermal Transmittance (U-factor), Physical Test:

- 1) Thermal transmittance test results in accordance with AAMA 1503 or CSA A440 are based upon 1" (25.4 mm) clear insulating glass (1/8", 3/4" AS, 1/8").
- 2) Project-Out Windows: when tested using AAMA 1503, the thermal transmittance (U-Factor) shall not be more than 0.68 Btu/(hr·ft²·°F).
- h. Thermal Transmittance (U-factor), Simulated:
 - a. Thermal transmittance simulation results using NFRC 100 or AAMA 507 are based on a Center of Glass (COG) U-factor of 0.24 Btu/(hr·ft²·°F) and a warm-edge spacer.
 - b. Project-Out Windows: When simulated using NFRC 100 or AAMA 507, the U-factor shall not be more than: 0.40 Btu/(hr·ft²·°F) or project specific (____) Btu/(hr·ft²·°F) per AAMA 507 or (____) Btu/(hr·ft²·°F) per NFRC 100.
2. Condensation Resistance (CRF) or Temperature Index (TI):
 - a. Condensation resistance test results in accordance with AAMA 1503 or CSA A440 are based upon aluminum windows with 1" (25.4 mm) clear insulating glass (1/8", 3/4" AS, 1/8").
 - b. If using CRF: When tested using AAMA 1503, the CRF_{frame} and CRF_{glass} shall not be less than 51 and 54 respectively.
 - c. If using TI: When tested to CSA A440-00, the TI_{frame} and TI_{glass} shall not be less than 47 and 48 respectively.
3. Forced Entry Resistance: All windows shall conform to ASTM F588, Grade 10.
4. Windborne-Debris-Impact-Resistance Performance: Shall be tested in accordance with ASTM E 1886 and information in ASTM E 1996 and TAS 201/203.
 - a. Small - Missile Impact: For aluminum-framed systems located within 30 feet (9.1m) above grade

2.6 ACCESSORY MATERIALS

- A. Joint Sealants: For installation at perimeter of aluminum-framed systems, as specified in Division 7 Section "Joint Sealants."
- B. Bituminous Paint: Cold-applied, asphalt-mastic paint complying with SSPC-Paint 12 requirements except containing no asbestos; formulated for 30-mil (0.762-mm) thickness per coat.

2.7 FABRICATION

- A. Form or extrude aluminum shapes before finishing.
- B. Weld in concealed locations to greatest extent possible to minimize distortion or discoloration of finish. Remove weld spatter and welding oxides from exposed surfaces by descaling or grinding.

- C. Framing Members, General: Fabricate components that, when assembled, have the following characteristics:
 - 1. Profiles that are sharp, straight, and free of defects or deformations.
 - 2. Accurately fitted joints with ends coped or mitered.
 - 3. Means to drain water passing joints, condensation within framing members, and moisture migrating within the system to exterior.
 - 4. Physical and thermal isolation of glazing from framing members.
 - 5. Accommodations for thermal and mechanical movements of glazing and framing to maintain required glazing edge clearances.
 - 6. Provisions for field replacement of glazing from exterior.
 - 7. Fasteners, anchors, and connection devices that are concealed from view to greatest extent possible.
- D. Mechanically Glazed Framing Members: Fabricate for flush glazing without projecting stops.
- E. After fabrication, clearly mark components to identify their locations in Project according to Shop Drawings.

2.8 ALUMINUM FINISHES

- A. General: Comply with NAAMM's "Metal Finishes Manual for Architectural and Metal Products" for recommendations for applying and designating finishes.
- B. Finish designations prefixed by AA comply with the system established by the Aluminum Association for designating aluminum finishes.
- C. Baked-Enamel or Powder-Coat Finish: AAMA 2603 except with a minimum dry film thickness of 1.5 mils (0.04 mm). Comply with coating manufacturer's written instructions for cleaning, conversion coating, and applying and baking finish.
 - 1. Color and Gloss: As selected by Architect from manufacturer's full range and to match aluminum window finish.

PART 3 - EXECUTION

3.1 EXAMINATION

- A. Examine areas and conditions, with Installer present, for compliance with requirements for installation tolerances and other conditions affecting performance of the Work.
- B. Proceed with installation only after unsatisfactory conditions have been corrected.

3.2 INSTALLATION

- A. General:
 - 1. Comply with manufacturer's written instructions.

2. Do not install damaged components.
3. Fit joints to produce hairline joints free of burrs and distortion.
4. Rigidly secure nonmovement joints.
5. Install anchors with separators and isolators to prevent metal corrosion and electrolytic deterioration.
6. Seal joints watertight unless otherwise indicated.

B. Metal Protection:

1. Where aluminum will contact dissimilar metals, protect against galvanic action by painting contact surfaces with primer or applying sealant or tape, or by installing nonconductive spacers as recommended by manufacturer for this purpose.
 2. Where aluminum will contact concrete or masonry, protect against corrosion by painting contact surfaces with bituminous paint.
- C.** Install components to drain water passing joints, condensation occurring within framing members, and moisture migrating within the system to exterior.
- D.** Set continuous sill members and flashing in full sealant bed as specified in Division 7 Section "Joint Sealants" to produce weathertight installation.
- E.** Install components plumb and true in alignment with established lines and grades, and without warp or rack.
- F.** Install glazing as specified in Division 8 Section "Glazing."
- G.** Install perimeter joint sealants as specified in Division 7 Section "Joint Sealants" to produce weathertight installation.

3.3 ERECTION TOLERANCES

- A.** Install aluminum framed systems to comply with the following maximum erection tolerances:
1. Location and Plane: Limit variation from true location and plane to 1/8 inch in 12 feet (3 mm in 3.7 m); 1/4 inch (6 mm) over total length.
 2. Alignment:
 - a. Where surfaces abut in line, limit offset from true alignment to 1/16 inch (1.5 mm).
 - b. Where surfaces meet at corners, limit offset from true alignment to 1/32 inch (0.8 mm).
- B.** Diagonal Measurements: Limit difference between diagonal measurements to 1/8 inch (3 mm).

3.4 FIELD QUALITY CONTROL

- A.** Testing Agency: Owner may engage a qualified independent testing and inspecting agency to perform field tests and inspections.

1. Water Spray Test: Before installation of interior finishes has begun, a minimum area of 75 feet (23 m) by 1 story of aluminum-framed systems designated by Architect shall be tested according to AAMA 501.2 and shall not evidence water penetration.
 - B. Repair or remove work if test results and inspections indicate that it does not comply with specified requirements.
 - C. Additional testing and inspecting, at Contractor's expense, will be performed to determine compliance of replaced or additional work with specified requirements.
 - D. Aluminum-framed assemblies will be considered defective if they do not pass tests and inspections.
 - E. Prepare test and inspection reports.
- 3.5 ADJUSTING
- A. Adjust operating vent hardware to function smoothly as recommended by manufacturer.

END OF SECTION 08 41 13

SECTION 08 71 00 - DOOR HARDWARE

PART 1 - GENERAL

1.1 SUMMARY:

- A. Section Includes: Finish Hardware for door openings, except as otherwise specified herein.
 - 1. Door hardware for steel (hollow metal) doors.
 - 2. Door hardware for wood doors.
 - 3. Keyed cylinders as indicated.
- B. Related Sections:
 - 1. Division 6: Rough Carpentry.
 - 2. Division 8: Hollow Metal Doors and Frames.
 - 3. Division 8: Wood Doors.
- C. References: Comply with applicable requirements of the following standards. Where these standards conflict with other specific requirements, the most restrictive shall govern.
 - 1. Builders Hardware Manufacturing Association (BHMA)
 - 2. NFPA 101 Life Safety Code
 - 3. NFPA 80 -Fire Doors and Windows
 - 4. ANSI-A156.xx- Various Performance Standards for Finish Hardware
 - 5. UL10C – Positive Pressure Fire Test of Door Assemblies
 - 6. ANSI-A117.1 – Accessible and Usable Buildings and Facilities
 - 7. DHI /ANSI A115.IG – Installation Guide for Doors and Hardware
- D. Intent of Hardware Groups
 - 1. Where items of hardware aren't definitely or correctly specified, are required for completion of the Work, a written statement of such omission, error, or other discrepancy to be submitted to Architect, prior to date specified for receipt of bids for clarification by addendum; or, furnish such items in the type and quality established by this specification, and appropriate to the service intended.

1.2 SUBSTITUTIONS:

- A. Comply with Division 1.
- B. Approval of products is at the discretion of the architect and their consultant

1.3 SUBMITTALS:

- A. Comply with Division 1.
- B. Special Submittal Requirements: Combine submittals of this Section with Sections listed below to ensure the "design intent" of the system/assembly is understood and can be reviewed together.
- C. Product Data: Manufacturer's specifications and technical data including the following:

1. Detailed specification of construction and fabrication.
 2. Manufacturer's installation instructions.
 3. Wiring diagrams for each electric product specified / in contract. Coordinate voltage with electrical before submitting.
 4. Submit catalog cuts with hardware schedule.
- D. Shop Drawings - Hardware Schedule: Submit detailed hardware schedule in a vertical format.
1. List groups and suffixes in proper sequence.
 2. Completely describe door and list architectural door number.
 3. Manufacturer, product name, and catalog number.
 4. Function, type, and style.
 5. Size and finish of each item.
 6. Mounting heights.
 7. Explanation of abbreviations and symbols used within schedule.
 8. Detailed wiring diagrams, specially developed for each opening, indicating any in contract electric hardware, security equipment and access control equipment, and door and frame rough-ins required for specific opening.
- E. Templates: Submit templates and "reviewed Hardware Schedule" to door and frame supplier and others as applicable to enable proper and accurate sizing and locations of cutouts and reinforcing.
1. Templates, wiring diagrams and "reviewed Hardware Schedule" of electrical terms to electrical for coordination and verification of voltages and locations.
- F. Keying Meeting: Arrange for a keying meeting, with Architect, Owner and hardware supplier, and other involved parties to ensure locksets and locking hardware, are functionally correct and keying complies with Owner's project requirements. Owner may perform keying themselves after project is complete.
- G. Samples:
1. 1 sample of metal finishes
- H. Contract Closeout Submittals: Comply with Division 1 including specific requirements indicated.
1. Operating and maintenance manuals: Submit 3 sets containing the following.
 - a. Complete information in care, maintenance, and adjustment, and data on repair and replacement parts, and information on preservation of finishes.
 - b. Catalog pages for each product.
 - c. Name, address, and phone number of local representatives for each manufacturer.
 - d. Parts list for each product.
 2. Copy of final hardware schedule, edited to reflect, "As installed".
 3. Copy of final keying schedule
 4. As installed "Wiring Diagrams" and "Point to Point" for each piece of hardware connected to power, both low voltage and 110 volts.
 5. One set of special tools required for maintenance and adjustment of hardware, including changing of cylinders.

1.4 QUALITY ASSURANCE

A. Comply with Division 1.

1. Statement of qualification for distributor and installers.
2. Statement of compliance with regulatory requirements and single source responsibility.
3. Distributor's Qualifications: Firm with 3 years experience in the distribution of commercial hardware.
 - a. Distributor to employ full time Architectural Hardware Consultants (AHC) for the purpose of scheduling and coordinating hardware and establishing keying schedule.
 - b. Hardware Schedule shall be prepared and signed by an AHC.
4. Installer's Qualifications: Firm with 3 years experienced in installation of similar hardware to that required for this Project, including specific requirements indicated.
5. Regulatory Label Requirements: Provide testing agency label or stamp on hardware for labeled openings.
 - a. Provide UL listed hardware for labeled and 20 minute openings in conformance with requirements for class of opening scheduled.
 - b. Underwriters Laboratories requirements have precedence over this specification where conflict exists.
6. Single Source Responsibility: Except where specified in hardware schedule, furnish products of only one manufacturer for each type of hardware.

- B. Review Project for extent of finish hardware required to complete the Work. Where there is a conflict between these Specifications and the existing hardware, notify the Architect in writing and furnish hardware in compliance with the Specification unless otherwise directed in writing by the Architect.**

1.5 DELIVERY, STORAGE, AND HANDLING

A. Packing and Shipping: Comply with Division 1.

1. Deliver products in original unopened packaging with legible manufacturer's identification.
2. Package hardware to prevent damage during transit and storage.
3. Mark hardware to correspond with "reviewed hardware schedule".
4. Deliver hardware to door and frame manufacturer upon request.

- B. Storage and Protection: Comply with manufacturer's recommendations.**

1.6 PROJECT CONDITIONS:

- A. Coordinate hardware with other work. Furnish hardware items of proper design for use on doors and frames of the thickness, profile, swing, security and similar requirements indicated, as necessary for the proper installation and function, regardless of omissions or conflicts in the information on the Contract Documents.**
- B. Review Shop Drawings for doors and entrances to confirm that adequate provisions will be made for the proper installation of hardware.**

1.7 WARRANTY:

- A. Refer to Conditions of the Contract
- B. Manufacturer's Warranty:
 - 1. Closers: Ten years
 - 2. Exit Devices: Three Years
 - 3. Locksets & Cylinders: Three years
 - 4. All other Hardware: Two years.

1.8 OWNER'S INSTRUCTION:

- A. Instruct Owner's personnel in operation and maintenance of hardware units.

1.9 MAINTENANCE:

- A. Extra Service Materials: Deliver to Owner extra materials from same production run as products installed. Package products with protective covering and identify with descriptive labels. Comply with Division 1 Closeout Submittals Section.
 - 1. Special Tools: Provide special wrenches and tools applicable to each different or special hardware component.
 - 2. Maintenance Tools: Provide maintenance tools and accessories supplied by hardware component manufacturer.
 - 3. Delivery, Storage and Protection: Comply with Owner's requirements for delivery, storage and protection of extra service materials.
- B. Maintenance Service: Submit for Owner's consideration maintenance service agreement for electronic products installed.

PART 2 - PRODUCTS

2.1 MANUFACTURERS

- A. Manufacturers identified are "basis of design" products by other manufacturers meeting the design intent, operation and specification of the basis of design may be substituted
 - 1. Acceptable Manufacturers include but are not limited to the following. Please refer to the Hardware Schedule for more information.
 - a. Best
 - b. Corbin Russwin
 - c. Stanley
 - d. Precision
 - e. Dorma
 - f. Trimco
 - g. National Guard
 - h. Schlage

2.2 MATERIALS:

- A. Hinges: Shall be Five Knuckle Ball Bearing hinges

1. Template screw hole locations
2. Bearings are to be fully hardened.
3. Bearing shell is to be consistent shape with barrel.
4. Minimum of 2 permanently lubricated non-detachable bearings on standard weight hinge and 4 permanently lubricated bearing on heavy weight hinges.
5. Equip with easily seated, non-rising pins.
6. Hinges shall be full polished, front, back and barrel.
7. Hinge pin is to be fully plated.
8. Bearing assembly is to be installed after plating.
9. Provide hinge type as listed in schedule.
10. Tested and approved by BHMA for all applicable ANSI Standards for type, size, function and finish

B. Mortise Type Locks and Latches:

1. Tested and approved by BHMA for ANSI A156.13, Series 000, Operational Grade 1, Extra-Heavy Duty, Security Grade 2 and be UL10C.
2. Furnish UL or recognized independent laboratory certified mechanical operational testing to 4 million cycles minimum.
3. Provide 9001-Quality Management and 14001-Environmental Management.
4. Fit ANSI A115.1 door preparation
5. Functions and design as indicated in the hardware groups
6. 3/4-inch (19mm) throw, anti-friction latchbolt made of self-lubricating stainless steel
7. Deadbolt functions shall have 1 inch (25mm) throw bolt made of hardened stainless steel
8. Latchbolt and Deadbolt are to extend into the case a minimum of 3/8 inch (9.5mm) when fully extended
9. Auxiliary deadlatch to be made of one-piece stainless steel, permanently lubricated
10. Provide enough curved strike lip to protect door trim.
11. Properly size lock strikes for pairs of doors, short lip.
12. Lever handles must be of forged or cast brass, bronze or stainless steel construction and conform to ANSI A117.1. Levers that contain a hollow cavity are not acceptable
13. Lock shall have self-aligning, thru-bolted trim
14. Levers to operate a roller bearing spindle hub mechanism
15. Mortise cylinders of lock shall have a concealed internal setscrew for securing the cylinder to the lockset. The internal setscrew will be accessible only by removing the core, with the control key, from the cylinder body.
16. Spindle to be designed to prevent forced entry from attacking of lever
17. Provide locksets with 6-pin removable and interchangeable core cylinders ALL CYLINDERS TO BE 0-BITTED, ALLOWING OWNER TO KEY DOORS INDEPENDENTLY AFTER THE PROJECT IS COMPLETED.
18. Each lever to have independent spring mechanism controlling it
19. Core face must be the same finish as the lockset.
20. Refer to Door Hardware schedule for more information.

C. Cylinders:

1. Provide the necessary interchangeable core cylinder housings, collars, rings & springs as recommended by the manufacturer for proper installation.
2. Provide the proper cylinder cams or tail piece as required to operate all locksets and other keyed hardware items listed in the hardware sets.
3. Coordinate and provide as required for related sections.

D. Door Closers:

1. Tested and approved by BHMA for ANSI 156.4, Grade 1
2. UL10C certified
3. Provide 9001-Quality Management and 14001-Environmental Management.
4. Closer shall have extra-duty arms and knuckles
5. Conform to ANSI 117.1
6. Maximum 2 7/16 inch case projection with non-ferrous cover
7. Separate adjusting valves for closing and latching speed, and backcheck
8. Provide adapter plates, shim spacers and blade stop spacers as required by frame and door conditions
9. Full rack and pinion type closer with 1½" minimum bore.
10. Mount closers on non-public side of door, unless otherwise noted in specification
11. Closers shall be non-handed, non-sized and multi-sized.

E. Kickplates: Provide with four beveled edges ANSI J102, .050 thickness, 10 inches high by width less 2 inches on single doors and 1 inch on pairs of doors. Furnish oval-head countersunk screws to match finish.

F. Silencers: Furnish silencers on all interior frames, 3 for single doors, 2 for pairs. Omit where any type of seals occurs.

2.3 FINISH:

A. Designations used in Schedule of Finish Hardware - 3.5, and elsewhere to indicate hardware finishes are those listed in ANSI/BHMA A156.18 including coordination with traditional U.S. finishes shown by certain manufacturers for their products

B. Powder coat door closers to match other hardware, unless otherwise noted.

C. Aluminum items shall be finished to match predominant adjacent material. Seals to coordinate with frame color.

2.4 KEYS AND KEYING

A. Provide keyed brass construction cores and keys during the construction period. Construction control and operating keys and core shall not be part of the Owner's permanent keying system or furnished in the same keyway (or key section) as the Owner's permanent keying system. Permanent cores and keys (prepared according to the accepted keying schedule) will be furnished to the Owner.

B. Cylinders, removable and interchangeable core systems: REFER TO HARDWARE SCHEDULE.

C. Permanent keys and cores: Stamped with the applicable key mark for identification. These visual key control marks or codes will not include the actual key cuts. Permanent keys will also be stamped "Do Not Duplicate."

D. Transmit Grand Masterkeys, Masterkeys and other Security keys to Owner by Registered Mail, return receipt requested.

E. Furnish keys in the following quantities:

1. 1 each Grand Masterkeys
2. 4 each Masterkeys
3. 2 each Change keys each keyed core
4. 15 each Construction masterkeys
5. 1 each Control keys

- F. The Owner, or the Owner's agent, will install permanent cores and return the construction cores to the Hardware Supplier. Construction cores and keys remain the property of the Hardware Supplier.

PART 3 - EXECUTION

3.1 EXAMINATION

- A. Verification of conditions: Examine doors, frames, related items and conditions under which Work is to be performed and identify conditions detrimental to proper and or timely completion.
1. Do not proceed until unsatisfactory conditions have been corrected.

3.2 HARDWARE LOCATIONS:

- A. Mount hardware units at heights indicated in the following publications except as specifically indicated or required to comply with the governing regulations.
1. Recommended Locations for Builder's Hardware for Standard Steel Doors and Frames, by the Door and Hardware Institute (DHI).
 2. Recommended locations for Architectural Hardware for flush wood doors (DHI).
 3. WDMA Industry Standard I.S.-1A-04, Industry Standard for Architectural wood flush doors.

3.3 INSTALLATION:

- A. Install each hardware item per manufacturer's instructions and recommendations. Do not install surface mounted items until finishes have been completed on the substrate. Set units level, plumb and true to line and location. Adjust and reinforce the attachment substrate as necessary for proper installation and operation.
- B. Conform to local governing agency security ordinance.
- C. Install Conforming to ICC/ANSI A117.1 Accessible and Useable Building and Facilities.
1. Adjust door closer sweep periods so that from the open position of 70 degrees, the door will take at least 3 seconds to move to a point 3 inches from the latch, measured to the landing side of the door.
- D. Provide solid wood blocking behind wall stops and any other wall mounted items.
- E. Installed hardware using the manufacturers fasteners provided. Drill and tap all screw holes located in metallic materials. Do not use "Riv-Nuts" or similar products.

3.4 FIELD QUALITY CONTROL AND FINAL ADJUSTMENT

- A. Contractor/Installers, Field Services: After installation is complete, contractor shall inspect the completed door openings on site to verify installation of hardware is complete and properly adjusted, in accordance with both the Contract Documents and final shop drawings.
1. Check and adjust closers to ensure proper operation.
 2. Check latchset, lockset, and exit devices are properly installed and adjusted to ensure proper operation.
 - a. Verify levers are free from binding.
 - b. Ensure latchbolts and dead bolts are engaged into strike and hardware is functioning.
 3. Report findings, in writing, to architect indicating that all hardware is installed and functioning properly. Include recommendations outlining corrective actions for improperly functioning hardware if required.

3.5 HARDWARE SCHEDULE

NOTES APPLICABLE TO ALL HARDWARE SETS:

1. All doors shall provide free egress out from the interior.
2. Provide proper blocking behind any wall mounted items, including wall stops.
3. Doors to be Corbin Russwin non-removable 6-pin "59B2" Cylinders.

EXTERIOR DOORS:

Hardware Set # 01	Door: 3.01	
Set Name	Contents	Basis of design
CORRIDOR	(2) 4.5x4.5 FBB Full Mortise (3) Silencers (1) Mortise Office Lockset (1) Closer (No Hold Open) (1) Wall stop (1) Kick plate 10"X2"LDW	Best FBB 179/26D IVES SR64/grey Best 45H-7A14H Dorma 8916 Ives WS401/402CVX Ives 8400 STAINLESS STEEL

Hardware Set # 02	Doors: 3.03, 3.04, 3.05, 3.07, 3.08, 3.09, 3.10, 3.11, 3.12, 3.13	
Set Name	Contents each door	Notes
OFFICE	(2) 4.5x4.5 FBB Full Mortise (3) Silencers (1) Mortise Office Lockset (1) Wall stop	BEST FBB 179/26D IVES SR64/GRAY BEST 45H-7A14H Ives WS401/402CVX

Hardware Set # 03	Doors: 3.06, 3.06A, 3.14, 3.15

Set Name	Contents each door	Notes
CONFERENCE ROOMS	(2) 4.5x4.5 FBB Full Mortise (3) Silencers (1) Mortise Office Lockset (1) Closer (with hold open) (1) Wall stop	Best FBB 179 IVES SR64 Best 45H-7A14H Dorma 8916 Ives WS401/402CVX

NOT FOR BIDDING

END OF SECTION 08 71 00

SECTION 08 80 00 - GLAZING

PART 1 - GENERAL

1.1 RELATED DOCUMENTS

- A. Drawings and general provisions of the Contract, including General and Supplementary Conditions and Division 1 Specification Sections, apply to this Section.

1.2 SUMMARY

- A. This Section includes glazing for the following products and applications, including those specified in other Sections where glazing requirements are specified by reference to this Section:
 - 1. Windows.
 - 2. Doors.
 - 3. Glazed entrances.
 - 4. Storefront framing.
 - 5. Privacy Film
- B. Related Sections include the following:
 - 1. Division 8 Section "Steel Doors and Frames "
 - 2. Division 8 Section "Wood Doors"
 - 3. Division 8 Section "Aluminum Framed Entrances and Storefronts"

1.3 DEFINITIONS

- A. Manufacturers of Glass Products: Firms that produce primary glass, fabricated glass, or both, as defined in referenced glazing publications.
- B. Glass Thicknesses: Indicated by thickness designations in millimeters according to ASTM C 1036.
- C. Interspace: Space between lites of an insulating-glass unit that contains dehydrated air or a specified gas.
- D. Deterioration of Coated Glass: Defects developed from normal use that are attributed to the manufacturing process and not to causes other than glass breakage and practices for maintaining and cleaning coated glass contrary to manufacturer's written instructions. Defects include peeling, cracking, and other indications of deterioration in metallic coating.
- E. Deterioration of Insulating Glass: Failure of hermetic seal under normal use that is attributed to the manufacturing process and not to causes other than glass breakage and practices for maintaining and cleaning insulating glass contrary to manufacturer's written instructions. Evidence of failure is the obstruction of vision by dust, moisture, or film on interior surfaces of glass.
- F. Deterioration of Laminated Glass: Defects developed from normal use that are attributed to the manufacturing process and not to causes other than glass breakage and practices for maintaining and cleaning laminated glass contrary to manufacturer's written instructions. Defects include

edge separation, delamination materially obstructing vision through glass, and blemishes exceeding those allowed by referenced laminated-glass standard.

1.4 PERFORMANCE REQUIREMENTS

- A. General: Provide glazing systems capable of withstanding normal thermal movement and wind and impact loads (where applicable) without failure, including loss or glass breakage attributable to the following: defective manufacture, fabrication, and installation; failure of sealants or gaskets to remain watertight and airtight; deterioration of glazing materials; or other defects in construction.
- B. Glass Design: Glass thickness designations indicated are minimums and are for detailing only. Confirm glass thicknesses by analyzing Project loads and in-service conditions. Provide glass lites in the thickness designations indicated for various size openings, but not less than thicknesses and in strengths (annealed or heat treated) required to meet or exceed the following criteria:
 - 1. Glass Thicknesses: Select minimum glass thicknesses to comply with ASTM E 1300, according to the following requirements:
 - a. Specified Design Wind Loads: 35 PSI, but not less than wind loads applicable to Project as required by ASCE 7 "Minimum Design Loads for Buildings and Other Structures": Section 6.0 "Wind Loads." Refer to Structural Drawings for design values
 - b. Specified Design Snow Loads: Not less than snow loads applicable to Project as required by ASCE 7, "Minimum Design Loads for Buildings and Other Structures": Section 7.0, "Snow Loads." Refer to Structural Drawings for design values.
 - c. Probability of Breakage for Vertical Glazing: 8 lites per 1000 for lites set vertically or not more than 15 degrees off vertical and under wind action. Load Duration: 3 seconds
 - d. Maximum Lateral Deflection: For the following types of glass supported on all 4 edges, provide thickness required that limits center deflection at design wind pressure to 1/50 times the short side length or 1 inch (25 mm), whichever is less.
 - 1) For monolithic-glass lites heat treated to resist wind loads.
 - 2) For insulating glass.
 - 3) For laminated-glass lites.
 - e. Minimum Glass Thickness for Exterior Lites: Not less than ¼ inch.
 - f. Thickness of Tinted and Heat-Absorbing Glass: Provide the same thickness for each tint color indicated throughout Project.
- C. Thermal Movements: Provide glazing that allows for thermal movements resulting from the following maximum change (range) in ambient and surface temperatures acting on glass framing members and glazing components. Base engineering calculation on surface temperatures of materials due to both solar heat gain and nighttime-sky heat loss.
 - 1. Temperature Change (Range): 120 deg F (67 deg C), ambient; 180 deg F (100 deg C), material surfaces.

- D. Thermal and Optical Performance Properties: Provide glass with performance properties specified based on manufacturer's published test data, as determined according to procedures indicated below:
1. For monolithic-glass lites, properties are based on units with lites $\frac{1}{4}$ inch.
 2. For laminated-glass lites, properties are based on products of construction indicated.
 3. For insulating-glass units, properties are based on units of thickness indicated for overall unit and for each lite.
 4. Center-of-Glass Values: Based on using LBL-44789 WINDOW 5.0 computer program for the following methodologies:
 - a. U-Factors: NFRC 100 expressed as Btu/ sq. ft. x h x deg F.
 - b. Solar Heat Gain Coefficient: NFRC 200.
 - c. Solar Optical Properties: NFRC 300.

1.5 SUBMITTALS

- A. Product Data: For each glass product and glazing material indicated.
- B. Samples: For the following products, in the form of 12-inch- (300-mm-) square Samples for glass.
1. Each color of tinted float glass.
 2. Each type of patterned glass.
 3. Coated vision glass.
 4. Wired glass.
 5. Each type of laminated glass with colored interlayer.
 6. Insulating glass for each designation indicated.
 7. For each color (except black) of exposed glazing sealant indicated.
- C. Glazing Schedule: Use same designations indicated on Drawings for glazed openings in preparing a schedule listing glass types and thicknesses for each size opening and location.
- D. Product Certificates: Signed by manufacturers of glass and glazing products certifying that products furnished comply with requirements. For solar-control low-e-coated glass, provide documentation demonstrating that manufacturer of coated glass is certified by coating manufacturer.
- E. Qualification Data: For installers.
- F. Preconstruction Adhesion and Compatibility Test Report: From glazing sealant manufacturer indicating glazing sealants were tested for adhesion to glass and glazing channel substrates and for compatibility with glass and other glazing materials.
- G. Product Test Reports: For each of the following types of glazing products:
1. Tinted float glass.
 2. Insulating glass.
 3. Glazing sealants and gaskets.
- H. Warranties: Special warranties specified in this Section.

1.6 QUALITY ASSURANCE

- A. Installer Qualifications: An experienced installer who has completed glazing similar in material, design, and extent to that indicated for this Project; whose work has resulted in glass installations with a record of successful in-service performance; and who employs glass installers for this Project who are certified under the National Glass Association's Certified Glass Installer Program.
- B. Source Limitations for Glass Sputter-Coated with Solar-Control Low-E Coatings: Where solar-control low-e coatings of a primary glass manufacturer that has established a certified fabricator program is specified, obtain sputter-coated solar-control low-e-coated glass in fabricated units from a manufacturer that is certified by coated-glass manufacturer.
- C. Source Limitations for Glazing Accessories: Obtain glazing accessories through one source from a single manufacturer for each product and installation method indicated.
- D. Glass Product Testing: Obtain glass test results for product test reports in "Submittals" Article from a qualified testing agency based on testing glass products.
 - 1. Glass Testing Agency Qualifications: An independent testing agency with the experience and capability to conduct the testing indicated, as documented according to ASTM E 548.
- E. Glazing for Fire-Rated Door Assemblies: Glazing for assemblies that comply with NFPA 80 and that are listed and labeled by a testing and inspecting agency acceptable to authorities having jurisdiction, for fire-protection ratings indicated, based on testing according to NFPA 252.
- F. Safety Glazing Products: Comply with testing requirements in 16 CFR 1201 and, for wired glass, ANSI Z97.1.
 - 1. Subject to compliance with requirements, obtain safety glazing products permanently marked with certification label of the Safety Glazing Certification Council or another certification agency acceptable to authorities having jurisdiction.
 - 2. Where glazing units, including Kind FT glass and laminated glass, are specified in Part 2 articles for glazing lites more than 9 sq. ft. (0.84 sq. m) in exposed surface area of one side, provide glazing products that comply with Category II materials, for lites 9 sq. ft. (0.84 sq. m) or less in exposed surface area of one side, provide glazing products that comply with Category I or II materials, except for hazardous locations where Category II materials are required by 16 CFR 1201 and regulations of authorities having jurisdiction.
- G. Glazing Publications: Comply with published recommendations of glass product manufacturers and organizations below, unless more stringent requirements are indicated. Refer to these publications for glazing terms not otherwise defined in this Section or in referenced standards.
 - 1. GANA Publications: GANA Laminated Division's "Laminated Glass Design Guide" and GANA's "Glazing Manual."
 - 2. IGMA Publication for Insulating Glass: SIGMA TM-3000, "Glazing Guidelines for Sealed Insulating Glass Units."
- H. Insulating-Glass Certification Program: Permanently marked either on spacers or on at least one component lite of units with appropriate certification label of the following testing and inspecting agency: Insulating Glass Certification Council.
- I. Preinstallation Conference: Conduct conference at Project site to comply with requirements in Division 1 Section "Project Management and Coordination."

1.7 DELIVERY, STORAGE, AND HANDLING

- A. Protect glazing materials according to manufacturer's written instructions and as needed to prevent damage to glass and glazing materials from condensation, temperature changes, direct exposure to sun, or other causes.

1.8 PROJECT CONDITIONS

- A. Environmental Limitations: Do not proceed with glazing when ambient and substrate temperature conditions are outside limits permitted by glazing material manufacturers and when glazing channel substrates are wet from rain, frost, condensation, or other causes.
 - 1. Do not install liquid glazing sealants when ambient and substrate temperature conditions are outside limits permitted by glazing sealant manufacturer or below 40 deg F (4.4 deg C).

1.9 WARRANTY

- A. Manufacturer's Special Warranty for Glass Products: For each of the listed products, Manufacturer's standard form, made out to Owner and signed by glass manufacturer agreeing to replace units that deteriorate as defined in "Definitions" Article, f.o.b. the nearest shipping point to Project site, within specified warranty period of 10 years from date of Substantial Completion.
 - 1. Coated Glass
 - 2. Laminated Glass
 - 3. Insulating Glass.

PART 2 - PRODUCTS

2.1 MANUFACTURERS

- A. In other Part 2 articles where titles below introduce lists, the following requirements apply to product selection:
 - 1. Available Products: Subject to compliance with requirements, products that may be incorporated into the Work include, but are not limited to, products specified.
Products: Subject to compliance with requirements, provide one of the products specified.
 - 2. Product: Subject to compliance with requirements, provide product specified.
 - 3. Available Manufacturers: Subject to compliance with requirements, manufacturers offering products that may be incorporated into the Work include, but are not limited to, manufacturers specified.
 - 4. Manufacturers: Subject to compliance with requirements, provide products by one of the manufacturers specified.
 - 5. Basis-of-Design Product: The design for each glazing product is based on the product named. Subject to compliance with requirements, provide either the named product or a comparable product by one of the other manufacturers specified.

2.2 GLASS PRODUCTS

- A. Annealed Float Glass: ASTM C 1036, Type I (transparent flat glass), Quality-Q3; of class indicated.
- B. Heat-Treated Float Glass: ASTM C 1048; Type I (transparent flat glass); Quality-Q3; of class, kind, and condition indicated.
 - 1. Fabrication Process: By horizontal (roller-hearth) process with roll-wave distortion parallel to bottom edge of glass as installed, unless otherwise indicated.
 - 2. Provide Kind HS (heat-strengthened) float glass in place of annealed float glass where needed to resist thermal stresses induced by differential shading of individual glass lites and to comply with glass design requirements specified in Part 1 "Performance Requirements" Article.
 - 3. For uncoated glass, comply with requirements for Condition A.
 - 4. For coated vision glass, comply with requirements for Condition C (other uncoated glass).
 - 5. Provide Kind FT (fully tempered) float glass in place of annealed or Kind HS (heat-strengthened) float glass where safety glass is indicated.
- C. Wired Glass: ASTM C 1036, Type II (patterned and wired flat glass), Class 1 (clear), Quality-Q-6; and of form and mesh pattern specified.
- D. Tempered Patterned Glass: ASTM C 1048, Kind FT (fully tempered), Type II (patterned flat glass), Class 1 (clear), Form 3 (patterned); and of quality, finish, and pattern specified.
- E. Laminated Glass: ASTM C 1172, and complying with other requirements specified and with the following:
 - 1. Interlayer: Polyvinyl butyral of thickness indicated with a proven record of no tendency to bubble, discolor, or lose physical and mechanical properties after laminating glass lites and installation. Laminate lites in autoclave with heat plus pressure.
 - 2. Laminating Process: Fabricate laminated glass to produce glass free of foreign substances and air or glass pockets.
- F. Insulating-Glass Units, General: Factory-assembled units consisting of sealed lites of glass separated by a dehydrated interspace, and complying with ASTM E 774 for Class CBA units and with requirements specified in this Article and in Part 2 "Insulating-Glass Units" Article.
 - 1. All insulated glass units to be argon gas filled with LowE coating on surface #3, unless noted otherwise.
 - 2. Provide Kind HS (heat-strengthened) float glass in place of annealed glass where needed to resist thermal stresses induced by differential shading of individual glass lites and to comply with glass design requirements specified in Part 1 "Performance Requirements" Article.
 - 3. Provide Kind FT (fully tempered) glass lites where safety glass is indicated or required.
 - 4. Overall Unit Thickness and Thickness of Each Lite: Dimensions indicated for insulating-glass units are nominal and the overall thicknesses of units are measured perpendicularly from outer surfaces of glass lites at unit's edge.
 - 5. Sealing System: Dual seal, with primary and secondary sealants.\
 - 6. Spacer Specifications: Manufacturer's standard spacer material and construction.

2.3 GLAZING GASKETS

- A. Compression Gaskets: Molded or extruded gaskets of material suitable for application and compatible with other materials and sealants used in assembly of storefront and curtainwall framing, and of profile and hardness required to maintain watertight seal:

2.4 GLAZING SEALANTS

- A. General: Provide products of type indicated, complying with the following requirements:
 - 1. Compatibility: Select glazing sealants that are compatible with one another and with other materials they will contact, including glass products, seals of insulating-glass units, and glazing channel substrates, under conditions of service and application, as demonstrated by sealant manufacturer based on testing and field experience.
 - 2. Suitability: Comply with sealant and glass manufacturers' written instructions for selecting glazing sealants suitable for applications indicated and for conditions existing at time of installation.
 - 3. Colors of Exposed Glazing Sealants: As selected by Architect from manufacturer's full range.
- B. Elastomeric Glazing Sealants: Comply with ASTM C 920 and other requirements indicated for each liquid-applied chemically curing sealant specified, including those referencing ASTM C 920 classifications for type, grade, class, and uses related to exposure and joint substrates.
- C. Glazing Sealants for Fire-Resistive Glazing Products: Identical to products used in test assemblies to obtain fire-protection rating.
- D. Neutral-Curing Silicone Glazing Sealants (Butt glazing):
 - a. Type and Grade: S (single component) and NS (nonsag).
 - b. Class: 25.
 - c. Use Related to Exposure: NT (nontraffic).
 - d. Uses Related to Glazing Substrates: G, A, and, as applicable to glazing substrates indicated, O.

2.5 GLAZING TAPES

- A. Back-Bedding Mastic Glazing Tapes: Preformed, butyl-based elastomeric tape with a solids content of 100 percent; nonstaining and nonmigrating in contact with nonporous surfaces; with or without spacer rod as recommended in writing by tape and glass manufacturers for application indicated; packaged on rolls with a release paper backing; and complying with ASTM C 1281 and AAMA 800 for products indicated below:
 - 1. AAMA 806.3 tape, for glazing applications in which tape is subject to continuous pressure.
 - 2. AAMA 807.3 tape, for glazing applications in which tape is not subject to continuous pressure.

- B. Expanded Cellular Glazing Tapes: Closed-cell, PVC foam tapes; factory coated with adhesive on both surfaces; packaged on rolls with release liner protecting adhesive; and complying with AAMA 800 for the following types:
 - 1. Type 1, for glazing applications in which tape acts as the primary sealant.
 - 2. Type 2, for glazing applications in which tape is used in combination with a full bead of liquid sealant.

2.6 MISCELLANEOUS GLAZING MATERIALS

- A. General: Provide products of material, size, and shape complying with referenced glazing standard, requirements of manufacturers of glass and other glazing materials for application indicated, and with a proven record of compatibility with surfaces contacted in installation.
- B. Cleaners, Primers, and Sealers: Types recommended by sealant or gasket manufacturer.
- C. Setting Blocks: Elastomeric material with a Shore, Type A durometer hardness of 85, plus or minus 5.
- D. Spacers: Elastomeric blocks or continuous extrusions with a Shore, Type A durometer hardness required by glass manufacturer to maintain glass lites in place for installation indicated.
- E. Edge Blocks: Elastomeric material of hardness needed to limit glass lateral movement (side walking).

2.7 FABRICATION OF GLAZING UNITS

- A. Fabricate glazing units in sizes required to glaze openings indicated for Project, with edge and face clearances, edge and surface conditions, and bite complying with written instructions of product manufacturer and referenced glazing publications, to comply with system performance requirements.
- B. Clean-cut or flat-grind vertical edges of butt-glazed monolithic lites in a manner that produces square edges with slight kerfs at junctions with outdoor and indoor faces.
- C. Grind smooth and polish exposed glass edges and corners.

2.8 PRIVACY FILM

- A. Basis of Design: Subject to compliance requirements, available products that may be incorporated into the work include, but are not limited to:
 - 1. 3M FASARA Glass Finishes Fabric / Washi SH2PTRK, Rikyu
 - 2. Approved Equal
- B. Adhesive Type: Pressure-Sensitive
- C. Overall Thickness: 1.969 mil
- D. Overall Width: 50 in
- E. Design Pattern: Fabric/Washi
- F. Surface Finish: Matte
- G. Product Color: White
- H. Performance Level: Premium

2.9 GLASS UNITS TYPES (Refer to A411 for more information)

- A. Glass Type (G-1): 1" Low-E Insulated Glass, ($\frac{1}{4}" + \frac{1}{2}" + \frac{1}{4}"$).
1. Outer Lite: $\frac{1}{4}"$ Pilkington Clear Eclipse Advantage Radiant Low-E #2 surface
 2. Air Space: $\frac{1}{2}"$ 90% Argon fill
 3. Inner Lite: $\frac{1}{4}"$ Pilkington Energy Advantage, Low-E (#3 surface)
 4. Safety Glazing Required, Both Lites
- B. Glass Type (G-2): 1" Spandrel Glass, ($\frac{1}{4}" + \frac{1}{2}" + \frac{1}{4}"$) Heat Strengthened
1. Outer Lite: $\frac{1}{4}"$ Pilkington Clear Eclipse Advantage Radiant Low-E #2 surface
 2. Air Space: 90% Argon fill
 3. Inner Lite: $\frac{1}{4}"$ Clear, tempered, "Charcoal" Ceramic coating on #4 surface
 4. Safety Glazing Required, Both Lites
- C. Glass Type (G- 3): $\frac{1}{4}"$ clear, tempered glass. Grade B fully tempered, Style 1 (uncoated surface),
1. Type 1 (float), Quality (glazing quality) Class 1 (transparent).
- D. Glass Type (G- 4): $\frac{3}{4}"$ clear, lightly frosted, tempered glass. Grade B fully tempered
1. Type 1 (float), Quality (glazing quality) Class 1 (transparent).
 2. Refer to Section 057300 – Decorative Metal Railings for glass guard infill panels as part of a decorative metal railing system.
- E. Glass Type (G- 5): Frosted Glass.
1. $\frac{1}{4}"$ clear, tempered glass. Grade B fully tempered, Style: Frosted. Type 1 (float), Quality (glazing quality)
- F. Glass Type (G-6): $\frac{7}{8}$ inch fire-rated glazing with 450 deg F (250 deg C) temperature rise limitation; laminated glass with intumescent interlayers.
1. Provide safety glazing labeling.
 - a. Basis of Design: Pilkington Group Limited (distributed by Technical Glass Products); PyroStop or approved equal.
- G. Refer to 088400 Plastic Glazing for Resin glazing elements.

PART 3 - EXECUTION

3.1 EXAMINATION

- A. Examine framing glazing, with Installer present, for compliance with the following:
1. Manufacturing and installation tolerances, including those for size, squareness, and offsets at corners.
 2. Presence and functioning of weep system.
 3. Minimum required face or edge clearances.
 4. Effective sealing between joints of glass-framing members.
- B. Proceed with installation only after unsatisfactory conditions have been corrected.

3.2 PREPARATION

- A. Clean glazing channels and other framing members receiving glass immediately before glazing. Remove coatings not firmly bonded to substrates.

3.3 GLAZING, GENERAL

- A. Comply with combined written instructions of manufacturers of glass, sealants, gaskets, and other glazing materials, unless more stringent requirements are indicated, including those in referenced glazing publications.
- B. Glazing channel dimensions, as indicated on Drawings, provide necessary bite on glass, minimum edge and face clearances, and adequate sealant thicknesses, with reasonable tolerances. Adjust as required by Project conditions during installation.
- C. Protect glass edges from damage during handling and installation. Remove damaged glass from Project site and legally dispose of off Project site. Damaged glass is glass with edge damage or other imperfections that, when installed, could weaken glass and impair performance and appearance.
- D. Apply primers to joint surfaces where required for adhesion of sealants, as determined by preconstruction sealant-substrate testing.
- E. Install setting blocks in sill rabbets, sized and located to comply with referenced glazing publications, unless otherwise required by glass manufacturer. Set blocks in thin course of compatible sealant suitable for heel bead.
- F. Do not exceed edge pressures stipulated by glass manufacturers for installing glass lites.
- G. Provide spacers for glass lites where length plus width is larger than 50 inches (1270 mm) as follows:
 - 1. Locate spacers directly opposite each other on both inside and outside faces of glass. Install correct size and spacing to preserve required face clearances, unless gaskets and glazing tapes are used that have demonstrated ability to maintain required face clearances and to comply with system performance requirements.
 - 2. Provide 1/8-inch (3-mm) minimum bite of spacers on glass and use thickness equal to sealant width. With glazing tape, use thickness slightly less than final compressed thickness of tape.
- H. Provide edge blocking where indicated or needed to prevent glass lites from moving sideways in glazing channel, as recommended in writing by glass manufacturer and according to requirements in referenced glazing publications.
- I. Set glass lites in each series with uniform pattern, draw, bow, and similar characteristics.
- J. Where wedge-shaped gaskets are driven into one side of channel to pressurize sealant or gasket on opposite side, provide adequate anchorage so gasket cannot walk out when installation is subjected to movement.
- K. Square cut wedge-shaped gaskets at corners and install gaskets in a manner recommended by gasket manufacturer to prevent corners from pulling away; seal corner joints and butt joints with sealant recommended by gasket manufacturer.

3.4 TAPE GLAZING

- A. Position tapes on fixed stops so that, when compressed by glass, their exposed edges are flush with or protrude slightly above sightline of stops.

- B. Install tapes continuously, but not necessarily in one continuous length. Do not stretch tapes to make them fit opening.
- C. Cover vertical framing joints by applying tapes to heads and sills first and then to jambs. Cover horizontal framing joints by applying tapes to jambs and then to heads and sills.
- D. Place joints in tapes at corners of opening with adjoining lengths butted together, not lapped. Seal joints in tapes with compatible sealant approved by tape manufacturer.
- E. Do not remove release paper from tape until just before each glazing unit is installed.
- F. Center glass lites in openings on setting blocks and press firmly against tape by inserting dense compression gaskets formed and installed to lock in place against faces of removable stops. Start gasket applications at corners and work toward centers of openings.
- G. Apply cap bead of elastomeric sealant over exposed edge of tape at all horizontal applications and where required.

3.5 GASKET GLAZING (DRY)

- A. Fabricate compression gaskets in lengths recommended by gasket manufacturer to fit openings exactly, with allowance for stretch during installation.
- B. Insert soft compression gasket between glass and frame or fixed stop so it is securely in place with joints miter cut and bonded together at corners.
- C. Center glass lites in openings on setting blocks and press firmly against soft compression gasket by inserting dense compression gaskets formed and installed to lock in place against faces of removable stops. Start gasket applications at corners and work toward centers of openings. Compress gaskets to produce a weathertight seal without developing bending stresses in glass. Seal gasket joints with sealant recommended by gasket manufacturer.
- D. Install gaskets so they protrude past face of glazing stops.

3.6 CLEANING AND PROTECTION

- A. Protect exterior glass from damage immediately after installation by attaching crossed streamers to framing held away from glass. Do not apply markers to glass surface. Remove nonpermanent labels and clean surfaces.
- B. Protect glass from contact with contaminating substances resulting from construction operations, including weld splatter. If, despite such protection, contaminating substances do come into contact with glass, remove substances immediately as recommended by glass manufacturer.
- C. Examine glass surfaces adjacent to or below exterior concrete and other masonry surfaces at frequent intervals during construction, but not less than once a month, for buildup of dirt, scum, alkaline deposits, or stains; remove as recommended in writing by glass manufacturer.
- D. Remove and replace glass that is broken, chipped, cracked, or abraded or that is damaged from natural causes, accidents, and vandalism, during construction period.
- E. Wash glass on both exposed surfaces in each area of Project not more than four days before date scheduled for inspections that establish date of Substantial Completion. Wash glass as recommended in writing by glass manufacturer.

END OF SECTION 08 80 00

SECTION 09 22 16 - NON-STRUCTURAL METAL FRAMING

PART 1 - GENERAL

1.1 RELATED DOCUMENTS

- A. Drawings and general provisions of the Contract, including General and Supplementary Conditions and Division 01 Specification Sections, apply to this Section.
 - 1. Division 01 Section 017419 – Construction Waste Management.

1.2 SUMMARY

- A. Section Includes:
 - 1. Non-load-bearing steel framing systems for interior gypsum board assemblies.
 - 2. Suspension systems for interior gypsum ceilings, soffits, and grid systems.
- B. Related Requirements:
 - 1. Division 05 Section "Cold-Formed Metal Framing" for exterior and interior load-bearing and exterior non-load-bearing wall studs; floor joists; roof rafters and ceiling joists; and roof trusses.

1.3 ACTION SUBMITTALS

- A. Product Data: For each type of product.

1.4 INFORMATIONAL SUBMITTALS

- A. Evaluation Reports: For dimpled steel studs and runners, from ICC-ES.

PART 2 - PRODUCTS

2.1 PERFORMANCE REQUIREMENTS

- A. Fire-Test-Response Characteristics: For fire-resistance-rated assemblies that incorporate non-load-bearing steel framing, provide materials and construction identical to those tested in assembly indicated, according to ASTM E 119 by an independent testing agency.
- B. STC-Rated Assemblies: For STC-rated assemblies, provide materials and construction identical to those tested in assembly indicated, according to ASTM E 90 and classified according to ASTM E 413 by an independent testing agency.

2.2 FRAMING SYSTEMS

- A. Recycled Content of Steel Products: Postconsumer recycled content plus one-half of pre-consumer recycled content not less than 25 percent.
- B. Framing Members, General: Comply with ASTM C 754 for conditions indicated.
 - 1. Steel Sheet Components: Comply with ASTM C 645 requirements for metal unless otherwise indicated.
 - 2. Protective Coating: hot-dip galvanized unless otherwise indicated.
- C. Studs and Runners: ASTM C 645. Use either steel studs and runners or dimpled steel studs and runners.
 - 1. Steel Studs and Runners:
 - a. Minimum Base-Metal Thickness: 0.027 inch (0.68 mm).
 - b. Depth: As indicated on Drawings.
 - 2. Dimpled Steel Studs and Runners:
 - a. Minimum Base-Metal Thickness: 0.025 inch (0.64 mm).
 - b. Depth: As indicated on Drawings.
- D. Slip-Type Head Joints: Where indicated, provide one of the following:
 - 1. Single Long-Leg Runner System: ASTM C 645 top runner with 2-inch- (51-mm-) deep flanges in thickness not less than indicated for studs, installed with studs friction fit into top runner and with continuous bridging located within 12 inches (305 mm) of the top of studs to provide lateral bracing.
 - 2. Double-Runner System: ASTM C 645 top runners, inside runner with 2-inch- (51-mm-) deep flanges in thickness not less than indicated for studs and fastened to studs, and outer runner sized to friction fit inside runner.
 - 3. Deflection Track: Steel sheet top runner manufactured to prevent cracking of finishes applied to interior partition framing resulting from deflection of structure above; in thickness not less than indicated for studs and in width to accommodate depth of studs.
 - a. Products: Subject to compliance with requirements, available products that may be incorporated into the Work include, but are not limited to, the following:
 - 1) Dietrich Metal Framing; SLP-TRK Slotted Deflection Track.
 - 2) MBA Building Supplies; FlatSteel Deflection Track or Slotted Deflecto Track.
 - 3) Steel Network Inc. (The); VertiClip SLD or VertiTrack VTD Series.
 - 4) Superior Metal Trim; Superior Flex Track System (SFT).
 - 5) Telling Industries; Vertical Slip Track or Vertical Slip Track II..
- E. Firestop Tracks: Top runner manufactured to allow partition heads to expand and contract with movement of the structure while maintaining continuity of fire-resistance-rated assembly indicated; in thickness not less than indicated for studs and in width to accommodate depth of studs.

1. Products: Subject to compliance with requirements, available products that may be incorporated into the Work include, but are not limited to, the following:
 - a. Fire Trak Corp.; Fire Trak System attached to studs with Fire Trak Posi Klip.
 - b. Grace Construction Products; FlameSafe FlowTrak System.
 - c. Metal-Lite, Inc.; The System.
 - d. Steel Network Inc. (The); VertiClip SLD or VertiTrack VTD Series.
 - F. Flat Strap and Backing Plate: Steel sheet for blocking and bracing in length and width indicated.
 1. Minimum Base-Metal Thickness: 0.027 inch (0.68 mm).
 - G. Cold-Rolled Channel Bridging: Steel, 0.053-inch (1.34-mm) minimum base-metal thickness, with minimum 1/2-inch- (13-mm-) wide flanges.
 1. Depth: As indicated on Drawings.
 2. Clip Angle: Not less than 1-1/2 by 1-1/2 inches (38 by 38 mm), 0.068-inch- (1.72-mm-) thick, galvanized steel.
 - H. Hat-Shaped, Rigid Furring Channels: ASTM C 646.
 1. Minimum Base-Metal Thickness: [0.033 inch (0.84 mm).
 2. Depth: As indicated on Drawings.
 - I. Resilient Furring Channels: 1/2-inch- (13-mm-) deep, steel sheet members designed to reduce sound transmission.
 1. Configuration: Asymmetrical or hat shaped .
 - J. Cold-Rolled Furring Channels: 0.053-inch (1.34-mm) uncoated-steel thickness, with minimum 1/2-inch- (13-mm-) wide flanges.
 1. Depth: As indicated on Drawings
 2. Furring Brackets: Adjustable, corrugated-edge type of steel sheet with minimum uncoated-steel thickness of 0.033 inch (0.8 mm).
 3. Tie Wire: ASTM A 641/A 641M, Class 1 zinc coating, soft temper, 0.062-inch- (1.59-mm-) diameter wire, or double strand of 0.048-inch- (1.21-mm-) diameter wire.
 - K. Z-Shaped Furring: With slotted or nonslotted web, face flange of 1-1/4 inches (32 mm), wall attachment flange of 7/8 inch (22 mm), minimum uncoated-metal thickness of 0.018 inch (0.45 mm), and depth required to fit insulation thickness indicated.
- 2.3 SUSPENSION SYSTEMS
- A. Tie Wire: ASTM A 641/A 641M, Class 1 zinc coating, soft temper, 0.062-inch- (1.59-mm-) diameter wire, or double strand of 0.048-inch- (1.21-mm-) diameter wire.
 - B. Hanger Attachments to Concrete:

1. Anchors: Fabricated from corrosion-resistant materials with holes or loops for attaching wire hangers and capable of sustaining, without failure, a load equal to 5 times that imposed by construction as determined by testing according to ASTM E 488 by an independent testing agency.
 - a. Type: Post-installed, expansion anchor.
2. Powder-Actuated Fasteners: Suitable for application indicated, fabricated from corrosion-resistant materials with clips or other devices for attaching hangers of type indicated, and capable of sustaining, without failure, a load equal to 10 times that imposed by construction as determined by testing according to ASTM E 1190 by an independent testing agency.
- C. Wire Hangers: ASTM A 641/A 641M, Class 1 zinc coating, soft temper, 0.16 inch (4.12 mm) in diameter.
- D. Flat Hangers: Steel sheet, in size indicated on Drawings.
- E. Carrying Channels: Cold-rolled, commercial-steel sheet with a base-metal thickness of 0.053 inch (1.34 mm) and minimum 1/2-inch- (13-mm-) wide flanges.
 1. Depth: As indicated on Drawings.
- F. Furring Channels (Furring Members):
 1. Cold-Rolled Channels: 0.053-inch (1.34-mm) uncoated-steel thickness, with minimum 1/2-inch- (13-mm-) wide flanges, 2 1/4 inch (19 mm) deep.
 2. Steel Studs and Runners: ASTM C 645.
 - a. Minimum Base-Metal Thickness: 0.027 inch (0.68 mm).
 - b. Depth: As indicated on Drawings.
 3. Dimpled Steel Studs and Runners: ASTM C 645.
 - a. Minimum Base-Metal Thickness: 0.025 inch (0.64 mm).
 - b. Depth: As indicated on Drawings.
 4. Hat-Shaped, Rigid Furring Channels: ASTM C 645, 7/8 inch (22 mm) deep.
 - a. Minimum Base-Metal Thickness: 0.033 inch (0.84 mm)
 5. Resilient Furring Channels: 1/2-inch- (13-mm-) deep members designed to reduce sound transmission.
 - a. Configuration: Asymmetrical or hat shaped.
- G. Grid Suspension System for Gypsum Board Ceilings: ASTM C 645, direct-hung system composed of main beams and cross-furring members that interlock.
 1. Products: Subject to compliance with requirements, available products that may be incorporated into the Work include, but are not limited to, the following:

- a. Armstrong World Industries, Inc.; Drywall Grid Systems.
- b. Chicago Metallic Corporation; Drywall Grid System.
- c. USG Corporation; Drywall Suspension System.

2.4 AUXILIARY MATERIALS

- A. General: Provide auxiliary materials that comply with referenced installation standards.
 1. Fasteners for Metal Framing: Of type, material, size, corrosion resistance, holding power, and other properties required to fasten steel members to substrates.
- B. Isolation Strip at Exterior Walls: Provide one of the following:
 1. Asphalt-Saturated Organic Felt: ASTM D 226, Type I (No. 15 asphalt felt), nonperforated.
 2. Foam Gasket: Adhesive-backed, closed-cell vinyl foam strips that allow fastener penetration without foam displacement, 1/8 inch (3.2 mm) thick, in width to suit steel stud size.

PART 3 - EXECUTION

3.1 EXAMINATION

- A. Examine areas and substrates, with Installer present, and including welded hollow-metal frames, cast-in anchors, and structural framing, for compliance with requirements and other conditions affecting performance of the Work.
- B. Proceed with installation only after unsatisfactory conditions have been corrected.

3.2 PREPARATION

- A. Suspended Assemblies: Coordinate installation of suspension systems with installation of overhead structure to ensure that inserts and other provisions for anchorages to building structure have been installed to receive hangers at spacing required to support the Work and that hangers will develop their full strength.
 1. Furnish concrete inserts and other devices indicated to other trades for installation in advance of time needed for coordination and construction.
- B. Installation Standard: ASTM C 754.
 1. Gypsum Plaster Assemblies: Also comply with requirements in ASTM C 841 that apply to framing installation.
 2. Portland Cement Plaster Assemblies: Also comply with requirements in ASTM C 1063 that apply to framing installation.
 3. Gypsum Veneer Plaster Assemblies: Also comply with requirements in ASTM C 844 that apply to framing installation.

4. Gypsum Board Assemblies: Also comply with requirements in ASTM C 840 that apply to framing installation.
- C. Install supplementary framing, and blocking to support fixtures, equipment services, heavy trim, grab bars, toilet accessories, furnishings, or similar construction.
- D. Install bracing at terminations in assemblies.
- E. Do not bridge building control and expansion joints with non-load-bearing steel framing members. Frame both sides of joints independently.

3.3 INSTALLING FRAMED ASSEMBLIES

- A. Install framing system components according to spacings indicated, but not greater than spacings required by referenced installation standards for assembly types.
 1. Single-Layer Application: 16 inches (406 mm) OC unless otherwise indicated.
 2. Multilayer Application: 16 inches (406 mm) OC unless otherwise indicated.
 3. Tile Backing Panels: 16 inches (406 mm) OC unless otherwise indicated.
- B. Where studs are installed directly against exterior masonry walls or dissimilar metals at exterior walls, install isolation strip between studs and exterior wall.
- C. Install studs so flanges within framing system point in same direction.
- D. Install tracks (runners) at floors and overhead supports. Extend framing full height to structural supports or substrates above suspended ceilings except where partitions are indicated to terminate at suspended ceilings. Continue framing around ducts penetrating partitions above ceiling.
 1. Slip-Type Head Joints: Where framing extends to overhead structural supports, install to produce joints at tops of framing systems that prevent axial loading of finished assemblies.
 2. Door Openings: Screw vertical studs at jambs to jamb anchor clips on door frames; install runner track section (for cripple studs) at head and secure to jamb studs.
 - a. Install two studs at each jamb unless otherwise indicated.
 - b. Install cripple studs at head adjacent to each jamb stud, with a minimum **1/2-inch (13-mm)** clearance from jamb stud to allow for installation of control joint in finished assembly.
 - c. Extend jamb studs through suspended ceilings and attach to underside of overhead structure.
 3. Other Framed Openings: Frame openings other than door openings the same as required for door openings unless otherwise indicated. Install framing below sills of openings to match framing required above door heads.
 4. Fire-Resistance-Rated Partitions: Install framing to comply with fire-resistance-rated assembly indicated and support closures and to make partitions continuous from floor to underside of solid structure.

- a. Firestop Track: Where indicated, install to maintain continuity of fire-resistance-rated assembly indicated.
 5. Sound-Rated Partitions: Install framing to comply with sound-rated assembly indicated.
 6. Curved Partitions:
 - a. Bend track to uniform curve and locate straight lengths so they are tangent to arcs.
 - b. Begin and end each arc with a stud, and space intermediate studs equally along arcs. On straight lengths of no fewer than two studs at ends of arcs, place studs 6 inches (150 mm) OC.
 - E. Direct Furring:
 1. Screw to wood framing.
 2. Attach to concrete or masonry with stub nails, screws designed for masonry attachment, or powder-driven fasteners spaced 24 inches (610 mm) OC.
 - F. Z-Furring Members:
 1. Erect insulation, specified in Division 07 Section "Thermal Insulation," vertically and hold in place with Z-furring members spaced 24 inches (610 mm) OC.
 2. Except at exterior corners, securely attach narrow flanges of furring members to wall with concrete stub nails, screws designed for masonry attachment, or powder-driven fasteners spaced 24 inches (610 mm) OC.
 3. At exterior corners, attach wide flange of furring members to wall with short flange extending beyond corner; on adjacent wall surface, screw-attach short flange of furring channel to web of attached channel. At interior corners, space second member no more than 12 inches (305 mm) from corner and cut insulation to fit.
 - G. Installation Tolerance: Install each framing member so fastening surfaces vary not more than 1/8 inch (3 mm) from the plane formed by faces of adjacent framing.
- 3.4 INSTALLING SUSPENSION SYSTEMS
- A. Install suspension system components according to spacings indicated, but not greater than spacings required by referenced installation standards for assembly types.
 1. Hangers: 48 inches (1219 mm) OC.
 2. Carrying Channels (Main Runners): 48 inches (1219 mm) OC.
 3. Furring Channels (Furring Members): 16 inches (406 mm) OC.
 - B. Isolate suspension systems from building structure where they abut or are penetrated by building structure to prevent transfer of loading imposed by structural movement.
 - C. Suspend hangers from building structure as follows:
 1. Install hangers plumb and free from contact with insulation or other objects within ceiling plenum that are not part of supporting structural or suspension system.

- a. Splay hangers only where required to miss obstructions and offset resulting horizontal forces by bracing, counter splaying, or other equally effective means.
2. Where width of ducts and other construction within ceiling plenum produces hanger spacings that interfere with locations of hangers required to support standard suspension system members, install supplemental suspension members and hangers in the form of trapezes or equivalent devices.
 - a. Size supplemental suspension members and hangers to support ceiling loads within performance limits established by referenced installation standards
3. Wire Hangers: Secure by looping and wire tying, either directly to structures or to inserts, eye screws, or other devices and fasteners that are secure and appropriate for substrate, and in a manner that will not cause hangers to deteriorate or otherwise fail.
4. Flat Hangers: Secure to structure, including intermediate framing members, by attaching to inserts, eye screws, or other devices and fasteners that are secure and appropriate for structure and hanger, and in a manner that will not cause hangers to deteriorate or otherwise fail.
5. Do not attach hangers to steel roof deck.
6. Do not attach hangers to permanent metal forms. Furnish cast-in-place hanger inserts that extend through forms.
7. Do not attach hangers to rolled-in hanger tabs of composite steel floor deck.
8. Do not connect or suspend steel framing from ducts, pipes, or conduit.
- D. Fire-Resistance-Rated Assemblies: Wire tie furring channels to supports.
- E. Seismic Bracing: Sway-brace suspension systems with hangers used for support.
- F. Grid Suspension Systems: Attach perimeter wall track or angle where grid suspension systems meet vertical surfaces. Mechanically join main beam and cross-furring members to each other and butt-cut to fit into wall track.
- G. Installation Tolerances: Install suspension systems that are level to within 1/8 inch in 12 feet (3 mm in 3.6 m) measured lengthwise on each member that will receive finishes and transversely between parallel members that will receive finishes.

END OF SECTION 09 22 16

SECTION 09 29 00 - GYPSUM BOARD

PART 1 - GENERAL

1.1 RELATED DOCUMENTS

- A. Drawings and general provisions of the Contract, including General and Supplementary Conditions and Division 01 Specification Sections, apply to this Section.
 - 1. Division 01 Section 017419 – Construction Waste Management.

1.2 SUMMARY

- A. Section Includes:
 - 1. Interior gypsum board.
- B. Related Requirements:
 - 1. Division 09 Section "Non-Structural Metal Framing" for non-structural framing and suspension systems that support gypsum board panels.

1.3 ACTION SUBMITTALS

- A. Product Data: For each type of product.
- B. Samples: For the following products:
 - 1. Trim Accessories: Full-size Sample in 12-inch- (300-mm-) long length for each trim accessory indicated.

1.4 DELIVERY, STORAGE AND HANDLING

- A. Store materials inside under cover and keep them dry and protected against weather, condensation, direct sunlight, construction traffic, and other potential causes of damage. Stack panels flat and supported on risers on a flat platform to prevent sagging.

1.5 FIELD CONDITIONS

- A. Environmental Limitations: Comply with ASTM C 840 requirements or gypsum board manufacturer's written recommendations, whichever are more stringent.
- B. Do not install paper-faced gypsum panels until installation areas are enclosed and conditioned.
- C. Do not install panels that are wet, those that are moisture damaged, and those that are mold damaged.
 - 1. Indications that panels are wet or moisture damaged include, but are not limited to, discoloration, sagging, or irregular shape.

2. Indications that panels are mold damaged include, but are not limited to, fuzzy or splotchy surface contamination and discoloration.

PART 2 - PRODUCTS

2.1 PERFORMANCE REQUIREMENTS

- A. Fire-Resistance-Rated Assemblies: For fire-resistance-rated assemblies, provide materials and construction identical to those tested in assembly indicated according to ASTM E 119 by an independent testing agency.
- B. STC-Rated Assemblies: For STC-rated assemblies, provide materials and construction identical to those tested in assembly indicated according to ASTM E 90 and classified according to ASTM E 413 by an independent testing agency.
- C. Low Emitting Materials: For ceiling and wall assemblies, provide materials and construction identical to those tested in assembly and complying with the testing and product requirements of the California Department of Health Services' "Standard Practice for the Testing of Volatile Organic Emissions from Various Sources Using Small-Scale Environmental Chambers."

2.2 GYPSUM BOARD, GENERAL

- A. Recycled Content of Gypsum Panel Products: Postconsumer recycled content plus one-half of preconsumer recycled content not less than 25 percent.
- B. Regional Materials: Gypsum panel products shall be manufactured within 500 miles (800 km) of Project site.
- C. Size: Provide maximum lengths and widths available that will minimize joints in each area and that correspond with support system indicated.

2.3 INTERIOR GYPSUM BOARD

- A. Manufacturers: Subject to compliance with requirements, provide products by one of the following:
 1. American Gypsum.
 2. CertainTeed Corp.
 3. Georgia-Pacific Gypsum LLC.
 4. Lafarge North America Inc.
 5. National Gypsum Company.
 6. USG Corporation.
- B. Gypsum Wallboard: ASTM C 1396/C 1396M.
 1. Thickness: 5/8 inch (15.9 mm).
 2. Long Edges: Tapered.

2.4 TRIM ACCESSORIES

- A. Interior Trim: ASTM C 1047.

1. Material: Galvanized or aluminum-coated steel sheet, rolled zinc, plastic, or paper-faced galvanized steel sheet.
2. Shapes:
 - a. Cornerbead.
 - b. Bullnose bead.
 - c. LC-Bead: J-shaped; exposed long flange receives joint compound.
 - d. L-Bead: L-shaped; exposed long flange receives joint compound.
 - e. U-Bead: J-shaped; exposed short flange does not receive joint compound.

2.5 JOINT TREATMENT MATERIALS

- A. General: Comply with ASTM C 475/C 475M.
- B. Joint Tape:
 1. Interior Gypsum Board: Paper.
 2. Exterior Gypsum Soffit Board: Paper.
 3. Glass-Mat Gypsum Sheathing Board: 10-by-10 glass mesh.
 4. Tile Backing Panels: As recommended by panel manufacturer.
- C. Joint Compound for Interior Gypsum Board: For each coat use formulation that is compatible with other compounds applied on previous or for successive coats.
 1. Prefilling: At open joints, rounded or beveled panel edges, and damaged surface areas, use setting-type taping compound.
 2. Embedding and First Coat: For embedding tape and first coat on joints, fasteners, and trim flanges, use drying-type, all-purpose compound.
 - a. Use setting-type compound for installing paper-faced metal trim accessories.
 3. Fill Coat: For second coat, use drying-type, all-purpose compound.
 4. Finish Coat: For third coat, use drying-type, all-purpose compound.
- D. Joint Compound for Exterior Applications:
 1. Exterior Gypsum Soffit Board: Use setting-type taping compound and setting-type, sandable topping compound.
 2. Glass-Mat Gypsum Sheathing Board: As recommended by sheathing board manufacturer.

2.6 AUXILIARY MATERIALS

- A. General: Provide auxiliary materials that comply with referenced installation standards and manufacturer's written recommendations.
- B. Steel Drill Screws: ASTM C 1002, unless otherwise indicated.
 1. Use screws complying with ASTM C 954 for fastening panels to steel members from 0.033 to 0.112 inch (0.84 to 2.84 mm) thick.

2. For fastening cementitious backer units, use screws of type and size recommended by panel manufacturer.
- C. Sound Attenuation Blankets: See section 07 21 00 THERMAL INSULATION
- D. Acoustical Joint Sealant: Manufacturer's standard nonsag, paintable, nonstaining latex sealant complying with ASTM C 834. Product effectively reduces airborne sound transmission through perimeter joints and openings in building construction as demonstrated by testing representative assemblies according to ASTM E 90.
 1. Products: Subject to compliance with requirements, available products that may be incorporated into the Work include, but are not limited to, the following:
 - a. Accumetric LLC; BOSS 824 Acoustical Sound Sealant.
 - b. Grabber Construction Products; Acoustical Sealant GSC
 - c. Pecora Corporation; AC-20 FTR or AIS-919.
 - d. Specified Technologies, Inc.; Smoke N Sound Acoustical Sealant.
 - e. USG Corporation; SHEETROCK Acoustical Sealant.
 2. Acoustical joint sealant shall have a VOC content of 250 g/L or less when calculated according to 40 CFR 59, Subpart D (EPA Method 24).
 3. Acoustical joint sealant shall comply with the testing and product requirements of the California Department of Health Services "Standard Practice for the Testing of Volatile Organic Emissions from Various Sources Using Small-Scale Environmental Chambers."
- E. Thermal Insulation: See section 07 21 00 THERMAL INSULATION

PART 3 - EXECUTION

3.1 EXAMINATION

- A. Examine areas and substrates including welded hollow-metal frames and framing, with Installer present, for compliance with requirements and other conditions affecting performance.
- B. Examine panels before installation. Reject panels that are wet, moisture damaged, and mold damaged.
- C. Proceed with installation only after unsatisfactory conditions have been corrected.

3.2 APPLYING AND FINISHING PANELS, GENERAL

- A. Comply with ASTM C 840.
- B. Install ceiling panels across framing to minimize the number of abutting end joints and to avoid abutting end joints in central area of each ceiling. Stagger abutting end joints of adjacent panels not less than one framing member.
- C. Install panels with face side out. Butt panels together for a light contact at edges and ends with not more than 1/16 inch (1.5 mm) of open space between panels. Do not force into place.
- D. Locate edge and end joints over supports, except in ceiling applications where intermediate supports or gypsum board back-blocking is provided behind end joints. Do not place tapered edges against cut edges or ends. Stagger vertical joints on opposite sides of partitions. Do not make joints other than control joints at corners of framed openings.

- E. Form control and expansion joints with space between edges of adjoining gypsum panels.
- F. Cover both faces of support framing with gypsum panels in concealed spaces (above ceilings, etc., except in chases braced internally).
 - 1. Unless concealed application is indicated or required for sound, fire, air, or smoke ratings, coverage may be accomplished with scraps of not less than 8 sq. ft. (0.7 sq. m) in area.
 - 2. Fit gypsum panels around ducts, pipes, and conduits.
 - 3. Where partitions intersect structural members projecting below underside of floor/roof slabs and decks, cut gypsum panels to fit profile formed by structural members; allow 1/4- to 3/8-inch- (6.4- to 9.5-mm-) wide joints to install sealant.
- G. Isolate perimeter of gypsum board applied to non-load-bearing partitions at structural abutments, except floors. Provide 1/4- to 1/2-inch- (6.4- to 12.7-mm-) wide spaces at these locations and trim edges with edge trim where edges of panels are exposed. Seal joints between edges and abutting structural surfaces with acoustical sealant.
- H. Attachment to Steel Framing: Attach panels so leading edge or end of each panel is attached to open (unsupported) edges of stud flanges first.
- I. Install sound attenuation blankets before installing gypsum panels unless blankets are readily installed after panels have been installed on one side.

3.3 APPLYING INTERIOR GYPSUM BOARD

- A. Install interior gypsum board in the following locations:
 - 1. Wallboard Type: Vertical surfaces unless otherwise indicated.
 - 2. Type X: Where required for fire-resistance-rated assembly.
 - 3. Ceiling Type: As indicated on Drawings.
 - 4. Glass-Mat Interior Type: As indicated on Drawings.
- B. Single-Layer Application:
 - 1. On ceilings, apply gypsum panels before wall/partition board application to greatest extent possible and at right angles to framing unless otherwise indicated.
 - 2. On partitions/walls, apply gypsum panels vertically (parallel to framing) unless otherwise indicated or required by fire-resistance-rated assembly, and minimize end joints.
 - a. Stagger abutting end joints not less than one framing member in alternate courses of panels.
 - b. At stairwells and other high walls, install panels horizontally unless otherwise indicated or required by fire-resistance-rated assembly.
 - 3. On Z-furring members, apply gypsum panels vertically (parallel to framing) with no end joints. Locate edge joints over furring members.
 - 4. Fastening Methods: Apply gypsum panels to supports with steel drill screws.

3.4 INSTALLING TRIM ACCESSORIES

- A. General: For trim with back flanges intended for fasteners, attach to framing with same fasteners used for panels. Otherwise, attach trim according to manufacturer's written instructions.
- B. Control Joints: Install control joints according to ASTM C 840 and per Gypsum Construction Handbook as published by United State Gypsum Company (Latest Edition) and in specific locations approved by Architect for visual effect.
 - 1. Control joints shall be employed in long expanses of gypsum board partitions at 30 foot intervals, from floor to ceiling. Additional control joints shall be provided at all door jambs and window frames in accordance with ASTM C 840 and per Gypsum Construction Handbook.
- C. Interior Trim: Install in the following locations:
 - 1. Cornerbead: Use at outside corners unless otherwise indicated.
 - 2. Bullnose Bead: Use at outside corners or where indicated.
 - 3. LC-Bead: Use at exposed panel edges.
 - 4. L-Bead: Use where indicated.
 - 5. U-Bead: Use at exposed panel edges or where indicated.
- D. Exterior Trim: Install in the following locations:
 - 1. Cornerbead: Use at outside corners.
 - 2. LC-Bead: Use at exposed panel edges.

3.5 FINISHING GYPSUM BOARD

- A. General: Treat gypsum board joints, interior angles, edge trim, control joints, penetrations, fastener heads, surface defects, and elsewhere as required to prepare gypsum board surfaces for decoration. Promptly remove residual joint compound from adjacent surfaces.
- B. Prefill open joints, rounded or beveled edges, and damaged surface areas.
- C. Apply joint tape over gypsum board joints, except for trim products specifically indicated as not intended to receive tape.
- D. Gypsum Board Finish Levels: Finish panels to levels indicated below and according to ASTM C 840:
 - 1. Level 1: Ceiling plenum areas, concealed areas, and where indicated.
 - 2. Level 2: Panels that are substrate for tile.
 - 3. Level 3: Where indicated on Drawings.
 - 4. Level 4: At panel surfaces that will be exposed to view unless otherwise indicate.
 - a. Primer and its application to surfaces are specified in other Division 09 Sections.
- E. Glass-Mat Gypsum Sheathing Board: Finish according to manufacturer's written instructions for use as exposed soffit board.

3.6 PROTECTION

- A. Protect adjacent surfaces from drywall compound and promptly remove from floors and other non-drywall surfaces. Repair surfaces stained, marred, or otherwise damaged during drywall application.
- B. Protect installed products from damage from weather, condensation, direct sunlight, construction, and other causes during remainder of the construction period.
- C. Remove and replace panels that are wet, moisture damaged, and mold damaged.
 - 1. Indications that panels are wet or moisture damaged include, but are not limited to, discoloration, sagging, or irregular shape.
 - 2. Indications that panels are mold damaged include, but are not limited to, fuzzy or splotchy surface contamination and discoloration.

END OF SECTION 09 29 00

NOT FOR BIDDING

SECTION 09 51 13 - ACOUSTICAL PANEL CEILINGS

PART 1 - GENERAL

1.1 RELATED DOCUMENTS

- A. Drawings and general provisions of the Contract, including General and Supplementary Conditions and Division 01 Specification Sections, apply to this Section.

1.2 SUMMARY

- A. This Section includes acoustical panels and exposed suspension systems for ceilings.
- B. Related Sections include the following:
 - 1. Division 09 Section "Acoustical Tile Ceilings" for ceilings consisting of mineral-base acoustical tiles used with concealed suspension systems, stapling, or adhesive bonding.
- C. Products furnished, but not installed under this Section, include anchors, clips, and other ceiling attachment devices to be cast in concrete at ceilings.

1.3 DEFINITIONS

- A. AC: Articulation Class.
- B. CAC: Ceiling Attenuation Class.
- C. LR: Light Reflectance Coefficient.
- D. NRC: Noise Reduction Coefficient.

1.4 SUBMITTALS

- A. Product Data: For each type of product indicated.
- B. Coordination Drawings: Reflected ceiling plans, drawn to scale, on which the following items are shown and coordinated with each other, based on input from installers of the items involved:
 - 1. Ceiling suspension system members.
 - 2. Method of attaching hangers to building structure.
 - a. Furnish layouts for cast-in-place anchors, clips, and other ceiling attachment devices whose installation is specified in other Sections.
 - 3. Ceiling-mounted items including lighting fixtures, diffusers, grilles, speakers, sprinklers, access panels, and special moldings.

4. Minimum Drawing Scale: 1/8 inch = 1 foot (1:96).
 - C. Samples for Initial Selection: For components with factory-applied color finishes.
 - D. Samples for Verification: For each component indicated and for each exposed finish required, prepared on Samples of size indicated below.
 1. Acoustical Panel: Set of 6-inch- (150-mm-) square Samples of each type, color, pattern, and texture.
 2. Exposed Suspension System Members, Moldings, and Trim: Set of 12-inch- (300-mm-) long Samples of each type, finish, and color.
 - E. Qualification Data: For testing agency.
 - F. Field quality-control test reports.
 - G. Product Test Reports: Based on evaluation of comprehensive tests performed by a qualified testing agency, for each acoustical panel ceiling.
 - H. Research/Evaluation Reports: For each acoustical panel ceiling and components and anchor and fastener type.
 - I. Maintenance Data: For finishes to include in maintenance manuals.
- 1.5 QUALITY ASSURANCE
- A. Acoustical Testing Agency Qualifications: An independent testing laboratory, or an NVLAP-accredited laboratory, with the experience and capability to conduct the testing indicated. NVLAP-accredited laboratories must document accreditation, based on a "Certificate of Accreditation" and a "Scope of Accreditation" listing the test methods specified.
 - B. Source Limitations:
 1. Acoustical Ceiling Panel: Obtain each type through one source from a single manufacturer.
 2. Suspension System: Obtain each type through one source from a single manufacturer.
 - C. Source Limitations: Obtain each type of acoustical ceiling panel and supporting suspension system through one source from a single manufacturer.
 - D. Seismic Standard: Provide acoustical panel ceilings designed and installed to withstand the effects of earthquake motions according to the following:
 1. Standard for Ceiling Suspension Systems Requiring Seismic Restraint: Comply with ASTM E 580.
 2. UBC Standard 25-2, "Metal Suspension Systems for Acoustical Tile and for Lay-in Panel Ceilings."

1.6 DELIVERY, STORAGE, AND HANDLING

- A. Deliver acoustical panels, suspension system components, and accessories to Project site in original, unopened packages and store them in a fully enclosed, conditioned space where they will be protected against damage from moisture, humidity, temperature extremes, direct sunlight, surface contamination, and other causes.
- B. Before installing acoustical panels, permit them to reach room temperature and a stabilized moisture content.
- C. Handle acoustical panels carefully to avoid chipping edges or damaging units in any way.

1.7 PROJECT CONDITIONS

- A. Environmental Limitations: Do not install acoustical panel ceilings until spaces are enclosed and weatherproof, wet work in spaces is complete and dry, work above ceilings is complete, and ambient temperature and humidity conditions are maintained at the levels indicated for Project when occupied for its intended use.
 - 1. Pressurized Plenums: Operate ventilation system for not less than 48 hours before beginning acoustical panel ceiling installation.

1.8 COORDINATION

- A. Coordinate layout and installation of acoustical panels and suspension system with other construction that penetrates ceilings or is supported by them, including light fixtures, HVAC equipment, fire-suppression system, and partition assemblies.

1.9 EXTRA MATERIALS

- A. Furnish extra materials described below that match products installed and that are packaged with protective covering for storage and identified with labels describing contents.
 - 1. Acoustical Ceiling Panels: Full-size panels equal to 2.0 percent of quantity installed.
 - 2. Suspension System Components: Quantity of each exposed component equal to 1.0 percent of quantity installed.
 - 3. Hold-Down Clips: Equal to 2.0 percent of quantity installed.

PART 2 - PRODUCTS

2.1 ACOUSTICAL PANELS, GENERAL

- A. Acoustical Panel Standard: Provide manufacturer's standard panels of configuration indicated that comply with ASTM E 1264 classifications as designated by types, patterns, acoustical ratings, and light reflectances, unless otherwise indicated.

1. Mounting Method for Measuring NRC: Type E-400; plenum mounting in which face of test specimen is 15-3/4 inches (400 mm) away from test surface per ASTM E 795.
- B. Acoustical Panel Colors and Patterns: Match appearance characteristics indicated for each product type.
 1. Where appearance characteristics of acoustical panels are indicated by referencing pattern designations in ASTM E 1264 and not manufacturers' proprietary product designations, provide products selected by Architect from each manufacturer's full range that comply with requirements indicated for type, pattern, color, light reflectance, acoustical performance, edge detail, and size.

2.2 CEILING TILE – ACT-1

- A. Basis-of-Design Product: Armstrong “Second Look II” 2767. Subject to compliance with requirements, Manufacturer’s meeting the specifications and design intent may be acceptable include, but are not limited to:
 1. BPB USA.
 2. Rockphon
 3. Ecophon CertainTeed, Inc.
 4. Tectum Inc.
- B. Color: White.
- C. LR: Not less than 0.81.
- D. NRC: Not less than 0.55.
- E. CAC: Not less than 35.
- F. Edge/Joint Detail: Beveled Tegalur
- G. Thickness: 3/4 inch
- H. Modular Size: 24 by 48 inches

2.3 METAL SUSPENSION SYSTEMS, GENERAL

- A. Metal Suspension System Standard: Provide manufacturer's standard direct-hung metal suspension systems of types, structural classifications, and finishes indicated that comply with applicable requirements in ASTM C 635.
- B. Finishes and Colors, General: Comply with NAAMM's "Metal Finishes Manual for Architectural and Metal Products" for recommendations for applying and designating finishes. Provide manufacturer's standard factory-applied finish for type of system indicated.
- C. Attachment Devices: Size for five times the design load indicated in ASTM C 635, Table 1, "Direct Hung," unless otherwise indicated. Comply with seismic design requirements.

1. Anchors in Concrete: Anchors of type and material indicated below, with holes or loops for attaching hangers of type indicated and with capability to sustain, without failure, a load equal to five times that imposed by ceiling construction, as determined by testing per ASTM E 488 or ASTM E 1512 as applicable, conducted by a qualified testing and inspecting agency.
 - a. Type: Postinstalled expansion anchors.
 - b. Corrosion Protection: Carbon-steel components zinc plated to comply with ASTM B 633, Class Fe/Zn 5 (0.005 mm) for Class SC 1 service condition.
 - c. Corrosion Protection: Stainless-steel components complying with ASTM F 593 and ASTM F 594, Group 1 Alloy 304 or 316 for bolts; Alloy 304 or 316 for anchor.
 - d. Corrosion Protection: Components fabricated from nickel-copper-alloy rods complying with ASTM B 164 for UNS No. N04400 alloy.
 2. Power-Actuated Fasteners in Concrete: Fastener system of type suitable for application indicated, fabricated from corrosion-resistant materials, with clips or other accessory devices for attaching hangers of type indicated, and with capability to sustain, without failure, a load equal to 10 times that imposed by ceiling construction, as determined by testing per ASTM E 1190, conducted by a qualified testing and inspecting agency.
- D. Wire Hangers, Braces, and Ties: Provide wires complying with the following requirements:
1. Zinc-Coated, Carbon-Steel Wire: ASTM A 641/A 641M, Class 1 zinc coating, soft temper.
 2. Stainless-Steel Wire: ASTM A 583/A 580M, Type 304, nonmagnetic.
 3. Nickel-Copper-Alloy Wire: ASTM B 164, nickel-copper-alloy UNS No. N04400.
 4. Size: Select wire diameter so its stress at 3 times hanger design load (ASTM C 635, Table 1, "Direct Hung") will be less than yield stress of wire, but provide not less than 0.135-inch- (3.5-mm-) diameter wire.
- E. Hanger Rods: steel, zinc coated or protected with rust-inhibitive paint.
- F. Angle Hangers: Angles with legs not less than 7/8 inch (22 mm) wide; formed with 0.04-inch- (1-mm-) thick, galvanized steel sheet complying with ASTM A 653/A 653M, G90 (Z275) coating designation; with bolted connections and 5/16-inch- (8-mm-) diameter bolts.

2.4 METAL SUSPENSION SYSTEM FOR ACOUSTICAL PANEL CEILING

Basis-of-Design Product: Armstrong "Prelude xl 15/16" Subject to compliance with requirements, Manufacturer's meeting the basis of design specifications and design intent may be acceptable include, but are not limited to:

1. BPB USA.
2. Rockphon.
3. Ecophon CertainTeed, Inc.
4. Armstrong World Industries.

2.5 METAL EDGE MOLDINGS AND TRIM

- A. Roll-Formed, Sheet-Metal Edge Moldings and Trim: By ceiling grid manufacturer. Type and profile indicated or, if not indicated, manufacturer's standard moldings for edges and penetrations that comply with seismic design requirements; formed from sheet metal of same material, finish, and color as that used for exposed flanges of suspension system runners.
 - 1. Provide manufacturer's standard edge moldings that fit acoustical panel edge details and suspension systems indicated and that match width and configuration of exposed runners, unless otherwise indicated.

2.6 ACOUSTICAL SEALANT

- A. Available Products: Subject to compliance with requirements, products that may be incorporated into the Work include, but are not limited to, the following:
- B. Products: Subject to compliance with requirements, provide one of the following:
 - 1. Acoustical Sealant for Exposed and Concealed Joints:
 - a. Pecora Corporation; AC-20 FTR Acoustical and Insulation Sealant.
 - b. USG Corporation; SHEETROCK Acoustical Sealant.
 - c. Approved equal.

PART 3 - EXECUTION

3.1 EXAMINATION

- A. Examine substrates, areas, and conditions, including structural framing to which acoustical panel ceilings attach or abut, with Installer present, for compliance with requirements specified in this and other Sections that affect ceiling installation and anchorage and with requirements for installation tolerances and other conditions affecting performance of acoustical panel ceilings.
 - 1. Proceed with installation only after unsatisfactory conditions have been corrected.

3.2 PREPARATION

- A. Measure each ceiling area and establish layout of acoustical panels to balance border widths at opposite edges of each ceiling. Avoid using less-than-half-width panels at borders, and comply with layout shown on reflected ceiling plans.

3.3 INSTALLATION

- A. General: Install acoustical panel ceilings to comply with ASTM C 636 and seismic design requirements indicated, per manufacturer's written instructions and CISCA's "Ceiling Systems Handbook."

- B. Suspend ceiling hangers from building's structural members and as follows:
1. Install hangers plumb and free from contact with insulation or other objects within ceiling plenum that are not part of supporting structure or of ceiling suspension system.
 2. Splay hangers only where required to miss obstructions; offset resulting horizontal forces by bracing, countersplaying, or other equally effective means.
 3. Splay hangers only where required.
 4. Where width of ducts and other construction within ceiling plenum produces hanger spacings that interfere with location of hangers at spacings required to support standard suspension system members, install supplemental suspension members and hangers in form of trapezes or equivalent devices.
 5. Secure wire hangers to ceiling suspension members and to supports above with a minimum of three tight turns. Connect hangers directly either to structures or to inserts, eye screws, or other devices that are secure and appropriate for substrate and that will not deteriorate or otherwise fail due to age, corrosion, or elevated temperatures.
 6. Secure flat, angle, channel, and rod hangers to structure, including intermediate framing members, by attaching to inserts, eye screws, or other devices that are secure and appropriate for both structure to which hangers are attached and type of hanger involved. Install hangers in a manner that will not cause them to deteriorate or fail due to age, corrosion, or elevated temperatures.
 7. Do not support ceilings directly from permanent metal forms or floor deck. Fasten hangers to cast-in-place hanger inserts, postinstalled mechanical or adhesive anchors, or power-actuated fasteners that extend through forms into concrete.
 8. When steel framing does not permit installation of hanger wires at spacing required, install carrying channels or other supplemental support for attachment of hanger wires.
 9. Do not attach hangers to steel deck tabs.
 10. Do not attach hangers to steel roof deck. Attach hangers to structural members.
 11. Space hangers not more than 48 inches (1200 mm) o.c. along each member supported directly from hangers, unless otherwise indicated; provide hangers not more than 8 inches (200 mm) from ends of each member.
 12. Size supplemental suspension members and hangers to support ceiling loads within performance limits established by referenced standards and publications.
- C. Secure bracing wires to ceiling suspension members and to supports with a minimum of four tight turns. Suspend bracing from building's structural members as required for hangers, without attaching to permanent metal forms, steel deck, or steel deck tabs. Fasten bracing wires into concrete with cast-in-place or postinstalled anchors.
- D. Install edge moldings and trim of type indicated at perimeter of acoustical ceiling area and where necessary to conceal edges of acoustical panels.
1. Apply acoustical sealant where indicated in a continuous ribbon concealed on back of vertical legs of moldings before they are installed.
 2. Screw attach moldings to substrate at intervals not more than 16 inches (400 mm) o.c. and not more than 3 inches (75 mm) from ends, leveling with ceiling suspension system to a tolerance of 1/8 inch in 12 feet (3.2 mm in 3.6 m). Miter corners accurately and connect securely.
 3. Do not use exposed fasteners, including pop rivets, on moldings and trim.
- E. Install suspension system runners so they are square and securely interlocked with one another. Remove and replace dented, bent, or kinked members.

- F. Install acoustical panels with undamaged edges and fit accurately into suspension system runners and edge moldings. Scribe and cut panels at borders and penetrations to provide a neat, precise fit.
1. Arrange directionally patterned acoustical panels as follows:
 - a. As indicated on reflected ceiling plans.
 2. For square-edged panels, install panels with edges fully hidden from view by flanges of suspension system runners and moldings.
 3. For reveal-edged panels on suspension system runners, install panels with bottom of reveal in firm contact with top surface of runner flanges.
 4. For reveal-edged panels on suspension system members with box-shaped flanges, install panels with reveal surfaces in firm contact with suspension system surfaces and panel faces flush with bottom face of runners.
 5. Paint cut edges of panel remaining exposed after installation; match color of exposed panel surfaces using coating recommended in writing for this purpose by acoustical panel manufacturer.
 6. Install hold-down clips in areas indicated, in areas required by authorities having jurisdiction, and for fire-resistance ratings; space as recommended by panel manufacturer's written instructions, unless otherwise indicated.
 7. Install clean-room gasket system in areas indicated, sealing each panel and fixture as recommended by panel manufacturer's written instructions.
 8. Protect lighting fixtures and air ducts to comply with requirements indicated for fire-resistance-rated assembly.

3.4 FIELD QUALITY CONTROL

- A. Special Inspections: Engage a qualified special inspector to perform the following special inspections and prepare reports:
1. Suspended ceiling system.
 2. Hangers, anchors and fasteners.
- B. Testing Agency: Owner may engage a qualified testing agency to perform tests and inspections and prepare test reports.
- C. Tests and Inspections: Testing and inspecting of completed installations of acoustical panel ceiling hangers and anchors and fasteners shall take place in successive stages, in areas of extent and using methods as follows. Do not proceed with installations of acoustical panel ceiling hangers for the next area until test results for previously completed installations of acoustical panel ceiling hangers show compliance with requirements.
1. Extent of Each Test Area: When installation of ceiling suspension systems on each floor has reached 20 percent completion but no panels have been installed.
 - a. Within each test area, testing agency will select 1 of every 10 power-actuated fasteners and postinstalled anchors used to attach hangers to concrete and will test them for 200 lbf (890 N) of tension; it will also select one of every 2 postinstalled

anchors used to attach bracing wires to concrete and will test them for 440 lbf (1957 N) of tension.

- b. When testing discovers fasteners and anchors that do not comply with requirements, testing agency will test those anchors not previously tested until 20 pass consecutively and then will resume initial testing frequency.

- D. Remove and replace acoustical panel ceiling hangers and anchors and fasteners that do not pass tests and inspections and retest as specified above.

3.5 CLEANING

- A. Clean exposed surfaces of acoustical panel ceilings, including trim, edge moldings, and suspension system members. Comply with manufacturer's written instructions for cleaning and touchup of minor finish damage. Remove and replace ceiling components that cannot be successfully cleaned and repaired to permanently eliminate evidence of damage.

END OF SECTION 09 51 13

SECTION 09 65 13 - RESILIENT BASE AND ACCESSORIES

PART 1 - GENERAL

1.1 RELATED DOCUMENTS

- A. Drawings and general provisions of the Contract, including General and Supplementary Conditions and Division 01 Specification Sections, apply to this Section.

1.2 SUMMARY

- A. Section Includes:
 - 1. Resilient Rubber Bases
 - 2. Resilient molding accessories
- B. Related Sections:
 - 1. Division 06 Section 064023 Interior Architectural Wood work
 - 2. Division 09 Section 096519 Resilient Tile flooring
 - 3. Division 09 Section 096813 Carpet tile

1.3 SUBMITTALS

- A. Product Data: For each type of product indicated.
- B. Samples for Initial Selection: For each type of product indicated.
- C. Samples for Verification: For each type of product indicated, in manufacturer's standard-size Samples but not less than 12 inches (300 mm) long, of each resilient product color, texture, and pattern required.
- D. Product Schedule: For resilient products: Use same designations indicated on Drawings.
- E. Samples for Initial Selection: For each type of product indicated.
- F. Samples for Verification: For each type of product indicated, in manufacturer's standard-size Samples but not less than 12 inches (300 mm) long, of each resilient product color, texture, and pattern required.
- G. Product Schedule: For resilient products. Use same designations indicated on Drawings.

1.4 QUALITY ASSURANCE

- A. Fire-Test-Response Characteristics: As determined by testing identical products according to ASTM E 648 or NFPA 253 by a qualified testing agency.

1. Critical Radiant Flux Classification: Class I, not less than 0.45 W/sq. cm.

1.5 DELIVERY, STORAGE, AND HANDLING

- A. Store resilient products and installation materials in dry spaces protected from the weather, with ambient temperatures maintained within range recommended by manufacturer, but not less than 50 deg F (10 deg C) or more than 90 deg F (32 deg C).

1.6 PROJECT CONDITIONS

- A. Maintain ambient temperatures within range recommended by manufacturer, but not less than 70 deg F (21 deg C) or more than 95 deg F (35 deg C), in spaces to receive resilient products during the following time periods:
 1. 48 hours before installation.
 2. During installation.
 3. 48 hours after installation.
- B. Until Substantial Completion, maintain ambient temperatures within range recommended by manufacturer, but not less than 55 deg F (13 deg C) or more than 95 deg F (35 deg C)
- C. Install resilient products after other finishing operations, including painting, have been completed.

1.7 EXTRA MATERIALS

- A. Furnish extra materials that match products installed and that are packaged with protective covering for storage and identified with labels describing contents.
 1. Furnish not less than 10 linear feet (3 linear m) > for every 500 linear feet (150 linear m) or fraction thereof, of each type, color, pattern, and size of resilient product installed.

PART 2 - PRODUCTS

2.1 RESILIENT BASE (B-1)

- A. Resilient Base:
 1. Basis of Design Manufacturers: Subject to compliance with requirements, provide Johnsonite traditional Duracove or a comparable product by one of the following:
 - a. Endura Rubber Flooring; Division of Burke Industries, Inc.
 - b. Flexco, Inc.
 - c. Mondo Rubber International, Inc.
 - d. Nora Rubber Flooring; Freudenberg Building Systems, Inc.
 - e. Roppe Corporation, USA.
- B. ASTM F 1861.

- C. Type (Material Requirement): TP (rubber, thermoplastic).
- D. Group (Manufacturing Method): I (solid, homogeneous).
- E. Style: Cove (with top-set toe) unless noted otherwise.
- F. Minimum Thickness: 1/8" (ASTM F386)
- G. Height: 4"
- H. Lengths: Coils in manufacturer's standard length.
- I. Outside Corners: Premolded.90 degree
- J. Surface: Smooth.
- K. Color: as indicated on Finish Legend.

2.2 RESILIENT BASE (MB-1)

- A. Resilient Base:
 - 1. Basis of Design Manufacturers: Subject to compliance with requirements, provide Johnsonite Millwork Wallbase Reveal MW-XX-F or a comparable product by one of the following:
 - a. Endura Rubber Flooring; Division of Burke Industries, Inc.
 - b. Flexco, Inc.
 - c. Mondo Rubber International, Inc.
 - d. Nora Rubber Flooring; Freudenberg Building Systems, Inc.
 - e. Roppe Corporation, USA.
- B. Wall Base: ASTM F 1861.
- C. Type (Material Requirement): TP (rubber, thermoplastic).
- D. Group (Manufacturing Method): I (solid, homogeneous).
- E. Style: Reveal
- F. Minimum Thickness: 0.375"
- G. Height: 6"
- H. Lengths: Coils in manufacturer's standard length.
- I. Outside Corners: Premolded.
- J. Inside Corners: Premolded.
- K. Surface: Smooth.

- L. Color: as indicated on Finish Legend.

2.3 RESILIENT MOLDING ACCESSORY

A. Resilient Molding Accessory:

1. Manufacturers: Subject to compliance with requirements, provide Johnsonite or a comparable product by one of the following:
 - a. Burke Mercer Flooring Products; Division of Burke Industries, Inc.
 - b. Flexco, Inc.
 - c. Roppe Corporation, USA.

B. Description: Transition and joiner strips as described herein and as indicated on drawings, including but not limited to:

1. Johnsonite #RRS-80-C (1/8" to floor) or approved equal
2. Johnsonite #CTA-80-H (1/4" to 1/8")
3. Johnsonite #CTA-80-K (3/8" to 1/8")
4. Floor Reducer strips.

C. Material: Rubber.

D. Profile and Dimensions: As indicated.

E. Colors and Patterns: As indicated in the Finish Legend.

2.4 INSTALLATION MATERIALS

A. Trowelable Leveling and Patching Compounds: Latex-modified, portland cement based or blended hydraulic-cement-based formulation provided or approved by manufacturer for applications indicated.

B. Adhesives: Water-resistant type recommended by manufacturer to suit resilient products and substrate conditions indicated.

1. Use adhesives that comply with the following limits for VOC content when calculated according to 40 CFR 59, Subpart D (EPA Method 24):
 - a. Cove Base Adhesives: Not more than 50 g/L.
 - b. Rubber Floor Adhesives: Not more than 60 g/L.

C. Floor Movement Joint: Schluter Model DILEX-KS, low profile stainless steel, model EKSB. Size for depth of flooring material; locate as indicated and where resilient flooring is installed across floor construction joints subject to movement.

D. Metal Edge Strips: Extruded aluminum with mill finish of width shown, of height required to protect exposed edges of tiles, and in maximum available lengths to minimize running joints.

- E. Floor Polish: Provide protective liquid floor polish products as recommended by resilient stair tread manufacturer.

PART 3 - EXECUTION

3.1 EXAMINATION

- A. Examine substrates, with Installer present, for compliance with requirements for maximum moisture content and other conditions affecting performance of the Work.
- B. Verify that finishes of substrates comply with tolerances and other requirements specified in other Sections and that substrates are free of cracks, ridges, depressions, scale, and foreign deposits that might interfere with adhesion of resilient products.
- C. Proceed with installation only after unsatisfactory conditions have been corrected.

3.2 PREPARATION

- A. Prepare substrates according to manufacturer's written instructions to ensure adhesion of resilient products.
- B. Do not install resilient products until they are same temperature as the space where they are to be installed.
 - 1. Move resilient products and installation materials into spaces where they will be installed at least 48 hours in advance of installation.
- C. Sweep and vacuum clean substrates to be covered by resilient products immediately before installation.

3.3 RESILIENT BASE INSTALLATION

- A. Comply with manufacturer's written instructions for installing resilient base.
- B. Apply resilient base to walls, columns, pilasters, casework and cabinets in toe spaces, and other permanent fixtures in rooms and areas where base is required.
- C. Install resilient base in lengths as long as practicable without gaps at seams and with tops of adjacent pieces aligned.
- D. Tightly adhere resilient base to substrate throughout length of each piece, with base in continuous contact with horizontal and vertical substrates.
- E. Do not stretch resilient base during installation.
- F. On masonry surfaces or other similar irregular substrates, fill voids along top edge of resilient base with manufacturer's recommended adhesive filler material.

- G. Preformed Corners: Install preformed corners before installing straight pieces.
- H. Job-Formed Corners:
 - 1. Outside Corners: Use straight pieces of maximum lengths possible. Form without producing discoloration (whitening) at bends.
 - 2. Inside Corners: Use straight pieces of maximum lengths possible.

3.4 RESILIENT ACCESSORY INSTALLATION

- A. Comply with manufacturer's written instructions for installing resilient accessories.
- B. Resilient Molding Accessories: Butt to adjacent materials and tightly adhere to substrates throughout length of each piece. Install reducer strips at edges of carpet resilient floor covering that would otherwise be exposed.

3.5 CLEANING AND PROTECTION

- A. Comply with manufacturer's written instructions for cleaning and protection of resilient products.
- B. Perform the following operations immediately after completing resilient product installation:
 - 1. Remove adhesive and other blemishes from exposed surfaces.
 - 2. Sweep and vacuum surfaces thoroughly.
 - 3. Damp-mop surfaces to remove marks and soil.
- C. Protect resilient products from nicks, marks, indentations, and other damage from construction operations and placement of equipment and fixtures during remainder of construction period.
- D. Floor Polish: Remove soil, visible adhesive, and surface blemishes from resilient stair treads before applying liquid floor polish.
 - 1. Apply three coat(s).
- E. Cover resilient products until Substantial Completion.

END OF SECTION 09 65 13

SECTION 09 65 19 - RESILIENT TILE FLOORING

PART 1 - GENERAL

1.1 RELATED DOCUMENTS

- A. Drawings and general provisions of the Contract, including General and Supplementary Conditions and Division 01 Specification Sections, apply to this Section.

1.2 SUMMARY

- A. Section Includes:
 - 1. Luxury Vinyl tile (LVT)
 - 2. Vinyl composition floor tile (VCT)
- B. Related Sections:
 - 1. Division 09 Section "Resilient Base and Accessories" for resilient base, reducer strips, and other accessories installed with resilient floor coverings.
 - 2. Division 09 Section "Resilient Sheet Flooring" for resilient sheet floor coverings.

1.3 SUBMITTALS

- A. Product Data: For each type of product indicated.
- B. Shop Drawings: For each type of floor tile. Include floor tile layouts, edges, columns, doorways, enclosing partitions, built-in furniture, cabinets, and cutouts.
 - 1. Show details of special patterns.
- C. Samples for Initial Selection: For each type of floor tile indicated.
- D. Samples for Verification: Full-size units of each color and pattern of floor tile required.
 - 1. For heat-welding bead, manufacturer's standard-size Samples, but not less than 9 inches (230 mm) long, of each color required.
- E. Seam Samples: For seamless-installation technique indicated and for each flooring product, color, and pattern required; with seam running lengthwise and in center of 6-by-9-inch (150-by-230-mm) Sample applied to a rigid backing and prepared by Installer for this Project.
- F. Product Schedule: For floor tile. Use same designations indicated on Drawings.
- G. Qualification Data: For qualified Installer.
- H. Maintenance Data: For each type of floor tile to include in maintenance manuals.

1.4 QUALITY ASSURANCE

- A. Installer Qualifications: A qualified installer who employs workers for this Project who are competent in techniques required by manufacturer for floor tile installation and seaming method indicated.
 - 1. Engage an installer who employs workers for this Project who are trained or certified by manufacturer for installation techniques required.
- B. Fire-Test-Response Characteristics: As determined by testing identical products according to ASTM E 648 or NFPA 253 by a qualified testing agency.
 - 1. Critical Radiant Flux Classification: Class I, not less than 0.45 W/sq. cm.

1.5 DELIVERY, STORAGE, AND HANDLING

- A. Store floor tile and installation materials in dry spaces protected from the weather, with ambient temperatures maintained within range recommended by manufacturer, but not less than 50 deg F (10 deg C) or more than 90 deg F (32 deg C). Store floor tiles on flat surfaces.

1.6 PROJECT CONDITIONS

- A. Maintain ambient temperatures within range recommended by manufacturer, but not less than 70 deg F (21 deg C) or more than 95 deg F (35 deg C), in spaces to receive floor tile during the following time periods:
 - 1. 48 hours before installation.
 - 2. During installation.
 - 3. 48 hours after installation.
- B. Until Substantial Completion, maintain ambient temperatures within range recommended by manufacturer, but not less than 55 deg F (13 deg C) or more than 95 deg F (35 deg C).
- C. Close spaces to traffic during floor tile installation.
- D. Close spaces to traffic for 48 hours after floor tile installation.
- E. Install floor tile after other finishing operations, including painting, have been completed.

1.7 EXTRA MATERIALS

- A. Furnish extra materials that match products installed and that are packaged with protective covering for storage and identified with labels describing contents.
 - 1. Floor Tile: Furnish 1 box for every 50 boxes or fraction thereof, of each type, color, and pattern of floor tile installed.

PART 2 - PRODUCTS

2.1 LUXURY VINYL TILE (LVT-1).

- A. Basis of Design: Subject to compliance with requirements, provide Armstrong Flooring; Natural Creations Luxury Vinyl Tile or a comparable product by one of the following:
 - 1. Shaw Contract Flooring, a Division of Berkshire Hathaway, Inc.
 - 2. J+J Flooring, a Division of Engineered Floors, LLC
 - 3. Tarkett, S.A
- B. Description: A layered construction consisting of a tough, clear, rigid vinyl wear layer protecting a high-fidelity print layer on a solid vinyl backing. Protected by a diamond-infused UV-cured polyurethane finish, the wear surface is embossed with different textures to enhance each of the printed visuals. Colors are insoluble in water and resistant to cleaning agents and light.
- C. Reference specification - ASTM F 1700, "Standard Specification for Solid Vinyl Tile", Class III, Type B – Embossed Surface. Meets requirements for size, squareness, thickness, thickness of wear layer, residual indentation, resistance to chemicals, resistance to light and resistance to heat.
- D. Pattern and Color: Refer to Finish Legend.
- E. Size: [6 in. x 36 in. (152 mm x 914 mm)]
- F. Wear layer thickness: 0.020 in. (0.5 mm).
- G. Thickness: 0.125 in. (3.2 mm).

2.2 STATIC DISSIPATIVE TILE (SDT-1)

- A. Basis of Design: Subject to compliance with requirements, provide Armstrong Flooring; Excelon SDT Static Dissipative Tile or a comparable product by one of the following:
 - 1. Roppe Corporation
 - 2. StaticWorx, Inc.
- B. Description: Static dissipative vinyl tile composed of polyvinyl chloride resin, plasticizers, fillers, pigments, and antistatic additive with colors and texture dispersed uniformly throughout its thickness.
- C. Tile shall meet size, thickness, indentation, impact, deflection, dimensional stability, resistance to chemicals, squareness, and resistance to heat requirements of ASTM F 1066 Standard Specification for Vinyl Composition Tile, Class 2, through pattern.
- D. Pattern and Color: As indicated in Finish Legend
- E. Size: 12 inch x 12 inch (305 mm x 305 mm)

- F. Thickness: 1/8 inch (3.2 mm)
- G. Wear Layer: 1/8 inch (3.2 mm)

2.3 VINYL COMPOSITION FLOOR TILE (VCT-1)

- A. Basis of Design: Subject to compliance with requirements, provide Armstrong Flooring; Standard Excelon Imperial Texture Tile Flooring or a comparable product by one of the following:
 - 1. Azrock
 - 2. Tarkett, Inc. (Basis of Design)
 - 3. Mannington Mills, Inc.
- B. Description: Tile composed of polyvinyl chloride resin, plasticizers, fillers, stabilizers and pigments with colors and texture dispersed uniformly throughout its entire thickness.
- C. Vinyl composition tile shall conform to the requirements of ASTM F 1066, "Standard Specification Vinyl Composition Floor Tile", Class 2, through-pattern.
- D. Wearing Surface: Smooth.
- E. Pattern and Color: As indicated in Finish Legend
- A. Size: 12 inch x 12 inch (305 mm x 305 mm)
- B. Thickness: 1/8 inch (3.2 mm)
- C. Wear Layer: 1/8 inch (3.2 mm)

2.4 INSTALLATION MATERIALS

- A. Trowelable Leveling and Patching Compounds: Latex-modified, portland cement based or blended hydraulic-cement-based formulation provided or approved by manufacturer for applications indicated.
- B. Adhesives: Water-resistant type recommended by manufacturer to suit floor tile and substrate conditions indicated.
 - 1. Use adhesives that comply with the following limits for VOC content when calculated according to 40 CFR 59, Subpart D (EPA Method 24):
 - a. VCT and Asphalt Tile Adhesives: Not more than 50 g/L.
 - b. Rubber Floor Adhesives: Not more than 60 g/L.
- C. Seamless-Installation Accessories:
 - 1. Heat-Welding Bead: Manufacturer's solid-strand product for heat welding seams.
 - a. Color: Match floor tile.

2. Chemical-Bonding Compound: Manufacturer's product for chemically bonding seams.
 - a. Use chemical-bonding compound that has a VOC content of 350 g/L or less when calculated according to 40 CFR 59, Subpart D (EPA Method 24).
- D. Floor Polish: Provide protective liquid floor polish products as recommended by manufacturer.
 1. Use sealant that has a VOC content of not more than 250 g/L when calculated according to 40 CFR 59, Subpart D (EPA Method 24).
 2. Joint-Sealant Color: Match floor tile.
- E. Metal Transition Strips: Angle or L-shape, height to match tile and setting-bed thickness, metallic or combination of metal and PVC or neoprene base, designed specifically for flooring applications, stainless steel; ASTM A 666, 300 Series exposed-edge material.
 1. Carpet Tile to Resinous Floor/VCT:
 - a. Basis of Design: Schluter; Reno-U
 - b. Size: Provide manufacturer recommended size for edge protection.
 - c. Color: Architect to select from full range of colors.
 2. Rubber Flooring/LVT to Resinous Flooring:
 - a. Basis of Design: Schluter; Vinpro-U
 - b. Size: Provide manufacturer recommended size for edge protection.
 - c. Color: Architect to select from full range of colors
 3. Same height material LVT to VCT:
 - a. Basis of Design: Schluter; Schiene
 - b. Size: Provide manufacturer recommended size for edge protection.
 - c. Color: Architect to select from full range of colors

PART 3 - EXECUTION

3.1 EXAMINATION

- A. Examine substrates, with Installer present, for compliance with requirements for maximum moisture content and other conditions affecting performance of the Work.
- B. Verify that finishes of substrates comply with tolerances and other requirements specified in other Sections and that substrates are free of cracks, ridges, depressions, scale, and foreign deposits that might interfere with adhesion of floor tile.
- C. Proceed with installation only after unsatisfactory conditions have been corrected.

3.2 PREPARATION

- A. Prepare substrates according to manufacturer's written instructions to ensure adhesion of resilient products.
- B. Concrete Substrates: Prepare according to ASTM F 710.
 - 1. Verify that substrates are dry and free of curing compounds, sealers, and hardeners.
 - 2. Remove substrate coatings and other substances that are incompatible with adhesives and that contain soap, wax, oil, or silicone, using mechanical methods recommended by manufacturer. Do not use solvents.
 - 3. Alkalinity and Adhesion Testing: Perform tests recommended by manufacturer. Proceed with installation only after substrates pass testing.
 - 4. Moisture Testing: Perform tests recommended by manufacturer and as follows. Proceed with installation only after substrates pass testing.
 - a. Perform anhydrous calcium chloride test, ASTM F 1869. Proceed with installation only after substrates have maximum moisture-vapor emission rate of 3 lb of water/1000 sq. ft. (1.36 kg of water/92.9 sq. m) in 24 hours.
 - b. Perform relative humidity test using in situ probes, ASTM F 2170. Proceed with installation only after substrates have a maximum 75% relative humidity level measurement.
- C. Access Flooring Panels: Remove protective film or oil or other coating using method recommended by access flooring manufacturer.
- D. Fill cracks, holes, and depressions in substrates with trowelable leveling and patching compound and remove bumps and ridges to produce a uniform and smooth substrate.
- E. Do not install floor tiles until they are same temperature as space where they are to be installed.
 - 1. Move resilient products and installation materials into spaces where they will be installed at least 48 hours in advance of installation.
- F. Sweep and vacuum clean substrates to be covered by resilient products immediately before installation.

3.3 FLOOR TILE INSTALLATION

- A. Comply with manufacturer's written instructions for installing floor tile.
- B. Lay out floor tiles from center marks established with principal walls, discounting minor offsets, so tiles at opposite edges of room are of equal width. Adjust as necessary to avoid using cut widths that equal less than one-half tile at perimeter.
 - 1. Lay tiles square with room axis and in pattern indicated.
- C. Match floor tiles for color and pattern by selecting tiles from cartons in the same sequence as manufactured and packaged, if so numbered. Discard broken, cracked, chipped, or deformed tiles.

1. Lay tiles with grain running in one direction.
- D. Scribe, cut, and fit floor tiles to butt neatly and tightly to vertical surfaces and permanent fixtures including built-in furniture, cabinets, pipes, outlets, and door frames.
- E. Extend floor tiles into toe spaces, door reveals, closets, and similar openings. Extend floor tiles to center of door openings.
- F. Maintain reference markers, holes, and openings that are in place or marked for future cutting by repeating on floor tiles as marked on substrates. Use chalk or other nonpermanent, nonstaining marking device.
- G. Install floor tiles on covers for telephone and electrical ducts, building expansion-joint covers, and similar items in finished floor areas. Maintain overall continuity of color and pattern between pieces of tile installed on covers and adjoining tiles. Tightly adhere tile edges to substrates that abut covers and to cover perimeters.
- H. Adhere floor tiles to flooring substrates using a full spread of adhesive applied to substrate to produce a completed installation without open cracks, voids, raising and puckering at joints, telegraphing of adhesive spreader marks, and other surface imperfections.
- I. Seamless Installation:
 1. Heat-Welded Seams: Comply with ASTM F 1516. Rout joints and heat weld with welding bead to permanently fuse sections into a seamless floor covering. Prepare, weld, and finish seams to produce surfaces flush with adjoining floor covering surfaces.
 2. Chemically Bonded Seams: Bond seams with chemical-bonding compound to permanently fuse sections into a seamless floor covering. Prepare seams and apply compound to produce tightly fitted seams without gaps, overlays, or excess bonding compound on floor covering surfaces.

3.4 CLEANING AND PROTECTION

- A. Comply with manufacturer's written instructions for cleaning and protection of floor tile.
- B. Perform the following operations immediately after completing floor tile installation:
 1. Remove adhesive and other blemishes from exposed surfaces.
 2. Sweep and vacuum surfaces thoroughly.
 3. Damp-mop surfaces to remove marks and soil.
- C. Protect floor tile products from marks, marks, indentations, and other damage from construction operations and placement of equipment and fixtures during remainder of construction period.
- D. Floor Polish: Remove soil, visible adhesive, and surface blemishes from floor tile surfaces before applying liquid floor polish.
 1. Apply three coat(s).

- E. Joint Sealant: Apply sealant to resilient terrazzo floor tile perimeter and around columns, at door frames, and at other joints and penetrations.
- F. Sealers and Finish Coats: Remove soil, visible adhesive, and surface blemishes from resilient terrazzo floor tile surfaces before applying liquid cleaners, sealers, and finish products.
 - 1. Sealer: Apply two base coats of liquid sealer.
 - 2. Finish: Apply three coats of liquid floor finish.
- G. Cover floor tile until Substantial Completion.

END OF SECTION 09 65 19

NOT FOR BIDDING

SECTION 09 68 13 - CARPET TILE

PART 1 - GENERAL

1.1 RELATED DOCUMENTS

- A. Drawings and general provisions of the Contract, including General and Supplementary Conditions and Division 1 Specification Sections, apply to this Section.

1.2 SUMMARY

- A. This Section includes modular, tufted carpet tile.
- B. Related Sections include the following:
 - 1. Division 9 Section "Resilient Tile Flooring, Resilient Base and Accessories" for resilient wall base and accessories installed with carpet tile

1.3 SUBMITTALS

- A. Product Data: For each type of product indicated. Include manufacturer's written data on physical characteristics, durability, and fade resistance. Include installation recommendations for each type of substrate.
- B. Shop Drawings: Show the following:
 - 1. Columns, doorways, enclosing walls or partitions, built-in cabinets, and locations where cutouts are required in carpet tiles.
 - 2. Existing flooring materials to be removed.
 - 3. Existing flooring materials to remain.
 - 4. Carpet tile type, color, and dye lot.
 - 5. Type of subfloor.
 - 6. Type of installation.
 - 7. Pattern of installation.
 - 8. Pattern type, location, and direction.
 - 9. Pile direction.
 - 10. Type, color, and location of insets and borders.
 - 11. Type, color, and location of edge, transition, and other accessory strips.
 - 12. Transition details to other flooring materials.
- C. Samples: For each of the following products and for each color and texture required. Label each Sample with manufacturer's name, material description, color, pattern, and designation indicated on Drawings and in schedules.
 - 1. Carpet Tile: Full-size Sample.
 - 2. Exposed Edge, Transition, and other Accessory Stripping: 12-inch- (300-mm-) long Samples.

- D. Product Schedule: For carpet tile. Use same designations indicated on Drawings.
- E. Qualification Data: For Installer.
- F. Product Test Reports: Based on evaluation of comprehensive tests performed by a qualified testing agency.
- G. Maintenance Data: For carpet tiles to include in maintenance manuals. Include the following:
 - 1. Methods for maintaining carpet tile, including cleaning and stain-removal products and procedures and manufacturer's recommended maintenance schedule.
 - 2. Precautions for cleaning materials and methods that could be detrimental to carpet tile.
- H. Warranty: Special warranty specified in this Section.

1.4 QUALITY ASSURANCE

- A. Installer Qualifications: An experienced installer who is certified by the Floor Covering Installation Board or who can demonstrate compliance with its certification program requirements.
- B. Fire-Test-Response Characteristics: Provide products with the critical radiant flux classification indicated in Part 2, as determined by testing identical products per ASTM E 648 by an independent testing and inspecting agency acceptable to authorities having jurisdiction.
- C. Mockups: Before installing carpet tile, build mockups to verify selections made under sample submittals and to demonstrate aesthetic effects and set quality standards for materials and execution.
 - 1. Approved mockups may become part of the completed Work if undamaged at time of Substantial Completion.
- D. Preinstallation Conference: Conduct conference at Project site to comply with requirements in Division 1 Section "Project Management and Coordination."

1.5 DELIVERY, STORAGE, AND HANDLING

- A. Comply with CRI 104 Section 5, "Storage and Handling."

1.6 PROJECT CONDITIONS

- A. Comply with CRI 104, Section 7.2, "Site Conditions; Temperature and Humidity" and Section 7.12, "Ventilation."
- B. Environmental Limitations: Do not install carpet tiles until wet work in spaces is complete and dry, and ambient temperature and humidity conditions are maintained at the levels indicated for Project when occupied for its intended use.
- C. Do not install carpet tiles over concrete slabs until slabs have cured and are sufficiently dry to bond with adhesive and concrete slabs have pH range recommended by carpet tile manufacturer.
- D. Where demountable partitions or other items are indicated for installation on top of carpet tiles, install carpet tiles before installing these items.

1.7 WARRANTY

- A. Special Warranty for Carpet Tiles: Manufacturer's standard form in which manufacturer agrees to repair or replace components of carpet tile installation that fail in materials or workmanship within specified warranty period.
1. Warranty does not include deterioration or failure of carpet tile due to unusual traffic, failure of substrate, vandalism, or abuse.
 2. Failures include, but are not limited to, more than 10 percent loss of face fiber, edge raveling, snags, runs, loss of tuft bind strength, dimensional stability, excess static discharge, and delamination.
 3. Warranty Period: 10 years from date of Substantial Completion.

1.8 EXTRA MATERIALS

- A. Furnish extra materials described below, before installation begins, that match products installed and that are packaged with protective covering for storage and identified with labels describing contents.
1. Carpet Tile: Full-size units equal to 5 percent of amount installed for each type indicated, but not less than 10 sq. yd. (8.3 sq. m).

PART 2 - PRODUCTS

2.1 CARPET TILE – CT-1

- A. Manufacturers: Basis-of-Design Product: Subject to compliance with requirements, provide Shaw Carpet Tile, "Shine Tile" or a comparable product by one of the following:
1. Mannington Commercial
 2. Interface
 3. Bently
 4. Lees
- B. Color: See Finish Legend
- C. Pattern: See Finish Legend
- D. Fiber System: Duracolor.
- E. Nylon Type: Antron Legacy.
- F. Dye Method: Solution dyed/Space dyed.
- G. Pile Characteristic: Textured multi-colored Loop
- H. Density: 7286.
- I. Pile Thickness: .084" (2.13 mm).
- J. Stitches per inch: 9.8 per inch (38.5 8/10 cm).
- K. Gauge: 1/2" (47 rows per 10 cm).
- L. Face Weight: 17.0 oz/ per sq. yd. (576 g/m2)
- M. Primary Backing/Backcoating: EcoFlex ICT.
- N. Antimicrobial Treatment: Manufacturer's standard material.
- O. Size: 24" x 24"
- P. Protective Treatment: DuraTech.

Q. Performance Characteristics: As follows:

1. Critical Radiant Flux Classification: Not less than 0.45 W/sq. cm.
2. Dry Breaking Strength: Not less than 100 lbf (445 N) per ASTM D 2646.
3. Tuft Bind: Not less than 3 lbf (13 N) per ASTM D 1335.
4. Delamination: Not less than 3.5 lbf/in. (15 N/mm) per ASTM D 3936.
5. Dimensional Tolerance: Within 1/32 inch (0.8 mm) of specified size dimensions, as determined by physical measurement.
6. Dimensional Stability: 0.2 percent or less per ISO 2551 (Aachen Test).
7. Resistance to Insects: Comply with AATCC 24.
8. Colorfastness to Crocking: Not less than 4, wet and dry, per AATCC 165.
9. Colorfastness to Light: Not less than 4 after 40 AFU (AATCC fading units) per AATCC 16, Option E.
10. Antimicrobial Activity: Not less than 2-mm halo of inhibition for gram-positive bacteria; not less than 1-mm halo of inhibition for gram-negative bacteria; no fungal growth; per AATCC 174.
11. Electrostatic Propensity: Less than 3.5 kV per AATCC 134.
12. Environmental Requirements: Provide carpet tile that complies with testing and product requirements of Carpet and Rug Institute's "Green Label Plus" program.

2.2 CARPET TILE – CT-1

A. Manufacturers: Basis-of-Design Product: Subject to compliance with requirements, provide Shaw Carpet Tile, “Allure Tile” or a comparable product by one of the following:

1. Mannington Commercial
2. Interface
3. Bently
4. Lees

B. Color: See Finish Legend

C. Pattern: See Finish Legend

D. Fiber System: Duracolor.

E. Nylon Type: Antron Legacy.

F. Dye Method: Solution dyed/Space dyed.

G. Pile Characteristics: Textured multi-colored Loop

H. Density: 7280

I. Pile Thickness: .084” (2.13 mm).

J. Stitches per inch: 9.8 per inch (38.5 8/10 cm).

K. Gauge: ½” (47 rows per 10 cm).

L. Face Weight: 17.0 oz/ per sq. yd. (576 g/m2)

M. Primary Backing/Backcoating: EcoFlex ICT.

N. Antimicrobial Treatment: Manufacturer's standard material.

O. Size: 24” x 24”

P. Protective Treatment: DuraTech.

Q. Performance Characteristics: As follows:

1. Critical Radiant Flux Classification: Not less than 0.45 W/sq. cm.
2. Dry Breaking Strength: Not less than 100 lbf (445 N) per ASTM D 2646.
3. Tuft Bind: Not less than 3 lbf (13 N) per ASTM D 1335.
4. Delamination: Not less than 3.5 lbf/in. (15 N/mm) per ASTM D 3936.

5. Dimensional Tolerance: Within 1/32 inch (0.8 mm) of specified size dimensions, as determined by physical measurement.
6. Dimensional Stability: 0.2 percent or less per ISO 2551 (Aachen Test).
7. Resistance to Insects: Comply with AATCC 24.
8. Colorfastness to Crocking: Not less than 4, wet and dry, per AATCC 165.
9. Colorfastness to Light: Not less than 4 after 40 AFU (AATCC fading units) per AATCC 16, Option E.
10. Antimicrobial Activity: Not less than 2-mm halo of inhibition for gram-positive bacteria; not less than 1-mm halo of inhibition for gram-negative bacteria; no fungal growth; per AATCC 174.
11. Electrostatic Propensity: Less than 3.5 kV per AATCC 134.
12. Environmental Requirements: Provide carpet tile that complies with testing and product requirements of Carpet and Rug Institute's "Green Label Plus" program.

2.3 CARPET TILE – CT-3 (WALK-OFF CARPET)

- A. Manufacturers: Basis-of-Design Product: Subject to compliance with requirements, provide Interface Flor, Entry Level #1290102500 or a comparable product by one of the following:

1. Mannington Commercial
2. Lees Commercial
3. Bentley
4. Atlas
5. Shaw

- B. Manufacturer: Interface Flor
Product Name / style: Entry Level
Product Number: 1290102500
Color: As indicated on Finish Legend.
Product Construction: Tufted Textured Loop
Yarn System: 100% Solution Dyed
Tufted Yarn Weight: 28 oz./sq. yd.
Pile Height: .22 in.
Pile Thickness: .15 in.
Pile Density: 6720
Size: 19.69 in X 19.69 in (50 cm X 50 cm)
Radiant Panel: (ASTM E-648) Class 1
Smoke Density: (ASTM E-662) <450
Lightfastness: (AATCC 16-E) >4.0 @ 60 AFU's
Static: (AATCC – 134) < 3.0 KV
Backing: Graphlar Tile
Gauge: 1/12 in.
Stitches: 10/in.
Installation Method: Monolithic

2.4 INSTALLATION ACCESSORIES

- A. Trowelable Leveling and Patching Compounds: Latex-modified, hydraulic-cement-based formulation provided or recommended by carpet tile manufacturer.

- B. Adhesives: Water-resistant, mildew-resistant, non-staining, pressure-sensitive type to suit products and subfloor conditions indicated, that complies with flammability requirements for installed carpet tile and is recommended by carpet tile manufacturer for releasable installation.
 - 1. VOC Limits: Provide adhesives with VOC content not more than 50 g/L when calculated according to 40 CFR 59, Subpart D (EPA method 24).

PART 3 - EXECUTION

3.1 EXAMINATION

- A. Examine substrates, areas, and conditions, with Installer present, for compliance with requirements for maximum moisture content, alkalinity range, installation tolerances, and other conditions affecting carpet tile performance. Examine carpet tile for type, color, pattern, and potential defects.
- B. Concrete Subfloors: Verify that concrete slabs comply with ASTM F 710 and the following:
 - 1. Slab substrates are dry and free of curing compounds, sealers, hardeners, and other materials that may interfere with adhesive bond. Determine adhesion and dryness characteristics by performing bond and moisture tests recommended by carpet tile manufacturer.
 - 2. Subfloor finishes comply with requirements specified in Division 3 Section "Cast-in-Place Concrete" for slabs receiving carpet tile.
 - 3. Subfloors are free of cracks, ridges, depressions, scale, and foreign deposits.
- C. Proceed with installation only after unsatisfactory conditions have been corrected.

3.2 PREPARATION

- A. General: Comply with CRI 104, Section 6.2, "Site Conditions; Floor Preparation," and with carpet tile manufacturer's written installation instructions for preparing substrates indicated to receive carpet tile installation.
- B. Use trowelable leveling and patching compounds, according to manufacturer's written instructions, to fill cracks, holes, depressions, and protrusions in substrates. Fill or level cracks, holes and depressions 1/8 inch (3 mm) wide or wider and protrusions more than 1/32 inch (0.8 mm), unless more stringent requirements are required by manufacturer's written instructions.
- C. Remove coatings, including curing compounds, and other substances that are incompatible with adhesives and that contain soap, wax, oil, or silicone, without using solvents. Use mechanical methods recommended in writing by carpet tile manufacturer.
- D. Clean metal substrates of grease, oil, soil and rust, and prime if directed by adhesive manufacturer. Rough sand painted metal surfaces and remove loose paint. Sand aluminum surfaces, to remove metal oxides, immediately before applying adhesive.
- E. Broom and vacuum clean substrates to be covered immediately before installing carpet tile.

3.3 INSTALLATION

- A. General: Comply with CRI 104, Section 14, "Carpet Modules," and with carpet tile manufacturer's written installation instructions.
- B. Installation Method: As recommended in writing by carpet tile manufacturer.
- C. Maintain dye lot integrity. Do not mix dye lots in same area.
- D. Cut and fit carpet tile to butt tightly to vertical surfaces, permanent fixtures, and built-in furniture including cabinets, pipes, outlets, edgings, thresholds, and nosings. Bind or seal cut edges as recommended by carpet tile manufacturer.
- E. Extend carpet tile into toe spaces, door reveals, closets, open-bottomed obstructions, removable flanges, alcoves, and similar openings.
- F. Maintain reference markers, holes, and openings that are in place or marked for future cutting by repeating on finish flooring as marked on subfloor. Use nonpermanent, nonstaining marking device.
- G. Install pattern parallel to walls and borders.
- H. Stagger joints of carpet tiles so carpet tile grid is offset from access flooring panel grid. Do not fill seams of access flooring panels with carpet adhesive; keep seams free of adhesive.

3.4 CLEANING AND PROTECTION

- A. Perform the following operations immediately after installing carpet tile:
 - 1. Remove excess adhesive, seam sealer, and other surface blemishes using cleaner recommended by carpet tile manufacturer.
 - 2. Remove yarns that protrude from carpet tile surface.
 - 3. Vacuum carpet tile using commercial machine with face-beater element.
- B. Protect installed carpet tile to comply with CRI 104, Section 16, "Protection of Indoor Installations."
- C. Protect carpet tile against damage from construction operations and placement of equipment and fixtures during the remainder of construction period. Use protection methods indicated or recommended in writing by carpet tile manufacturer.

END OF SECTION 09 68 13

SECTION 09 91 00 - PAINTING

PART 1 - GENERAL

1.1 RELATED DOCUMENTS

- A. Drawings and general provisions of the Contract, including General and Supplementary Conditions and Division 1 Specification Sections, apply to this Section.
- B. This Section includes surface preparation and the application of paint systems on the following exterior substrates:
 - 1. Concrete.
 - 2. Gypsum Board.
 - 3. Steel.
 - 4. Galvanized metal.
 - 5. Aluminum (not anodized or otherwise coated).
 - 6. Wood.
 - 7. Mechanical and electrical work (MEP)
- C. Related Sections include the following:
 - 1. Division 3 Sections "Concrete" for sealers of concrete flatwork.
 - 2. Division 5 Sections for shop priming of metal substrates with primers specified in this Section.
 - 3. Division 6 Sections for shop priming carpentry with primers specified in this Section.

1.4 SUBMITTALS

- A. Product Data: For each type of product indicated.
- C. Samples for Initial Selection: Upon request, for each type of topcoat product indicated.
- D. Samples for Verification: For each type of paint system and each color and gloss of topcoat indicated.
 - 1. Submit Samples on rigid backing, 8 inches (200 mm) square.
 - 2. Step coats on Samples to show each coat required for system.
 - 3. Label each coat of each Sample.
 - 4. Label each Sample for location and application area.
 - 5. Label each sample as to date painted.
- E. Product List: For each product indicated, include the following:
 - 1. Cross-reference to paint system and locations of application areas. Use same designations indicated on Drawings and in schedules.
 - 2. Printout of current "MPI Approved Products List" for each product category specified in Part 2, with the proposed product highlighted.

1.5 QUALITY ASSURANCE

A. MPI Standards:

1. Products: Complying with MPI standards indicated and listed in "MPI Approved Products List."
2. Preparation and Workmanship: Comply with requirements in "MPI Architectural Painting Specification Manual" for products and paint systems indicated.

B. Mockups: Apply benchmark samples of each paint system indicated and each color and finish selected to verify preliminary selections made under sample submittals and to demonstrate aesthetic effects and set quality standards for materials and execution.

1.6 DELIVERY, STORAGE, AND HANDLING

A. Store materials not in use in tightly covered containers in well-ventilated areas with ambient temperatures continuously maintained at not less than 45 deg F (7 deg C).

1. Maintain containers in clean condition, free of foreign materials and residue.
2. Remove rags and waste from storage areas daily.

1.7 PROJECT CONDITIONS

A. Apply paints only when temperature of surfaces to be painted and ambient air temperatures are between 50 and 95 deg F (10 and 35 deg C).

B. Do not apply paints in snow, rain, fog or mist; when relative humidity exceeds 85 percent; at temperatures less than 5 deg F (3 deg C) above the dew point; or to damp or wet surfaces.

1.8 EXTRA MATERIALS

A. Furnish extra materials described below that are from same production run (batch mix) as materials applied and that are packaged for storage and identified with labels describing contents. Furnish an additional 2 percent, but not less than 1 gal. of each material and color applied.

PART 2 - PRODUCTS

2.1 MANUFACTURERS

A. Basis of Manufacturers (Interior Gypsum Wall Finishes): Subject to compliance with requirements, provide products by one of the following:

1. Sherwin-Williams Company (Basis of Design).
2. Benjamin Moore & Co.
3. Duron, Inc.
4. Finnaren & Haley Inc (F&H)
5. M.A.B. Paints.

6. Architect approved equal.

2.2 PAINT, GENERAL

A. Material Compatibility:

1. Provide materials for use within each paint system that are compatible with one another and substrates indicated, under conditions of service and application as demonstrated by manufacturer, based on testing and field experience.
2. For each coat in a paint system, provide products recommended in writing by manufacturers of topcoat for use in paint system and on substrate indicated.

B. VOC Content of Field-Applied Interior Paints and Coatings: Provide products that comply with the following limits for VOC content, exclusive of colorants added to a tint base, when calculated according to 40 CFR 59, Subpart D (EPA Method 24); these requirements do not apply to paints and coatings that are applied in a fabrication or finishing shop:

1. Flat Paints, Coatings, and Primers: VOC content of not more than 50 g/L.
2. Non-flat Paints, Coatings, and Primers: VOC content of not more than 150 g/L.
3. Anti-Corrosive and Anti-Rust Paints Applied to Ferrous Metals: VOC not more than 250 g/L.
4. Floor Coatings: VOC not more than 100 g/L.
5. Shellacs, Clear: VOC not more than 750 g/L.
6. Shellacs, Pigmented: VOC not more than 550 g/L.

C. Colors: Match Architect's samples or as indicated in a color schedule.

- o P-1: Sherwin Williams #SW Color as indicated on Finish Legend.
- o P-2: Sherwin Williams #SW Color as indicated on Finish Legend.
- o P-3: Sherwin Williams #SW Color as indicated on Finish Legend.
- o P-4: Sherwin Williams #SW Color as indicated on Finish Legend.
- o P-5: Sherwin Williams #SW Color as indicated on Finish Legend.
- o P-6: Sherwin Williams B71W00211 – Bond-Plex Waterbased Acrylic Coating – Color to Match Ex. Courtyard Paint (2 Coats)
- o P-7: Sherwin Williams B66W00651 – Pro Industrial High Performance Acrylic – Color to Match Ex. Courtyard Paint

2.3 BLOCK FILLERS

A. Interior/Exterior Latex Block Filler: MPI #4.

1. VOC Content: E Range of E2.

B. Epoxy Block Filler: MPI #116.

1. VOC Content: E Range of E2.

2.4 PRIMERS/SEALERS

- A. Alkali-Resistant Primer: MPI #3: Factory-formulated water based, alkali-resistant acrylic-latex interior primer for interior plaster applications.
 - 1. VOC Content: E Range of E2.
- B. Exterior Primer under Acrylic Finishes: Factory-formulated acrylic-based primer for exterior application. Provide breathable primer at masonry locations.
 - 1. VOC Content: E Range of E2.
 - 2. Benjamin Moore; Moore's IMC Acrylic Metal Primer No. M04: Applied at a dry film thickness of not less than 2.0 mils.
 - 3. M. A. B. Paint; Rust-O-Lastic Hydro-Prime II Acrylic (DTM) Maintenance Primer 073-189: Applied at a dry film thickness of not less than 2.0 mils.
- C. Interior Latex Primer/Sealer: MPI #50.
 - 1. VOC Content: E Range of E2.
 - 2. Environmental Performance Rating: EPR 2.
- D. Interior Alkyd Primer/Sealer: MPI #45.
 - 1. VOC Content: E Range of E2.
- E. Wood-Knot Sealer: Sealer recommended in writing by topcoat manufacturer for use in paint systems indicated.

2.5 METAL PRIMERS

- A. Alkyd Anticorrosive Metal Primer: MPI #79.
 - 1. VOC Content: E Range of E2.
- B. Waterborne Galvanized-Metal Primer: MPI #134.
 - 1. VOC Content: E Range of E2.
- C. Quick-Drying Primer for Aluminum: MPI #95.
 - 1. VOC Content: E Range of E2.
- D. Rust-Inhibitive Primer (Water Based): MPI #107.
 - 1. VOC Content: E Range of E2.
 - 2. Environmental Performance Rating: EPR 2.
- E. Vinyl Wash Primer: MPI #80.

2.6 WOOD PRIMERS

- A. Exterior Latex Wood Primer: MPI #6.
 - 1. VOC Content: E Range of E2.
- B. Exterior Alkyd Wood Primer: MPI #5.
 - 1. VOC Content: E Range of E2.
- C. Interior Latex-Based Wood Primer: MPI #39.
 - 1. VOC Content: E Range of E2.
 - 2. Environmental Performance Rating: EPR 2.

2.7 EPOXY PAINT

- A. Water-Based Epoxy (Interior and Exterior): MPI #215. A water based, two component epoxy type, semi-gloss finish coating. Subject to compliance with requirements, provide one of the following:
 - 1. Benjamin Moore; M43/M44- 84 Acrylic Epoxy Semi-Gloss.
 - 2. M. A. B. Paint; Ply-Tile 530 Water-Reducible Acrylic Epoxy Semi-Gloss.
- B. Water-Based Epoxy (Interior and Exterior): MPI #115. A water based, two component epoxy type, Gloss finish coating. Subject to compliance with requirements, provide one of the following:
 - 1. Benjamin Moore & Co.; Acrylic Epoxy Gloss "A", Hardener "B", M43/M44.
 - 2. ICI Paints; Devco Coatings, Tru Glaze WB Epoxy Gloss Coating, 4408/4418
 - 3. Porter Paints; Dura-Glaze WB, Gloss Epoxy, 9371.
 - 4. PPG Architectural Finishes, Inc.; Aquapon, Waterborne Epoxy, 98-1/98-98.
 - 5. Sherwin-Williams Company (The); Industrial & Marine, Water Based Catalyzed Epoxy, B70W Series.

2.8 ALKYD PAINTS

- A. Exterior Alkyd Enamel (Flat): MPI #8 (Gloss Level 1).
 - 1. VOC Content: E Range of E1.
- B. Exterior Alkyd Enamel (Semi-gloss): MPI #94 (Gloss Level 5).
 - 1. VOC Content: E Range of E1.
- C. Exterior Alkyd Enamel (Gloss): MPI #9 (Gloss Level 6).
 - 1. VOC Content: E Range of E1.
- D. Interior Alkyd (Flat): MPI #49 (Gloss Level 1).

1. VOC Content: E Range of E1.
 - E. Interior Alkyd (Eggshell): MPI #51 (Gloss Level 3).
 1. VOC Content: E Range of E1.
 - F. Interior Alkyd (Semi-gloss): MPI #47 (Gloss Level 5).
 1. VOC Content: E Range of E1.
 - G. Interior Alkyd (Gloss): MPI #48 (Gloss Level 6).
 1. VOC Content: E Range of E1.
- 2.9 ACRYLIC-RESIN COATING.
- A. Breathable cement masonry paint formulated with colorfast pigments for use over cement plaster or masonry substrates. Include manufacturer's recommended primers. Coating shall be mildew resistant and breathable with perm rating of not less than .15 per ASTM E 96.
 1. Thoro Products, "Thorosheen" or equal.
 2. Primer: Thoroseal 1000.
 3. Texture: smooth
- 2.10 LATEX PAINTS
- A. Interior Latex (Flat): MPI #53 (Gloss Level 1).
 1. VOC Content: E Range of E1.
 2. Environmental Performance Rating: EPR 1.5.
 - B. Interior Latex (Low Sheen): MPI #44 (Gloss Level 2).
 1. VOC Content: E Range of E1.
 2. Environmental Performance Rating: EPR 2.
 - C. Interior Latex (Eggshell): MPI #52 (Gloss Level 3).
 1. VOC Content: E Range of E1.
 2. Environmental Performance Rating: EPR 2.
 - D. Interior Latex (Satin): MPI #43 (Gloss Level 4).
 1. VOC Content: E Range of E1.
 2. Environmental Performance Rating: EPR 2.
 - E. Interior Latex (Semi-gloss): MPI #54 (Gloss Level 5).
 1. VOC Content: E Range of E1.
 2. Environmental Performance Rating: EPR 2.

- F. Interior Latex (Gloss): MPI #114 (Gloss Level 6, except minimum gloss of 65 units at 60 deg).
 - 1. VOC Content: E Range of E1.
 - 2. Environmental Performance Rating: EPR 2.
- G. Exterior Acrylic Latex (Flat): MPI #10 (Gloss Level 1).
 - 1. VOC Content: E Range of E1.
- H. Exterior Acrylic Latex (Semi-gloss): MPI #11 (Gloss Level 5).
 - 1. VOC Content: E Range of E1.

2.11 DRY FOG/FALL COATINGS

- A. Flat, Latex Dry Fog/Fall (MPI #118): Provide a water-based, emulsion-type, fast-drying coating used on overhead metal and other surfaces for application methods by airless and/or conventional spray equipment. Overspray will dry to a sweepable powder over a short distance for easier clean up.
 - 1. VOC Content: E Range of E1.
- B. Flat Dry-Fall for Galvanized Steel (water based) MPI # 133: Provide a waterborne coating, designed for direct application to cleaned, interior overhead galvanized metal surfaces, for application methods by airless and/or conventional spray equipment. Overspray will dry to a sweepable powder over a short distance for easier clean up.
 - 1. VOC Content: E Range of E1.

PART 3 - EXECUTION

3.1 EXAMINATION

- A. Examine substrates and conditions, with Applicator present, for compliance with requirements for maximum moisture content and other conditions affecting performance of work.
- B. Maximum Moisture Content of Substrates: When measured with an electronic moisture meter as follows:
 - 1. Concrete: 12 percent.
 - 2. Masonry (Clay and CMU): 12 percent.
 - 3. Wood: 15 percent.
 - 4. Plaster: 12 percent.
 - 5. Gypsum Board: 12 percent.
- C. Verify suitability of substrates, including surface conditions and compatibility with existing finishes and primers.
- D. Begin coating application only after unsatisfactory conditions have been corrected and surfaces are dry.

1. Beginning coating application constitutes Contractor's acceptance of substrates and conditions.

3.2 PREPARATION

- A. Comply with manufacturer's written instructions and recommendations in "MPI Architectural Painting Specification Manual" applicable to substrates and paint systems indicated.
- B. Remove plates, machined surfaces, and similar items already in place that are not to be painted. If removal is impractical or impossible because of size or weight of item, provide surface-applied protection before surface preparation and painting.
 1. After completing painting operations, use workers skilled in the trades involved to reinstall items that were removed. Remove surface-applied protection if any.
 2. Do not paint over labels of independent testing agencies or equipment name, identification, performance rating, or nomenclature plates.
- C. Clean substrates of substances that could impair bond of paints, including dirt, oil, grease, and incompatible paints and encapsulants.
 1. Remove incompatible primers and re-prime substrate with compatible primers as required to produce paint systems indicated.
 2. Use abrasive blast-cleaning methods if recommended by paint manufacturer.
 3. Determine alkalinity and moisture content of surfaces by performing appropriate tests. If surfaces are sufficiently alkaline to cause the finish paint to blister and burn, correct this condition before application. Do not paint surfaces if moisture content exceeds that permitted in manufacturer's written instructions.
 4. Clean concrete floors to be painted with a 5 percent solution of muriatic acid or other etching cleaner. Flush the floor with clean water to remove acid, neutralize with ammonia, rinse, allow to dry, and vacuum before painting.
- D. Concrete Masonry Substrates: Remove efflorescence and chalk. Do not paint surfaces if moisture content or alkalinity of surfaces to be painted exceeds that permitted in manufacturer's written instructions.
- E. Steel Substrates: Remove rust and loose mill scale. Clean using methods recommended in writing by paint manufacturer.
- F. Ferrous Metals: Clean un-galvanized ferrous-metal surfaces that have not been shop coated; remove oil, grease, dirt, loose mill scale, and other foreign substances. Use solvent or mechanical cleaning methods that comply with SSPC's recommendations.
 1. Blast steel surfaces clean as recommended by paint system manufacturer and according to SSPC-SP 6/NACE No. 3.
 2. Treat bare and sandblasted or pickled clean metal with a metal treatment wash coat before priming.
 3. Touch up bare areas and shop-applied prime coats that have been damaged. Wire-brush, clean with solvents recommended by paint manufacturer, and touch up with same primer as the shop coat.

- G. Galvanized-Metal Substrates: Remove grease and oil residue from galvanized sheet metal fabricated from coil stock by mechanical methods to produce clean, lightly etched surfaces that promote adhesion of subsequently applied paints.
- H. Wood Substrates:
 - 1. Scrape and clean knots, and apply coat of knot sealer before applying primer.
 - 2. Sand surfaces that will be exposed to view, and dust off.
 - 3. Prime edges, ends, faces, undersides, and backsides of wood.
 - 4. After priming, fill holes and imperfections in the finish surfaces with putty or plastic wood filler. Sand smooth when dried.
- I. Plaster Substrates: Do not begin paint application until plaster is fully cured and dry.

3.3 APPLICATION

- A. Apply paints according to manufacturer's written instructions.
 - 1. Use applicators and techniques suited for paint and substrate indicated.
 - 2. Paint surfaces behind movable items same as similar exposed surfaces. Before final installation, paint surfaces behind permanently fixed items with prime coat only.
- B. Tint each undercoat a lighter shade to facilitate identification of each coat if multiple coats of same material are to be applied. Tint undercoats to match color of topcoat, but provide sufficient difference in shade of undercoats to distinguish each separate coat.
- C. If undercoats or other conditions show through topcoat, apply additional coats until cured film has a uniform paint finish, color, and appearance.
- D. Apply paints to produce surface films without cloudiness, spotting, holidays, laps, brush marks, roller tracking, runs, sags, ropiness, or other surface imperfections. Cut in sharp lines and color breaks.
- E. Application Procedures: Apply paints and coatings by brush, roller, spray, or other applicators according to manufacturer's written instructions.
 - 1. Brushes: Use brushes best suited for type of material applied. Use brush of appropriate size for surface or item being painted.
 - 2. Rollers: Use rollers of carpet, velvet-back, or high-pile sheep's wool as recommended by manufacturer for material and texture required.
 - 3. Spray Equipment: Use airless spray equipment with orifice size as recommended by manufacturer for material and texture required.
- F. Minimum Coating Thickness: Apply paint materials no thinner than manufacturer's recommended spreading rate to achieve dry film thickness indicated. Provide total dry film thickness of the entire system as recommended by manufacturer.
- G. Overhead Structure and Exposed Ceiling Steel and Galvanized-Metal Substrates:
 - 1. Prep substrate as required minimum. Repair existing primed surfaces.
 - 2. Galvanized surface shall be prepared by either solvent cleaning and test for chromate passivation, with an SSPC SP 7 Brush-off blast cleaning if required or chemical-etching cleaners may be substituted for solvent washing and SSPC-SP 7 cleaning.
 - 3. Apply primer coat to unprimed surfaces.

4. Paint exposed metal deck, structural steel, conduit, un-insulated ductwork and piping, and other mechanical and electrical work in finish and occupied rooms. Protect surfaces not to be painted. Dry-Fall painting shall not be required in mechanical-electrical equipment, custodial, storage and similar rooms.
- H. Exterior Mechanical and Electrical Work: Painting of mechanical and electrical work is limited to items exposed on exterior of building, excluding roof mounted mechanical and electrical work. Items to be painted include, but are not limited to, the following:
 1. Un-insulated metal and plastic piping, including hangers and supports.
 2. Louvers, grilles, vents unless pre-finished.
 3. Mechanical equipment that is indicated to have a factory-primed finish for field painting.
 4. Conduit and junction boxes.
 5. Electrical equipment that is indicated to have a factory-primed finish for field painting.
 6. Do not paint unless noted otherwise.
 - a. Pre-finished mechanical equipment and items
 - b. pipe and duct insulation
 - c. Pre-finished electrical devices and/or cover plates
 - d. Electrical fixtures
 - e. Name plates
 - f. Moving parts
 7. Touch up damaged finishes, including field applied and pre-finished surfaces.
- I. Interior Mechanical and Electrical Work: Unless otherwise noted, painting of mechanical and electrical work is limited to items exposed to view in finished spaces as defined herein.
 1. Locations where MEP work to be field painted include following
 - a. Occupied or Finished spaces are to include all rooms and other spaces with suspended drywall or plaster ceiling, including toilet rooms and storage rooms. Also stairs, classroom and other rooms used by students
 - b. Occupied or Finished Spaces with ceilings – Paint all exposed MEP work as described herein exposed to view.
 - c. Occupied or Finished Spaces without ceilings - Paint all exposed MEP work as described herein exposed to view, including the structure above - unless noted otherwise.
 - d. Occupied or Finished Spaces without ceilings (i.e., Egress Stairs, Gym, and Stage house), partial ceilings, and where indicated.
 - e. Unless noted otherwise, painting of MEP work is not required of Unfinished or unoccupied spaces include mechanical and electrical equipment rooms (rooms whose primary purpose is to house HVAC or other MEP equipt), elevator equipment rooms, IT equipt and MDF rooms, storage rooms without finish ceilings, shafts and chases.
 2. Items to be painted include, but are not limited to, the following:
 - a. Duct, equipment, and pipe insulation having cotton or canvas insulation covering or other paintable jacket material.
 - b. Un-insulated metal and plastic piping

- c. Piping hangers and supports.
 - d. Louvers grilles vents unless pre-finished
 - e. Mechanical equipment that is indicated to have a factory-primed finish for field painting.
 - f. Electrical equipment that is indicated to have a factory-primed finish for field painting.
 - g. Conduit and junction boxes, including metallic and PVC materials, fire alarm, BAS, attachments exposed and semi-exposed to view in finish areas
 - h. Electrical and control panels in finish areas and exposed to view
3. Do not paint, unless noted otherwise.
- a. Pre-finished mechanical equipment and items
 - b. pipe and duct insulation
 - c. Pre-finished electrical devices and/or cover plates
 - d. Electrical fixtures
 - e. Name places
 - f. Moving parts
 - g. Sight exposed interior of ductwork and other equipment
4. Touch up damaged finishes, including field applied and pre-finished surfaces.

3.4 CLEANING AND PROTECTION

- A. At end of each workday, remove rubbish, empty cans, rags, and other discarded materials from Project site.
- B. After completing paint application, clean spattered surfaces. Remove spattered paints by washing, scraping, or other methods. Do not scratch or damage adjacent finished surfaces.
- C. Protect work of other trades against damage from paint application. Correct damage to work of other trades by cleaning, repairing, replacing, and refinishing, as approved by Architect, and leave in an undamaged condition.
- D. At completion of construction activities of other trades, touch up and restore damaged or defaced painted surfaces.

3.5 EXTERIOR PAINTING SCHEDULE

- A. CMU Substrates:
 - 1. Latex System: MPI EXT 4.2A.
 - a. Prime Coat: Interior/exterior latex block filler.
 - b. Intermediate Coat: Exterior latex matching topcoat.
 - c. Topcoat: Exterior latex (semi-gloss).
 - 2. Latex Over Alkali-Resistant Primer System: MPI EXT 4.2L.
 - a. Prime Coat: Alkali-resistant primer.
 - b. Intermediate Coat: Exterior latex matching topcoat.
 - c. Topcoat: Exterior latex (semi-gloss).

B. Galvanized-Metal Substrates:

1. Water-Based Light Industrial Coating System:

- a. Prime Coat: Primer, galvanized metal, as recommended in writing by topcoat manufacturer for exterior use on galvanized-metal substrates with topcoat indicated.
- b. Intermediate Coat: Light industrial coating, exterior, water based, matching topcoat.
- c. Topcoat: Light industrial coating, exterior, water based (Semi-gloss unless noted otherwise)

C. Aluminum Substrates:

1. Water-Based Light Industrial Coating System:

- a. Prime Coat: Primer, quick dry, for aluminum, **MPI #95.**
- b. Intermediate Coat: Light industrial coating, exterior, water based, matching topcoat.
- c. Topcoat: Light industrial coating, exterior, water based (Semi-gloss unless noted otherwise)

D. Steel Substrates:

1. Water-Based Light Industrial Coating System:

- a. Prime Coat: Primer, alkyd, anti-corrosive for metal, **MPI #79.**
- b. Intermediate Coat: Light industrial coating, exterior, water based, matching topcoat.
- c. Topcoat: Light industrial coating, exterior, water based (Semi-gloss unless noted otherwise)

3.6 INTERIOR PAINTING SCHEDULE

A. Steel Substrates:

1. Alkyd System: MPI INT 5.1E.

- a. Prime Coat: Quick-drying alkyd metal primer where required
- b. Intermediate Coat: Interior alkyd matching topcoat.
- c. Topcoat: Interior alkyd (Semi-gloss unless noted otherwise)

2. Water-Based Dry-Fall System: MPI INT 5.1C.

- a. Prime Coat: Quick-drying alkyd metal primer where required.
- b. Topcoat: Waterborne dry fall.

B. Galvanized-Metal Substrates:

1. Water-Based Dry-Fall System: MPI INT 5.3H.

- a. Prime Coat: Waterborne dry fall where required
 - b. Topcoat: Waterborne dry fall.
- 2. Alkyd System: MPI INT 5.3C.
 - a. Prime Coat: Cementitious galvanized-metal primer.
 - b. Intermediate Coat: Interior alkyd matching topcoat.
 - c. Topcoat: Interior alkyd (Semi-gloss unless noted otherwise).
- C. Wood Substrates: Including wood trim, architectural woodwork and windows.
 - 1. Latex System:
 - a. Prime Coat: Primer, latex, for interior wood, MPI #39.
 - b. Intermediate Coat: Latex, interior, matching topcoat.
 - c. Topcoat: Latex, interior, semi-gloss, (Gloss Level 5), MPI #144.
 - 2. Institutional Low-Odor/VOC Latex System:
 - a. Prime Coat: Primer, latex, for interior wood, MPI #39.
 - b. Intermediate Coat: Latex, interior, institutional low odor/VOC, matching topcoat.
 - c. Topcoat: Latex, interior, institutional low odor/VOC, semi-gloss (Gloss Level 5), MPI #147.
- D. Dressed Lumber Substrates: Including architectural woodwork.
 - 1. Latex System: MPI INT 6.3T.
 - a. Prime Coat: Interior latex-based wood primer.
 - b. Intermediate Coat: Interior latex matching topcoat.
 - c. Topcoat: Interior latex (semi-gloss).
- E. Gypsum Board Substrates:
 - 1. Latex System: MPI INT 9.2A.
 - a. Prime Coat: Interior latex primer/sealer
 - b. Intermediate Coat: Interior latex matching topcoat.
 - c. Topcoat: Interior latex. (Refer to finish schedule for gloss level.)
- F. Cotton or Canvas Insulation-Covering Substrates: Including pipe and duct coverings
 - 1. Alkyd Over Latex Primer System: MPI INT 10.1B.
 - a. Prime Coat: Interior latex primer/sealer.
 - b. Intermediate Coat: Interior alkyd matching topcoat.
 - c. Topcoat: Interior alkyd (Flat)

END OF SECTION 09 91 00

SECTION 10 44 00 - FIRE-PROTECTION SPECIALTIES

PART 1 - GENERAL

1.1 RELATED DOCUMENTS

- A. Drawings and general provisions of the Contract, including General and Supplementary Conditions and Division 1 Specification Sections, apply to this Section.

1.2 SUMMARY

- A. This Section includes the following:
 - 1. Portable fire extinguishers.
 - 2. Fire extinguishers cabinets
 - 3. Mounting brackets for fire extinguishers.

1.3 SUBMITTALS

- A. Product Data: Include construction details, material descriptions, dimensions of individual components and profiles, and finishes for fire-protection cabinets.
 - 1. Fire Extinguishers: Include rating and classification.
 - 2. Fire-Protection Cabinets: Include roughing-in dimensions, details showing mounting methods, relationships of box and trim to surrounding construction, door hardware, and cabinet type, trim style, and panel style.
- B. Maintenance Data: For fire extinguishers to include in maintenance manuals.

1.4 QUALITY ASSURANCE

- A. Source Limitations: Obtain fire extinguishers and fire-protection cabinets each through one source from a single manufacturer.
- B. NFPA Compliance: Fabricate and label fire extinguishers to comply with NFPA 10, "Portable Fire Extinguishers."
- C. Fire Extinguishers: Listed and labeled for type, rating, and classification by an independent testing agency acceptable to authorities having jurisdiction. Provide fire extinguishers approved, listed, and labeled by FMG.

1.5 COORDINATION

- A. Coordinate size of fire-protection cabinets to ensure that type and capacity of fire extinguishers indicated are accommodated.

1.6 WARRANTY

- A. Special Warranty: Manufacturer's standard form in which manufacturer agrees to repair or replace components of portable fire extinguishers that fail in materials or workmanship within specified warranty period.
 - 1. Failures include, but are not limited to, the following:
 - a. Failure of hydrostatic test according to NFPA 10.
 - b. Faulty operation of valves or release levers.
 - 2. Warranty Period: Six years from date of Substantial Completion.

PART 2 - PRODUCTS

2.1 PORTABLE FIRE EXTINGUISHERS

- A. Available Manufacturers:
 - 1. JL Industries, Inc.
 - 2. Larsen's Manufacturing Company.
 - 3. Modern Metal Products
 - 4. Strike First
- B. Multipurpose Dry-Chemical Type in cabinet or bracket: UL-rated min. 2A, 10 BC, nominal capacity, with monoammonium phosphate-based dry chemical in enameled-steel container with indicating gage and hose.

2.2 FIRE-PROTECTION CABINETS

- A. Basis of Design: JL Industries/Activar "Cosmopolitan" stainless steel semi-recessed with vertical vision lite. Products by other manufacturers meeting the specifications including design intent may be substituted. Manufacturers include, but are not limited to
 - 1. Larsen's Manufacturing Company
 - 2. Modern Metal Products
 - 3. Strike First Corporation
- B. Cabinets Tub: Sized to accommodate submitted fire extinguisher. Cold rolled steel with white powder coated finish Provide factory-drilled mounting holes. Provide fire rated cabinets where located in rated walls
- C. Doors and trim: #4 stainless steel, 2- 1/2" rolled edge continuous hinge and manufacturer standard handle and catch
- D. Door Glazing to be vertical lite clear tempered float glass.
- E. Identification: Lettering complying with authorities having jurisdiction for letter style, size, spacing, and location. Glass-mounted decal to be vertical vinyl red lettering. Identify bracket-mounted fire extinguishers with the words "FIRE EXTINGUISHER" in vertical red letter decals applied to mounting surface.

2.3 FINISHES, GENERAL

- A. Comply with Name's "Metal Finishes Manual for Architectural and Metal Products" for recommendations for applying and designating finishes.
- B. Protect mechanical finishes on exposed surfaces from damage by applying a strippable, temporary protective covering before shipping.
- C. Finish fire-protection cabinets after assembly.
- D. Appearance of Finished Work: Variations in appearance of abutting or adjacent pieces are acceptable if they are within one-half of the range of approved Samples. Noticeable variations in the same piece are not acceptable. Variations in appearance of other components are acceptable if they are within the range of approved Samples and are assembled or installed to minimize contrast.

2.4 STEEL FINISHES

- A. Surface Preparation: Clean surfaces of dirt, oil, grease, mill scale, rust, and other contaminants that could impair paint bond using manufacturer's standard methods.
- B. Stainless Steel: No. 4 finish

2.5 SCHEDULE of FIRE-PROTECTION SPECIALTIES

FE #1: Cabinet mounted
FE #2: Bracket mounted

PART 3 - EXECUTION

3.1 EXAMINATION

- A. Examine walls and partitions for suitable framing depth and blocking where recessed cabinets will be installed. Examine fire extinguishers for proper charging and tagging. Remove and replace damaged, defective, or undercharged units. Proceed with installation only after unsatisfactory conditions have been corrected.

3.2 PREPARATION

- A. Prepare recesses for recessed fire-protection cabinets as required by type and size of cabinet and trim style.

3.3 INSTALLATION

- A. General: Install fire-protection specialties in locations and at mounting heights indicated or, if not indicated, at heights acceptable to authorities having jurisdiction. Fire-Protection Cabinets: Fasten fire-protection cabinets to structure, square and plumb.

1. Unless otherwise indicated, provide recessed fire-protection cabinets. If wall thickness is not adequate for recessed cabinets, provide semi-recessed fire-protection cabinets.
 2. Provide inside latch and lock for break-glass panels.
 3. Fasten mounting brackets to inside surface of fire-protection cabinets, square and plumb.
- B. Mounting Brackets: Fasten mounting brackets to surfaces, square and plumb, at locations indicated.
- C. Identification: Apply vinyl lettering at locations indicated.
- D. Mounting height: Recessed and semi-recessed cabinets to be 56" (verify) to top of rough-in opening above finish floor.

3.4 ADJUSTING AND CLEANING

- A. Remove temporary protective coverings and strippable films, if any, as fire-protection specialties are installed, unless otherwise indicated in manufacturer's written installation instructions.
- B. Adjust fire-protection cabinet doors to operate easily without binding. Verify that integral locking devices operate properly.
- C. On completion of fire-protection cabinet installation, clean interior and exterior surfaces as recommended by manufacturer.
- D. Touch up marred finishes, or replace fire-protection cabinets that cannot be restored to factory-finished appearance. Use only materials and procedures recommended or furnished by fire-protection cabinet manufacturer.
- E. Replace fire-protection cabinets that have been damaged or have deteriorated beyond successful repair by finish touchup or similar minor repair procedures.

END OF SECTION 10 44 00

SECTION 12 24 13 - ROLLER WINDOW SHADES

PART 1 - GENERAL

1.1 RELATED DOCUMENTS

- A. Drawings and general provisions of the Contract, including General and Supplementary Conditions and Division 01 Specification Sections, apply to this Section.

1.2 SUMMARY

- A. Section Includes:

- 1. Manual roller shades with single rollers.
 - 2. Motorized roller shades with double rollers.
 - 3. Networked Shade Controller

- B. Related Requirements:

- 1. Division 06 Section "Miscellaneous Rough Carpentry" for wood blocking and grounds for mounting roller shades and accessories.

1.3 ACTION SUBMITTALS

- A. Product Data: For each type of product.

- 1. Include styles, material descriptions, construction details, dimensions of individual components and profiles, features, finishes, and operating instructions for roller shades.

- B. Shop Drawings: Show fabrication and installation details for roller shades, including shadeband materials, their orientation to rollers, and their seam and batten locations.

- C. Motor-Operated Shades: Include details of installation and diagrams for power, signal, and control wiring.

- D. Coordination Drawings: Reflected ceiling plans, drawn to scale, on which the following items are shown and coordinated with each other, based on input from installers of the items involved:

- 1. Ceiling suspension system members and attachment to building structure.
 - 2. Ceiling-mounted or penetrating items including light fixtures, air outlets and inlets, speakers, sprinklers, recessed shades, and special moldings at walls, column penetrations, and other junctures of acoustical ceilings with adjoining construction.
 - 3. Shade mounting assembly and attachment.
 - 4. Size and location of access to shade operator and adjustable components.
 - 5. Minimum Drawing Scale: 1/8 inch = 1 foot (1:96).

- E. Samples for Initial Selection: For each type and color of shadeband material.

- 1. Include samples of accessories involving color selection.

- F. Samples for Verification: For each type of roller shade.
 - 1. Shadeband Material: Not less than 10 inches (250 mm) square. Mark inside face of material if applicable.
 - 2. Roller Shade: Full-size operating unit, not less than 12 inches wide by 12 inches long for each type of roller shade indicated.
 - 3. Installation Accessories: Full-size unit, not less than 10 inches (250 mm) long.
- G. Roller-Shade Schedule: Use same designations indicated on Drawings.

1.4 INFORMATIONAL SUBMITTALS

- A. Qualification Data: For Installer.
- B. Product Certificates: For each type of shadeband material, signed by product manufacturer.
- C. Product Test Reports:
 - 1. Fire-Test-Response Characteristics: Passes NFPA 701-99 small and large-scale vertical burn. Materials tested shall be identical to products proposed for use.
 - 2. Electrical Components: NFPA Article 100 listed and labeled by either UL or ETL or other testing agency acceptable to authorities having jurisdiction, marked for intended use, and tested as a system. Individual testing of components will not be acceptable in lieu of system testing.
 - 3. Anti-Microbial Characteristics: 'No Growth' per ASTM G 21 results for fungi ATCC9642, ATCC 9644, ATCC9645.

1.5 CLOSEOUT SUBMITTALS

- A. Maintenance Data: For roller shades to include in maintenance manuals.

1.6 MAINTENANCE MATERIAL SUBMITTALS

- A. Furnish extra materials that match products installed and that are packaged with protective covering for storage and identified with labels describing contents.
 - 1. Roller Shades:
 - a. Fabric equal to 5 percent of quantity installed for each color, and shadeband material indicated.
 - b. Brackets equal to 5 percent of quantity installed for each type on project.
 - c. Motors equal to 5 percent of quantity installed for each type on project.

1.7 QUALITY ASSURANCE

- A. Installer Qualifications: Installer trained and certified by the manufacturer having at least ten years experience installing products comparable to those specified in this section.

1.8 WARRANTY

- A. Roller Shade Hardware and Shadecloth: Manufacturer's standard non-depreciating twenty-five year limited warranty.
- B. Roller Shade Motors and Motor Control Systems: Manufacturer's standard non-depreciating five year warranty extended to eight years if turnkey wired.
- C. Roller Shade Installation: One year from date of substantial completion, not including scaffolding, lifts and other means of access.

1.9 DELIVERY, STORAGE, AND HANDLING

- A. Deliver roller shades in factory packages, marked with manufacturer, product name, and location of installation using same designations indicated on Drawings.

1.10 FIELD CONDITIONS

- A. Environmental Limitations: Do not install roller shades until construction and finish work in spaces, including painting, is complete and dry and ambient temperature and humidity conditions are maintained at the levels indicated for Project when occupied for its intended use.
- B. Field Measurements: Where roller shades are indicated to fit to other construction, verify dimensions of other construction by field measurements before fabrication and indicate measurements on Shop Drawings. Allow clearances for operating hardware of operable glazed units through entire operating range. Notify Architect of installation conditions that vary from Drawings. Coordinate fabrication schedule with construction progress to avoid delaying the Work.

PART 2 - PRODUCTS

2.1 ROLLER SHADE MANUFACTURERS

- A. Basis-of-Design Manufacturer: MechoShade Systems, LLC.
 - 1. Manual Shade Assembly:
 - Mecho/5 Shade System
 - 2. Motorized Shade Assembly:
 - a) ElectroShade Electro/2 DoubleShade
- B. See Rollershade Schedule below for Coordination with Accessories.
- C. Subject to compliance with requirements, products by the following manufacturers are also acceptable.
- D. Manual Shade Assemblies:
 - 1. Draper Inc – NEXD Manual
 - 2. Hunter Douglas, Inc., – RB500 Manual Roller Shades
 - 3. Approved Equal.
- E. Motorized Shade Assemblies:
 - 1. Draper Inc – Motorized Flexshade I/O AC
 - 2. Hunter Douglas, Inc., – RB500 Automated Roller Shades

3. Approved Equal.

2.2 MANUAL ROLLER SHADES

- A. Chain-and-Clutch Operating Mechanisms: With continuous-loop bead chain and clutch that stops shade movement when bead chain is released; permanently adjusted, oil-impregnated porous hub, and heat from friction of use causing oil to flow and continuously lubricate the hub for smooth operation, inhibiting corrosion of steel parts.
1. Bead Chains: Stainless steel rated to 90lb. minimum breaking strength.
 - a. Loop Length: Full length of roller shade.
 - b. Limit Stops: Provide upper and lower ball stops.
 - c. Chain-Retainer Type: Standard Clip.
 - d. Chain Position: Provide for universal, regular, and offset drive capacity, allowing drive chain to fall at front, rear, or non-offset for all shade drive end brackets. Universal offset shall be adjustable for future change.
 2. Spring Lift-Assist Mechanisms: Manufacturer's standard for balancing roller-shade weight and lifting heavy roller shades.
 - a. Provide for shadebands that weigh more than 8 lb or for shades as recommended by manufacturer, whichever criteria are more stringent.
- B. Rollers: Corrosion-resistant extruded aluminum tubes of diameters and wall thicknesses required for accommodating operating mechanisms and weights and widths of shadebands indicated without deflection. Provide with permanently lubricated drive-end assemblies and idle-end assemblies designed to facilitate removal of shadebands for service.
1. Roller Drive-End Location: As indicated on Drawings.
 2. Direction of Shadeband Roll: Regular, from back of roller.
 3. Shadeband-to-Roller Attachment: Removable spline fitting integral channel in tube.
- C. Mounting Hardware: Brackets or endcaps, corrosion resistant and compatible with roller assembly, operating mechanism, installation accessories, and mounting location and conditions indicated.
1. Basis of Design: Mecho's Mecho/5
 2. Provide hardware capable for installation of a removable fascia, for both regular and/or reverse roll, which shall be installed without exposed fastening devices of any kind.
 3. Provide shade hardware system that allows for removable regular and/or reverse roll fascias to be mounted continuously across two or more shade bands.
 4. Brackets: Constructed of minimum 1/8-inch thick plated steel or heavier as required to support 150 percent of the full weight of each shade.
 5. Provide shade hardware system that allows multi-banded manually operated shades to be capable of smooth operation when the axis is offset a maximum of 6 degrees on each side of the plane perpendicular to the radial line of the curve, for a 12 degree offset.
 6. Pull Force: Algorithm based spring lift assist coil formula to limit pull force between 3.5 lbs and 8 lbs. with a load capacity up to 30 lbs. for consistent smooth operation of shades regardless of size and within ADA standards.

7. Pull Angle: Expanded pull angle up to 26 degrees to allow for flexible use of pull chains when access to windows is obstructed.
 8. Capable of operating single or multi-banded shades up to 288" wide and 120" tall.
- D. Roller-Coupling Assemblies: Coordinated with operating mechanism and designed to join up to five inline rollers, up to twenty-four feet, into a multiband shade that is operated by one roller drive-end assembly.
1. Basis of Design: Mecho's Mecho/5
 2. Provide shade hardware system that allows for multi-banded manually operated shades to have clearances no greater than 5/8-inch between shade bands.
 3. Drive sprocket and brake assembly shall rotate and be supported on a welded 3/8-inch steel pin. The brake shall be an over-running clutch design which disengages to 90 percent during the raising and lowering of a shade. The brake shall withstand a pull force of 50 lbs. in the stopped position.
 4. The entire roller shade assembly shall be fully mounted on the steel support bracket and fully independent of the shade tube assembly, which may be removed and reinstalled without effecting the roller shade limit adjustments.

2.3 MOTORIZED ROLLER SHADES

- A. Motorized Operating System: Provide factory-assembled, shade-operator system of size and capacity and with features, characteristics, and accessories suitable for conditions indicated, complete with electric motor and factory-wired motor controls, power disconnect switch, enclosures protecting controls and operating parts, and accessories required for reliable operation without malfunction. Wiring from motor controls to motors to be by site electrical contractor. Shade installer to provide diagrams and site coordination with electrical contractor. Coordinate operator wiring requirements and electrical characteristics with building electrical system.
1. Electrical Components: Listed and labeled as defined in NFPA 70, by a qualified testing agency, and marked for intended location and application.
 2. Motor: WhisperShade IQ2 Electronic Drive Unit System as manufactured by MechoSystems Inc. Tubular, asynchronous, integral; temperature Class B, thermally-protected, totally enclosed, maintenance-free. Powered by line voltage power supply connection equipped with disconnect plug assembly furnished with EDU.
 - a. Audible Noise: 38 dBA measured 3 ft (914 mm) from motor unit, depending on motor torque.
 - b. Nominal Speed: 10 to 28 RPM. Configurable. Speed managed such that it does not vary due to load/lift capacity.
 - c. Line voltage power supply for powering external accessories connected to either the dry contact or network port.
 - a) Products that require accessories to be powered by a plug-in or externally-supplied power supply are not acceptable.
 3. Limit Switches: Provide programming of upper and lower stopping points (operating limits) of shade band's into motors via a hand held removable program module configurator or a local switch.
 4. Wall Switches: IQ-Switch for 5 alignment points, single gang backbox, low voltage.

a. Operating Features:

- a) Group switching with integrated five button, single gang switch control.
 - b) Provide intermediate stopping positions for shades that allow for up to three (3) repeatable and precise aligned positions. All shades on the same switch circuit with the same opening height shall align at each intermediate stopping position
 - c) Provide two modes of operation, uniform and regular. Uniform mode shall allow for shades to only move to intermediate stop positions. Regular mode shall allow for shades to move to both intermediate stop positions, plus any position desired between the upper and lower limits as set by the installer.
5. Rollers: Corrosion-resistant steel or extruded-aluminum tubes of diameters and wall thicknesses required for accommodating operating mechanisms and weights and widths of shadebands indicated without deflection. Provide with permanently lubricated drive-end assemblies and idle-end assemblies designed to facilitate removal of shadebands for service.
 6. Roller Drive-End Location: Closest proximity to Junction Box
 7. Direction of Shadeband Roll: Regular, from back of roller.
 8. Shadeband-to-Roller Attachment: Removable spline fitting integral channel in tube.
 9. Refer to Roller Shade Schedule below for more information.

B. Networked Shade Controller

1. Basis of Design: Mecho Shade IQ/MLC2
2. Dimensions: 10"x10"x4"
3. Weight: 7.5 lbs
4. Mounting: Wall-Mounted
5. Four-Motor, networked shade controller operates motorized shades equipped with standard line-voltage motors.
 - a. 4 DIP-switch configurable local control ports, which permit control of any combination of the four motors within the controller via dry contact.
 - b. Control port with one-touch shade positioning to 5 alignment points, including 3 mid-window presets. (0%, 25%, 50%, 75%, and 100%).
6. Refer to drawings for quantity and location.

C. Mounting Hardware: Provide shade hardware constructed of minimum 1/8-inch (3.18 mm) thick plated steel or heavier as required to support 150 percent of the full weight of each shade.

1. Basis of Design: MechoSystems ElectroShade #1 Bracket

2.4 SHADEBAND MATERIALS

A. Shadebands:

1. Solar Shadeband Material:
 - a. Basis of Design: Mechoshade 6000 series

- b. Type: Extruded vinyl/polyester yarn
 - c. Weave: Twill
 - d. Thickness: single fabric thickness 0.025 inches (0.635 mm) thick vinyl fabric, woven from 0.010-inch (0.254 mm) diameter vinyl/polyester yarn
 - e. Roll Width: 96 inches
 - f. Orientation on Shadeband: As indicated on Drawings.
 - g. Openness Factor: 3 percent.
 - h. Color: 6018 Stone
2. Light-Blocking Fabric: Opaque fabric, stain and fade resistant.
- a. Basis of Design: Mechoshade Systems 0700 series
 - b. Type: Washable and colorfast laminated and embossed vinyl coated fabric.
 - c. Thickness: 0.012 inches thick (0.30 mm).
 - d. Weight: 0.81 lbs. per square yard, with a minimum of 62 threads per square inch.
 - e. Roll Width: 72 inches (1829 mm)
 - f. Orientation on Shadeband: As indicated on Drawings
 - g. Features: Washable.
 - h. Color: 0701 White

2.5 INSTALLATION ACCESSORIES

Refer to Roller Shade Schedule below for full coordination with accessories.

- A. Front and Rear Fascia: Continuous removable extruded aluminum that attaches to shade mounting brackets without the use of adhesives, magnetic strips, or exposed fasteners. Fascia shall be able to be installed across two or more shade bands in one piece. Fascia shall fully conceal brackets, shade roller, and fabric on tube. Notching of fascia for manual chain shall not be acceptable.
- 1. Basis of Design: Mecho SnapLoc Fascia
 - 2. Shape: L-shaped.
 - 3. Height: Manufacturer's recommended height required to cover entire bracket.
 - 4. Fascia to be compatible with Motorized Shades
- B. Closure and Closure Mount: Provided by shade contractor.
- 1. Provide exposed extruded aluminum closure mount to provide access to shades as noted on roller shade schedule.
- C. End Caps: Provided by shade contractor for all exposed shade brackets.
- D. Accessories Color and Finish: Clear Anodized.

2.6 ROLLER-SHADE FABRICATION

- A. Product Safety Standard: Fabricate roller shades to comply with WCMA A 100.1, including requirements for flexible, chain-loop devices; lead content of components; and warning labels.
- B. Unit Sizes: Fabricate units in sizes to fill window and other openings as follows, measured at 74 deg F (23 deg C):

1. Outside of Jamb Installation: Width and length as indicated, with terminations between shades of end-to-end installations at centerlines of mullion or other defined vertical separations between openings.
- C. Shadeband Fabrication: Fabricate shadebands without battens or seams to extent possible except as follows:
1. Railroaded Materials: Railroad material where material roll width is less than the required width of shadeband and where indicated. Provide battens and seams as required by railroaded material to produce shadebands with full roll-width panel(s) plus, if required, one partial roll-width panel located at top of shadeband.

ROLLER SHADE SCHEDULE

- D. Refer to Drawings for more information, including details, length of run, and locations.

Roller Shade Tag	Description	Basis of Design Product	Accessories	Notes
RS-1 RS-1B	Double Motorized Roller Tube & Shade Assembly	ElectroShade Electro/2 DoubleShade	• 2" Drywall Closure Mount (No Tile Support) • Standard Bracket Flange Top • Front Fascia	Coordinate with Electrical, Motors and Networked Shade Controller.
RS-2	Double Motorized Roller Tube & Shade Assembly	ElectroShade Electro/2 DoubleShade	• Rear & Front Fascia • Standard Bracket Flange Top.	Coordinate with Electrical, Motors and Networked Shade Controller.
RS-3 RS-4 RS-5	Single Manual Roller Tube & Shade Assembly	Mecho/5 Shade System	• Rear & Front Fascia • Standard Bracket Flange Top	Verify Existing Conditions in Field.

PART 3 - EXECUTION

3.1 EXAMINATION

- A. Examine substrates, areas, and conditions, with Installer present, for compliance with requirements for installation tolerances, operational clearances, accurate locations of connections to building electrical system, and other conditions affecting performance of the Work.
- B. Proceed with installation only after unsatisfactory conditions have been corrected.

3.2 ROLLER-SHADE INSTALLATION

- A. Install roller shades level, plumb, and aligned with adjacent units according to manufacturer's written instructions.
- B. Electrical Connections: Connect motor-operated roller shades to building electrical system.
- C. Turn-Key Single-Source Responsibility for Motorized Interior Roller Shades (By site electrical contractor with coordination from Shades dealer): To control the responsibility for performance of motorized roller shade systems, assign the design, engineering, and installation of motorized roller shade systems, motors, controls, and low voltage electrical control wiring specified in this

Section to a single manufacturer and their authorized installer/dealer. The Architect will not produce a set of electrical drawings for the installation of control wiring for the motors, or motor controllers of the motorized roller shades. Power wiring (line voltage), shall be provided by the electrical contractor, in accordance with the requirements provided by the manufacturer. Coordinate the following with the roller shade installer/dealer:

1. Main Contractor shall provide power panels and circuits of sufficient size to accommodate roller shade manufacturer's requirements, as indicated on the mechanical and electrical drawings.
2. Main Contractor shall coordinate with requirements of roller shade installer/dealer, before inaccessible areas are constructed.
3. Roller shade installer/dealer shall run line voltage (of sufficient quantity, in sufficient capacity as required) terminating in junction boxes in locations designated by roller shade dealer.
4. Roller shade installer/dealer shall provide and run all line voltage (from the terminating points) to the motor controllers, wire all roller shade motors to the motor controllers, and provide and run low voltage control wiring from motor controllers to switch/ control locations designated by the Architect. All above-ceiling and concealed wiring shall be plenum-rated, or installed in conduit, as required by the electrical code having jurisdiction.
5. Main Contractor shall provide conduit with pull wire in all areas, which might not be accessible to roller shade contractor due to building design, equipment location or schedule.

3.3 ADJUSTING

- A. Adjust and balance roller shades to operate smoothly, easily, safely, and free from binding or malfunction throughout entire operational range.

3.4 CLEANING AND PROTECTION

- A. Clean roller-shade surfaces after installation, according to manufacturer's written instructions.
- B. Provide final protection and maintain conditions, in a manner acceptable to manufacturer and installer that ensure that roller shades are without damage or deterioration at time of Substantial Completion.
- C. Replace damaged roller shades that cannot be repaired, in a manner approved by Architect, before time of Substantial Completion.

3.5 DEMONSTRATION

- A. Engage a factory-authorized service representative to train Owner's maintenance personnel to adjust, operate, and maintain motor-operated roller shades.

END OF SECTION 12 24 13

SECTION 21 05 00
COMMON WORK RESULTS FOR FIRE SUPPRESSION

PART 1 GENERAL

1.01 SECTION INCLUDES

- A. Above ground piping.
- B. Escutcheons.
- C. Mechanical couplings.
- D. Pipe hangers and supports.
- E. Pipe sleeves.
- F. Pipe sleeve-seal systems.
- G. Piping specialties.
- H. Pressure gauges.
- I. Pressure relief valves.

1.02 RELATED REQUIREMENTS

- A. Section 07 84 00 - Firestopping.
- B. Section 21 05 23 - General-Duty Valves for Water-Based Fire-Suppression Piping.
- C. Section 21 05 53 - Identification for Fire Suppression Piping and Equipment: Piping identification.
- D. Section 21 13 00 - Fire-Suppression Sprinkler Systems: Sprinkler systems design.

1.03 REFERENCE STANDARDS

- A. ANSI Z21.22 - American National Standard for Relief Valves for Hot Water Supply Systems; 2015 (Reaffirmed 2020).
- B. ASME A112.18.1 - Plumbing Supply Fittings; 2024.
- C. ASME B40.100 - Pressure Gauges and Gauge Attachments; 2022.
- D. ASME BPVC-IX - Boiler and Pressure Vessel Code, Section IX - Qualification Standard for Welding, Brazing, and Fusing Procedures; Welders; Brazers; and Welding, Brazing, and Fusing Operators; 2023.
- E. ASME B16.1 - Gray Iron Pipe Flanges and Flanged Fittings: Classes 25, 125, and 250; 2020.
- F. ASME B16.3 - Malleable Iron Threaded Fittings: Classes 150 and 300; 2021.
- G. ASME B16.4 - Gray Iron Threaded Fittings: Classes 125 and 250; 2021.
- H. ASME B16.5 - Pipe Flanges and Flanged Fittings: NPS 1/2 through NPS 24 Metric/Inch Standard; 2020.
- I. ASTM A47/A47M - Standard Specification for Ferritic Malleable Iron Castings; 1999, with Editorial Revision (2022).
- J. ASTM A269/A269M - Standard Specification for Seamless and Welded Austenitic Stainless Steel Tubing for General Service; 2022.
- K. ASTM A536 - Standard Specification for Ductile Iron Castings; 1984, with Editorial Revision (2019).
- L. ASTM A795/A795M - Standard Specification for Black and Hot-Dipped Zinc-Coated (Galvanized) Welded and Seamless Steel Pipe for Fire Protection Use; 2021.
- M. ASTM E814 - Standard Test Method for Fire Tests of Penetration Firestop Systems; 2023a.
- N. AWWA C606 - Grooved and Shouldered Joints; 2022.

- O. FM (AG) - FM Approval Guide; Current Edition.
- P. ITS (DIR) - Directory of Listed Products; Current Edition.
- Q. NFPA 13 - Standard for the Installation of Sprinkler Systems; Most Recent Edition Adopted by Authority Having Jurisdiction, Including All Applicable Amendments and Supplements.
- R. NFPA 14 - Standard for the Installation of Standpipe and Hose Systems; 2024.
- S. NFPA 1963 - Standard for Fire Hose Connections; 2019.
- T. UL (DIR) - Online Certifications Directory; Current Edition.
- U. UL 393 - Indicating Pressure Gauges for Fire-Protection Service; Current Edition, Including All Revisions.
- V. UL 723 - Standard for Test for Surface Burning Characteristics of Building Materials; Current Edition, Including All Revisions.

1.04 SUBMITTALS

- A. See Section 01 30 00 - Administrative Requirements for submittal procedures.
- B. Product Data: Provide manufacturer's catalog information. Indicate valve data and ratings.
- C. Shop Drawings: Indicate pipe materials used, jointing methods, supports, and floor and wall penetration seals. Indicate installation, layout, weights, mounting and support details, and piping connections.
- D. Project Record Documents: Record actual locations of components and tag numbering.

1.05 QUALITY ASSURANCE

- A. Comply with FM (AG) and UL (DIR) requirements.
- B. Valves: Bear FM (AG), UL (DIR), and ITS (DIR) or Warnock Hersey product listing label or marking. Provide manufacturer's name and pressure rating marked on valve body.

1.06 DELIVERY, STORAGE, AND HANDLING

- A. Deliver and store valves in shipping containers, with labeling in place.
- B. Provide temporary protective coating on cast iron and steel valves.
- C. Provide temporary end caps and closures on piping and fittings. Maintain in place until installation.

1.07 WARRANTY

- A. See Section 01 78 00 - Closeout Submittals for additional warranty requirements.
- B. Correct defective Work within a two year period after Date of Substantial Completion.

PART 2 PRODUCTS

2.01 GENERAL REQUIREMENTS

- A. Sprinkler-based System:
 - 1. Comply with NFPA 13.
 - 2. See Section 21 13 00.
- B. Welding Materials and Procedures: Comply with ASME BPVC-IX.
- C. Provide system pipes, fittings, sleeves, escutcheons, seals, and other related accessories.

2.02 ABOVE GROUND PIPING

- A. Steel Pipe: ASTM A795 Schedule 40, black.
 - 1. Steel Fittings: ASME B16.5 steel flanges and fittings.
 - 2. Cast Iron Fittings: ASME B16.1, flanges and flanged fittings and ASME B16.4, threaded fittings.
 - 3. Malleable Iron Fittings: ASME B16.3, threaded fittings and ASTM A47/A47M.

4. Mechanical Grooved Couplings: Malleable iron housing clamps to engage and lock, "C" shaped elastomeric sealing gasket, steel bolts, nuts, and washers; galvanized for galvanized pipe.
5. Mechanical Formed Fittings: Carbon steel housing with integral pipe stop and O-ring pocked and O-ring, uniformly compressed into permanent mechanical engagement onto pipe.

2.03 PIPE SLEEVES

- A. Vertical Piping:
 1. Sleeve Length: 1 inch above finished floor.
 2. Provide sealant for watertight joint.
 3. Drilled Penetrations: Provide 1-1/2 inch angle ring or square set in silicone adhesive around penetration.
- B. Clearances:
 1. Provide allowance for insulated piping.
 2. Wall, Floor, Floor, Partitions, and Beam Flanges: 1 inch greater than external; pipe diameter.
 3. Rated Openings: Caulked tight with firestopping material complying with ASTM E814 in accordance with Section 07 84 00 to prevent the spread of fire, smoke, and gases.

2.04 PIPE SLEEVE-SEAL SYSTEMS

- A. Manufacturers:
 1. Advance Products & Systems, Inc; Innerlyn: www.apsonline.com/#sle.
 2. GPT, a company of Enpro Industries, Inc: www.gptindustries.com/#sle.
 3. Substitutions: See Section 01 60 00 - Product Requirements.
- B. Modular Mechanical Seals:
 1. Elastomer-based interlocking links to continuously fill annular space between pipe and wall-sleeve, wall or casing opening.
 2. Watertight seal between pipe and wall-sleeve, wall or casing opening.
 3. Size and select seal component materials in accordance with service requirements.
 4. Service Requirements:
 - a. Underground, buried, and wet conditions.
 5. Glass-reinforced plastic pressure end plates.
- C. Wall Sleeve: PVC material with waterstop collar, and nailer end caps.
- D. Sleeve-Forming Disk: Nonconductive plastic-based material, 3 inch thick.
- E. Pipeline-Casing Seals:
 1. End Seals: 1/8 inch, pull-on type, rubber or synthetic rubber based.

2.05 ESCUTCHEONS

- A. Manufacturers:
 1. Fire Protection Products, Inc: www.fppi.com/#sle.com/#sle.
 2. Tyco Fire Protection Products: www.tyco-fire.com/#sle.
 3. Viking Group Inc: www.vikinggroupinc.com/#sle.
 4. Substitutions: See Section 01 60 00 - Product Requirements.
- B. Material:
 1. Grade TP304, seamless tube, ASTM A269/A269M stainless steel.
 2. Metals and Finish: Comply with ASME A112.18.1.
- C. Construction:
 1. One-piece for mounting on chrome-plated tubing or pipe and one-piece or split-pattern type elsewhere.
 2. Internal spring tension devices or setscrews to maintain a fixed position against a surface.

2.06 PIPE HANGERS AND SUPPORTS

- A. Hangers for Pipe Sizes 1/2 to 1-1/2 inch: Malleable iron, adjustable swivel, split ring.
 - 1. Manufacturers:
 - a. AFCON, a brand of Anvil International: www.anvilintl.com/#sle.
 - b. FNW: www.fnw.com/#sle.
- B. Hangers for Pipe Sizes 2 inches and Over: Carbon steel, adjustable, clevis.
 - 1. Manufacturers:
 - a. AFCON, a brand of Anvil International: www.anvilintl.com/#sle.
 - b. FNW: www.fnw.com/#sle.
- C. Multiple or Trapeze Hangers: Steel channels with welded spacers and hanger rods.
- D. Wall Support for Pipe Sizes to 3 inches: Cast iron hook.
- E. Wall Support for Pipe Sizes 4 inches and Over: Welded steel bracket and wrought steel clamp.
- F. Vertical Support: Steel riser clamp.
- G. Floor Support: Cast iron adjustable pipe saddle, lock nut, nipple, floor flange, and concrete pier or steel support.
- H. Seismic Hangers and Couplings:
 - 1. Provide coupling with a factory set disengagement rating of 140 percent to 160 percent of the static weight.
 - 2. Provide resettable and reusable, break away couplings.
 - 3. Provide tether cables to avoid excessive seismic joint movement.
 - 4. Coupling to be manufactured from non-corrosive materials.

2.07 MECHANICAL COUPLINGS

- A. Manufacturers:
 - 1. Anvil International: www.anvilintl.com/#sle.
 - 2. Shurjoint Piping Products, Inc: www.shurjoint.com/#sle.
 - 3. Tyco Fire Protection Products: www.tyco-fire.com/#sle.
 - 4. Victaulic Company; Firelock Style 009H: www.victaulic.com/#sle.
- B. Rigid Mechanical Couplings for Grooved Joints:
 - 1. Dimensions and Testing: Comply with AWWA C606.
 - 2. Minimum Working Pressure: 300 psig.
 - 3. Housing Material: Fabricate of ductile iron complying with ASTM A536.
 - 4. Housing Coating: Factory applied orange enamel.
 - 5. Gasket Material: EPDM suitable for operating temperature range from minus 30 degrees F to 230 degrees F.
 - 6. Bolts and Nuts: Hot-dipped-galvanized or zinc-electroplated steel.

2.08 PIPING SPECIALTIES

- A. Wet Pipe Sprinkler Alarm Valve: Check type valve with divided seat ring, rubber-faced clapper to automatically actuate water motor alarm, pressure retard chamber and variable pressure trim with the following additional capabilities and features:
 - 1. Activate electric alarm.
 - 2. Test and drain valve.
 - 3. Replaceable internal components without removing valve from installed position.
- B. Preaction Valve:
 - 1. Operated by detection system listed for releasing service and independent of building fire alarm system with provisions for indicated remote, local, and manual releases.
 - 2. Incorporate mechanical latching mechanism with valve clappers independent of system water pressure fluctuations.

3. Provide test detection device for each actuation circuit adjacent to each controlled valve in accordance with NFPA 13.
- C. Test Connections:
 1. Inspector's Test Connection for Preaction and Dry Pipe Systems:
 - a. Provide test connections approximately 6 feet above floor for each or portion of each sprinkler system equipped with an alarm device, located at most remote part of each system.
 - b. Route test connection to an open-site drain location, excluding janitor sinks, accepting full flow without negative consequences.
 - c. Supply discharge orifice with same size as corresponding sprinkler orifice.
 - d. Limit vertical height of exterior wall penetration to 2 feet above finished grade.

2.09 PRESSURE GAUGES

- A. Manufacturers:
 1. AGF Manufacturing: www.agfmfg.com/#sle.
 2. Dwyer Instruments, Inc: www.dwyer-inst.com/#sle.
 3. Omega Engineering, Inc: www.omega.com/#sle.
- B. Pressure Gauges: ASME B40.100, UL 393 drawn steel case, phosphor bronze bourdon tube, rotary brass movement, brass socket, with front recalibration adjustment, black scale on white background.
 1. Case: Steel with brass bourdon tube.
 2. Diameter: 4-1/2 inch.
 3. Mid-Scale Accuracy: One percent.

2.10 PRESSURE RELIEF VALVES

- A. ANSI Z21.22, AGA certified, bronze body, teflon seat, steel stem and springs, automatic, direct pressure actuated.

PART 3 EXECUTION

3.01 PREPARATION

- A. Ream pipe and tube ends. Remove burrs. Bevel plain end ferrous pipe.
- B. Remove scale and foreign material, from inside and outside, before assembly.
- C. Prepare piping connections to equipment with flanges or unions.

3.02 INSTALLATION

- A. Install sprinkler system and service main piping, hangers, and supports in accordance with NFPA 13.
- B. Route piping in orderly manner, plumb and parallel to building structure. Maintain gradient.
- C. Install piping to conserve building space, to not interfere with use of space and other work.
- D. Group piping whenever practical at common elevations.
- E. Install piping to allow for expansion and contraction without stressing pipe, joints, or connected equipment.
- F. Pipe Hangers and Supports:
 1. Install hangers to provide minimum 1/2 inch space between finished covering and adjacent work.
 2. Place hangers within 12 inches of each horizontal elbow.
 3. Use hangers with 1-1/2 inch minimum vertical adjustment. Design hangers for pipe movement without disengagement of supported pipe.
 4. Support vertical piping at every other floor. Support riser piping independently of connected horizontal piping.

- 5. Where several pipes can be installed in parallel and at same elevation, provide multiple or trapeze hangers.
- G. Slope piping and arrange systems to drain at low points. Use eccentric reducers to maintain top of pipe level.
- H. Prepare pipe, fittings, supports, and accessories for finish painting. Where pipe support members are welded to structural building framing, scrape, brush clean, and apply one coat of zinc-rich primer to welding.
- I. Structural Considerations:
 - 1. Do not penetrate building structural members unless indicated.
- J. Provide sleeves when penetrating footings, floors, walls, and partitions. Seal pipe including sleeve penetrations to achieve fire resistance equivalent to fire separation required.
- K. Manufactured Sleeve-Seal Systems:
 - 1. Install manufactured sleeve-seal systems in sleeves located in grade slabs and exterior concrete walls at piping entrances into building.
 - 2. Provide sealing elements of the size, quantity, and type required for the piping and sleeve inner diameter or penetration diameter.
 - 3. Locate piping in center of sleeve or penetration.
 - 4. Install field assembled sleeve-seal system components in annular space between sleeve and piping.
 - 5. Tighten bolting for a watertight seal.
 - 6. Install in accordance with manufacturer's recommendations.
- L. Escutcheons:
 - 1. Install and firmly attach escutcheons at piping penetrations into finished spaces.
 - 2. Provide escutcheons on both sides of partitions separating finished areas through which piping passes.
 - 3. Use chrome plated escutcheons in occupied spaces and to conceal openings in construction.
- M. When installing more than one piping system material, ensure system components are compatible and joined to ensure the integrity of the system. Provide necessary joining fittings. Ensure flanges, unions, and couplings for servicing are consistently provided.

END OF SECTION

SECTION 21 05 23
GENERAL-DUTY VALVES FOR WATER-BASED FIRE-SUPPRESSION PIPING

PART 1 GENERAL

1.01 SECTION INCLUDES

- A. Two-piece ball valves with indicators.
- B. Bronze butterfly valves with indicators.
- C. Iron butterfly valves with indicators.
- D. Check valves.
- E. Iron OS&Y gate valves.

1.02 RELATED REQUIREMENTS

- A. Section 07 84 00 - Firestopping.
- B. Section 21 05 53 - Identification for Fire Suppression Piping and Equipment.
- C. Section 21 13 00 - Fire-Suppression Sprinkler Systems.

1.03 ABBREVIATIONS AND ACRONYMS

- A. EPDM: Ethylene-propylene diene monomer.
- B. NRS: Non-rising stem.
- C. OS&Y: Outside screw and yoke.
- D. PTFE: Polytetrafluoroethylene.

1.04 REFERENCE STANDARDS

- A. ASME B1.20.1 - Pipe Threads, General Purpose, Inch; 2013 (Reaffirmed 2018).
- B. ASME B16.1 - Gray Iron Pipe Flanges and Flanged Fittings: Classes 25, 125, and 250; 2020.
- C. ASME B16.42 - Ductile Iron Pipe Flanges and Flanged Fittings: Classes 150 and 300; 2021.
- D. AWWA C606 - Grooved and Shouldered Joints; 2022.
- E. FM (AG) - FM Approval Guide, Current Edition.
- F. FM 1112 - Examination Standard for Indicating Valves (Butterfly or Ball Type); 2020.
- G. FM 1120/1130 - Approval Standard for Fire Service Water Control Valves (OS&Y and NRS Gate Valves); 1997.
- H. FM 1210 - Approval Standard for Swing Check Valves; 2004.
- I. UL (DIR) - Online Certifications Directory; Current Edition.
- J. UL 262 - Gate Valves for Fire-Protection Service; Current Edition, Including All Revisions.
- K. UL 312 - Check Valves for Fire-Protection Service; Current Edition, Including All Revisions.
- L. UL 1091 - Standard for Butterfly Valves for Fire-Protection Service; Current Edition, Including All Revisions.

1.05 ADMINISTRATIVE REQUIREMENTS

- A. Preinstallation Meeting: Conduct a preinstallation meeting one week prior to the start of the work of this section; require attendance by all affected installers.

1.06 SUBMITTALS

- A. See Section 01 30 00 - Administrative Requirements for submittal procedures.
- B. Product Data: Provide data on valves including manufacturers catalog information. Submit performance ratings, rough-in details, weights, support requirements, and piping connections.

- C. Warranty: Submit manufacturer warranty and ensure that forms have been completed in Del Tech's name and registered with manufacturer.

1.07 QUALITY ASSURANCE

- A. Installer Qualifications: Company specializing in performing work of type specified and with at least five years of documented experience.
- B. Where listed products are specified, provide products listed, certified, and labeled by FM (AG), UL (DIR), or testing firm acceptable to authorities having jurisdiction as suitable for purpose indicated.

1.08 DELIVERY, STORAGE, AND HANDLING

- A. Prepare valves for shipping as follows:
1. Protect internal parts against rust and corrosion.
 2. Protect valve ends and flange faces.
 3. Set valves open to minimize exposure of functional surfaces.
- B. Use the following precautions during storage:
1. Maintain valve end protection and protect flanges and specialties from dirt.
 - a. Provide temporary inlet and outlet caps.
 - b. Maintain caps in place until installation.
 2. Store valves in shipping containers and maintain in place until installation.
 - a. Store valves indoors and maintain at higher than ambient dew point temperature.
 - b. If outdoor storage is unavoidable, store valves off the ground in watertight enclosures.
- C. Use the following precautions for handling:
1. Use sling to handle large valves, rig to avoid damage to exposed parts.
 2. Do not use operating handles or stems as lifting or rigging points.

PART 2 PRODUCTS

2.01 GENERAL REQUIREMENTS

- A. Source Limitations: Furnish valves of same kind by same manufacturer.
- B. Valve-End Connections:
1. Flanges on Iron Valves: ASME B16.1 or ASME B16.42.
 2. Threaded Ends: ASME B1.20.1.
 3. Grooved Ends: AWWA C606.
- C. Valve Pressure Ratings: Not less than minimum pressure rating indicated or higher as required.
- D. Valve Sizes: Same as upstream piping unless otherwise indicated.

2.02 TWO PIECE BALL VALVES WITH INDICATORS

- A. UL 1091 and FM 1112 listed.
- B. Description:
1. Minimum Pressure Rating: 175 psig.
 2. Body Design: Two piece.
 3. Body Material: Forged brass or bronze.
 4. Port Size: Full or standard.
 5. Seat: PTFE.
 6. Stem: Bronze or stainless steel.
 7. Ball: Chrome-plated brass.
 8. Actuator: Worm gear or traveling nut.
 9. End Connections: Threaded or grooved.

2.03 BRONZE BUTTERFLY VALVES WITH INDICATORS

- A. UL 1091 and FM 1112 listed.
- B. Minimum Pressure Rating: 175 psig.
- C. Body Material: Bronze.
- D. Seat: EPDM.
- E. Stem: Bronze or stainless steel.
- F. Disc: Bronze with EPDM coating or stainless steel.
- G. Actuator: Worm gear or traveling nut.
- H. End Connections: Threaded or grooved.

2.04 IRON BUTTERFLY VALVES WITH INDICATORS

- A. UL 1091 and FM 1112 listed.
- B. Minimum Pressure Rating: 175 psig.
- C. Body Material: Cast or ductile iron.
- D. Seat: EPDM.
- E. Stem: Stainless steel.
- F. Disc: Ductile iron with EPDM coating.
- G. Actuator: Worm gear or traveling nut.
- H. Body Design: Grooved-end or wafer style.

2.05 SWING CHECK VALVES

- A. UL 312 and FM 1210 listed.
- B. Minimum Pressure Rating: 175 psig.
- C. Body Material: Cast or ductile iron.
- D. Clapper: Bronze, EPDM-coated ductile iron, or stainless steel.
- E. Seat: Bronze or EPDM-coated bronze.
- F. End Connections: Flanged.

2.06 IRON OS&Y GATE VALVES

- A. UL 262 and FM 1120/1130 listed.
- B. Minimum Pressure Rating: 175 psig.
- C. Body and Bonnet Material: Cast or ductile iron.
- D. Wedge: Cast or ductile iron, or bronze with elastomeric coating.
- E. Stem: Brass, bronze, or stainless steel.
- F. Packing: Non-asbestos PTFE.
- G. Supervisory Switch: External.

PART 3 EXECUTION

3.01 EXAMINATION

- A. Confirm valve interior to be free of foreign matter and corrosion.
- B. Remove packing materials.
- C. Examine guides and seats by operating valves from the fully open position to the fully closed position.
- D. Examine valve threads and mating pipe for form and cleanliness.

- E. Examine mating flange faces for conditions that might cause leakage.
 - 1. Check bolting for proper size, length, and material.
 - 2. Verify gasket for size, defects, damage, and suitable material composition for service.
- F. Replace defective valves with new valves.

3.02 INSTALLATION

- A. Install valves in accessible locations to allow for operation, inspections, tests, and maintenance.
- B. Install listed valves in accordance with their listing.
- C. Install valves in accordance with manufacturer's instructions.
- D. Support valves independently of adjacent piping.
- E. Install valves in horizontal piping with stem at or above pipe center.
- F. Position valves to allow full actuator movement.
- G. Install OS&Y valves with full clearance for rising stem. Install surrounding components so they do not interfere with nor are they impacted by full extension of rising stem.
- H. Install supervised shutoff valves in supervised-open position.
- I. Install permanent identification signs indicating portion of system controlled by each shutoff valve.
- J. Install threaded-end valves with unions upstream and downstream.
- K. Install valve tags. See Section 21 05 53. Label valves in accordance with NFPA standard applying to the piping system in which valves are installed.

END OF SECTION

SECTION 21 05 48

VIBRATION AND SEISMIC CONTROLS FOR FIRE SUPPRESSION PIPING AND EQUIPMENT

PART 1 GENERAL

1.01 SECTION INCLUDES

- A. Vibration isolation requirements.
- B. Vibration isolators.

1.02 RELATED REQUIREMENTS

- A. Section 03 30 00 - Cast-in-Place Concrete.
- B. Section 23 05 48 - Vibration and Seismic Controls for HVAC

1.03 DEFINITIONS

- A. Fire Suppression Component: Where referenced in this section in regards to seismic controls, applies to any portion of the fire suppression system subject to seismic evaluation in accordance with applicable codes, including distributed systems (e.g. piping).
- B. Seismic Restraint: Structural members or assemblies of members or manufactured elements specifically designed and applied for transmitting seismic forces between components and the seismic force-resisting system of the structure.

1.04 REFERENCE STANDARDS

- A. ASCE 7 - Minimum Design Loads and Associated Criteria for Buildings and Other Structures; Most Recent Edition Cited by Referring Code or Reference Standard.
- B. ASCE 19 - Structural Applications of Steel Cables for Buildings; 2016.
- C. ASHRAE (HVAC) - ASHRAE Handbook - HVAC Applications; Most Recent Edition Cited by Referring Code or Reference Standard.
- D. FEMA 412 - Installing Seismic Restraints for Mechanical Equipment; 2014.
- E. ICC (IBC) - International Building Code; Most Recent Edition Adopted by Authority Having Jurisdiction, Including All Applicable Amendments and Supplements.
- F. ICC-ES AC156 - Acceptance Criteria for Seismic Certification by Shake-Table Testing of Nonstructural Components; 2010, with Editorial Revision (2020).
- G. NFPA 13 - Standard for the Installation of Sprinkler Systems; Most Recent Edition Adopted by Authority Having Jurisdiction, Including All Applicable Amendments and Supplements.
- H. SMACNA (SRM) - Seismic Restraint Manual Guidelines for Mechanical Systems; 2008.
- I. UL 203A - Standard for Sway Brace Devices for Sprinkler System Piping; Current Edition, Including All Revisions.

1.05 ADMINISTRATIVE REQUIREMENTS

- A. Coordination:
 - 1. Coordinate selection and arrangement of vibration isolation and/or seismic control components with the actual equipment to be installed.
 - 2. Coordinate the work with other trades to provide additional framing and materials required for installation.
 - 3. Coordinate compatibility of support and attachment components with mounting surfaces at the installed locations.
 - 4. Notify DEDC, LLC of any conflicts with or deviations from Contract Documents. Obtain direction before proceeding with work.
- B. Sequencing:
 - 1. Do not install products on or provide attachment to concrete surfaces until concrete has fully cured in accordance with Section 03 30 00.

1.06 SUBMITTALS

- A. See Section 01 30 00 - Administrative Requirements, for submittal procedures.
- B. Design Documents: Prepare and submit all information required for plan review and permitting by authorities having jurisdiction, including but not limited to floor plans, details, and calculations.
- C. Product Data: Provide manufacturer's standard catalog pages and data sheets for products, including materials, fabrication details, dimensions, and finishes.
 - 1. Vibration Isolators: Include rated load capacities and deflections; include information on color coding or other identification methods for spring element load capacities.
- D. Shop Drawings - Vibration Isolation Systems:
 - 1. Include dimensioned plan views and sections indicating proposed arrangement of vibration isolators; indicate equipment weights and static deflections.
 - 2. Vibration-Isolated Equipment Support Bases: Include base weights, including concrete fill where applicable; indicate equipment mounting provisions.

1.07 QUALITY ASSURANCE

- A. Comply with applicable building code.
- B. Maintain at the project site a copy of each referenced document that prescribes execution requirements.

1.08 DELIVERY, STORAGE, AND HANDLING

- A. Receive, inspect, handle, and store products in accordance with manufacturer's instructions.

PART 2 PRODUCTS

2.01 VIBRATION ISOLATION REQUIREMENTS

- A. Design and provide vibration isolation systems to reduce vibration transmission to supporting structure from vibration-producing fire suppression equipment.
- B. Comply with applicable general recommendations of ASHRAE (HVACA), where not in conflict with other specified requirements:
- C. General Requirements:
 - 1. Select vibration isolators to provide required static deflection.
 - 2. Select vibration isolators for uniform deflection based on distributed operating weight of actual installed equipment.

2.02 VIBRATION ISOLATORS

- A. Manufacturers:
 - 1. Vibration Isolators:
 - a. Kinetics Noise Control, Inc: www.kineticsnoise.com.
 - b. Mason Industries: www.mason-ind.com.
 - c. Vibration Eliminator Company, Inc: www.vec-co-nyc.com.
- B. General Requirements:
 - 1. Resilient Materials for Vibration Isolators: Oil, ozone, and oxidant resistant.
 - 2. Spring Elements for Spring Isolators:
 - a. Color code or otherwise identify springs to indicate load capacity.
 - b. Lateral Stability: Minimum lateral stiffness to vertical stiffness ratio of 0.8.
 - c. Designed to operate in the linear portion of their load versus deflection curve over deflection range of not less than 50 percent above specified deflection.
 - d. Designed to provide additional travel to solid of not less than 50 percent of rated deflection at rated load.

- e. Selected to provide designed deflection of not less than 75 percent of specified deflection.
- f. Selected to function without undue stress or overloading.
- C. Vibration Isolators for Nonseismic Applications:
 - 1. Resilient Material Isolator Pads:
 - a. Description: Single or multiple layer pads utilizing elastomeric (e.g., neoprene, rubber) or fiberglass isolator material.
 - b. Pad Thickness: As required for specified minimum static deflection; minimum 0.25 inch thickness.
 - c. Multiple Layer Pads: Provide bonded, galvanized sheet metal separation plate between each layer.

PART 3 EXECUTION

3.01 EXAMINATION

- A. Verify that field measurements are as shown on the drawings.
- B. Verify that mounting surfaces are ready to receive vibration isolation and/or seismic control components and associated attachments.
- C. Verify that conditions are satisfactory for installation prior to starting work.

3.02 INSTALLATION

- A. Install products in accordance with manufacturer's instructions.
- B. Install anchors and fasteners in accordance with ICC Evaluation Services, LLC (ICC-ES) evaluation report conditions of use where applicable.
- C. Secure fasteners according to manufacturer's recommended torque settings.
- D. Install flexible piping connections to provide sufficient slack for vibration isolation and/or seismic relative displacements as indicated or as required.
- E. Vibration Isolation Systems:
 - 1. Spring Isolators:
 - a. Position equipment at operating height; provide temporary blocking as required.
 - b. Lift equipment free of isolators prior to lateral repositioning to avoid damage to isolators.
 - c. Level equipment by adjusting isolators gradually in sequence to raise equipment uniformly such that excessive weight or stress is not placed on any single isolator.
 - 2. Isolator Hangers:
 - a. Use precompressed isolator hangers where required to facilitate installation and prevent damage to equipment utility connection provisions.
 - b. Locate isolator hangers at top of hanger rods in accordance with manufacturer's instructions.
 - 3. Clean debris from beneath vibration-isolated equipment that could cause short-circuiting of isolation.
 - 4. Use elastomeric grommets for attachments where required to prevent short-circuiting of isolation.
 - 5. Adjust isolators to be free of isolation short circuits during normal operation.
 - 6. Do not overtighten fasteners such that resilient material isolator pads are compressed beyond manufacturer's maximum recommended deflection.
- F. Seismic Controls:
 - 1. Provide specified snubbing element air gap; remove any factory-installed spacers, debris, or other obstructions.
 - 2. Use only specified components, anchorage, and hardware evaluated by seismic design. Comply with conditions of seismic certification where applicable.

3. Where mounting hole diameter exceeds bolt diameter by more than 0.125 inch, use epoxy grout, elastomeric grommet, or welded washer to reduce clearance to 0.125 inch or less.
4. Equipment with Sheet Metal Housings:
 - a. Use Belleville washers to distribute stress over a larger surface area of the sheet metal connection interface as approved by manufacturer.
 - b. Attach additional steel as approved by manufacturer where required to transfer loads to structure.
 - c. Where mounting surface is irregular, do not shim housing; reinforce housing with additional steel as approved by manufacturer.
5. Seismic Restraint Systems:
 - a. Do not attach seismic restraints and gravity supports to dissimilar parts of structure that may move differently during an earthquake.
 - b. Install restraints within permissible angles in accordance with seismic design.
 - c. Install cable restraints straight between component/run and structural attachment; do not bend around other nonstructural components or structural elements.
 - d. Install cable restraints for vibration-isolated components slightly slack to prevent short-circuiting of isolation.
 - e. Install hanger rod stiffeners where indicated using only specified clamps; do not weld stiffeners to hanger rod.

3.03 FIELD QUALITY CONTROL

- A. See Section 01 40 00 - Quality Requirements, for additional requirements.
- B. Inspect vibration isolation and/or seismic control components for damage and defects.
- C. Vibration Isolation Systems:
 1. Verify isolator static deflections.
 2. Verify vibration isolation performance during normal operation; investigate sources of isolation short circuits.
- D. Correct deficiencies and replace damaged or defective vibration isolation and/or seismic control components.

END OF SECTION

SECTION 21 05 53
IDENTIFICATION FOR FIRE SUPPRESSION PIPING AND EQUIPMENT

PART 1 GENERAL

1.01 SECTION INCLUDES

- A. Nameplates.
- B. Tags.
- C. Stencils.
- D. Pipe markers.
- E. Ceiling tacks.

1.02 REFERENCE STANDARDS

- A. ASME A13.1 - Scheme for the Identification of Piping Systems; 2023.
- B. ASTM D709 - Standard Specification for Laminated Thermosetting Materials; 2017.

1.03 SUBMITTALS

- A. See Section 01 30 00 - Administrative Requirements, for submittal procedures.
- B. List: Submit list of wording, symbols, letter size, and color coding for mechanical identification.
- C. Chart and Schedule: Submit valve chart and schedule, including valve tag number, location, function, and valve manufacturer's name and model number.
- D. Manufacturer's Installation Instructions: Indicate special procedures, and installation instructions.
- E. Project Record Documents: Record actual locations of tagged valves.

PART 2 PRODUCTS

2.01 IDENTIFICATION APPLICATIONS

- A. Control Panels: Nameplates.
- B. Major Control Components: Nameplates.
- C. Piping: Tags.
- D. Pumps: Nameplates.
- E. Relays: Tags.
- F. Small-sized Equipment: Tags.
- G. Valves: Nameplates and ceiling tacks where above lay-in ceilings.

2.02 NAMEPLATES

- A. Manufacturers:
 - 1. Brimar Industries, Inc: www.pipemarker.com/#sle.
 - 2. Kolbi Pipe Marker Co: www.kolbipipemarkers.com/#sle.
 - 3. Seton Identification Products, a Tricor Direct Company: www.seton.com/#sle.
- B. Description: Laminated three-layer plastic with engraved letters.
 - 1. Letter Color: White.
 - 2. Background Color: Black.
 - 3. Thickness: 1/8 inch.
 - 4. Plastic: Comply with ASTM D709.

2.03 TAGS

- A. Manufacturers:
 - 1. Brimar Industries, Inc: www.pipemarker.com/#sle.

2. Kolbi Pipe Marker Co: www.kolbipipemarkers.com/#sle.
3. Seton Identification Products, a Tricor Direct Company: www.seton.com/#sle.
- B. Plastic Tags: Laminated three-layer plastic with engraved black letters on light contrasting background color. Tag size minimum 1-1/2 inch diameter.
- C. Metal Tags: Brass with stamped letters; tag size minimum 1-1/2 inch diameter with smooth edges.
- D. Valve Tag Chart: Typewritten letter size list in anodized aluminum frame.

2.04 STENCILS

- A. Manufacturers:
 1. Brady Corporation: www.bradycorp.com/#sle.
 2. Craftmark Pipe Markers: www.craftmarkid.com/#sle.
 3. Kolbi Pipe Marker Co: www.kolbipipemarkers.com/#sle.
 4. Seton Identification Products, a Tricor Direct Company: www.seton.com/#sle.
- B. Stencils: With clean cut symbols and letters of following size:
 1. 3/4 to 1-1/4 inch Outside Diameter of Insulation or Pipe: 8 inch long color field, 1/2 inch high letters.
 2. 2-1/2 to 6 inch Outside Diameter of Insulation or Pipe: 12 inch long color field, 1-1/4 inch high letters.

2.05 PIPE MARKERS

- A. Manufacturers:
 1. Brimar Industries, Inc: www.pipemarkers.com/#sle.
 2. Kolbi Pipe Marker Co: www.kolbipipemarkers.com/#sle.
 3. Seton Identification Products, a Tricor Company: www.seton.com/#sle.
- B. Color: Comply with ASME A13.1.
- C. Plastic Pipe Markers: Factory fabricated, flexible, semi-rigid plastic, preformed to fit around pipe or pipe covering; minimum information indicating flow direction arrow and identification of fluid being conveyed.
- D. Plastic Tape Pipe Markers: Flexible, vinyl film tape with pressure-sensitive adhesive backing and printed markings.
- E. Color code as follows:
 1. Fire Quenching Fluids: Red with white letters.

2.06 CEILING TACKS

- A. Description: Steel with 3/4 inch diameter color coded head.

PART 3 EXECUTION

3.01 PREPARATION

- A. Degrease and clean surfaces to receive adhesive for identification materials.

3.02 INSTALLATION

- A. Install nameplates with corrosive-resistant mechanical fasteners, or adhesive. Apply with sufficient adhesive to ensure permanent adhesion and seal with clear lacquer.
- B. Install tags with corrosion resistant chain.
- C. Install plastic pipe markers in accordance with manufacturer's instructions.
- D. Use tags on piping 3/4 inch diameter and smaller.
 1. Identify service, flow direction, and pressure.
 2. Install in clear view and align with axis of piping.

- E. Locate ceiling tacks to locate valves above T-bar type panel ceilings. Locate in corner of panel closest to equipment.

END OF SECTION

NOT FOR BIDDING

NOT FOR BIDDING

This page intentionally left blank

SECTION 21 13 00
FIRE-SUPPRESSION SPRINKLER SYSTEMS

PART 1 GENERAL

1.01 SECTION INCLUDES

- A. Wet-pipe sprinkler system.
- B. System design, installation, and certification.

1.02 RELATED REQUIREMENTS

- A. Section 07 84 00 - Firestopping.
- B. Section 21 05 00 - Common Work Results for Fire Suppression: Pipe and fittings.
- C. Section 21 05 23 - General-Duty Valves for Water-Based Fire-Suppression Piping.

1.03 REFERENCE STANDARDS

- A. FM (AG) - FM Approval Guide; Current Edition.
- B. ICC-ES AC01 - Acceptance Criteria for Expansion Anchors in Masonry Elements; 2018, with Editorial Revision (2020).
- C. ICC-ES AC106 - Acceptance Criteria for Predrilled Fasteners (Screw Anchors) in Masonry; 2018, with Editorial Revision (2020).
- D. ICC-ES AC193 - Acceptance Criteria for Mechanical Anchors in Concrete Elements; 2017, with Editorial Revision (2020).
- E. ICC-ES AC308 - Acceptance Criteria for Post-Installed Adhesive Anchors in Concrete Elements; 2023.
- F. NFPA 13 - Standard for the Installation of Sprinkler Systems; Most Recent Edition Adopted by Authority Having Jurisdiction, Including All Applicable Amendments and Supplements.
- G. NFPA 13R - Standard for the Installation of Sprinkler Systems in Low-Rise Residential Occupancies; 2025.
- H. NFPA 1963 - Standard for Fire Hose Connections; 2019.
- I. UL 405 - Standard for Safety Fire Department Connection Devices; Current Edition, Including All Revisions.

1.04 ADMINISTRATIVE REQUIREMENTS

- A. Preinstallation Meeting: Convene one week before starting work of this section.

1.05 SUBMITTALS

- A. See Section 01 30 00 - Administrative Requirements for submittal procedures.
- B. Product Data: Provide data on sprinklers, valves, and specialties, including manufacturers catalog information. Submit performance ratings, rough-in details, weights, support requirements, and piping connections.
- C. Shop Drawings:
 - 1. Submit preliminary layout of finished ceiling areas indicating only sprinkler locations coordinated with ceiling installation.
 - 2. Indicate hydraulic calculations, detailed pipe layout, hangers and supports, sprinklers, components, and accessories. Indicate system controls.
 - 3. Submit shop drawings to Authorities Having Jurisdiction for approval. Submit proof of approval to DEDC, LLC.
- D. Operation and Maintenance Data: Include components of system, servicing requirements, record drawings, inspection data, replacement part numbers and availability, and location and numbers of service depot.

- E. Maintenance Materials: Furnish the following for Del Tech's use in maintenance of project.
 - 1. See Section 01 60 00 - Product Requirements for additional provisions.
 - 2. Extra Sprinklers: Type and size matching those installed in quantity required by referenced NFPA design and installation standard.
 - 3. Sprinkler Wrenches: For each sprinkler type.
- F. Project Record Documents: Record actual locations of sprinklers and deviations of piping from drawings. Indicate drain and test locations.

1.06 QUALITY ASSURANCE

- A. Comply with FM (AG) requirements.
- B. Designer Qualifications: Design system under direct supervision of a Professional Engineer experienced in design of this type of work and licensed in the State in which the Project is located.

1.07 DELIVERY, STORAGE, AND HANDLING

- A. Store products in shipping containers and maintain in place until installation. Provide temporary inlet and outlet caps. Maintain caps in place until installation.

PART 2 PRODUCTS

2.01 MANUFACTURERS

- A. Sprinklers, Valves, and Equipment:
 - 1. Anvil International: www.anvilintl.com/#sle.
 - 2. Tyco Fire Protection Products: www.tyco-fire.com/#sle.
 - 3. Viking Corporation: www.vikinggroupinc.com/#sle.

2.02 SPRINKLER SYSTEM

- A. Sprinkler System: Provide coverage for building areas noted.
- B. Occupancy: Light hazard; comply with NFPA 13.
- C. Water Supply: Determine volume and pressure from water flow test data.
- D. Interface system with building control system.
- E. Storage Cabinet for Spare Sprinklers and Tools: Steel, located adjacent to alarm valve.
- F. Pipe Hanger Fasteners: Attach hangers to structure using appropriate fasteners, as follows:
 - 1. Concrete Wedge Expansion Anchors: Complying with ICC-ES AC193.
 - 2. Masonry Wedge Expansion Anchors: Complying with ICC-ES AC01.
 - 3. Concrete Screw Type Anchors: Complying with ICC-ES AC193.
 - 4. Masonry Screw Type Anchors: Complying with ICC-ES AC106.
 - 5. Concrete Adhesive Type Anchors: Complying with ICC-ES AC308.
 - 6. Other Types: As required.

2.03 SPRINKLERS

- A. Suspended Ceiling Type: Concealed pendant type with matching push on escutcheon plate.
 - 1. Response Type: Quick.
 - 2. Coverage Type: Standard.
 - 3. Fusible Link: Fusible solder link type temperature rated for specific area hazard.
- B. Exposed Area Type: Pendant type with guard.
 - 1. Response Type: Quick.
 - 2. Coverage Type: Standard.
 - 3. Fusible Link: Fusible solder link type temperature rated for specific area hazard.
- C. Sidewall Type: Semi-recessed horizontal sidewall type with matching push on escutcheon plate.

1. Response Type: Quick.
 2. Coverage Type: Standard.
 3. Fusible Link: Fusible solder link type temperature rated for specific area hazard.
- D. Storage Sprinklers: Pendant type with guard.
1. Response Type: Standard.
 2. Coverage Type: Standard.
 3. Fusible Link: Fusible solder link type temperature rated for specific area hazard.
- E. Guards: Finish to match sprinkler finish.

2.04 PIPING SPECIALTIES

- A. Wet Pipe Sprinkler Alarm Valve: Check type valve with divided seat ring, rubber-faced clapper to automatically actuate water motor alarm, pressure retard chamber and variable pressure trim with the following additional capabilities and features:
1. Activate electric alarm.
 2. Test and drain valve.
 3. Replaceable internal components without removing valve from installed position.

PART 3 EXECUTION

3.01 INSTALLATION

- A. Install in accordance with referenced NFPA design and installation standard.
- B. Install equipment in accordance with manufacturer's instructions.
- C. Place pipe runs to minimize obstruction to other work.
- D. Place piping in concealed spaces above finished ceilings.
- E. Apply masking tape or paper cover to ensure concealed sprinklers, cover plates, and sprinkler escutcheons do not receive field paint finish. Remove after painting. Replace painted sprinklers.
- F. Flush entire piping system of foreign matter.
- G. Install guards on sprinklers where indicated.
- H. Hydrostatically test entire system.
- I. Require test be witnessed by Fire Marshal.

END OF SECTION

NOT FOR BIDDING

This page intentionally left blank

SECTION 23 01 30.51
HVAC AIR-DISTRIBUTION SYSTEM CLEANING

PART 1 GENERAL

1.01 SECTION INCLUDES

- A. Cleaning of HVAC duct system, equipment, and related components.

1.02 DEFINITIONS

- A. HVAC System: For purposes of this section, the surfaces to be cleaned include all interior surfaces of the heating, air-conditioning and ventilation system from the points where the air enters the system to the points where the air is discharged from the system, including the inside of air distribution equipment, coils, and condensate drain pans; see NADCA ACR for more details.

1.03 REFERENCE STANDARDS

- A. NADCA ACR - The NADCA Standard for Assessment, Cleaning, and Restoration of HVAC System; 2021.
- B. UL 181 - Standard for Factory-Made Air Ducts and Air Connectors, Current Edition, Including All Revisions.
- C. UL 181A - Closure Systems for Use with Rigid Air Ducts, Current Edition, Including All Revisions.

1.04 QUALITY ASSURANCE

- A. Cleaning Contractor Qualifications: Company specializing in the cleaning and restoration of HVAC systems as specified in this section.
 - 1. Certified by one of the following:
 - a. NADCA, National Air Duct Cleaners Association: www.nadca.com.
 - 2. Having minimum of three years documented experience.
 - 3. Employing for this project a supervisor certified as an Air Systems Cleaning Specialist by NADCA.

PART 2 PRODUCTS

2.01 TOOLS AND EQUIPMENT

- A. Vacuum Devices and Other Tools: Exceptionally clean, in good working order, and sealed when brought into the facility.
- B. Vacuum Devices That Exhaust Air Inside Building, Including Hand-Held and Wet Vacuums: Equipped with HEPA filtration with 99.97 percent collection efficiency for minimum 0.3-micron size particles and DOP test number.
- C. Vacuum Devices That Exhaust Air Outside Building, Including Truck- and Trailer-Mounted Types: Equipped with particulate collection including adequate filtration to contain debris removed from the HVAC system; exhausted in manner that prevents contaminant re-entry to building; compliant with applicable regulations as to outdoor environmental contamination.

2.02 REPLACEMENT PRODUCTS

- A. Fibrous Glass Insulation: Provide material complying with UL 181 equivalent to existing material in quality and thickness.

PART 3 EXECUTION

3.01 PROJECT CONDITIONS

- A. Comply with applicable federal, state, and local requirements.
- B. Perform cleaning, inspection, and remediation in accordance with the recommendations of NADCA "Assessment, Cleaning and Restoration of HVAC Systems" (ACR) and as specified

herein.

- C. Where NADCA ACR uses the terms "recommended", "highly recommended", or "ideally" in regard to a certain procedure or activity, do that unless it is clearly inapplicable to the project.
- D. Obtain Del Tech's approval of proposed temporary locations for large equipment.
- E. Designate a decontamination area and obtain Del Tech's approval.
- F. If unforeseen mold or other biological contamination is encountered, notify DEDC, LLC immediately, identifying areas affected and extent and type of contamination.

3.02 EXAMINATION

- A. Inspect the system as required to determine appropriate methods, tools, equipment, and protection.
- B. Start of cleaning work constitutes acceptance of existing conditions.
- C. When concealed spaces are later made accessible, examine and document interior conditions prior to beginning cleaning.
- D. Document all instances of mold growth, rodent droppings, other biological hazards, and damaged system components.

3.03 PREPARATION

- A. When cleaning work might adversely affect life safety systems, including fire and smoke detection, alarm, and control, coordinate scheduling and testing and inspection procedures with authorities having jurisdiction.
- B. Ensure that electrical components that might be adversely affected by cleaning are de-energized, locked out, and protected prior to beginning work.
- C. Air-Volume Control Devices: Mark the original position of dampers and other air-directional mechanical devices inside the HVAC system prior to starting cleaning.
- D. Access to Concealed Spaces: Use existing service openings and make additional service openings as required to accomplish cleaning and inspection.
 - 1. Do not cut openings in non-HVAC components without obtaining the prior approval of Del Tech.
 - 2. Make new openings in HVAC components in accordance with NADCA Standard 05; do not compromise the structural integrity of the system.
 - 3. Do not cut service openings into flexible duct; disconnect at ends for cleaning and inspection.
- E. Ceiling Tile: Lay-in ceiling tile may be removed to gain access to HVAC systems during the cleaning process; protect tile from damage and reinstall upon completion; replace damaged tile.

3.04 CLEANING

- A. Use any cleaning method recommended by NADCA ACR unless otherwise specified; do not use methods prohibited by NADCA ACR, or that will damage HVAC components or other work, or that will significantly alter the integrity of the system.
- B. Obtain Del Tech's approval before using wet cleaning methods; ensure that drainage is adequate before beginning.
- C. Ducts: Mechanically clean all portions of ducts.
- D. Hoses, Cables, and Extension Rods: Clean using suitable sanitary damp wipes at the time they are being removed or withdrawn from their normal position.
- E. Registers, Diffusers, and Grilles: When removing, take care to prevent containment exposure due to accumulated debris.
- F. Coils: Follow NADCA ACR completely including measuring static pressure drop before and after cleaning; do not remove refrigeration coils from system to clean; report coils that are

permanently impacted.

- G. Collect debris removed during cleaning; ensure that debris is not dispersed outside the HVAC system during the cleaning process.
- H. Store contaminated tools and equipment in polyethylene bags until cleaned in the designated decontamination area.

3.05 REPAIR

- A. Repair openings cut in the ventilation system so that they do not significantly alter the airflow or adversely impact the facility's indoor air quality.
- B. At insulated ducts and components, accomplish repairs in such a manner as to achieve the equivalent thermal value.
- C. Reseal new openings in accordance with NADCA Standard 05.
- D. Reseal rigid fiber glass duct systems using closure techniques that comply with UL 181 or UL 181A.
- E. When new openings are intended to be capable of being re-opened in the future, clearly mark them and report their locations to Del Tech in project report documents.

3.06 FIELD QUALITY CONTROL

- A. Ensure that the following field quality control activities are completed prior to application of any treatments or coatings and prior to returning HVAC system to normal operation.
- B. Visually inspect all portions of the cleaned components; if not visibly clean as defined in NADCA ACR, re-clean and reinspect.
- C. Coils: Cleaning must restore the coil pressure drop to within 10 percent of the coil's original installed pressure drop; if original pressure drop is not known, coil will be considered clean if free of foreign matter and chemical residue based on visual inspection.
- D. Notify DEDC, LLC when cleaned components are ready for inspection.
- E. When directed, re-clean components until they pass.
- F. Submit evidence that all portions of the system required to be cleaned have been cleaned satisfactorily.

3.07 ADJUSTING

- A. After satisfactory completion of field quality control activities, restore adjustable devices to original settings, including, but not limited to, dampers, air directional devices, valves, fuses, and circuit breakers.

3.08 WASTE MANAGEMENT

- A. Double-bag waste and debris in 6 mil, 0.006 inch thick polyethylene plastic bags.
- B. Dispose of debris off-site in accordance with applicable federal, state and local requirements.

END OF SECTION

NOT FOR BIDDING

This page intentionally left blank

SECTION 23 05 17
SLEEVES AND SLEEVE SEALS FOR HVAC PIPING

PART 1 GENERAL

1.01 SECTION INCLUDES

- A. Pipe sleeves.
- B. Pipe-sleeve seals.

1.02 RELATED REQUIREMENTS

- A. Section 23 05 23 - General-Duty Valves for HVAC Piping.
- B. Section 23 05 53 - Identification for HVAC Piping and Equipment: Piping identification.
- C. Section 23 07 19 - HVAC Piping Insulation.

1.03 REFERENCE STANDARDS

- A. ASTM C592 - Standard Specification for Mineral Fiber Blanket Insulation and Blanket-Type Pipe Insulation (Metal-Mesh Covered) (Industrial Type); 2022a.
- B. ASTM E814 - Standard Test Method for Fire Tests of Penetration Firestop Systems; 2023a.
- C. FM (AG) - FM Approval Guide; Current Edition.
- D. UL (DIR) - Online Certifications Directory; Current Edition.

1.04 SUBMITTALS

- A. See Section 01 30 00 - Administrative Requirements for submittal procedures.
- B. Shop Drawings: Indicate pipe materials used, joining methods, supports, floor and wall penetration seals. Indicate installation, layout, weights, mounting and support details, and piping connections.

1.05 QUALITY ASSURANCE

- A. Clean equipment, pipes, valves, and fittings of grease, metal cuttings, and sludge that may have accumulated from the installation and testing of the system.

1.06 DELIVERY, STORAGE, AND HANDLING

- A. Deliver and store sleeve and sleeve seals in shipping containers, with labeling in place.
- B. Provide temporary protective coating on cast iron and steel sleeves if shipped loose.

PART 2 PRODUCTS

2.01 PIPE SLEEVES

- A. Manufacturers:
 - 1. Flexicraft Industries; Pipe Wall Sleeve: www.flexicraft.com/#sle.
 - 2. Substitutions: See Section 01 60 00 - Product Requirements.
- B. Vertical Piping:
 - 1. Sleeve Length: 1 inch above finished floor.
 - 2. Provide sealant for watertight joint.
 - 3. Blocked Out Floor Openings: Provide 1-1/2 inch angle set in silicon adhesive around opening.
 - 4. Drilled Penetrations: Provide 1-1/2 inch angle ring or square set in silicone adhesive around penetration.
- C. Plastic or Sheet Metal: Pipe passing through interior walls, partitions, and floors, unless steel or brass sleeves are specified below.
- D. Clearances:
 - 1. Provide allowance for insulated piping.

2. Wall, Floor, Partitions, and Beam Flanges: 1 inch greater than external pipe diameter.
3. All Rated Openings: Caulked tight with fire stopping material in compliance with ASTM E814 in accordance with Section 07 84 00 to prevent the spread of fire, smoke, and gases.

2.02 PIPE-SLEEVE SEALS

- A. Manufacturers:
 1. Advance Products & Systems, LLC; Innerlynx: www.apsonline.com/#sle.
 2. American Polywater Corporation; PGKD Modular Seals: www.polywater-haufftechnik.com/#sle.
 3. Flexicraft Industries; PipeSeal: www.flexicraft.com/#sle.
- B. Modular Mechanical Sleeve-Seal:
 1. Elastomer-based interlocking links continuously fill annular space between pipe and wall-sleeve, wall or casing opening.
 2. Watertight seal between pipe and wall-sleeve, wall or casing opening.
 3. Size and select seal component materials in accordance with service requirements.
 4. Glass-reinforced plastic pressure end plates.
- C. Sealing Compounds:
 1. Provide packing and sealing compound to fill pipe to sleeve thickness.
 2. Combined packing and seal compound is to match partition fire-resistance hourly rating.
- D. Wall Sleeve: PVC material with waterstop collar, and nailer end-caps.

PART 3 EXECUTION

3.01 PREPARATION

- A. Ream pipe and tube ends. Remove burrs. Bevel plain end ferrous pipe.
- B. Remove scale and foreign material, from inside and outside, before assembly.

3.02 INSTALLATION

- A. Route piping in orderly manner, plumb and parallel to building structure. Maintain gradient.
- B. Install piping to conserve building space, to not interfere with use of space and other work.
- C. Install piping and pipe sleeves to allow for expansion and contraction without stressing pipe, joints, or connected equipment.
- D. Inserts:
 1. Provide inserts for placement in concrete formwork.
 2. Provide hooked rod to concrete reinforcement section for inserts carrying pipe over 4 inches.
 3. Where concrete slabs form finished ceiling, locate inserts flush with slab surface.
 4. Where inserts are omitted, drill through concrete slab from below and provide through-bolt with recessed square steel plate and nut above slab.
- E. Structural Considerations:
 1. Do not penetrate building structural members unless indicated.
- F. Provide sleeves when penetrating footings, floors, walls, partitions, and _____. Seal pipe including sleeve penetrations to achieve fire resistance equivalent to fire separation required.
 1. Aboveground Piping:
 - a. Pack solid using mineral fiber in compliance with ASTM C592.
 - b. Fill space with an elastomer caulk to a depth of 0.50 inch where penetrations occur between conditioned and unconditioned spaces.
- G. Manufactured Sleeve-Seal Systems:
 1. Install manufactured sleeve-seal systems in sleeves located in grade slabs and exterior concrete walls at piping entrances into building.

2. Provide sealing elements of the size, quantity, and type required for the piping and sleeve inner diameter or penetration diameter.
 3. Locate piping in center of sleeve or penetration.
 4. Install field assembled sleeve-seal system components in annular space between sleeve and piping.
 5. Tighten bolting for a water-tight seal.
 6. Install in accordance with manufacturer's recommendations.
- H. When installing more than one piping system material, ensure system components are compatible and joined to ensure the integrity of the system. Provide necessary joining fittings. Ensure flanges, union, and couplings for servicing are consistently provided.

END OF SECTION

NOT FOR BIDDING

NOT FOR BIDDING

This page intentionally left blank

SECTION 23 05 23
GENERAL-DUTY VALVES FOR HVAC PIPING

PART 1 GENERAL

1.01 SECTION INCLUDES

- A. Angle valves.
- B. Globe valves.
- C. Ball valves.
- D. Butterfly valves.
- E. Check valves.
- F. Gate valves.
- G. Plug valves.

1.02 RELATED REQUIREMENTS

- A. Section 23 05 53 - Identification for HVAC Piping and Equipment.
- B. Section 23 07 19 - HVAC Piping Insulation.

1.03 ABBREVIATIONS AND ACRONYMS

- A. CWP: Cold working pressure.
- B. EPDM: Ethylene propylene copolymer rubber.
- C. NBR: Acrylonitrile-butadiene, Buna-N, or nitrile rubber.
- D. NRS: Nonrising stem.
- E. OS&Y: Outside screw and yoke.
- F. PTFE: Polytetrafluoroethylene.
- G. RS: Rising stem.
- H. TFE: Tetrafluoroethylene.
- I. WOG: Water, oil, and gas.

1.04 REFERENCE STANDARDS

- A. API STD 594 - Check Valves: Flanged, Lug, Wafer, and Butt-Welding; 2022.
- B. ASME B1.20.1 - Pipe Threads, General Purpose, Inch; 2013 (Reaffirmed 2018).
- C. ASME B16.1 - Gray Iron Pipe Flanges and Flanged Fittings: Classes 25, 125, and 250; 2020.
- D. ASME B16.18 - Cast Copper Alloy Solder Joint Pressure Fittings; 2021.
- E. ASME B31.9 - Building Services Piping; 2020.
- F. ASTM A48/A48M - Standard Specification for Gray Iron Castings; 2022.
- G. ASTM A126 - Standard Specification for Gray Iron Castings for Valves, Flanges, and Pipe Fittings; 2004 (Reapproved 2023).
- H. ASTM A536 - Standard Specification for Ductile Iron Castings; 1984, with Editorial Revision (2019).
- I. ASTM B61 - Standard Specification for Steam or Valve Bronze Castings; 2015 (Reapproved 2021).
- J. ASTM B62 - Standard Specification for Composition Bronze or Ounce Metal Castings; 2017.
- K. AWWA C606 - Grooved and Shouldered Joints; 2022.
- L. MSS SP-45 - Drain and Bypass Connections; 2020.

- M. MSS SP-67 - Butterfly Valves; 2022.
- N. MSS SP-70 - Gray Iron Gate Valves, Flanged and Threaded Ends; 2011.
- O. MSS SP-71 - Gray Iron Swing Check Valves, Flanged and Threaded Ends; 2018.
- P. MSS SP-72 - Ball Valves with Flanged or Butt-Welding Ends for General Service; 2010a.
- Q. MSS SP-78 - Gray Iron Plug Valves, Flanged and Threaded Ends; 2011.
- R. MSS SP-80 - Bronze Gate, Globe, Angle, and Check Valves; 2019.
- S. MSS SP-85 - Gray Iron Globe and Angle Valves, Flanged and Threaded Ends; 2011.
- T. MSS SP-110 - Ball Valves Threaded, Socket-Welding, Solder Joint, Grooved and Flared Ends; 2010, with Errata .

1.05 SUBMITTALS

- A. See Section 01 30 00 - Administrative Requirements for submittal procedures.
- B. Product Data: Provide data on valves including manufacturers catalog information. Submit performance ratings, rough-in details, weights, support requirements, and piping connections.
- C. Operation and Maintenance Data: Include manufacturer's descriptive literature, operating instructions, maintenance and repair data, and parts listings.
- D. Maintenance Materials: Furnish Del Tech with one wrench for every five plug valves, in each size of square plug valve head.
 - 1. See Section 01 60 00 - Product Requirements for additional provisions.

1.06 DELIVERY, STORAGE, AND HANDLING

- A. Prepare valves for shipping as follows:
 - 1. Minimize exposure of operable surfaces by setting plug and ball valves to open position.
 - 2. Protect valve parts exposed to pipe medium against rust and corrosion.
 - 3. Protect valve piping connections such as grooves, weld ends, threads, and flange faces.
 - 4. Adjust globe, gate, and angle valves to the closed position to avoid clattering.
 - 5. Secure check valves in either the closed position or open position.
 - 6. Adjust butterfly valves to closed or partially closed position.
- B. Use the following precautions during storage:
 - 1. Maintain valve end protection and protect flanges and specialties from dirt.
 - a. Provide temporary inlet and outlet caps.
 - b. Maintain caps in place until installation.
 - 2. Store valves in shipping containers and maintain in place until installation.
 - a. Store valves indoors in dry environment.
 - b. Store valves off the ground in watertight enclosures when indoor storage is not an option.
- C. Exercise the following precautions for handling:
 - 1. Handle large valves with sling, modified to avoid damage to exposed parts.
 - 2. Avoid the use of operating handles or stems as rigging or lifting points.

PART 2 PRODUCTS

2.01 APPLICATIONS

- A. Listed pipe sizes shown using nominal pipe sizes (NPS) and nominal diameter (DN).
- B. Provide the following valves for the applications if not indicated on drawings:
 - 1. Throttling (Hydronic): Butterfly, Ball, Globe, and Angle.
 - 2. Isolation (Shutoff): Butterfly, Gate, Ball, and Plug.
- C. Condenser Water Valves:
 - 1. Size 2 inch and Smaller, Brass and Bronze Valves:

- a. Threaded ends.
- b. Angle: Bronze disc, Class 125.
- c. Ball: Full port, one piece, brass trim.
- d. Swing Check: Bronze disc, Class 125.
- e. Gate: NRS, Class 125.
- f. Globe: Bronze disc, Class 125.
- 2. Size 2-1/2 inch and Larger, Iron Valves:
 - a. 2-1/2 inch to 4 inch: Threaded ends.
 - b. Ball: 2-1/2 inch to 10 inch, Class 150.
 - c. Single-Flange Butterfly: 2-1/2 inch to 12 inch, aluminum-bronze disc, EPDM seat, 200 CWP.
 - d. Grooved-End Butterfly: 2-1/2 inch to 12 inch, 175 CWP.
 - e. Swing Check: Metal seats, Class 125.
 - f. Swing Check with Closure Control, 2-1/2 inch to 12 inch: Lever and spring, Class 125.
 - g. Grooved-End Swing Check: 3 inch to 12 inch, 300 CWP.
 - h. Iron Center-Guided Check: 2-1/2 inch to 24 inch, compact wafer, metal seat, Class 125.
 - i. Iron Plate-Type Check: Single plate, metal seat, Class 125.
 - j. Iron Gate: NRS, Class 125.
 - k. Iron Globe: 2-1/2 inch to 12 inch, Class 125.
 - l. Lubricated Plug: Regular gland, Class 125.

2.02 GENERAL REQUIREMENTS

- A. Valve Pressure and Temperature Ratings: No less than rating indicated; as required for system pressures and temperatures.
- B. Valve Sizes: Match upstream piping unless otherwise indicated.
- C. Valve Actuator Types:
 - 1. Wrench: Plug valves with square heads.
- D. Valves in Insulated Piping: Provide 2 inch stem extensions and the following features:
 - 1. Gate Valves: Rising stem.
 - 2. Ball Valves: Extended operating handle of non-thermal-conductive material, and protective sleeve that allows operation of valve without breaking the vapor seal or disturbing insulation.
 - 3. Butterfly Valves: Extended neck.
 - 4. Memory Stops: Fully adjustable after insulation is installed.
- E. Valve-End Connections:
 - 1. Threaded End Valves: ASME B1.20.1.
 - 2. Flanges on Iron Valves: ASME B16.1 for flanges on iron valves.
 - 3. Solder Joint Connections: ASME B16.18.
 - 4. Grooved End Connections: AWWA C606.
- F. General ASME Compliance:
 - 1. Building Services Piping Valves: ASME B31.9.
- G. Valve Bypass and Drain Connections: MSS SP-45.
- H. Source Limitations: Obtain each valve type from a single manufacturer.

2.03 BRONZE, ANGLE VALVES

- A. CWP Rating: Class 125: 200 psi and Class 150: 300 psi:
 - 1. Comply with MSS SP-80, Type 1.
 - 2. Body: Bronze; ASTM B62, with integral seat and screw in bonnet.

3. Ends: Threaded.
4. Stem: Bronze.
5. Disc: Bronze, PTFE, or TFE.
6. Packing: Asbestos free.
7. Handwheel: Bronze or aluminum.

2.04 IRON, GLOBE VALVES

- A. CWP Ratings: Class 125: 200 psi and Class 250: 500 psi:
 1. Comply with MSS SP-85, Type I.
 2. Body: Gray iron; ASTM A126, with bolted bonnet.
 3. Ends: Flanged.
 4. Trim: Bronze.
 5. Packing and Gasket: Asbestos free.
 6. Operator: Handwheel or chainwheel.
 7. Manufacturers:
 - a. Apollo Valves: www.apollovalves.com/#sle.
 - b. FNW; 661: www.fnw.com/#sle.

2.05 BRASS, BALL VALVES

- A. One Piece, Full Port with Brass Trim and Push-to-fit or Threaded Connections:
 1. Comply with MSS SP-110.
 2. CWP Rating: 200 psi.
 3. Body: Forged brass.
 4. Ends: Threaded.
 5. Seats: PTFE or TFE.
 6. Stem: Brass.
 7. Ball: Chrome-plated brass.
 8. Operator: Handle.
- B. Two Piece, Full Port with Stainless Steel Trim and Female Thread, Male thread, or Solder Connections:
 1. Comply with MSS SP-110.
 2. SWP Rating: 150 psi.
 3. WOG Rating: 600 psi.
 4. Vacuum Rating: 28.9 in-Hg.
 5. Body: Forged brass.
 6. Seats: PTFE.
 7. Stem: Stainless Steel.
 8. Ball: Chrome-plated brass.
 9. Operator: Lockable handle and memory stop.
- C. Two Piece, Full Port with Press Connection:
 1. WOG Rating: 250 psi.
 2. Body: Forged brass.
 3. Seats: EPDM.
 4. Ball: Chrome-plated brass.
 5. Blow-out Proof Stem: Forged brass.
 6. Operator: Provide lockable handle.
 7. Maximum Service Temperature: 250 degrees F.

2.06 BRONZE, BALL VALVES

- A. General:
 1. Fabricate from dezincification resistant material.
 2. Copper alloys containing more than 15 percent zinc are not permitted.

- B. One Piece, Reduced Port with Bronze Trim:
 - 1. Comply with MSS SP-110.
 - 2. CWP Rating: 400 psi.
 - 3. Ends: Threaded.
 - 4. Seats: PTFE.
 - 5. Stem: Bronze.
 - 6. Ball: Chrome plated brass.
- C. Two Piece, Full Port with Bronze or Brass Trim:
 - 1. Comply with MSS SP-110.
 - 2. WSP Rating: 150 psi.
 - 3. WOG Rating: 400 psi.
 - 4. Body: Forged bronze or dezincified-brass alloy.
 - 5. End Connections: Pipe thread or solder.
 - 6. Seats: PTFE.
 - 7. Stem: Bronze or brass.
 - 8. Ball: Chrome plated brass.
 - 9. Operator: Provide lockable handle and stem extension.

2.07 IRON, BALL VALVES

- A. Split Body, Full Port:
 - 1. Comply with MSS SP-72.
 - 2. CWP Rating: 200 psi.
 - 3. Body: ASTM A126, gray iron.
 - 4. Ends: Flanged.
 - 5. Seats: PTFE.
 - 6. Stem: Stainless steel.
 - 7. Ball: Stainless steel.

2.08 IRON, SINGLE FLANGE BUTTERFLY VALVES

- A. Wafer Style:
 - 1. Comply with MSS SP-67, Type I.
 - 2. Wafer Style, CWP Ratings:
 - a. Sizes 2 to 12 inch: 200 psi.
 - b. Sizes 14 to 24 inch: 150 psi.
 - c. Vacuum Service: Down to 29.9 in-Hg.
 - 3. Body Material: ASTM A126 cast iron or ASTM A536 ductile iron.
 - 4. Stem: One or two-piece stainless steel.
 - 5. Seat: NBR.
 - 6. Disc: Aluminum-bronze.

2.09 IRON, GROOVED-END BUTTERFLY VALVES

- A. CWP Rating: 175 psi.
 - 1. Comply with MSS SP-67, Type I.
 - 2. Body: Coated ductile iron.
 - 3. Stem: Two-piece stainless steel.
 - 4. Disc: Coated ductile iron.
 - 5. Disc Seal: EPDM.

2.10 BRASS, INLINE CHECK VALVES

- A. Class 150: CWP Rating: 200 psi .
- B. Maximum Service Temperature: 250 degrees F.

- C. Body: Forged brass.
- D. Disc: Forged brass.
- E. Seal: PTFE, bubble tight.
- F. End-Connections: Press.

2.11 BRASS, HORIZONTAL SWING CHECK VALVES

- A. Threaded End-Connections:
 - 1. Class 125: CWP Rating: 200 psi.
 - 2. Body: Forged brass.
 - 3. Disc: Forged brass.
 - 4. Hinge-Pin, Screw, and Cap: Forged brass.
- B. Press End-Connections:
 - 1. Class 125: WOG Rating: 200 psi.
 - 2. Body: Forged brass.
 - 3. Disc: Forged brass.
 - 4. Hinge-Pin, Screw, and Cap: Forged brass.

2.12 BRONZE, SWING CHECK VALVES

- A. Class 125:
 - 1. Pressure and Temperature Rating: MSS SP-80, Type 3.
 - 2. Design: Y-pattern, horizontal or vertical flow.
 - 3. WSP Rating: 200 psi.
 - 4. Body: Bronze, ASTM B62.
 - 5. End Connections: Threaded or soldered.
 - 6. Disc: Bronze.
- B. Class 150:
 - 1. Pressure and Temperature Rating: MSS SP-80, Type 3.
 - 2. Design: Y-pattern, horizontal or vertical flow.
 - 3. CWP Rating: 300 psi.
 - 4. Body: Bronze, ASTM B62.
 - 5. End Connections: Threaded or soldered.
 - 6. Disc: Bronze.

2.13 IRON, SWING CHECK VALVES WITH CLOSURE CONTROL

- A. Class 125:
 - 1. Comply with MSS SP-71, Type I.
 - 2. Body Design: Clear or full waterway.
 - 3. Body Material: ASTM A126, gray iron with bolted bonnet.
 - 4. Ends: Flanged.
 - 5. Trim: Bronze.
 - 6. Gasket: Asbestos free.
 - 7. Closer Control: Factory installed, exterior lever, and spring or weight.

2.14 IRON, GROOVED-END SWING CHECK VALVES

- A. Class 300:
 - 1. CWP Rating: 300 psi.
 - 2. Body Material: ASTM A536, Grade 65-45-12 ductile iron.
 - 3. Seal: EPDM or Nitrile.
 - 4. Disc: Ductile iron.
 - 5. Coating: Black, non-lead paint.

2.15 BRONZE, GATE VALVES

- A. Rising Stem or OS&Y:
 - 1. Pressure-Temperature Range: MSS SP-80, Type I.
 - 2. Body: ASTM B62, bronze with integral seat and screw-in bonnet.
 - 3. End Connections: Threaded or solder.
 - 4. Stem: Bronze.
 - 5. Disc: Solid wedge; bronze.
 - 6. Packing: Asbestos free.
 - 7. Handwheel Operator: Malleable iron, bronze, or aluminum.
- B. Nonrising Stem or NRS:
 - 1. Pressure-Temperature Range: MSS SP-80, Type I.
 - 2. Class 125:
 - 3. Class 150: CWP Rating; 300 psi.
 - 4. Body: ASTM B62, bronze with integral seat and screw-in bonnet.
 - 5. Ends Connections: Threaded or solder.
 - 6. Stem: Bronze.
 - 7. Disc: Solid wedge; bronze.
 - 8. Packing: Asbestos free.
 - 9. Handwheel Operator: Malleable iron, bronze, or aluminum.

2.16 IRON, GATE VALVES

- A. NRS or OS&Y:
 - 1. Comply with MSS SP-70, Type I.
 - 2. Body Material: Gray iron with bolted bonnet.
 - 3. Ends: Flanged.
 - 4. Trim: Bronze.
 - 5. Disc: Solid wedge.
 - 6. Packing and Gasket: Asbestos free.

2.17 LUBRICATED PLUG VALVES

- A. Regular Gland and Cylindrical with Threaded Ends:
 - 1. Comply with MSS SP-78, Type II.
 - 2. Body Material: Cast iron with lubrication sealing system.
 - 3. Pattern: Regular or short.
 - 4. Plug: Cast iron or bronze with sealant groove.

PART 3 EXECUTION

3.01 EXAMINATION

- A. Discard all packing materials and verify that valve interior, including threads and flanges, are completely clean without signs of damage or degradation that could result in leakage.
- B. Verify valve parts to be fully operational in all positions from closed to fully open.
- C. Confirm gasket material to be suitable for the service, to be of correct size, and without defects that could compromise effectiveness.
- D. Should valve is determined to be defective, replace with new valve.

3.02 INSTALLATION

- A. Provide unions or flanges with valves to facilitate equipment removal and maintenance while maintaining system operation and full accessibility for servicing.
- B. Provide separate valve support as required and locate valve with stem at or above center of piping, maintaining unimpeded stem movement.

- C. Where valve support members are welded to structural building framing, scrape, brush clean, and apply one coat of zinc-rich primer to welds.
- D. Install check valves where necessary to maintain direction of flow as follows:
 - 1. Lift Check: Install with stem plumb and vertical.
 - 2. Swing Check: Install horizontal maintaining hinge pin level.

END OF SECTION

NOT FOR BIDDING

SECTION 23 05 29
HANGERS AND SUPPORTS FOR HVAC PIPING AND EQUIPMENT

PART 1 GENERAL

1.01 SECTION INCLUDES

- A. Support and attachment components.

1.02 RELATED REQUIREMENTS

- A. Section 03 30 00 - Cast-in-Place Concrete: Concrete equipment pads.
- B. Section 23 05 48 - Vibration and Seismic Controls for HVAC.

1.03 REFERENCE STANDARDS

- A. ASTM A123/A123M - Standard Specification for Zinc (Hot-Dip Galvanized) Coatings on Iron and Steel Products; 2017.
- B. ASTM A153/A153M - Standard Specification for Zinc Coating (Hot-Dip) on Iron and Steel Hardware; 2023.
- C. ASTM A181/A181M - Standard Specification for Carbon Steel Forgings, for General-Purpose Piping; 2023.
- D. ASTM A36/A36M - Standard Specification for Carbon Structural Steel; 2019.
- E. ASTM A47/A47M - Standard Specification for Ferritic Malleable Iron Castings; 1999, with Editorial Revision (2022).
- F. ASTM A283/A283M - Standard Specification for Low and Intermediate Tensile Strength Carbon Steel Plates; 2018.
- G. ASTM A395/A395M - Standard Specification for Ferritic Ductile Iron Pressure-Retaining Castings for Use at Elevated Temperatures; 1999 (Reapproved 2022).
- H. ASTM A653/A653M - Standard Specification for Steel Sheet, Zinc-Coated (Galvanized) or Zinc-Iron Alloy-Coated (Galvannealed) by the Hot-Dip Process; 2023.
- I. ASTM A1011/A1011M - Standard Specification for Steel, Sheet and Strip, Hot-Rolled, Carbon, Structural, High-Strength Low-Alloy, High-Strength Low-Alloy with Improved Formability, and Ultra-High Strength; 2023.
- J. ASTM B633 - Standard Specification for Electrodeposited Coatings of Zinc on Iron and Steel; 2023.
- K. ASTM E84 - Standard Test Method for Surface Burning Characteristics of Building Materials; 2023d.
- L. FM (AG) - FM Approval Guide; Current Edition.
- M. MFMA-4 - Metal Framing Standards Publication; 2004.
- N. MSS SP-58 - Pipe Hangers and Supports - Materials, Design, Manufacture, Selection, Application, and Installation; 2018, with Amendment (2019).
- O. NFPA 101 - Life Safety Code; Most Recent Edition Adopted by Authority Having Jurisdiction, Including All Applicable Amendments and Supplements.
- P. UL (DIR) - Online Certifications Directory; Current Edition.
- Q. UL 723 - Standard for Test for Surface Burning Characteristics of Building Materials; Current Edition, Including All Revisions.

1.04 ADMINISTRATIVE REQUIREMENTS

- A. Coordination:
 - 1. Coordinate sizes and arrangement of supports and bases with the actual equipment and components to be installed.

2. Coordinate the work with other trades to provide additional framing and materials required for installation.
 3. Coordinate compatibility of support and attachment components with mounting surfaces at the installed locations.
 4. Coordinate the arrangement of supports with ductwork, piping, equipment and other potential conflicts installed under other sections or by others.
 5. Notify DEDC, LLC of any conflicts with or deviations from Contract Documents. Obtain direction before proceeding with work.
- B. Sequencing:
1. Do not install products on or provide attachment to concrete surfaces until concrete has fully cured in accordance with Section 03 30 00.

1.05 SUBMITTALS

- A. See Section 01 30 00 - Administrative Requirements for submittal procedures.
- B. Product Data: Provide manufacturer's standard catalog pages and data sheets for channel (strut) framing systems, nonpenetrating rooftop supports, post-installed concrete and masonry anchors, and thermal insulated pipe supports.
- C. Shop Drawings: Include details for fabricated hangers and supports where materials or methods other than those indicated are proposed for substitution.

1.06 QUALITY ASSURANCE

- A. Comply with applicable building code.
- B. Maintain at the project site a copy of each referenced document that prescribes execution requirements.

1.07 DELIVERY, STORAGE, AND HANDLING

- A. Receive, inspect, handle, and store products in accordance with manufacturer's instructions.

PART 2 PRODUCTS

2.01 SUPPORT AND ATTACHMENT COMPONENTS

- A. General Requirements:
 1. Provide all required hangers, supports, anchors, fasteners, fittings, accessories, and hardware as necessary for the complete installation of plumbing work.
 2. Provide products listed, classified, and labeled as suitable for the purpose intended, where applicable.
 3. Where support and attachment component types and sizes are not indicated, select in accordance with manufacturer's application criteria as required for the load to be supported. Include consideration for vibration, equipment operation, and shock loads where applicable.
 4. Steel Components: Use corrosion resistant materials suitable for the environment where installed.
 - a. Zinc-Plated Steel: Electroplated in accordance with ASTM B633.
 - b. Galvanized Steel: Hot-dip galvanized after fabrication in accordance with ASTM A123/A123M or ASTM A153/A153M.
- B. Prefabricated Trapeze-Framed Metal Strut Systems:
 1. Manufacturers:
 - a. ABB Installation Products: electrification.us.abb.com/#sle.
 - b. B-Line, a brand of Eaton Corporation: www.eaton.com/#sle.
 - c. Gripple, Inc; Fast Track - Standard: www.gripple.com/#sle.
 - d. Source Limitations: Furnish hardware, fittings, and accessories from single manufacturer.

2. MFMA-4 compliant, pre-fabricated, MSS SP-58 type 59 continuous-slot metal strut channel with associated tracks, fittings, and related accessories.
 3. Strut Channel or Bracket Material:
 - a. Indoor Dry Locations: Use painted steel, zinc-plated steel, or galvanized steel.
 4. Minimum Channel Thickness: Steel sheet, 12 gauge, 0.1046 inch.
 5. Minimum Channel Dimensions: 1-5/8 inch width by 13/16 inch height.
 6. Accessories: Provide bracket covers, cable basket clips, cable tray clips, clamps, conduit clamps, fire-retarding brackets, j-hooks, protectors, and vibration dampeners.
- C. Strut Channels:
1. Manufacturers:
 - a. B-Line, a brand of Eaton Corporation: www.eaton.com/#sle.
 - b. Gripple, Inc; Universal Bracket: www.gripple.com/#sle.
 - c. Unistrut, a brand of Atkore International Inc: www.unistrut.com/#sle.
 - d. Source Limitations: Furnish hardware, fittings, and accessories from single manufacturer.
 2. ASTM A653/A653M galvanized steel bracket with clamps for surface mounting of piping or plumbing equipment support.
 3. Channel or Bracket Kits: Include rods, brackets, end-fixed fittings, covers, clips, and other related hardware required to complete sectional trapeze section for piping or other support.
- D. Channel Nuts:
1. Provide carbon steel channel nut with epoxy copper or zinc finish and long, regular, or short spring.
- E. Hanger Rods:
1. Threaded zinc-plated steel unless otherwise indicated.
 2. Minimum Size, Unless Otherwise Indicated or Required:
 - a. Equipment Supports: 1/2 inch diameter.
 - b. Piping up to 1 inch: 1/4 inch diameter.
 - c. Piping larger than 1 inch: 3/8 inch diameter.
 - d. Trapeze Support for Multiple Pipes: 3/8 inch diameter.
- F. Cable Hanging System Kits:
1. Manufacturers:
 - a. B-Line, a brand of Eaton Corporation: www.eaton.com/#sle.
 - b. Ductmate Industries, Inc: ductmate.com/#sle.
 - c. Gripple, Inc: www.gripple.com/#sle.
 - d. Source Limitations: Furnish hardware, fittings, and accessories from single manufacturer.
 2. Provide cable-wire in bulk or precut lengths with respective cable hangers as required to hold minimum weight of 120 lb.
 3. Accessories: Provide brackets, clip or c-clip hangers, covers, and y-hook hangers.
- G. Pipe Supports:
1. Material: ASTM A395/A395M ductile iron, ASTM A36/A36M carbon steel, ASTM A47/A47M malleable iron, ASTM A181/A181M forged steel, or ASTM A283/A283M steel.
 2. Liquid Temperatures Up To 122 degrees F:
 - a. Overhead Support: MSS SP-58 Types 1, 3 through 12.
 - b. Support From Below: MSS SP-58 Types 35 through 38.
 3. Operating Temperatures from 122 to 446 degrees F:
 - a. Overhead Support: MSS SP-58 Type 1 or 3 through 12, with appropriate saddle of MSS SP-58 Type 40 for insulated pipe.
- H. Roller Chairs:

1. Manufacturers:
 - a. ASC Engineered Solutions: www.asc-es.com/#sle.
 - b. FNW; 7901: www.fnw.com/#sle.
 - c. Substitutions: See Section 01 60 00 - Product Requirements.
 - d. Source Limitations: Furnish hardware, fittings, and accessories from single manufacturer.
2. MSS SP-58 type 43 based on required load, nonconductive and corrosion resistant.
3. Steel Yoke Type: MSS SP-58 type 44, vertically adjustable, nonconductive, and corrosion resistant.
4. Material: Zinc plated ASTM A36/A36M carbon steel or ASTM A47/A47M malleable iron.
- I. Pipe Stanchions:
 1. Manufacturers:
 - a. Anvil International; H-Block: www.anvilintl.com/#sle.
 - b. Substitutions: See Section 01 60 00 - Product Requirements.
 - c. Source Limitations: Furnish hardware, fittings, and accessories from single manufacturer.
 2. Material: Malleable iron, ASTM A47/A47M; or carbon steel, ASTM A36/A36M.
 3. Provide coated or plated saddles to isolate steel hangers from dissimilar metal tube or pipe.
 4. For pipe runs, use stanchions of same type and material where vertical adjustment is required for stationary pipe.
- J. Beam Clamps:
 1. Manufacturers:
 - a. FNW; 7201: www.fnw.com/#sle.
 - b. Substitutions: See Section 01 60 00 - Product Requirements.
 - c. Source Limitations: Furnish hardware, fittings, and accessories from single manufacturer.
 2. MSS SP-58 types 19 through 23, 25 or 27 through 30 based on required load.
 3. Beam C-Clamp: MSS SP-58 type 23, malleable iron and steel with plain, stainless steel, and zinc finish.
 4. Small or Junior Beam Clamp: MSS SP-58 type 19, malleable iron with plain finish. For inverted usage provide manufacturer listed size(s).
 5. Wide Mouth Beam Clamp: MSS SP-58 type 19, malleable iron with plain finish.
 6. Centerload Beam Clamp with Extension Piece: MSS SP-58 type 30, malleable iron with plain finish.
 7. FM (AG) and UL (DIR) Approved Beam Clamp: MSS SP-58 type 19, plain finish,
 8. Provide clamps with hardened steel cup-point set screws and lock-nuts for anchoring in place.
 9. Material: ASTM A395/A395M ductile iron, ASTM A36/A36M carbon steel, ASTM A47/A47M malleable iron, ASTM A181/A181M forged steel, or ASTM A283/A283M steel.
- K. Riser Clamps:
 1. Manufacturers:
 - a. FNW; 7020: www.fnw.com/#sle.
 - b. Substitutions: See Section 01 60 00 - Product Requirements.
 - c. Source Limitations: Furnish hardware, fittings, and accessories from single manufacturer.
 2. For insulated pipe runs, provide two bolt-type clamps designed for installation under insulation.
 3. MSS SP-58 type 1 or 8, carbon steel or steel with epoxy plated, plain, stainless steel, or zinc plated finish.

-
4. Medium Split Horizontal Pipe Clamp: MSS SP-58 type 4, carbon steel or stainless steel with epoxy plated, plain, stainless steel, or zinc plated finish.
 5. Copper Tube Pipe Clamp: MSS SP-58 type 8, epoxy plated copper.
 6. UL (DIR) listed: Pipe sizes 1/2 to 8 inch.
- L. U-Bolts:
1. Manufacturers:
 - a. FNW; 7610: www.fnw.com/#sle.
 - b. Substitutions: See Section 01 60 00 - Product Requirements.
 - c. Source Limitations: Furnish hardware, fittings, and accessories from single manufacturer.
 2. MSS SP-58 Type 24, carbon steel u-bolt for pipe support or anchoring.
- M. Offset Pipe Clamps: Double-leg design two-piece pipe clamp.
- N. Strut Clamps:
1. Manufacturers:
 - a. FNW; 7815: www.fnw.com/#sle.
 - b. Substitutions: See Section 01 60 00 - Product Requirements.
 - c. Source Limitations: Furnish hardware, fittings, and accessories from single manufacturer.
 2. Pipe Clamp: Two-piece rigid, universal, or outer diameter type, carbon steel with epoxy copper or zinc finish.
 3. Service Temperature Range: Minus 65 to 275 degrees F.
- O. Pipe Hangers:
1. Split Ring Hangers:
 - a. Manufacturers:
 - 1) FNW; 7001: www.fnw.com/#sle.
 - 2) Substitutions: See Section 01 60 00 - Product Requirements.
 - 3) Source Limitations: Furnish hardware, fittings, and accessories from single manufacturer.
 - b. Provide hinged splitting and yoke roller hanger with epoxy copper or plain finish.
 - c. Material: ASTM A47/A47M malleable iron or ASTM A36/A36M carbon steel.
 - d. Provide hanger rod and nuts of the same type and material for a given pipe run.
 - e. Provide coated or plated hangers to isolate steel hangers from dissimilar metal tube or pipe.
 2. Band Hangers, Adjustable:
 - a. Manufacturers:
 - 1) Gripple, Inc; Universal Clamp (Threaded): www.gripple.com/#sle.
 - 2) Substitutions: See Section 01 60 00 - Product Requirements.
 - 3) Source Limitations: Furnish hardware, fittings, and accessories from single manufacturer.
 - b. MSS SP-58 Type 7 or 9, Zinc-plated ASTM A1011/A1011M steel or ASTM A653/A653M carbon steel.
 3. J-Hangers, Adjustable:
 - a. Manufacturers:
 - 1) FNW; 7025: www.fnw.com/#sle.
 - 2) Substitutions: See Section 01 60 00 - Product Requirements.
 - 3) Source Limitations: Furnish hardware, fittings, and accessories from single manufacturer.
 - b. MSS SP-58 Type 5, Zinc-plated ASTM A1011/A1011M steel or ASTM A653/A653M carbon steel.
 4. Swivel Ring Hangers, Adjustable:

- a. Manufacturers:
 - 1) FNW; 7010: www.fnw.com/#sle.
 - 2) Substitutions: See Section 01 60 00 - Product Requirements.
 - 3) Source Limitations: Furnish hardware, fittings, and accessories from single manufacturer.
- b. MSS SP-58 Type 10, epoxy-painted, zinc-colored.
- c. Material: ASTM A395/A395M ductile iron, ASTM A36/A36M carbon steel, ASTM A47/A47M malleable iron, ASTM A181/A181M forged steel, or ASTM A283/A283M steel.
- d. FM (AG) and UL (DIR) listed for specific pipe size runs and loads.
- 5. Clevis Hangers, Adjustable:
 - a. Manufacturers:
 - 1) FNW; 7005: www.fnw.com/#sle.
 - 2) Substitutions: See Section 01 60 00 - Product Requirements.
 - 3) Source Limitations: Furnish hardware, fittings, and accessories from single manufacturer.
 - b. Copper Tube: MSS SP-58 Type 1, epoxy-plated copper.
 - c. UL (DIR) listed: Pipe sizes 2-1/2 to 8 inch.
 - d. FM (AG) listed: Pipe sizes 2-1/2 to 8 inch.
- P. Pipe Alignment Guides:
 - 1. Manufacturers:
 - a. Anvil International: www.anvilintl.com/#sle.
 - b. The Metraflex Company; Style IV Spider Type Guide: www.metraflex.com/#sle.
 - c. Substitutions: See Section 01 60 00 - Product Requirements.
 - d. Source Limitations: Furnish hardware, fittings, and accessories from single manufacturer.
 - 2. Pipe Sizes 8 inch and Smaller: Spider or sleeve type.
 - 3. Pipe Sizes 10 inch and Larger: Roller type.
- Q. Dielectric Barriers: Provide between metallic supports and metallic piping and associated items of dissimilar type; acceptable dielectric barriers include rubber or plastic sheets or coatings attached securely to pipe or item.
- R. Pipe Shields for Insulated Piping:
 - 1. Manufacturers:
 - a. Anvil International: www.anvilintl.com/#sle.
 - b. FNW; 7750: www.fnw.com/#sle.
 - c. Substitutions: See Section 01 60 00 - Product Requirements.
 - d. Source Limitations: Furnish hardware, fittings, and accessories from single manufacturer.
 - 2. MSS SP-58 Type 40, ASTM A1011/A1011M steel or ASTM A653/A653M carbon steel
 - 3. General Construction and Requirements:
 - a. Surface Burning Characteristics: Comply with ASTM E84 or UL 723.
 - b. Shields Material: UV-resistant polypropylene with glass fill.
 - c. Maximum Insulated Pipe Outer Diameter: 12-5/8 inch.
 - d. Minimum Service Temperature: Minus 40 degrees F.
 - e. Maximum Service Temperature: 178 degrees F.
 - f. Pipe shields to be provided at hanger, support, and guide locations on pipe requiring insulation or additional support.
- S. Anchors and Fasteners:
 - 1. Manufacturers - Mechanical Anchors:
 - a. FNW; 7502: www.fnw.com/#sle.

- b. Hilti, Inc: www.us.hilti.com/#sle.
- c. Powers Fasteners, Inc: www.powers.com/#sle.
- d. Substitutions: See Section 01 60 00 - Product Requirements.
- 2. Unless otherwise indicated and where not otherwise restricted, use the anchor and fastener types indicated for the specified applications.
- 3. Hollow Masonry: Use toggle bolts.
- 4. Hollow Stud Walls: Use toggle bolts.
- 5. Steel: Use beam-ceiling clamps, beam clamps, machine bolts, or welded threaded studs.
- 6. Beam Ceiling Flanges: ASTM A47/A47M Grade 32510, malleable iron or stainless steel with copper, plain, stainless steel, or zinc finish.
- 7. Sheet Metal: Use sheet metal screws.
- 8. Wood: Use wood screws.
- 9. Plastic and lead anchors are not permitted.
- 10. Powder-actuated fasteners are not permitted.
- 11. Hammer-driven anchors and fasteners are not permitted.
- T. Pipe Installation Accessories:
 - 1. Copper Pipe Supports:
 - a. Manufacturers:
 - 1) HoldRite, a brand of Reliance Worldwide Corporation: www.holdrite.com/#sle.
 - 2) Substitutions: See Section 01 60 00 - Product Requirements.
 - 3) Source Limitations: Furnish hardware, fittings, and accessories from single manufacturer.
 - 2. Overhead Pipe Supports:
 - a. Manufacturers:
 - 1) HoldRite, a brand of Reliance Worldwide Corporation: www.holdrite.com/#sle.
 - 2) Substitutions: See Section 01 60 00 - Product Requirements.
 - 3) Source Limitations: Furnish hardware, fittings, and accessories from single manufacturer.
 - 3. Seismic Bracing Hardware:
 - a. Cable Suspension Systems:
 - 1) Manufacturers:
 - (a) B-Line, a brand of Eaton Corporation: www.eaton.com/#sle.
 - (b) Gripple, Inc; UniGrip Standard: www.gripple.com/#sle.
 - (c) Substitutions: See Section 01 60 00 - Product Requirements.
 - (d) Source Limitations: Furnish hardware, fittings, and accessories from single manufacturer.
 - 2) Strut channel or bracket-fitted fitting with locking mechanism for pipe or equipment suspension using cable wires extended to surface-mounted end-fixing fittings.
 - 3) Provide cable wire and end-fixing as required to hold minimum weight of 120 lb.
 - b. Cable Sway Bracing Systems:
 - 1) Manufacturers:
 - (a) B-Line, a brand of Eaton Corporation: www.eaton.com/#sle.
 - (b) Gripple, Inc; Standard Hanger: www.gripple.com/#sle.
 - (c) Substitutions: See Section 01 60 00 - Product Requirements.
 - (d) Source Limitations: Furnish hardware, fittings, and accessories from single manufacturer.
 - 2) Cable wire hanger with fix and release spring mechanism enclosed using zinc housing with 302 stainless steel components for pipe or equipment suspension to surface-mounted end-fixing fittings.
 - 3) Provide cable wire and end-fixing as required to hold minimum weight of 25 lb.

PART 3 EXECUTION

3.01 EXAMINATION

- A. Verify that field measurements are as indicated.
- B. Verify that mounting surfaces are ready to receive support and attachment components.
- C. Verify that conditions are satisfactory for installation prior to starting work.

3.02 INSTALLATION

- A. Install products in accordance with manufacturer's instructions.
- B. Provide independent support from building structure. Do not provide support from piping, ductwork, conduit, or other systems.
- C. Unless specifically indicated or approved by DEDC, LLC, do not provide support from suspended ceiling support system or ceiling grid.
- D. Unless specifically indicated or approved by DEDC, LLC, do not provide support from roof deck.
- E. Do not penetrate or otherwise notch or cut structural members without approval of Structural Engineer.
- F. Equipment Support and Attachment:
 - 1. Use metal fabricated supports or supports assembled from metal channel (strut) to support equipment as required.
 - 2. Use metal channel (strut) secured to studs to support equipment surface-mounted on hollow stud walls when wall strength is not sufficient to resist pull-out.
 - 3. Use metal channel (strut) to support surface-mounted equipment in wet or damp locations to provide space between equipment and mounting surface.
 - 4. Securely fasten floor-mounted equipment. Do not install equipment such that it relies on its own weight for support.
- G. Secure fasteners according to manufacturer's recommended torque settings.
- H. Remove temporary supports.

END OF SECTION

SECTION 23 05 48
VIBRATION AND SEISMIC CONTROLS FOR HVAC

PART 1 GENERAL

1.01 SECTION INCLUDES

- A. Vibration isolation requirements.
- B. Seismic control requirements.
- C. Vibration-isolated equipment support bases.
- D. Vibration isolators.
- E. Seismic restraint systems.

1.02 RELATED REQUIREMENTS

- A. Section 01 45 33 - Code-Required Special Inspections and Procedures.
- B. Section 03 30 00 - Cast-in-Place Concrete.
- C. Section 23 05 29 - Hangers and Supports for HVAC Piping and Equipment.

1.03 DEFINITIONS

- A. HVAC Component: Where referenced in this section in regards to seismic controls, applies to any portion of the HVAC system subject to seismic evaluation in accordance with applicable codes, including distributed systems (e.g., ductwork, piping).
- B. Seismic Restraint: Structural members or assemblies or members or manufactured elements specifically designed and applied for transmitting seismic forces between components and the seismic force-resisting system of the structure.

1.04 REFERENCE STANDARDS

- A. ASCE 19 - Structural Applications of Steel Cables for Buildings; 2016.
- B. ASHRAE (HVAC) - ASHRAE Handbook - HVAC Applications; Most Recent Edition Cited by Referring Code or Reference Standard.
- C. FEMA 412 - Installing Seismic Restraints for Mechanical Equipment; 2014.
- D. ICC (IBC) - International Building Code; Most Recent Edition Adopted by Authority Having Jurisdiction, Including All Applicable Amendments and Supplements.
- E. SMACNA (SRM) - Seismic Restraint Manual Guidelines for Mechanical Systems; 2008.

1.05 ADMINISTRATIVE REQUIREMENTS

- A. Coordination:
 - 1. Coordinate selection and arrangement of vibration isolation and/or seismic control components with the actual equipment to be installed.
 - 2. Coordinate the work with other trades to provide additional framing and materials required for installation.
 - 3. Coordinate compatibility of support and attachment components with mounting surfaces at the installed locations.
 - 4. Notify DEDC, LLC of any conflicts with or deviations from Contract Documents. Obtain direction before proceeding with work.

1.06 SUBMITTALS

- A. See Section 01 30 00 - Administrative Requirements for submittal procedures.
- B. Product Data: Provide manufacturer's standard catalog pages and data sheets for products, including materials, fabrication details, dimensions, and finishes.
 - 1. Vibration Isolators: Include rated load capacities and deflections; include information on color coding or other identification methods for spring element load capacities.

2. Seismic Controls: Include seismic load capacities.
- C. Shop Drawings - Vibration Isolation Systems:
 1. Include dimensioned plan views and sections indicating proposed arrangement of vibration isolators; indicate equipment weights and static deflections.
 2. Vibration-Isolated Equipment Support Bases: Include base weights, including concrete fill where applicable; indicate equipment mounting provisions.
- D. Shop Drawings - Seismic Controls:
 1. Include dimensioned plan views and sections indicating proposed HVAC component locations and distributed system routing, with locations and details of gravity supports and seismic restraints and associated attachments.
 2. Identify anchor manufacturer, type, minimum embedment, minimum spacing, minimum member thickness, and minimum edge distance requirements.
 3. Indicate proposed arrangement of distributed system trapeze support groupings.
 4. Indicate proposed locations for distributed system flexible fittings and/or connections.
 5. Indicate locations of seismic separations where applicable.

1.07 QUALITY ASSURANCE

- A. Comply with applicable building code.

1.08 DELIVERY, STORAGE, AND HANDLING

- A. Receive, inspect, handle, and store products in accordance with manufacturer's instructions.

PART 2 PRODUCTS

2.01 VIBRATION ISOLATION REQUIREMENTS

- A. Design and provide vibration isolation system to reduce vibration transmission to supporting structure from vibration-producing HVAC equipment and/or HVAC connections to vibration-isolated equipment.
- B. Comply with applicable general recommendations of ASHRAE (HVACA), where not in conflict with other specified requirements.
- C. General Requirements:
 1. Select vibration isolators to provide required static deflection.
 2. Select vibration isolators for uniform deflection based on distributed operating weight of actual installed equipment.
- D. Piping Isolation:
 1. Provide vibration isolators for piping supports:
 - a. Located in equipment rooms.
 - b. Located within 50 feet of connected vibration-isolated equipment and pressure-regulating valve (PRV) stations.
 - c. For piping over 2 inch located below or within 50 feet of noise-sensitive areas indicated.
 2. Minimum Static Deflection:
 - a. First Three Supports Closest to Isolated Equipment: Same as static deflection of equipment; maximum of 2 inch deflection required.
 - b. Remainder of Supports: 0.75 inch deflection unless otherwise indicated.
 3. Suspended Piping, Nonseismic Applications: Use resilient material isolator hangers, spring isolator hangers, or combination resilient material/spring isolator hangers.
 4. Suspended Piping, Seismic Applications: Use seismic type resilient material isolator hangers, seismic type spring isolator hangers, or seismic type combination resilient material/spring isolator hangers.

2.02 VIBRATION-ISOLATED EQUIPMENT SUPPORT BASES

- A. Manufacturers:

1. Vibration-Isolated Equipment Support Bases:
 - a. Kinetics Noise Control, Inc: www.kineticsnoise.com/#sle.
 - b. Mason Industries: www.mason-ind.com/#sle.
 - c. Vibration Eliminator Company, Inc: www.veco-nyc.com/#sle.
 - d. Vibro-Acoustics: www.vibro-acoustics.com/#sle.
 - e. Substitutions: See Section 01 60 00 - Product Requirements.
 2. Source Limitations: Furnish vibration-isolated equipment support bases and associated components and accessories produced by the same manufacturer as the vibration isolators and obtained from a single supplier.
- B. Vibration-Isolated Structural Steel Bases:
1. Description: Engineered structural steel frames with integral mounting provisions for vibration isolators, sized and configured for mounting of equipment.
 2. Centrifugal Fan Applications: Provide adjustable motor slide rails as required.
 3. Maximum Deflection: 1 inch.
 4. Color code or otherwise identify springs to indicate load capacity.
 5. Lateral Stability: Minimum lateral stiffness to vertical stiffness ratio of 0.8.
 6. Select springs to provide designed deflection of not less than 50 percent of specified deflection.
- C. Vibration-Isolated Concrete Inertia Bases:
1. Description: Concrete-filled engineered steel forms with integral mounting provisions for vibration isolators, sized and configured for mounting of equipment.
 2. Minimum Base Depth: 6 inches.
 3. Minimum Base Mass (Including Concrete): 1.5 times weight of supported equipment.
 4. Concrete Reinforcement: Welded or tied reinforcing bars running both ways in a single layer.
 5. Concrete: Filled on site with minimum 3000 psi concrete in accordance with Section 03 30 00.

2.03 VIBRATION ISOLATORS

- A. Manufacturers:
1. Vibration Isolators:
 - a. Kinetics Noise Control, Inc: www.kineticsnoise.com/#sle.
 - b. Mason Industries: www.mason-ind.com/#sle.
 - c. Vibration Eliminator Company, Inc: www.veco-nyc.com/#sle.
 - d. Vibro-Acoustics: www.vibro-acoustics.com/#sle.
 - e. Substitutions: See Section 01 60 00 - Product Requirements.
 2. Source Limitations: Furnish vibration-isolators and associated accessories produced by a single manufacturer and obtained from a single supplier.
- B. General Requirements:
1. Resilient Materials for Vibration Isolators: Oil, ozone, and oxidant resistant.
 2. Spring Elements for Spring Isolators:
 - a. Color code or otherwise identify springs to indicate load capacity.
 - b. Lateral Stability: Minimum lateral stiffness to vertical stiffness ratio of 0.8.
 - c. Designed to operate in the linear portion of their load versus deflection curve over deflection range of not less than 50 percent above specified deflection.
 - d. Designed to provide additional travel to solid of not less than 50 percent of rated deflection at rated load.
 - e. Selected to provide designed deflection of not less than 75 percent of specified deflection.
 - f. Selected to function without undue stress or overloading.
- C. Vibration Isolators for Nonseismic Applications:

1. Resilient Material Isolator Pads:
 - a. Description: Single or multiple layer pads utilizing elastomeric (e.g., neoprene, rubber) or fiberglass isolator material.
 - b. Pad Thickness: As required for specified minimum static deflection; minimum 0.25 inch thickness.
 - c. Multiple Layer Pads: Provide bonded, galvanized sheet metal separation plate between each layer.
2. Housed Spring Isolators:
 - a. Description: Isolator assembly consisting of single or multiple free-standing, laterally stable steel spring(s) within a metal housing.
 - b. Furnished with integral elastomeric snubbing elements, nonadjustable type, for limiting equipment movement and preventing metal-to-metal contact between housing elements.
 - c. Bottom Load Plate: Steel with nonskid, elastomeric isolator pad with provisions for bolting to supporting structure as required.
 - d. Furnished with integral leveling device for positioning and securing supported equipment.
3. Spring Isolator Hangers, Nonseismic:
 - a. Description: Isolator assembly designed for installation in hanger rod suspension system utilizing single or multiple free-standing, laterally stable steel spring(s) in series with an elastomeric element for the lower hanger rod connection.
 - b. Designed to accommodate misalignment of bottom hanger rod up to 30 degrees (plus/minus 15 degrees) without short-circuiting of isolation.

PART 3 EXECUTION

3.01 EXAMINATION

- A. Verify that field measurements are as shown on the drawings.
- B. Verify that mounting surfaces are ready to receive vibration isolation and/or seismic control components and associated attachments.
- C. Verify that conditions are satisfactory for installation prior to starting work.

3.02 CODE-REQUIRED SPECIAL INSPECTIONS

- A. Arrange work to accommodate tests and/or inspections performed by Special Inspection Agency employed by Del Tech or DEDC, LLC in accordance with Section 01 45 33 and statement of special inspections as required by applicable building code.
- B. Frequency of Special Inspections: Where special inspections are designated as continuous or periodic, arrange work accordingly.
 1. Continuous Special Inspections: Special Inspection Agency to be present in the area where the work is being performed and observe the work at all times the work is in progress.
 2. Periodic Special Inspections: Special Inspection Agency to be present in the area where work is being performed and observe the work part-time or intermittently and at the completion of the work.
- C. Prior to starting work, Contractor to submit written statement of responsibility to authorities having jurisdiction and to Del Tech acknowledging awareness of special requirements contained in the statement of special inspections.
- D. Special Inspection Agency services do not relieve Contractor from performing inspections and testing specified elsewhere.

3.03 INSTALLATION

- A. Install products in accordance with manufacturer's instructions.

-
- B. Install anchors and fasteners in accordance with ICC Evaluation Services, LLC (ICC-ES) evaluation report conditions of use where applicable.
 - C. Secure fasteners according to manufacturer's recommended torque settings.
 - D. Install flexible piping connections to provide sufficient slack for vibration isolation and/or seismic relative displacements as indicated or as required.
 - E. Vibration Isolation Systems:
 - 1. Vibration-Isolated Equipment Support Bases:
 - a. Provide specified minimum clearance beneath base.
 - 2. Spring Isolators:
 - a. Position equipment at operating height; provide temporary blocking as required.
 - b. Lift equipment free of isolators prior to lateral repositioning to avoid damage to isolators.
 - c. Level equipment by adjusting isolators gradually in sequence to raise equipment uniformly such that excessive weight or stress is not placed on any single isolator.
 - 3. Isolator Hangers:
 - a. Use precompressed isolator hangers where required to facilitate installation and prevent damage to equipment utility connection provisions.
 - b. Locate isolator hangers at top of hanger rods in accordance with manufacturer's instructions.
 - 4. Clean debris from beneath vibration-isolated equipment that could cause short-circuiting of isolation.
 - 5. Use elastomeric grommets for attachments where required to prevent short-circuiting of isolation.
 - 6. Adjust isolators to be free of isolation short circuits during normal operation.
 - 7. Do not overtighten fasteners such that resilient material isolator pads are compressed beyond manufacturer's maximum recommended deflection.
 - F. Seismic Controls:
 - 1. Provide specified snubbing element air gap; remove any factory-installed spacers, debris, or other obstructions.
 - 2. Use only specified components, anchorage, and hardware evaluated by seismic design. Comply with conditions of seismic certification where applicable.
 - 3. Where mounting hole diameter exceeds bolt diameter by more than 0.125 inch, use epoxy grout, elastomeric grommet, or welded washer to reduce clearance to 0.125 inch or less.
 - 4. Equipment with Sheet Metal Housings:
 - a. Use Belleville washers to distribute stress over a larger surface area of the sheet metal connection interface as approved by manufacturer.
 - b. Attach additional steel as approved by manufacturer where required to transfer loads to structure.
 - c. Where mounting surface is irregular, do not shim housing; reinforce housing with additional steel as approved by manufacturer.
 - 5. Concrete Housekeeping Pads:
 - a. Size in accordance with seismic design to meet anchor requirements.
 - b. Install pad reinforcement and doweling in accordance with seismic design to ensure integrity of pad and associated connection to slab.
 - 6. Seismic Restraint Systems:
 - a. Do not attach seismic restraints and gravity supports to dissimilar parts of structure that may move differently during an earthquake.
 - b. Install restraints within permissible angles in accordance with seismic design.
 - c. Install cable restraints straight between component/run and structural attachment; do not bend around other nonstructural components or structural elements.

- d. Install cable restraints for vibration-isolated components slightly slack to prevent short-circuiting of isolation.
- e. Install hanger rod stiffeners where indicated using only specified clamps; do not weld stiffeners to hanger rod.

3.04 FIELD QUALITY CONTROL

- A. See Section 01 40 00 - Quality Requirements, for additional requirements.
- B. Inspect vibration isolation and/or seismic control components for damage and defects.
- C. Vibration Isolation Systems:
 - 1. Verify isolator static deflections.
 - 2. Verify vibration isolation performance during normal operation; investigate sources of isolation short circuits.
- D. Correct deficiencies and replace damaged or defective vibration isolation and/or seismic control components.

END OF SECTION

NOT FOR BIDDING

SECTION 23 05 53
IDENTIFICATION FOR HVAC PIPING AND EQUIPMENT

PART 1 GENERAL

1.01 SECTION INCLUDES

- A. Nameplates.
- B. Tags.
- C. Adhesive-backed duct markers.
- D. Stencils.
- E. Pipe markers.
- F. Ceiling tacks.

1.02 REFERENCE STANDARDS

- A. ASME A13.1 - Scheme for the Identification of Piping Systems; 2023.
- B. ASTM D709 - Standard Specification for Laminated Thermosetting Materials; 2017.

1.03 SUBMITTALS

- A. See Section 01 30 00 - Administrative Requirements for submittal procedures.
- B. List: Submit list of wording, symbols, letter size, and color coding for mechanical identification.
- C. Chart and Schedule: Submit valve chart and schedule, including valve tag number, location, function, and valve manufacturer's name and model number.
- D. Product Data: Provide manufacturers catalog literature for each product required.
- E. Project Record Documents: Record actual locations of tagged valves.

PART 2 PRODUCTS

2.01 IDENTIFICATION APPLICATIONS

- A. Air Handling Units: Nameplates and ceiling tacks where located above lay-in ceiling..
- B. Air Terminal Units: Tags.
- C. Automatic Controls: Tags. Key to control schematic.
- D. Piping: Tags.
- E. Pumps: Nameplates.
- F. Thermostats: Nameplates.
- G. Valves: Tags and ceiling tacks where located above lay-in ceiling.

2.02 NAMEPLATES

- A. Manufacturers:
 - 1. Advanced Graphic Engraving, LLC: www.advancedgraphicengraving.com/#sle.
 - 2. Brimar Industries, Inc: www.pipemarker.com/#sle.
 - 3. Craftmark Pipe Markers: www.craftmarkid.com/#sle.
 - 4. Seton Identification Products, a Tricor Direct Company: www.seton.com/#sle.
- B. Letter Color: White.
- C. Background Color: Black.
- D. Plastic: Comply with ASTM D709.

2.03 TAGS

- A. Manufacturers:
 - 1. Advanced Graphic Engraving: www.advancedgraphicengraving.com/#sle.

2. Brimar Industries, Inc: www.pipemarker.com/#sle.
 3. Craftmark Pipe Markers: www.craftmarkid.com/#sle.
 4. Seton Identification Products, a Tricor Company: www.seton.com/#sle.
 5. Substitutions: See Section 01 60 00 - Product Requirements.
- B. Plastic Tags: Laminated three-layer plastic with engraved black letters on light contrasting background color. Tag size minimum 1-1/2 inch diameter.
- C. Metal Tags: Brass with stamped letters; tag size minimum 1-1/2 inch diameter with smooth edges.
- D. Valve Tag Chart: Typewritten letter size list in anodized aluminum frame.

2.04 ADHESIVE-BACKED DUCT MARKERS

- A. Manufacturers:
1. Brimar Industries, Inc: www.pipemarker.com/#sle.
 2. Craftmark Pipe Markers: www.craftmarkid.com/#sle.
 3. Kolbi Pipe Marker Co: www.kolbipipemarkers.com/#sle.
 4. Substitutions: See Section 01 60 00 - Product Requirements.
- B. Material: High gloss acrylic adhesive-backed vinyl film 0.0032 inch; printed with UV and chemical resistant inks.
- C. Style: Individual Label.
- D. Color: Yellow/Black.

2.05 STENCILS

- A. Manufacturers:
1. Brady Corporation: www.bradycorp.com/#sle.
 2. Craftmark Pipe Markers: www.craftmarkid.com/#sle.
 3. Kolbi Pipe Marker Co: www.kolbipipemarkers.com/#sle.
 4. Seton Identification Products, a Tricor Company: www.seton.com/#sle.
 5. Substitutions: See Section 01 60 00 - Product Requirements.
- B. Stencils: With clean cut symbols and letters of following size:
1. 3/4 to 1-1/4 inch Outside Diameter of Insulation or Pipe: 8 inch long color field, 1/2 inch high letters.
 2. 1-1/2 to 2 inch Outside Diameter of Insulation or Pipe: 8 inch long color field, 3/4 inch high letters.
 3. 2-1/2 to 6 inch Outside Diameter of Insulation or Pipe: 12 inch long color field, 1-1/4 inch high letters.
 4. Ductwork and Equipment: 2-1/2 inch high letters.

2.06 PIPE MARKERS

- A. Manufacturers:
1. Brady Corporation: www.bradycorp.com/#sle.
 2. Brimar Industries, Inc: www.pipemarker.com/#sle.
 3. Craftmark Pipe Markers: www.craftmarkid.com/#sle.
 4. Kolbi Pipe Marker Co: www.kolbipipemarkers.com/#sle.
 5. Seton Identification Products, a Tricor Company: www.seton.com/#sle.
 6. Substitutions: See Section 01 60 00 - Product Requirements.
- B. Color: Comply with ASME A13.1.
- C. Plastic Pipe Markers: Factory fabricated, flexible, semi-rigid plastic, preformed to fit around pipe or pipe covering; minimum information indicating flow direction arrow and identification of fluid being conveyed.

- D. Plastic Tape Pipe Markers: Flexible, vinyl film tape with pressure-sensitive adhesive backing and printed markings.

2.07 CEILING TACKS

- A. Manufacturers:
 - 1. Craftmark Pipe Markers: www.craftmarkid.com/#sle.
 - 2. Substitutions: See Section 01 60 00 - Product Requirements.
- B. Description: Steel with 3/4 inch diameter color coded head.
- C. Color code as follows:
 - 1. HVAC Equipment: Yellow.
 - 2. Fire Dampers and Smoke Dampers: Red.
 - 3. Heating/Cooling Valves: Blue.

PART 3 EXECUTION

3.01 PREPARATION

- A. Degrease and clean surfaces to receive adhesive for identification materials.

3.02 INSTALLATION

- A. Install nameplates with corrosive-resistant mechanical fasteners, or adhesive. Apply with sufficient adhesive to ensure permanent adhesion and seal with clear lacquer.
- B. Install tags with corrosion resistant chain.
- C. Install plastic pipe markers in accordance with manufacturer's instructions.
- D. Install plastic tape pipe markers complete around pipe in accordance with manufacturer's instructions.
- E. Use tags on piping 3/4 inch diameter and smaller.
 - 1. Identify service, flow direction, and pressure.
 - 2. Install in clear view and align with axis of piping.
 - 3. Locate identification not to exceed 20 feet on straight runs including risers and drops, adjacent to each valve and Tee, at each side of penetration of structure or enclosure, and at each obstruction.
- F. Locate ceiling tacks to locate valves or dampers above lay-in panel ceilings. Locate in corner of panel closest to equipment.

END OF SECTION

NOT FOR BIDDING

This page intentionally left blank

SECTION 23 05 93
TESTING, ADJUSTING, AND BALANCING FOR HVAC

PART 1 GENERAL

1.01 SECTION INCLUDES

- A. Testing, adjustment, and balancing of air systems.
- B. Testing, adjustment, and balancing of hydronic systems.
- C. Measurement of final operating condition of HVAC systems.
- D. Sound measurement of equipment operating conditions.
- E. Vibration measurement of equipment operating conditions.

1.02 REFERENCE STANDARDS

- A. AABC (NSTSB) - AABC National Standards for Total System Balance, 7th Edition; 2016.
- B. ASHRAE Std 110 - Methods of Testing Performance of Laboratory Fume Hoods; 2016, with Errata.
- C. ASHRAE Std 111 - Measurement, Testing, Adjusting, and Balancing of Building HVAC Systems; 2024.
- D. SMACNA (TAB) - HVAC Systems Testing, Adjusting and Balancing; 2023.

1.03 SUBMITTALS

- A. See Section 01 30 00 - Administrative Requirements, for submittal procedures.
- B. TAB Plan: Submit a written plan indicating the testing, adjusting, and balancing standard to be followed and the specific approach for each system and component.
 - 1. Include at least the following in the plan:
 - a. List of all air flow, water flow, sound level, system capacity and efficiency measurements to be performed and a description of specific test procedures, parameters, formulas to be used.
 - b. Copy of field checkout sheets and logs to be used, listing each piece of equipment to be tested, adjusted and balanced with the data cells to be gathered for each.
 - c. Discussion of what notations and markings will be made on the duct and piping drawings during the process.
 - d. Final test report forms to be used.
 - e. Procedures for formal deficiency reports, including scope, frequency and distribution.
- C. Final Report: Indicate deficiencies in systems that would prevent proper testing, adjusting, and balancing of systems and equipment to achieve specified performance.
 - 1. Revise TAB plan to reflect actual procedures and submit as part of final report.
 - 2. Submit draft copies of report for review prior to final acceptance of Project. Provide final copies for DEDC, LLC and for inclusion in operating and maintenance manuals.
 - 3. Include actual instrument list, with manufacturer name, serial number, and date of calibration.
 - 4. Form of Test Reports: Where the TAB standard being followed recommends a report format use that; otherwise, follow ASHRAE Std 111.
 - 5. Units of Measure: Report data in both I-P (inch-pound) and SI (metric) units.

PART 2 PRODUCTS - NOT USED

PART 3 EXECUTION

3.01 GENERAL REQUIREMENTS

- A. Perform total system balance in accordance with one of the following:
 - 1. AABC (NSTSB), AABC National Standards for Total System Balance.

2. ASHRAE Std 111, Practices for Measurement, Testing, Adjusting and Balancing of Building Heating, Ventilation, Air-Conditioning, and Refrigeration Systems.
3. SMACNA (TAB).
- B. Begin work after completion of systems to be tested, adjusted, or balanced and complete work prior to Substantial Completion of the project.
- C. TAB Agency Qualifications:
 1. Company specializing in the testing, adjusting, and balancing of systems specified in this section.
 2. Having minimum of three years documented experience.
 3. Certified by one of the following:
 - a. AABC, Associated Air Balance Council: www.aabc.com/#sle; upon completion submit AABC National Performance Guaranty.
 - b. NEBB, National Environmental Balancing Bureau: www.nebb.org/#sle.
 - c. TABB, The Testing, Adjusting, and Balancing Bureau of National Energy Management Institute: www.tabbcertified.org/#sle.
- D. TAB Supervisor and Technician Qualifications: Certified by same organization as TAB agency.

3.02 EXAMINATION

- A. Verify that systems are complete and operable before commencing work. Ensure the following conditions:
 1. Systems are started and operating in a safe and normal condition.
 2. Temperature control systems are installed complete and operable.
 3. Proper thermal overload protection is in place for electrical equipment.
 4. Final filters are clean and in place. If required, install temporary media in addition to final filters.
 5. Duct systems are clean of debris.
 6. Fans are rotating correctly.
 7. Fire and volume dampers are in place and open.
 8. Air coil fins are cleaned and combed.
 9. Access doors are closed and duct end caps are in place.
 10. Air outlets are installed and connected.
 11. Duct system leakage is minimized.
 12. Hydronic systems are flushed, filled, and vented.
 13. Pumps are rotating correctly.
 14. Proper strainer baskets are clean and in place.
 15. Service and balance valves are open.
- B. Submit field reports. Report defects and deficiencies that will or could prevent proper system balance.
- C. Beginning of work means acceptance of existing conditions.

3.03 PREPARATION

- A. Hold a pre-balancing meeting at least one week prior to starting TAB work.
 1. Require attendance by all installers whose work will be tested, adjusted, or balanced.
- B. Provide additional balancing devices as required.

3.04 ADJUSTMENT TOLERANCES

- A. Air Outlets and Inlets: Adjust total to within plus 10 percent and minus 5 percent of design to space. Adjust outlets and inlets in space to within plus or minus 10 percent of design.
- B. Hydronic Systems: Adjust to within plus or minus 10 percent of design.

3.05 RECORDING AND ADJUSTING

- A. Ensure recorded data represents actual measured or observed conditions.
- B. Permanently mark settings of valves, dampers, and other adjustment devices allowing settings to be restored. Set and lock memory stops.
- C. After adjustment, take measurements to verify balance has not been disrupted or that such disruption has been rectified.
- D. Leave systems in proper working order, replacing belt guards, closing access doors, closing doors to electrical switch boxes, and restoring thermostats to specified settings.

3.06 AIR SYSTEM PROCEDURE

- A. Adjust air handling and distribution systems to provide required or design supply, return, and exhaust air quantities at site altitude.
- B. Make air quantity measurements in ducts by Pitot tube traverse of entire cross sectional area of duct.
- C. Measure air quantities at air inlets and outlets.
- D. Adjust distribution system to obtain uniform space temperatures free from objectionable drafts and noise.
- E. Use volume control devices to regulate air quantities only to extent that adjustments do not create objectionable air motion or sound levels. Effect volume control by duct internal devices such as dampers and splitters.
- F. Vary total system air quantities by adjustment of fan speeds. Provide drive changes required. Vary branch air quantities by damper regulation.
- G. Provide system schematic with required and actual air quantities recorded at each outlet or inlet.
- H. Measure static air pressure conditions on air supply units, including filter and coil pressure drops, and total pressure across the fan. Make allowances for 50 percent loading of filters.
- I. Adjust outside air automatic dampers, outside air, return air, and exhaust dampers for design conditions.
- J. Where modulating dampers are provided, take measurements and balance at extreme conditions. Balance variable volume systems at maximum air flow rate, full cooling, and at minimum air flow rate, full heating.
- K. Measure building static pressure and adjust supply, return, and exhaust air systems to provide required relationship between each to maintain approximately 0.05 inches positive static pressure near the building entries.
- L. Check multi-zone units for motorized damper leakage. Adjust air quantities with mixing dampers set first for cooling, then heating, then modulating.
- M. For variable air volume system powered units set volume controller to air flow setting indicated. Confirm connections properly made and confirm proper operation for automatic variable air volume temperature control.
- N. On fan powered VAV boxes, adjust air flow switches for proper operation.

3.07 WATER SYSTEM PROCEDURE

- A. Adjust water systems to provide required or design quantities.
- B. Use calibrated Venturi tubes, orifices, or other metered fittings and pressure gauges to determine flow rates for system balance. Where flow metering devices are not installed, base flow balance on temperature difference across various heat transfer elements in the system.

- C. Adjust systems to provide specified pressure drops and flows through heat transfer elements prior to thermal testing. Perform balancing by measurement of temperature differential in conjunction with air balancing.
- D. Effect system balance with automatic control valves fully open to heat transfer elements.
- E. Effect adjustment of water distribution systems by means of balancing cocks, valves, and fittings. Do not use service or shut-off valves for balancing unless indexed for balance point.
- F. Where available pump capacity is less than total flow requirements or individual system parts, full flow in one part may be simulated by temporary restriction of flow to other parts.

3.08 SCOPE

- A. Test, adjust, and balance the following:
 - 1. HVAC Pumps.
 - 2. Air Handling Units.
 - 3. Fans.
 - 4. Air Terminal Units.
 - 5. Air Inlets and Outlets.

END OF SECTION

NOT FOR BIDDING

**SECTION 23 07 13
DUCT INSULATION**

PART 1 GENERAL

1.01 SECTION INCLUDES

- A. Duct insulation.
- B. Jacketing and accessories.

1.02 RELATED REQUIREMENTS

- A. Section 23 05 53 - Identification for HVAC Piping and Equipment.
- B. Section 23 31 00 - HVAC Ducts and Casings: Glass fiber ducts.

1.03 REFERENCE STANDARDS

- A. ASTM B209/B209M - Standard Specification for Aluminum and Aluminum-Alloy Sheet and Plate; 2021a.
- B. ASTM C177 - Standard Test Method for Steady-State Heat Flux Measurements and Thermal Transmission Properties by Means of the Guarded-Hot-Plate Apparatus; 2019, with Editorial Revision (2023).
- C. ASTM C518 - Standard Test Method for Steady-State Thermal Transmission Properties by Means of the Heat Flow Meter Apparatus; 2021.
- D. ASTM C553 - Standard Specification for Mineral Fiber Blanket Thermal Insulation for Commercial and Industrial Applications; 2013 (Reapproved 2019).
- E. ASTM C612 - Standard Specification for Mineral Fiber Block and Board Thermal Insulation; 2014 (Reapproved 2019).
- F. ASTM C1423 - Standard Guide for Selecting Jacketing Materials for Thermal Insulation; 2021.
- G. ASTM E84 - Standard Test Method for Surface Burning Characteristics of Building Materials; 2023d.
- H. ASTM E96/E96M - Standard Test Methods for Gravimetric Determination of Water Vapor Transmission Rate of Materials; 2023.
- I. SAE AMS3779 - Tape, Adhesive, Pressure-Sensitive Thermal Radiation Resistant, Aluminum Coated Glass Cloth; 2016b.
- J. UL 181 - Standard for Factory-Made Air Ducts and Air Connectors; Current Edition, Including All Revisions.
- K. UL 181A - Closure Systems for Use with Rigid Air Ducts; Current Edition, Including All Revisions.
- L. UL 181B - Closure Systems for Use with Flexible Air Ducts and Air Connectors; Current Edition, Including All Revisions.
- M. UL 723 - Standard for Test for Surface Burning Characteristics of Building Materials; Current Edition, Including All Revisions.

1.04 SUBMITTALS

- A. See Section 01 30 00 - Administrative Requirements for submittal procedures.
- B. Product Data: Provide product description, thermal characteristics, list of materials and thickness for each service, and locations.
- C. Manufacturer's Instructions: Indicate installation procedures necessary to ensure acceptable workmanship and that installation standards will be achieved.

1.05 DELIVERY, STORAGE, AND HANDLING

- A. Accept materials on site in original factory packaging, labelled with manufacturer's identification, including product density and thickness.
- B. Protect insulation from weather and construction traffic, dirt, water, chemical, and mechanical damage, by storing in original wrapping.

1.06 FIELD CONDITIONS

- A. Maintain ambient temperatures and conditions required by manufacturers of adhesives, mastics, and insulation cements.
- B. Maintain temperature during and after installation for minimum period of 24 hours.

PART 2 PRODUCTS

2.01 REGULATORY REQUIREMENTS

- A. Surface Burning Characteristics: Flame spread index/Smoke developed index of 25/50, maximum, when tested in accordance with ASTM E84 or UL 723.

2.02 GLASS FIBER, FLEXIBLE

- A. Manufacturer:
 - 1. CertainTeed Corporation: www.certainteed.com/#sle.
 - 2. Johns Manville: www.jm.com/#sle.
 - 3. Knauf Insulation; Performance+ Duct Wrap: www.knaufinsulation.com/#sle.
 - 4. Owens Corning Corporation: www.ocbuildingspec.com/#sle.
- B. Insulation: ASTM C553; flexible, noncombustible blanket.
 - 1. Maximum Service Temperature: 1,200 degrees F.
 - 2. Maximum Water Vapor Absorption: 5.0 percent by weight.
- C. Vapor Barrier Jacket:
 - 1. Moisture Vapor Permeability: 0.02 perm inch, when tested in accordance with ASTM E96/E96M.
 - 2. Secure with pressure-sensitive tape.
- D. Vapor Barrier Tape:
 - 1. Kraft paper reinforced with glass fiber yarn and bonded to aluminized film, with pressure-sensitive rubber-based adhesive.

2.03 GLASS FIBER, RIGID

- A. Manufacturer:
 - 1. CertainTeed Corporation: www.certainteed.com/#sle.
 - 2. Johns Manville: www.jm.com/#sle.
 - 3. Knauf Insulation; Earthwool Insulation Board: www.knaufinsulation.com/#sle.
 - 4. Owens Corning Corporation; 700 Series FIBERGLAS Insulation: www.ocbuildingspec.com/#sle.
- B. Insulation: ASTM C612; rigid, noncombustible blanket.
 - 1. K Value: 0.24 at 75 degrees F, when tested in accordance with ASTM C518.
 - 2. Maximum Service Temperature: 450 degrees F.
- C. Vapor Barrier Jacket:
 - 1. Moisture Vapor Permeability: 0.02 perm inch, when tested in accordance with ASTM E96/E96M.
 - 2. Secure with pressure-sensitive tape.

2.04 JACKETING AND ACCESSORIES

- A. Canvas Jacket: UL listed 6 oz/sq yd plain weave cotton fabric treated with dilute fire-retardant lagging adhesive.

- B. Aluminum Jacket:
 - 1. Comply with ASTM B209/B209M, Temper H14, minimum thickness of 0.016 inch with factory-applied polyethylene and kraft paper moisture barrier on the inside surface.
 - 2. Thickness: 0.016 inch sheet.
 - 3. Finish: Smooth.
 - 4. Joining: Longitudinal slip joints and 2 inch laps.
 - 5. Fittings: 0.016 inch thick die-shaped fitting covers with factory-attached protective liner.
 - 6. Metal Jacket Bands: 3/8 inch wide; 0.015 inch thick aluminum.
- C. Reinforced Tape:
 - 1. FSK tape suitable for sealing seams between insulation, insulated elbows, and fittings resulting in a tight, smooth surface without wrinkles.
 - 2. Comply with UL 723 or ASTM E84.
 - 3. Moisture Vapor Permeability: 0.00 perm inch, when tested in accordance with ASTM E96/E96M.
- D. UL181 Tape for Rigid and Flexible Ductwork:
 - 1. Comply with UL 181A for rigid ductwork.
 - 2. Comply with UL 181B for flexible ductwork.
 - 3. Aluminum foil coated with pressure-sensitive adhesive on paper release liner.
 - 4. Foil tape suitable for sealing seams between insulation, insulated elbows, and fittings resulting in a tight, smooth surface without wrinkles.

PART 3 EXECUTION

3.01 EXAMINATION

- A. Test ductwork for design pressure prior to applying insulation materials.
- B. Verify that surfaces are clean, foreign material removed, and dry.

3.02 INSTALLATION

- A. Install in accordance with manufacturer's instructions.
- B. Insulated Ducts Conveying Air Below Ambient Temperature:
 - 1. Provide insulation with vapor barrier jackets.
 - 2. Finish with tape and vapor barrier jacket.
 - 3. Continue insulation through walls, sleeves, hangers, and other duct penetrations.
 - 4. Insulate entire system, including fittings, joints, flanges, fire dampers, flexible connections, and expansion joints.
- C. Insulated Ducts Conveying Air Above Ambient Temperature:
 - 1. Provide with or without standard vapor barrier jacket.
 - 2. Insulate fittings and joints. Where service access is required, bevel and seal ends of insulation.
- D. Ducts Exposed in Mechanical Equipment Rooms or Finished Spaces (below 10 feet above finished floor): Finish with canvas jacket sized for finish painting.

END OF SECTION

NOT FOR BIDDING

This page intentionally left blank

**SECTION 23 07 19
HVAC PIPING INSULATION**

PART 1 GENERAL

1.01 SECTION INCLUDES

- A. Piping insulation.
- B. Flexible removable and reusable blanket insulation.
- C. Jacketing and accessories.
- D. Engineered wall outlet seals and refrigerant piping insulation protection.

1.02 RELATED REQUIREMENTS

- A. Section 23 21 13 - Hydronic Piping: Placement of hangers and hanger inserts.
- B. Section 23 23 00 - Refrigerant Piping: Placement of inserts.

1.03 REFERENCE STANDARDS

- A. ASTM C449 - Standard Specification for Mineral Fiber Hydraulic-Setting Thermal Insulating and Finishing Cement; 2007 (Reapproved 2019).
- B. ASTM C518 - Standard Test Method for Steady-State Thermal Transmission Properties by Means of the Heat Flow Meter Apparatus; 2021.
- C. ASTM C534/C534M - Standard Specification for Preformed Flexible Elastomeric Cellular Thermal Insulation in Sheet and Tubular Form; 2023.
- D. ASTM C547 - Standard Specification for Mineral Fiber Pipe Insulation; 2022a.
- E. ASTM C552 - Standard Specification for Cellular Glass Thermal Insulation; 2022.
- F. ASTM C553 - Standard Specification for Mineral Fiber Blanket Thermal Insulation for Commercial and Industrial Applications; 2013 (Reapproved 2019).
- G. ASTM C585 - Standard Practice for Inner and Outer Diameters of Thermal Insulation for Nominal Sizes of Pipe and Tubing; 2022.
- H. ASTM C591 - Standard Specification for Unfaced Preformed Rigid Cellular Polyisocyanurate Thermal Insulation; 2022.
- I. ASTM C795 - Standard Specification for Thermal Insulation for Use in Contact with Austenitic Stainless Steel; 2008 (Reapproved 2023).
- J. ASTM C1136 - Standard Specification for Flexible, Low Permeance Vapor Retarders for Thermal Insulation; 2023.
- K. ASTM C1423 - Standard Guide for Selecting Jacketing Materials for Thermal Insulation; 2021.
- L. ASTM D412 - Standard Test Methods for Vulcanized Rubber and Thermoplastic Elastomers--Tension; 2016 (Reapproved 2021).
- M. ASTM D570 - Standard Test Method for Water Absorption of Plastics; 2022.
- N. ASTM D1056 - Standard Specification for Flexible Cellular Materials—Sponge or Expanded Rubber; 2020.
- O. ASTM D1621 - Standard Test Method for Compressive Properties of Rigid Cellular Plastics; 2016 (Reapproved 2023).
- P. ASTM D2842 - Standard Test Method for Water Absorption of Rigid Cellular Plastics; 2019.
- Q. ASTM E84 - Standard Test Method for Surface Burning Characteristics of Building Materials; 2023d.
- R. ASTM E96/E96M - Standard Test Methods for Gravimetric Determination of Water Vapor Transmission Rate of Materials; 2023.

- S. ASTM E283/E283M - Standard Test Method for Determining Rate of Air Leakage Through Exterior Windows, Skylights, Curtain Walls, and Doors Under Specified Pressure Differences Across the Specimen; 2019.
- T. ASTM E331 - Standard Test Method for Water Penetration of Exterior Windows, Skylights, Doors, and Curtain Walls by Uniform Static Air Pressure Difference; 2000 (Reapproved 2023).
- U. ASTM E2178 - Standard Test Method for Determining Air Leakage Rate and Calculation of Air Permeance of Building Materials; 2021a.
- V. ASTM G21 - Standard Practice for Determining Resistance of Synthetic Polymeric Materials to Fungi; 2015, with Editorial Revision (2021).
- W. ASTM G153 - Standard Practice for Operating Enclosed Carbon Arc Light Apparatus for Exposure of Nonmetallic Materials; 2013 (Reapproved 2021).
- X. SAE AMS3779 - Tape, Adhesive, Pressure-Sensitive Thermal Radiation Resistant, Aluminum Coated Glass Cloth; 2016b.
- Y. UL 723 - Standard for Test for Surface Burning Characteristics of Building Materials; Current Edition, Including All Revisions.

1.04 SUBMITTALS

- A. See Section 01 30 00 - Administrative Requirements for submittal procedures.
- B. Product Data: Provide product description, thermal characteristics, list of materials and thickness for each service, and locations.
- C. Manufacturer's Instructions: Indicate installation procedures that ensure acceptable workmanship and installation standards will be achieved.

1.05 DELIVERY, STORAGE, AND HANDLING

- A. Accept materials on site, labeled with manufacturer's identification, product density, and thickness.

1.06 FIELD CONDITIONS

- A. Maintain ambient conditions required by manufacturers of each product.
- B. Maintain temperature before, during, and after installation for minimum of 24 hours.

PART 2 PRODUCTS

2.01 REGULATORY REQUIREMENTS

- A. Surface Burning Characteristics: Flame spread index/Smoke developed index of 25/50, maximum, when tested in accordance with ASTM E84 or UL 723.

2.02 GLASS FIBER, FLEXIBLE

- A. Manufacturers:
 - 1. JP Lamborn Co; Thermal Sleeve MT: www.jpflex.com/#sle.
 - 2. Substitutions: See Section 01 60 00 - Product Requirements.
- B. Insulation: ASTM C553; flexible, noncombustible blanket.
 - 1. K Value: 0.36 at 75 degrees F, when tested in accordance with ASTM C518.
 - 2. Maximum Service Temperature: 1,200 degrees F.
 - 3. Maximum Water Vapor Absorption: 5.0 percent by weight.
- C. Vapor Barrier Jacket:
 - 1. Kraft paper with glass fiber yarn and bonded to aluminized film.
 - 2. Moisture Vapor Permeability: 0.02 perm inch, when tested in accordance with ASTM E96/E96M.
 - 3. Secure with pressure-sensitive tape.

2.03 GLASS FIBER, RIGID

2.04 POLYISOCYANURATE CELLULAR PLASTIC

- A. Insulation Material: ASTM C591, rigid molded modified polyisocyanurate cellular plastic.
 - 1. Dimension: Comply with requirements of ASTM C585.
 - 2. K Value: 0.18 at 75 degrees F, when tested in accordance with ASTM C518.
 - 3. Minimum Service Temperature: Minus 70 degrees F.
 - 4. Maximum Service Temperature: 300 degrees F.
 - 5. Water Absorption: 0.5 percent by volume, maximum, when tested in accordance with ASTM D2842.
 - 6. Moisture Vapor Transmission: 4.0 perm inch.
 - 7. Connection: Waterproof vapor barrier adhesive.

2.05 FLEXIBLE ELASTOMERIC CELLULAR INSULATION

- A. Manufacturers:
 - 1. Aeroflex USA; AEROFLEX Self-Seal: www.aeroflexusa.com/#sle.
 - 2. Armacell LLC; ArmaFlex Ultra with FlameDefense: www.armacell.us/#sle.
 - 3. K-Flex USA LLC; Insul-Tube: www.kflexusa.com/#sle.
 - 4. Substitutions: See Section 01 60 00 - Product Requirements.
- B. Insulation: Preformed flexible elastomeric cellular rubber insulation complying with ASTM C534/C534M Grade 1; use molded tubular material where possible.
 - 1. Minimum Service Temperature: Minus 40 degrees F.
 - 2. Maximum Service Temperature: 180 degrees F.
 - 3. Connection: Waterproof vapor barrier adhesive.
- C. Elastomeric Foam Adhesive: Air dried, contact adhesive, compatible with insulation.
- D. Weather Barrier Coating: Air dried, contact adhesive, compatible with insulation and ASTM E84 compliant.

2.06 JACKETING AND ACCESSORIES

- A. PVC Plastic.
 - 1. Manufacturers:
 - a. Johns Manville Corporation: www.jm.com/#sle.
 - b. Substitutions: See Section 01 60 00 - Product Requirements.
 - 2. Jacket: One piece molded type fitting covers and sheet material, off-white color.
 - a. Minimum Service Temperature: 0 degrees F.
 - b. Maximum Service Temperature: 150 degrees F.
 - c. Moisture Vapor Permeability: 0.002 perm inch, maximum, when tested in accordance with ASTM E96/E96M.
 - d. Thickness: 10 mil, 0.010 inch.
 - e. Connections: Brush on welding adhesive.
- B. Canvas Jacket: UL listed 6 oz/sq yd plain weave cotton fabric treated with dilute fire-retardant lagging adhesive.
- C. Reinforced Tape:
 - 1. Manufacturers:
 - a. Ideal Tape Co., Inc: www.idealtape.com/#sle.
 - b. Substitutions: See Section 01 60 00 - Product Requirements.
 - 2. FSK tape suitable for sealing seams between insulation, insulated pipe bends, and fittings resulting in a tight, smooth surface without wrinkles.
 - 3. Comply with UL 723, ASTM E84.
 - 4. Moisture Vapor Permeability: 0.00 perm inch, when tested in accordance with ASTM E96/E96M.

2.07 ENGINEERED WALL OUTLET SEALS AND REFRIGERANT PIPING INSULATION PROTECTION

- A. Manufacturers:
 - 1. Airex Manufacturing, Inc: www.airexmfg.com/#sle.
 - 2. Substitutions: See Section 01 60 00 - Product Requirements.
- B. Basis of Design: Airex Manufacturing, Inc; www.airexmfg.com/#sle.
 - 1. Pipe Penetration Wall Seal: Airex Titan Outlet.
 - 2. Refrigeration Pipe Insulation Protection System: Airex E-Flex Guard.
- C. Pipe Penetration Wall Seal: Seals HVAC piping wall penetrations with compression gasket wall mounted rigid plastic outlet cover.
 - 1. Outlet Cover Color: Gray.
 - 2. Water Penetration: Comply with ASTM E331.
 - 3. Air Leakage: Comply with ASTM E283/E283M.
 - 4. Air Permeance: Comply with ASTM E2178.
- D. Insulation Protection System: Refrigerant piping insulation PVC protective cover.
 - 1. PVC Insulation Cover Color: Black with full-length velcro fastener.
 - 2. Weatherization and Ultraviolet Exposure Protection: Comply with ASTM G153.
 - 3. Water/Vapor Permeability: Comply with ASTM E96/E96M.
 - 4. Anti-Fungal and Anti-Microbial Resistance: Comply with ASTM G21.
 - 5. Flame Spread and Smoke Development Rating of 24/450: Comply with ASTM E84 or UL 723.
 - 6. Tensile Strength After UV Exposure and Water Immersion: Comply with ASTM D412.
 - 7. Water Absorption of Plastics: Comply with ASTM D570.
 - 8. Adhesive free.

2.08 ACCESSORIES

- A. General Requirements:
 - 1. Furnish compatible materials which do not contribute to corrosion, soften, or otherwise attack surfaces to which applied, in either the wet or dry state.
 - 2. Comply with ASTM C795 requirements for materials to be used on stainless steel surfaces.
 - 3. Supply materials that are asbestos free.

PART 3 EXECUTION

3.01 EXAMINATION

- A. Test piping for design pressure, liquid tightness, and continuity prior to applying insulation materials.
- B. Verify that surfaces are clean and dry, with foreign material removed.

3.02 INSTALLATION

- A. Install in accordance with manufacturer's instructions.
- B. Exposed Piping: Locate insulation and cover seams in least visible locations.
- C. Insulated Pipes Conveying Fluids Below Ambient Temperature:
 - 1. Insulate entire system, including fittings, valves, unions, flanges, strainers, flexible connections, pump bodies, and expansion joints.
- D. Glass Fiber Insulated Pipes Conveying Fluids Below Ambient Temperature:
 - 1. Provide vapor barrier jackets, factory-applied or field-applied; secure with self-sealing longitudinal laps and butt strips with pressure-sensitive adhesive. Secure with outward clinch expanding staples and vapor barrier mastic.

2. Insulate fittings, joints, and valves with molded insulation of like material and thickness as adjacent pipe. Finish with glass cloth and vapor barrier adhesive or PVC fitting covers.
- E. Glass Fiber Insulated Pipes Conveying Fluids Above Ambient Temperature:
 1. Provide standard jackets, with or without vapor barrier, factory-applied, or field-applied. Secure with self-sealing longitudinal laps and butt strips with pressure-sensitive adhesive. Secure with outward clinch expanding staples.
 2. Insulate fittings, joints, and valves with insulation of like material and thickness as adjoining pipe. Finish with glass cloth and adhesive or PVC fitting covers.
- F. Inserts and Shields:
 1. Application: Piping 1-1/2 inches diameter or larger.
 2. Shields: Galvanized steel between pipe hangers or pipe hanger rolls and inserts.
 3. Insert Configuration: Minimum 6 inches long, of same thickness and contour as adjoining insulation; may be factory fabricated.
 4. Insert Material: Hydrous calcium silicate insulation or other heavy density insulating material suitable for the planned temperature range.
- G. Pipe Exposed in Mechanical Equipment Rooms or Finished Spaces (less than 10 feet above finished floor): Finish with canvas jacket sized for finish painting.
- H. Exterior Applications: Provide vapor barrier jacket. Insulate fittings, joints, and valves with insulation of like material and thickness as adjoining pipe, and finish with glass mesh reinforced vapor barrier cement. Cover with aluminum jacket with seams located on bottom side of horizontal piping. Provide two coats of UV-resistant finish for flexible elastomeric cellular insulation without jacketing.

END OF SECTION

NOT FOR BIDDING

This page intentionally left blank

SECTION 23 09 13
INSTRUMENTATION AND CONTROL DEVICES FOR HVAC

PART 1 GENERAL

1.01 SECTION INCLUDES

- A. Control panels.
- B. Control Valves:
 - 1. Electronic valve operators.
- C. Dampers.
- D. Damper Operators:
 - 1. Electric operators.
 - 2. Inlet vane operators.
- E. Humidistats:
 - 1. Room humidistats.
- F. Wall-, Surface-, and Duct-Mounted Sensors:
 - 1. Temperature sensors.
 - 2. Humidity sensors.
 - 3. Airflow meters; pitot tubes.
 - 4. Damper position indicators.
 - 5. Carbon dioxide sensors.
- G. Thermostats:
 - 1. Electric thermostats.
 - 2. Freezestats.
- H. Pipe-Mounted Sensors and Transmitters:
 - 1. Temperature sensors.
 - 2. Differential pressure transmitters.
 - 3. Flow switches.
- I. Flow Sensors:
 - 1. Flow nozzles.
 - 2. Venturi tubes.

1.02 RELATED REQUIREMENTS

- A. Section 23 05 19 - Meters and Gauges for HVAC Piping: Thermometer sockets and gauge taps.
- B. Section 23 21 13 - Hydronic Piping: Installation of control valves, flow switches, temperature sensor sockets, and gauge taps.
- C. Section 23 21 14 - Hydronic Specialties.
- D. Section 25 35 13 - Integrated Automation Actuators and Operators.
- E. Section 26 05 83 - Wiring Connections: Electrical characteristics and wiring connections.
- F. Section 26 27 26 - Wiring Devices: Elevation of exposed components.

1.03 REFERENCE STANDARDS

- A. AMCA 500-D - Laboratory Methods of Testing Dampers for Rating; 2018.
- B. ANSI/FCI 70-2 - Control Valve Seat Leakage; 2021.
- C. ASTM B88 - Standard Specification for Seamless Copper Water Tube; 2022.
- D. IEEE 802.3 - IEEE Standard for Ethernet; 2022 (Corrigendum 2024).
- E. Modbus (PS) - The Modbus Organization Communications Protocol.; Latest Update.

- F. NEMA 250 - Enclosures for Electrical Equipment (1000 Volts Maximum); 2020.
- G. NEMA DC 3 - Residential Controls - Electrical Wall-Mounted Room Thermostats; 2013.
- H. NFPA 70 - National Electrical Code; Most Recent Edition Adopted by Authority Having Jurisdiction, Including All Applicable Amendments and Supplements.
- I. NFPA 90A - Standard for the Installation of Air-Conditioning and Ventilating Systems; 2024.
- J. UL 94 - Tests for Flammability of Plastic Materials for Parts in Devices and Appliances; Current Edition, Including All Revisions.
- K. UL 916 - Energy Management Equipment; Current Edition, Including All Revisions.

1.04 ADMINISTRATIVE REQUIREMENTS

- A. Preinstallation Meeting: Conduct a preinstallation meeting one week before starting work of this section; require attendance by all affected installers.
- B. Sequencing: Ensure that utility connections are achieved in an orderly and expeditious manner.

1.05 SUBMITTALS

- A. See Section 01 30 00 - Administrative Requirements for submittal procedures.
- B. Product Data: Provide description and engineering data for each control system component. Include sizing as requested. Provide data for each system component and software module.
- C. Manufacturer's Instructions: Provide for all manufactured components.
- D. Designer's qualification statement.
- E. Manufacturer's qualification statement.
- F. Operation and Maintenance Data: Include inspection period, cleaning methods, recommended cleaning materials, and calibration tolerances.
- G. Project Record Documents: Record actual location of control components, including panels, thermostats, and sensors.

1.06 WARRANTY

- A. See Section 01 78 00 - Closeout Submittals for additional warranty requirements.

PART 2 PRODUCTS

2.01 EQUIPMENT - GENERAL

- A. Products Requiring Electrical Connection: Listed and classified by Underwriters Laboratories Inc., as suitable for the purpose specified and indicated.

2.02 CONTROL PANELS

- A. Unitized cabinet type for each system under automatic control with relays and controls mounted in cabinet and temperature indicators, pressure gauges, pilot lights, push buttons and switches flush on cabinet panel face.
- B. NEMA 250, general purpose utility enclosures with enameled finished face panel.
- C. Provide common keying for all panels.

2.03 CONTROL VALVES

- A. Electronic Valve Actuators:
 - 1. Manufacturers:
 - a. Honeywell International, Inc: buildingcontrols.honeywell.com/#sle.
 - b. Johnson Controls International, PLC: www.johnsoncontrols.com/#sle.
 - 2. Valves shall spring return to normal position as indicated on freeze, fire, or temperature protection.

3. Select operator for full shut-off at maximum pump differential pressure.

2.04 DAMPERS

- A. See Section 23 33 00 for dampers and this section for actuators and operators.

2.05 DAMPER OPERATORS

- A. General:
 1. Provide actuators with torque capacity sized for minimum of 20 percent greater than maximum design stream velocity and hold tight seal against maximum system pressures.
 2. Provide spring return for two position control and for fail safe operation.
 3. Provide sufficient number of operators to achieve unrestricted movement throughout damper range.
 4. Provide one operator for maximum 36 sq ft damper section.
 5. See Section 25 35 13 for field-mount damper actuators and operators.
- B. Electric Operators:
 1. Manufacturers:
 - a. Honeywell International, Inc: buildingcontrols.honeywell.com/#sle.
 - b. Johnson Controls International, PLC: www.johnsoncontrols.com/#sle.
 2. Spring return, adjustable stroke motor having oil immersed gear train, with auxiliary end switch.
- C. Inlet Vane Operators:
 1. High pressure with pilot positioners and sufficient force to move vanes when fan is started with vanes in closed position. Return vane operator to closed position on fan shutdown.

2.06 HUMIDISTATS

- A. Room Humidistats:
 1. Manufacturers:
 - a. Honeywell International, Inc: buildingcontrols.honeywell.com/#sle.
 - b. Johnson Controls International, PLC: www.johnsoncontrols.com/#sle.
 2. Wall mounted, proportioning type.
 3. Throttling Range: Adjustable 2 percent relative humidity.
 4. Operating Range: 30 to 80 percent.
 5. Cover: Set point indication.

2.07 WALL-, SURFACE- AND DUCT-MOUNT SENSORS

- A. Temperature Sensors:
 1. Manufacturers:
 - a. Dwyer Instruments Inc: www.dwyer-inst.com/#sle.
 - b. Johnson Controls International, PLC: www.johnsoncontrols.com/#sle.
 - c. Setra Systems, Inc: www.setra.com/#sle.
 - d. Substitutions: See Section 01 60 00 - Product Requirements.
 2. Use thermistor or RTD type temperature sensing elements with characteristics resistant to moisture, vibration, and other conditions consistent with the application without affecting accuracy and life expectancy.
 3. Construct RTD of nickel or platinum with base resistance of 1000 ohms at 70 degrees F.
 4. 100 ohm platinum RTD is acceptable if used with project DDC controllers.
 5. Temperature Sensing Device: Compatible with project DDC controllers.
 6. Performance Characteristics:
 - a. RTD:
 - 1) Room Sensor Accuracy: Plus/minus 0.50 degrees F minimum.
 - 2) Duct Averaging Accuracy: Plus/minus 0.50 degrees F minimum.
 - 3) Chilled Water Accuracy: Plus/minus 0.50 degrees F minimum.

-
- 4) All Other Accuracy: Plus/minus 0.75 degrees F minimum.
 - 5) Range: Minus 40 degrees F through 220 degrees F minimum.
 - b. Thermistor:
 - 1) Accuracy (All): Plus/minus 0.36 degrees F minimum.
 - 2) Range: Minus 25 degrees F through 122 degrees F minimum.
 - 3) Heat Dissipation Constant: 2.7 mW per degree C.
 - c. Sensing Range:
 - 1) Provide limited range sensors if required to sense the range expected for a respective point.
 - 2) Use RTD type sensors for extended ranges beyond minus 30 to 230 degrees F.
 - 3) Use temperature transmitters in conjunction with RTDs when RTDs are incompatible with DDC controller direct temperature input.
 - d. Wire Resistance:
 - 1) Use appropriate wire size to limit temperature offset due to wire resistance to 1.0 degree F or use temperature transmitter when offset is greater than 1.0 degree F due to wire resistance.
 - 2) Compensate for wire resistance in software input definition when feature is available in the DDC controller.
 - B. Humidity Sensors, Duct-Mounted:
 - 1. Manufacturers:
 - a. Dwyer Instruments Inc: www.dwyer-inst.com/#sle.
 - b. Johnson Controls International, PLC: www.johnsoncontrols.com/#sle.
 - c. Setra Systems, Inc: www.setra.com/#sle.
 - 2. Digitally profiled thin-film capacitive sensor probe extended from die-cast metal, weather-proof plastic or metal housing designed for duct mounting.
 - 3. Measuring Scale: 0 to 100 percent RH, noncondensing, temperature compensated.
 - 4. Hardwired Output: Two-wire, 4 to 20 mA, loop powered.
 - 5. Accuracy: Plus/minus 1 percent between 20 to 40 percent RH linear range, NIST traceable with multi-point calibration.
 - C. Airflow Meters; Pitot Tubes:
 - 1. Sensor Type: Provide duct-inserted probe, duct-inserted pitot-tube assembly, and wall-mounted assembly for outside air with built-in transmitter.
 - 2. Flow Range: Equivalent velocity pressure required to match scheduled flow range with a 100 to 1 signal turndown ratio.
 - 3. Accuracy: Two percent over a 30 to 50 millisecond response time, adjustable.
 - 4. Linearity: 0.1 percent of calibrated span.
 - 5. Minimum Overpressure: 150 percent over highest range value.
 - 6. Output: Two-wire, 4 to 20 mA.
 - 7. Access Box: NEMA 250, Type 1 with hinged cover housing and cable access ports.
 - D. Damper Position Indicators: Potentiometer mounted in enclosure with adjustable crank arm assembly connected to damper to transmit 0 to 100 percent damper travel.
 - E. Carbon Dioxide Sensors, Duct and Wall:
 - 1. General: Provide nondispersive infrared (NDIR), diffusion sampling CO2 sensors with integral transducers and linear output.
 - 2. Air Temperature: Range of 32 to 122 degrees F.
 - 3. Relative Humidity: Range of 0 to 95 percent (noncondensing).
 - 4. Calibration Characteristics:
 - a. Automatically compensating algorithm for sensor drift due to sensor degradation.
 - b. Maximum Drift: 2 percent.
 - c. User calibratable with a minimum calibration interval of 5 years.

5. Construction:
 - a. Sensor Chamber: Noncorrosive material for neutral effect on carbon dioxide sample.
 - b. Provide duct mounted sensors with duct probe designed to protect sensing element from dust accumulation and mechanical damage.
 - c. Housing: High impact plastic.

2.08 THERMOSTATS

- A. Electric Thermostats:
 1. Type: NEMA DC 3, 24 volts, with setback/setup temperature control.
 2. Service: Cooling and heating.
 3. Covers: Locking with set point adjustment, with thermometer.
- B. Freezestats:
 1. Configuration: Vapor-filled capillary.
 2. Probe Sensing Length: 20 feet.
 3. Setpoint Adjust Control: Screw with manual reset switch.
 4. Switch Type: SPDT, snap-action, form C in dust-protected enclosure.
 5. Mounting: Locate on cooling coil intake side or pre-heating/heating coil intake side.
 6. Field Interface: Connect load line-voltage to starter.
 7. Electrical Rating: As indicated on drawings.

2.09 PIPE-MOUNTED SENSORS AND TRANSMITTERS

- A. Temperature Sensors:
 1. Pipe-mounted temperature probe tied to weather-resistant enclosure for direct insertion into compatible liquids or gases or inserted into intermediary thermal grease-filled pipe-well compatible with interfaced fluid.
 2. Sensor Type: 1,000 ohm Platinum RTD.
 3. Transmitter: Fitted within probe interface enclosure, calibrated.
 - a. Monitoring Range: 32 to 132 degrees F, adjustable.
 - b. Hardwired Output: Two-wire, 4 to 20 mA, loop powered.
 - c. Accuracy: Plus/minus three percent, adjustable on the transmitter end.
 4. Accessories: Provide downstream PT test plug and brass pipe-well.
- B. Flow Switches:
 1. Repetitive Accuracy: Plus/minus 10 percent of actual flow setting.
 2. Switch Actuation: Adjustable over the operating range and sized for the application, such that the setpoint is between 25 and 75 percent of the full range.
 3. Provide Form C snap-action contacts, rated for the application.
 4. Furnish nonflexible paddle with magnetically actuated contacts, rated for service at a pressure greater than the installed conditions.

2.10 FLOW SENSORS

- A. Flow Nozzles:
 1. Fabricate flow nozzle from austenitic stainless steel with an accuracy of plus/minus 1 percent of full flow.
 2. Inlet Nozzle: Elliptical with the nozzle throat to be the quadrant of an ellipse.
 3. Thickness of the nozzle wall and flange to be such that distortion of the nozzle throat from strains caused by the pipeline pressure and temperature, flange bolting, or other methods of installing the nozzle in the pipeline must not cause the accuracy to degrade beyond the specified limit.
 4. Outside Diameter of the Nozzle Flange or Design of the Flange Facing: Nozzle throat to be centered accurately in the pipe.
- B. Venturi Tubes:

1. Fabricate the venturi tube from cast iron with an accuracy of plus/minus 1 percent of full flow.
2. Line the throat section with austenitic stainless steel.
3. Thermal Expansion Characteristics of the Lining: Same as that of the throat casting material.
4. Machine the surface of the throat to plus/minus 50 micro-inches, including the short curvature leading from the converging entrance section into the throat.

PART 3 EXECUTION

3.01 EXAMINATION

- A. Verify existing conditions before starting work.
- B. Beginning of installation means installer accepts existing conditions.
- C. Coordinate installation of system components with installation of mechanical systems equipment such as air handling units and air terminal units.
- D. Ensure installation of components is complementary to installation of similar components.
- E. Coordinate installation of system components with installation of mechanical systems equipment such as air handling units and air terminal units.

3.02 INSTALLATION

- A. Install in accordance with manufacturer's instructions.
- B. Conceal tubing. Run exposed only in mechanical rooms, storage rooms and like, in neat manner and properly supported.
- C. Mechanically attach tubing to supporting surfaces. Sleeve through concrete surfaces in minimum 1 inch sleeves, extended 6 inches above floors and 1 inch below bottom surface of slabs.
- D. Check and verify location of thermostats with plans and room details before installation. Locate 60 inches above floor. Align with lighting switches and humidistats; see Section 26 27 26.
- E. Provide conduit and electrical wiring in accordance with Section 26 05 83. Electrical material and installation shall be in accordance with appropriate requirements of Division 26.

END OF SECTION

SECTION 23 09 23
DIRECT-DIGITAL CONTROL SYSTEM FOR HVAC

PART 1 GENERAL

1.01 SECTION INCLUDES

- A. System description.
- B. Operator interface.
- C. Controllers.
- D. Power supplies and line filtering.
- E. System software.
- F. Controller software.
- G. HVAC control programs.

1.02 RELATED REQUIREMENTS

- A. Section 23 09 13 - Instrumentation and Control Devices for HVAC.
- B. Section 23 09 93 - Sequence of Operations for HVAC Controls.
- C. Section 26 05 83 - Wiring Connections: Electrical characteristics and wiring connections.

1.03 REFERENCE STANDARDS

- A. ASHRAE Std 135 - A Data Communication Protocol for Building Automation and Control Networks; 2020, with Addendum (2024).
- B. IEEE 802.11 - IEEE Standard for Information Technology--Telecommunications and Information Exchange between Systems - Local and Metropolitan Area Networks--Specific Requirements - Part 11: Wireless LAN Medium Access Control (MAC) and Physical Layer (PHY) Specifications; 2020, with Amendment (2023).
- C. IEEE 802.15.4 - IEEE Standard for Low-Rate Wireless Networks; 2024.
- D. MIL-STD-810 - Environmental Engineering Considerations and Laboratory Tests; 2022h, with Editorial Revision.
- E. Modbus (PS) - The Modbus Organization Communications Protocol.; Latest Update.
- F. NFPA 70 - National Electrical Code; Most Recent Edition Adopted by Authority Having Jurisdiction, Including All Applicable Amendments and Supplements.
- G. UL (DIR) - Online Certifications Directory; Current Edition.

1.04 ADMINISTRATIVE REQUIREMENTS

- A. Preinstallation Meeting: Conduct a preinstallation meeting one week prior to the start of the work of this section; require attendance by all affected installers.

1.05 SUBMITTALS

- A. See Section 01 30 00 - Administrative Requirements for submittal procedures.
- B. Product Data: Provide data for each system component and software module.
- C. Shop Drawings:
 - 1. Indicate trunk cable schematic showing programmable control unit locations, and trunk data conductors.
 - 2. List connected data points, including connected control unit and input device.
 - 3. Indicate system graphics indicating monitored systems, data (connected and calculated) point addresses, and operator notations. Provide demonstration digital media containing graphics.

4. Show system configuration with peripheral devices, batteries, power supplies, diagrams, modems, and interconnections.
5. Indicate description and sequence of operation of operating, user, and application software.
- D. Manufacturer's Instructions: Indicate manufacturer's installation instructions for all manufactured components.
- E. Installer's Qualification Statement.
- F. Project Record Documents: Record actual locations of control components, including control units, thermostats, and sensors.
 1. Revise shop drawings to reflect actual installation and operating sequences.
 2. Include submittals data in final "Record Documents" form.
- G. Operation and Maintenance Data:
 1. Include interconnection wiring diagrams complete field installed systems with identified and numbered, system components and devices.
 2. Include keyboard illustrations and step-by-step procedures indexed for each operator function.
 3. Include inspection period, cleaning methods, cleaning materials recommended, and calibration tolerances.

1.06 QUALITY ASSURANCE

- A. Designer Qualifications: Perform design of system using manufacturer's software under direct supervision of a Professional Engineer experienced in design of this type of work and licensed in the State in which the Project is located.
- B. Manufacturer Qualifications: Company specializing in manufacturing products specified in this section with minimum three years of documented experience.
- C. Products Requiring Electrical Connection: Listed and classified by UL (DIR) as suitable for purpose specified and indicated.

1.07 PROTECTION OF SOFTWARE RIGHTS

- A. Prior to delivery of software, the Del Tech and the party providing the software will enter into a software license agreement with provisions for the following:
 1. Limiting use of software to equipment provided under these specifications.
 2. Limiting copying.
 3. Preserving confidentiality.
 4. Prohibiting transfer to a third party.

PART 2 PRODUCTS

2.01 SYSTEM DESCRIPTION

- A. Automatic temperature control field monitoring and control system using field programmable micro-processor based units.
- B. Base system on distributed system of fully intelligent, stand-alone controllers, operating in a multi-tasking, multi-user environment on token passing network, with central and remote hardware, software, and interconnecting wire and conduit.
- C. Include computer software and hardware, operator input/output devices, control units, local area networks (LAN), sensors, control devices, actuators.
- D. Controls for variable air volume terminals, radiation, reheat coils, unit heaters, fan coils, and the like when directly connected to the control units. Individual terminal unit control is specified in Section 23 09 13.
- E. Provide control systems consisting of thermostats, control valves, dampers and operators, indicating devices, interface equipment and other apparatus and accessories required to

operate mechanical systems, and to perform functions specified.

- F. Include installation and calibration, supervision, adjustments, and fine tuning necessary for complete and fully operational system.
- G. The BAS controls shall tie into the existing Johnson Controls Systems in the building by Modern Controls.

2.02 OPERATOR INTERFACE

- A. PC Based Work Station:
 - 1. Resides on high speed network with building controllers.
- B. Workstation, controllers, and control backbone to communicate using BACnet protocol and addressing.
- C. BACnet protocol to comply with ASHRAE Std 135.
- D. Hardware:
 - 1. Desktop:
 - a. Computer(s) and display(s) to be provided by DDC controls manufacturer.
 - b. Quantity: As indicated on the drawings.
 - c. Minimum RAM: _____.
 - d. Minimum Processing Speed: _____.
 - e. Minimum Hard Drive Memory: _____.
 - f. Drives: _____.
 - g. Ports: _____.
 - h. Monitor: _____.
 - i. Location(s): As indicated on the drawings.
 - j. Network Connection:
 - 1) Ethernet interface card.
 - 2) Minimum Speed: _____.
 - k. System Printer:
 - 1) Printer(s) to be provided by DDC controls manufacturer.
 - 2) Quantity: As indicated on the drawings.
 - 3) Type: _____.
 - 4) Resolution: _____.
 - 5) Minimum Print Speed: _____.
 - 6) Locations(s): As indicated on the drawings.

2.03 CONTROLLERS

- A. Building Controllers:
 - 1. General:
 - a. Manage global strategies by one or more, independent, standalone, microprocessor based controllers.
 - b. Provide sufficient memory to support controller's operating system, database, and programming requirements.
 - c. Share data between networked controllers.
 - d. Controller operating system manages input and output communication signals allowing distributed controllers to share real and virtual object information and allowing for central monitoring and alarms.
 - e. Utilize real-time clock for scheduling.
 - f. Continuously check processor status and memory circuits for abnormal operation.
 - g. Controller to assume predetermined failure mode and generate alarm notification upon detection of abnormal operation.
 - h. Communication with other network devices to be based on assigned protocol.
 - 2. Communication:

- a. Controller to reside on a BACnet network using ISO 8802-3 (ETHERNET) Data Link/Physical layer protocol.
 - b. Perform routing when connected to a network of custom application and application specific controllers.
 - c. Provide service communication port for connection to a portable operator's terminal or hand held device with compatible protocol.
- 3. External Input-Output (I-O) Data Bus:
 - a. Variable frequency drives (VFD's).
 - b. Universal I-O module (configurable).
 - c. Access control module for single door.
 - d. Specific wired and wireless data integration modules.
 - e. DALI (Digital addressable lighting interface) modules.
 - f. Motor control of devices like blinds, roller shutters, and sun protection systems.
 - g. Multiple Input Output (I-O) Module:
 - 1) IAQ: Temperature, humidity, and CO2.
 - 2) Audio: Microphone, tone generator, and speaker.
 - 3) Occupancy: Light and thermal sensing with multi-colored LED feedback.
- 4. Anticipated Environmental Ambient Conditions:
 - a. Outdoors and/or in Wet Ambient Conditions:
 - 1) Mount within waterproof enclosures.
 - 2) Rated for operation at 40 to 150 degrees F.
 - b. Conditioned Space:
 - 1) Mount within dustproof enclosures.
 - 2) Rated for operation at 32 to 120 degrees F.
- 5. Provisions for Serviceability:
 - a. Diagnostic LEDs for power, communication, and processor.
 - b. Make all wiring connections to field removable, modular terminal strips, or to a termination card connected by a ribbon cable.
- 6. Memory: In the event of a power loss, maintain all BIOS and programming information for a minimum of 72 hours.
- 7. Power and Noise Immunity:
 - a. Maintain operation at 90 to 110 percent of nominal voltage rating.
 - b. Perform orderly shutdown below 80 percent of nominal voltage.
 - c. Operation protected against electrical noise of 5 to 120 Hz and from keyed radios up to 5 W. at 3 feet.
- B. Custom Application Controller:
 - 1. General:
 - a. Provide sufficient memory to support controller's operating system, database, and programming requirements.
 - b. Share data between networked, microprocessor based controllers.
 - c. Controller operating system manages input and output communication signals allowing distributed controllers to share real and virtual object information and allowing for central monitoring and alarms.
 - d. Utilize real-time clock for scheduling.
 - e. Continuously check processor status and memory circuits for abnormal operation.
 - f. Controller to assume predetermined failure mode and generate alarm notification upon detection of abnormal operation.
 - g. Communication with other network devices to be based on assigned protocol.
 - 2. Communication:
 - a. Controller to reside on a BACnet network using MS/TP Data Link/Physical layer protocol.

- b. Provide service communication port for connection to a portable operator's terminal or hand held device with compatible protocol.
 - 3. Anticipated Environmental Ambient Conditions:
 - a. Outdoors and/or in Wet Ambient Conditions:
 - 1) Mount within waterproof enclosures.
 - 2) Rated for operation at 40 to 150 degrees F.
 - b. Conditioned Space:
 - 1) Mount within dustproof enclosures.
 - 2) Rated for operation at 32 to 120 degrees F.
 - 4. Provisions for Serviceability:
 - a. Diagnostic LED's for power, communication, and processor.
 - b. Make all wiring connections to field removable, modular terminal strips, or to a termination card connected by a ribbon cable.
 - 5. Memory: In the event of a power loss, maintain all BIOS and programming information for a minimum of 72 hours.
 - 6. Power and Noise Immunity:
 - a. Maintain operation at 90 to 110 percent of nominal voltage rating.
 - b. Perform orderly shutdown below 80 percent of nominal voltage.
 - c. Operation protected against electrical noise of 5 to 120 Hz and from keyed radios up to 5 W. at 3 feet.
- C. Application Specific Controllers:
 - 1. General:
 - a. Not fully user programmable, microprocessor based controllers dedicated to control specific equipment.
 - b. Customized for operation within the confines of equipment served.
 - c. Communication with other network devices to be based on assigned protocol.
 - 2. Communication:
 - a. Controller to reside on a BACnet network using MS/TP Data Link/Physical layer protocol.
 - b. Provide service communication port for connection to a portable operator's terminal or hand held device with compatible protocol.
 - 3. Anticipated Environmental Ambient Conditions:
 - a. Outdoors and/or in Wet Ambient Conditions:
 - 1) Mount within waterproof enclosures.
 - 2) Rated for operation at 40 to 150 degrees F.
 - b. Conditioned Space:
 - 1) Mount within dustproof enclosures.
 - 2) Rated for operation at 32 to 120 degrees F.
 - 4. Provisions for Serviceability:
 - a. Diagnostic LEDs for power, communication, and processor.
 - b. Make all wiring connections to field removable, modular terminal strips, or to a termination card connected by a ribbon cable.
 - 5. Memory: In the event of a power loss, maintain all BIOS and programming information for a minimum of 72 hours.
 - 6. Power and Noise Immunity:
 - a. Maintain operation at 90 to 110 percent of nominal voltage rating.
 - b. Perform orderly shutdown below 80 percent of nominal voltage.
 - c. Operation protected against electrical noise of 5 to 120 Hz and from keyed radios up to 5 W at 3 feet.
- D. Input/Output Interface:

1. Hardwired inputs and outputs tie into the DDC system through building, custom application, or application specific controllers.
2. All Input/Output Points:
 - a. Protect controller from damage resulting from any point short-circuiting or grounding and from voltage up to 24 volts of any duration.
 - b. Provide universal type for building and custom application controllers where input or output is software designated as either binary or analog type with appropriate properties.
3. Binary Inputs:
 - a. Allow monitoring of On/Off signals from remote devices.
 - b. Provide wetting current of 12 mA minimum, compatible with commonly available control devices and protected against the effects of contact bounce and noise.
 - c. Sense dry contact closure with power provided only by the controller.
4. Pulse Accumulation Input Objects: Comply with all requirements of binary input objects and accept up to 10 pulses per second.
5. Analog Inputs:
 - a. Allow for monitoring of low voltage 0 to 10 VDC, 4 to 20 mA current, or resistance signals (thermistor, RTD).
 - b. Compatible with and field configurable to commonly available sensing devices.
6. Binary Outputs:
 - a. Used for On/Off operation or a pulsed low voltage signal for pulse width modulation control.
 - b. Outputs provided with three position (On/Off/Auto) override switches.
 - c. Status lights for building and custom application controllers to be selectable for normally open or normally closed operation.
7. Analog Outputs:
 - a. Monitoring signal provides a 0 to 10 VDC or a 4 to 20 mA output signal for end device control.
 - b. Provide status lights and two position (AUTO/MANUAL) switch for building and custom application controllers with manually adjustable potentiometer for manual override on building and custom application controllers.
 - c. Drift to not exceed 0.4 percent of range per year.
8. Tri State Outputs:
 - a. Coordinate two binary outputs to control three point, floating type, electronic actuators without feedback.
 - b. Limit the use of three point, floating devices to the following zone and terminal unit control applications:
 - c. Control algorithms run the zone actuator to one end of its stroke once every 24 hours for verification of operator tracking.
9. System Object Capacity:
 - a. System size to be expandable to twice the number of input output objects required by providing additional controllers, including associated devices and wiring.
 - b. Hardware additions or software revisions for the installed operator interfaces are not to be required for future, system expansions.

2.04 SYSTEM SOFTWARE

- A. Operating System:
 1. Concurrent, multi-tasking capability.
 - a. Common Software Applications Supported: Microsoft Excel.
 2. System Graphics:
 - a. Allow up to 10 graphic screens, simultaneously displayed for comparison and monitoring of system status.

-
- b. Animation displayed by shifting image files based on object status.
 - c. Provide method for operator with password to perform the following:
 - 1) Move between, change size, and change location of graphic displays.
 - 2) Modify on-line.
 - 3) Add, delete, or change dynamic objects consisting of:
 - (a) Analog and binary values.
 - (b) Dynamic text.
 - (c) Static text.
 - (d) Animation files.
 - 3. Custom Graphics Generation Package:
 - a. Create, modify, and save graphic files and visio format graphics in PCX formats.
 - b. HTML graphics to support web browser compatible formats.
 - c. Capture or convert graphics from AutoCAD.
 - 4. Standard HVAC Graphics Library:
 - a. HVAC Equipment:
 - 1) Terminal HVAC Units.
 - b. Ancillary Equipment:
 - 1) Fans.
 - 2) Pumps.
 - 3) Coils.
 - 4) Valves.
 - 5) Piping.
 - 6) Dampers.
 - 7) Ductwork.
 - B. Workstation System Applications:
 - 1. Automatic System Database Save and Restore Functions:
 - a. Current database copy of each Building Controller is automatically stored on hard disk.
 - b. Automatic update occurs upon change in any system panel.
 - c. In the event of database loss in any system panel, the first workstation to detect the loss automatically restores the database for that panel unless disabled by the operator.
 - 2. Manual System Database Save and Restore Functions by Operator with Password Clearance:
 - a. Save database from any system panel.
 - b. Clear a panel database.
 - c. Initiate a download of a specified database to any system panel.
 - 3. Software provided allows system configuration and future changes or additions by operators under proper password protection.
 - 4. On-line Help:
 - a. Context-sensitive system assists operator in operation and editing.
 - b. Available for all applications.
 - c. Relevant screen data provided for particular screen display.
 - d. Additional help available via hypertext.
 - 5. Security:
 - a. Operator log-on requires user name and password to view, edit, add, or delete data.
 - b. System security selectable for each operator.
 - c. System supervisor sets passwords and security levels for all other operators.
 - d. Operator passwords to restrict functions accessible to viewing and/or changing system applications, editor, and object.

- e. Automatic, operator log-off results from keyboard or mouse inactivity during user-adjustable, time period.
- f. All system security data stored in encrypted format.
- 6. System Diagnostics:
 - a. Operations Automatically Monitored:
 - 1) Workstations.
 - 2) Printers.
 - 3) Modems.
 - 4) Network connections.
 - 5) Building management panels.
 - 6) Controllers.
 - b. Device failure is annunciated to the operator.
- 7. Alarm Processing:
 - a. All system objects are configurable to "alarm in" and "alarm out" of normal state.
 - b. Configurable Objects:
 - 1) Alarm limits.
 - 2) Alarm limit differentials.
 - 3) States.
 - 4) Reactions for each object.
- 8. Alarm Messages:
 - a. Descriptor: English language.
 - b. Recognizable Features:
 - 1) Source.
 - 2) Location.
 - 3) Nature.
- 9. Configurable Alarm Reactions by Workstation and Time of Day:
 - a. Logging.
 - b. Printing.
 - c. Starting programs.
 - d. Displaying messages.
 - e. Dialing out to remote locations.
 - f. Paging.
 - g. Providing audible annunciation.
 - h. Displaying specific system graphics.
- 10. Custom Trend Logs:
 - a. Definable for any data object in the system including interval, start time, and stop time.
 - b. Trend Data:
 - 1) Sampled and stored on the building controller panel.
 - 2) Archivable on hard disk.
 - 3) Retrievable for use in reports, spreadsheets and standard database programs.
 - 4) Archival on LAN accessible storage media including hard disk, tape, Raid array drive, and virtual cloud environment.
 - 5) Protected and encrypted format to prevent manipulation, or editing of historical data and event logs.
- 11. Alarm and Event Log:
 - a. View all system alarms and change of states from any system location.
 - b. Events listed chronologically.
 - c. Operator with proper security acknowledges and clears alarms.
 - d. Alarms not cleared by operator are archived to the workstation hard disk.
- 12. Object, Property Status and Control:

- a. Provide a method to view, edit if applicable, the status of any object and property in the system.
- b. Status Available by the Following Methods:
 - 1) Menu.
 - 2) Graphics.
 - 3) Custom Programs.
- 13. Reports and Logs:
 - a. Reporting Package:
 - 1) Allows operator to select, modify, or create reports.
 - 2) Definable as to data content, format, interval, and date.
 - 3) Archivable to hard disk.
 - b. Real-time logs available by type or status such as alarm, lockout, normal, etc.
 - c. Stored on hard disk and readily accessible by standard software applications, including spreadsheets and word processing.
 - d. Set to be printed on operator command or specific time(s)
- 14. Reports:
 - a. Standard:
 - 1) Objects with current values.
 - 2) Current alarms not locked out.
 - 3) Disabled and overridden objects, points and S/NVTs.
 - 4) Objects in manual or automatic alarm lockout.
 - 5) Objects in alarm lockout currently in alarm.
 - 6) Logs:
 - (a) Alarm History.
 - (b) System messages.
 - (c) System events.
 - (d) Trends.
 - b. Custom:
 - 1) Daily.
 - 2) Weekly.
 - 3) Monthly.
 - 4) Annual.
 - 5) Time and date stamped.
 - 6) Title.
 - 7) Facility name.
 - c. Tenant Override:
 - 1) Monthly report showing total, requested, after-hours HVAC and lighting services on a daily basis for each tenant.
 - 2) Annual report showing override usage on a monthly basis.
 - d. Electrical, Fuel, and Weather:
 - 1) Electrical Meter(s):
 - (a) Monthly showing daily electrical consumption and peak electrical demand with time and date stamp for each meter.
 - (b) Annual summary showing monthly electrical consumption and peak demand with time and date stamp for each meter.
 - 2) Fuel Meter(s):
 - (a) Monthly showing daily natural gas consumption for each meter.
 - (b) Annual summary showing monthly consumption for each meter.
 - 3) Weather:
 - (a) Monthly showing minimum, maximum, average outdoor air temperature and heating/cooling degree-days for the month.

- C. Workstation Applications Editors:
1. Provide editing software for each system application at PC workstation.
 2. Downloaded application is executed at controller panel.
 3. Full screen editor for each application allows operator to view and change:
 - a. Configuration.
 - b. Name.
 - c. Control parameters.
 - d. Set-points.
 4. Scheduling:
 - a. Monthly calendar indicates schedules, holidays, and exceptions.
 - b. Allows several related objects to be scheduled and copied to other objects or dates.
 - c. Start and stop times adjustable from master schedule.
 5. Custom Application Programming:
 - a. Create, modify, debug, edit, compile, and download custom application programming during operation and without disruption of all other system applications.
 - b. Programming Features:
 - 1) English oriented language, based on BASIC, FORTRAN, C, or PASCAL syntax allowing for free form programming.
 - 2) Alternative language graphically based using appropriate function blocks suitable for all required functions and amenable to customizing or compounding.
 - 3) Insert, add, modify, and delete custom programming code that incorporates word processing features such as cut/paste and find/replace.
 - 4) Allows the development of independently, executing, program modules designed to enable and disable other modules.
 - 5) Debugging/simulation capability that displays intermediate values and/or results including syntax/execution error messages.
 - 6) Support for conditional statements (IF/THEN/ELSE/ELSE-F) using compound Boolean (AND, OR, and NOT) and/or relations (EQUAL, LESS THAN, GREATER THAN, NOT EQUAL) comparisons.
 - 7) Support for floating-point arithmetic utilizing plus, minus, divide, times, square root operators; including absolute value; minimum/maximum value from a list of values for mathematical functions.
 - 8) Language consisting of resettable, predefined, variables representing time of day, day of the week, month of the year, date; and elapsed time in seconds, minutes, hours, and days where the variable values can be used in IF/THEN comparisons, calculations, programming statement logic, etc.
 - 9) Language having predefined variables representing status and results of the system software enables, disables, and changes the set points of the controller software.

2.05 CONTROLLER SOFTWARE

- A. All applications reside and operate in the system controllers and editing of all applications occurs at the operator workstation.
- B. System Security:
1. User access secured via user passwords and user names.
 2. Passwords restrict user to the objects, applications, and system functions as assigned by the system manager.
 3. User Log On/Log Off attempts are recorded.
 4. Automatic Log Off occurs following the last keystroke after a user defined delay time.
- C. Object or Object Group Scheduling:
1. Weekly Schedules Based on Separate, Daily Schedules:
 - a. Include start, stop, optimal stop, and night economizer.

- b. 10 events maximum per schedule.
 - c. Start/stop times adjustable for each group object.
- D. Provide standard application for equipment coordination and grouping based on function and location to be used for scheduling and other applications.
- E. Alarms:
 - 1. Binary object is set to alarm based on the operator specified state.
 - 2. Analog object to have high/low alarm limits.
 - 3. All alarming is capable of being automatically and manually disabled.
 - 4. Alarm Reporting:
 - a. Operator determines action to be taken for alarm event.
 - b. Alarms to be routed to appropriate workstation.
 - c. Reporting Options:
- F. Maintenance Management: System monitors equipment status and generates maintenance messages based upon user-designated run-time limits.
- G. Sequencing: Application software based upon specified sequences of operation in Section 23 09 93.
- H. PID Control Characteristics:
 - 1. Direct or reverse action.
 - 2. Anti-windup.
 - 3. Calculated, time-varying, analog value, positions an output or stages a series of outputs.
 - 4. User selectable controlled variable, set-point, and PID gains.
- I. Staggered Start Application:
 - 1. Prevents all controlled equipment from simultaneously restarting after power outage.
 - 2. Order of equipment startup is user selectable.
- J. Energy Calculations:
 - 1. Accumulated instantaneous power or flow rates are converted to energy use data.
 - 2. Algorithm calculates a rolling average and allows window of time to be user specified in minute intervals.
 - 3. Algorithm calculates a fixed window average with a digital input signal from a utility meter defining the start of the window period that in turn synchronizes the fixed-window average with that used by the power company.
- K. Anti-Short Cycling:
 - 1. All binary output objects protected from short-cycling.
 - 2. Allows minimum on-time and off-time to be selected.
- L. On-Off Control with Differential:
 - 1. Algorithm allows binary output to be cycled based on a controlled variable and set-point.
 - 2. Algorithm to be direct-acting or reverse-acting incorporating an adjustable differential.
- M. Run-Time Totalization:
 - 1. Totalize run-times for all binary input objects.
 - 2. Provides operator with capability to assign high run-time alarm.

2.06 HVAC CONTROL PROGRAMS

- A. General:
 - 1. Support Inch-pounds and SI (metric) units of measurement.
 - 2. Identify each HVAC Control system.
- B. Optimal Run Time:
 - 1. Control start-up and shutdown times of HVAC equipment for both heating and cooling.
 - 2. Base on occupancy schedules, outside air temperature, seasonal requirements, and interior room mass temperature.

3. Start-up systems by using outside air temperature, room mass temperatures, and adaptive model prediction for how long building takes to warm up or cool down under different conditions.
4. Use outside air temperature to determine early shut down with ventilation override.
5. Operator commands:
 - a. Define term schedule.
 - b. Add/delete fan status point.
 - c. Add/delete outside air temperature point.
 - d. Add/delete mass temperature point.
 - e. Define heating/cooling parameters.
 - f. Define mass sensor heating/cooling parameters.
 - g. Lock/unlock program.
 - h. Request HVAC point summary.
6. Control Summary:
 - a. HVAC Control system begin/end status.
 - b. Optimal run time lock/unlock control status.
 - c. Optimal run time schedule.
 - d. Start/Stop times.
 - e. Selected mass temperature point ID.
 - f. Optimal run time system normal start times.
 - g. Occupancy and vacancy times.
 - h. Optimal run time system heating/cooling mode parameters.
7. Mass temperature summary:
 - a. Mass temperature point type and ID.
 - b. Desired and current mass temperature values.
 - c. Heating/cooling season limits.
 - d. Break point temperature for cooling mode analysis.
8. HVAC point summary:
 - a. Point ID and status.
 - b. Outside air temperature point ID and status.
 - c. Mass temperature point ID and point.
 - d. Calculated optimal start and stop times.
 - e. Period start

PART 3 EXECUTION

3.01 EXAMINATION

- A. Verify existing conditions before starting work.
- B. Verify that conditioned power supply is available to the control units and to the operator work station. Verify that field end devices, wiring, and pneumatic tubing is installed prior to installation proceeding.

3.02 INSTALLATION

- A. Install control units and other hardware in position on permanent walls where not subject to excessive vibration.
- B. Install software in control units and in operator work station. Implement all features of programs to specified requirements and appropriate to sequence of operation. Refer to Section 23 09 93.
- C. Provide conduit and electrical wiring in accordance with Section 26 05 83. Electrical material and installation shall be in accordance with appropriate requirements of Division 26.

3.03 MANUFACTURER'S FIELD SERVICES

- A. Start and commission systems. Allow sufficient time for start-up and commissioning prior to placing control systems in permanent operation.

3.04 MAINTENANCE

- A. Provide service and maintenance of energy management and control systems for one years from Date of Substantial Completion.
- B. Provide two complete inspections, one in each season, to inspect, calibrate, and adjust controls as required, and submit written reports.
- C. Provide complete service of systems, including call backs. Make minimum of ____ complete normal inspections of approximately ____ hours duration in addition to normal service calls to inspect, calibrate, and adjust controls, and submit written reports.

END OF SECTION

NOT FOR BIDDING

NOT FOR BIDDING

This page intentionally left blank

SECTION 23 09 34
VARIABLE-FREQUENCY MOTOR CONTROLLERS FOR HVAC

PART 1 GENERAL

1.01 SECTION INCLUDES

- A. Variable-frequency motor controllers for low-voltage (600 V and less) AC motor applications.
- B. Overcurrent protective devices for motor controllers, including overload relays.

1.02 RELATED REQUIREMENTS

- A. Section 23 05 29 - Hangers and Supports for HVAC Piping and Equipment.
- B. Section 23 05 53 - Identification for HVAC Piping and Equipment: Identification products and requirements.
- C. Section 26 05 26 - Grounding and Bonding for Electrical Systems.
- D. Section 26 28 13 - Fuses.

1.03 REFERENCE STANDARDS

- A. IEC 60529 - Degrees of Protection Provided by Enclosures (IP Code), 1989 (Corrigendum 2019).
- B. NEMA 250 - Enclosures for Electrical Equipment (1000 Volts Maximum); 2020.
- C. NEMA ICS 2 - Industrial Control and Systems Controllers, Contactors and Overload Relays Rated 600 Volts; 2008 (Reaffirmed 2020).
- D. NEMA ICS 5 - Industrial Control and Systems: Control Circuit and Pilot Devices; 2017.
- E. NEMA ICS 6 - Industrial Control and Systems: Enclosures; 1993 (Reaffirmed 2016).
- F. NEMA ICS 7 - Industrial Control and Systems: Adjustable-Speed Drives; 2020.
- G. NEMA ICS 7.1 - Safety Standards for Construction and Guide for Selection, Installation, and Operation of Adjustable-Speed Drive Systems; 2022.
- H. NEMA ICS 7.2 - Application Guide for AC Adjustable Speed Drive Systems; 2021.
- I. NEMA ICS 61800-2 - Adjustable Speed Electrical Power Drive Systems, Part 2: General Requirements-Rating Specifications for Low Voltage Adjustable Frequency AC Power Drive Systems; 2005.
- J. NEMA KS 1 - Heavy Duty Enclosed and Dead-Front Switches (600 Volts Maximum); 2013.
- K. NEMA MG 1 - Motors and Generators; 2021.
- L. NFPA 70 - National Electrical Code; Most Recent Edition Adopted by Authority Having Jurisdiction, Including All Applicable Amendments and Supplements.
- M. UL 98 - Enclosed and Dead-Front Switches; Current Edition, Including All Revisions.
- N. UL 489 - Molded-Case Circuit Breakers, Molded-Case Switches and Circuit Breaker Enclosures; Current Edition, Including All Revisions.
- O. UL 508A - Industrial Control Panels; Current Edition, Including All Revisions.
- P. UL 61800-5-1 - Standard for Adjustable Speed Electrical Power Drive Systems - Part 5-1: Safety Requirements – Electrical, Thermal, and Energy (Ed. 2); Current Edition, Including All Revisions.

1.04 ADMINISTRATIVE REQUIREMENTS

- A. Coordination:
 - 1. Coordinate work to provide motor controllers suitable for use with actual motors to be installed.

2. Coordinate work to provide controllers and associated wiring suitable for interface with control devices to be installed.
3. Coordinate arrangement with dimensions and clearance requirements of actual equipment to be installed.
4. Verify with manufacturer that conductor terminations are suitable for use with conductors to be installed.
5. Notify DEDC, LLC of conflicts with or deviations from Contract Documents. Obtain direction before proceeding with work.

1.05 SUBMITTALS

- A. See Section 01 30 00 - Administrative Requirements, for submittal procedures.
- B. Product Data: Provide manufacturer's standard catalog pages and data sheets for motor controllers, enclosures, overcurrent protective devices, and other installed components and accessories.
- C. Shop Drawings: Indicate dimensions, voltage, controller sizes, short circuit current ratings, conduit entry locations, conductor terminal information, and installed features and accessories.
 1. Include dimensioned plan and elevation views of controllers and adjacent equipment with required clearances indicated.
 2. Include wiring diagrams showing factory and field connections.
 3. Identify mounting conditions required for equipment seismic qualification.
- D. Manufacturer's Installation Instructions: Indicate application conditions and limitations of use stipulated by product testing agency. Include instructions for storage, handling, protection, examination, preparation, and installation of product.
- E. Operation and Maintenance Data: Include detailed information on system operation, equipment programming and setup, replacement parts, and recommended maintenance procedures and intervals.
- F. Project Record Documents: Record actual installed locations of controllers and final equipment settings.
 1. Include nameplate data of actual installed motors and associated overload relay selections and settings.

1.06 QUALITY ASSURANCE

- A. Comply with requirements of NFPA 70.
- B. Maintain copy of each referenced document that prescribes execution requirements at project site.

1.07 DELIVERY, STORAGE, AND HANDLING

- A. Store in clean, dry space. Maintain factory wrapping or provide additional heavy canvas or heavy plastic cover to protect units from dirt, water, construction debris, and traffic.
- B. Handle carefully in accordance with manufacturer's written instructions to avoid damage to internal components, enclosure, and finish.

1.08 FIELD CONDITIONS

- A. Maintain field conditions within required service conditions during and after installation.

1.09 WARRANTY

- A. See Section 01 78 00 - Closeout Submittals, for additional warranty requirements.
- B. Provide minimum 18 month manufacturer warranty covering repair or replacement due to defective materials or workmanship.

PART 2 PRODUCTS

2.01 MANUFACTURERS

- A. ABB: www.abb.com/#sle.
- B. Danfoss: www.danfoss.com/#sle.
- C. Yaskawa America, Inc; : www.yaskawa.com/#sle.
- D. Source Limitations: Furnish variable-frequency motor controllers and associated components produced by a single manufacturer and obtained from a single supplier.

2.02 VARIABLE-FREQUENCY MOTOR CONTROLLERS

- A. Provide variable-frequency motor control system consisting of required controller assemblies, operator interfaces, control power transformers, instrumentation and control wiring, sensors, accessories, system programming, etc. as necessary for complete operating system.
- B. Provide products listed, classified, and labeled as suitable for purpose intended.
- C. Controller Assemblies: Comply with NEMA ICS 7, NEMA ICS 7.1, and NEMA ICS 61800-2; list and label as complying with UL 61800-5-1 or UL 508A as applicable.
- D. Provide controllers selected for actual installed motors and coupled mechanical loads in accordance with NEMA ICS 7.2, NEMA MG 1 Part 30, and recommendations of manufacturers of both controller and load, where not in conflict with specified requirements; considerations include, but are not limited to:
 - 1. Motor type (e.g., induction, reluctance, and permanent magnet); consider NEMA MG 1 design letter or inverter duty rating for induction motors.
 - 2. Motor load type (e.g., constant torque, variable torque, and constant horsepower); consider duty cycle, impact loads, and high inertia loads.
 - 3. Motor nameplate data.
 - 4. Requirements for speed control range, speed regulation, and braking.
 - 5. Motor suitability for bypass starting method, where applicable.
- E. Devices on Load Side of Controller: Suitable for application across full controller output frequency range.
- F. Operating Requirements:
 - 1. Input Voltage Tolerance: Plus/minus 10 percent of nominal.
 - 2. Input Frequency Tolerance: Plus/minus 5 percent of nominal.
 - 3. Efficiency: Minimum of 96 percent at full speed and load.
 - 4. Input Displacement Power Factor: Minimum of 0.96 throughout speed and load range.
 - 5. Overload Rating:
 - a. Variable Torque Loads: Minimum of 110 percent of nominal for 60 seconds.
 - b. Constant Torque Loads: Minimum of 150 percent of nominal for 60 seconds.
- G. Power Conversion System: Microprocessor-based, pulse width modulation type.
- H. Control System:
 - 1. Provide microprocessor-based control system for automatic control, monitoring, and protection of motors. Include sensors, wiring, and connections necessary for functions and status/alarm indications specified.
 - 2. Provide integral operator interface for controller programming, display of status/alarm indications, fault reset, and local control functions including motor run/stop, motor forward/reverse selection, motor speed increase/decrease, and local/remote control selection.
 - 3. Control Functions:
 - a. Control Method: Selectable vector and scalar/volts per hertz unless otherwise indicated.

- 1) Scalar/Volts per Hertz Control: Provide IR compensation for improved low-speed torque.
 - 2) Vector Control: Provide selectable autotuning function.
 - b. Adjustable acceleration and deceleration time; linear and S-curve ramps; selectable coast to stop.
 - c. Selectable braking control; DC injection or flux braking.
 - d. Adjustable minimum/maximum speed limits.
 - e. Adjustable pulse width modulation switching carrier frequency.
 - f. Adjustable motor slip compensation.
 - g. Selectable autorestart after noncritical fault; programmable number of time delay between restart attempts.
4. Status Indications:
 - a. Motor run/stop status.
 - b. Motor forward/reverse status.
 - c. Local/remote control status.
 - d. Output voltage.
 - e. Output current.
 - f. Output frequency.
 - g. DC bus voltage.
 - h. Motor speed.
5. Protective Functions/Alarm Indications:
 - a. Overcurrent.
 - b. Motor overload.
 - c. Undervoltage.
 - d. Overvoltage.
 - e. Controller overtemperature.
 - f. Input/output phase loss.
 - g. Output short circuit protection.
 - h. Output ground fault protection.
6. Inputs:
 - a. Digital Input(s): Three.
 - b. Analog Input(s): Two.
7. Outputs:
8. Features:
 - a. Password protected security access.
 - b. Event log.
- I. Power Conditioning/Filtering:
 1. Provide DC link choke or input/line reactor for each controller unless otherwise indicated or required.
 2. Reactor Impedance: 3 percent, unless otherwise indicated or required.
- J. Packaged Controllers: Controllers factory-mounted in separate enclosure with externally operable disconnect and specified accessories.
 1. Disconnects: Circuit breaker or disconnect switch type.
 - a. Disconnect Switches: Fusible type or nonfusible type with separate input fuses.
 - b. Provide externally operable handle with means for locking in OFF position. Provide safety interlock to prevent opening cover with disconnect in ON position with capability of overriding interlock for testing purposes.
 - c. Provide auxiliary interlock for disconnection of external control power sources where applicable.
 2. Provide door-mounted remote operator interface.
- K. Service Conditions:

1. Provide controllers and associated components suitable for operation under following service conditions without derating:
 - a. Altitude: Less than 3,300 feet.
 - b. Ambient Temperature: Between 32 degrees F and 104 degrees F.
2. Provide controllers and associated components suitable for operation at indicated ratings under service conditions at installed location.
- L. Short Circuit Current Rating:
 1. Provide line/input reactors where specified by manufacturer for required short circuit current rating.
- M. Conductor Terminations: Suitable for use with conductors to be installed.
- N. Enclosures:
 1. Comply with NEMA ICS 6.
 2. NEMA 250 Environment Type or Equivalent IEC 60529 Rating: Unless otherwise indicated, as specified for following installation locations:
 3. Finish: Manufacturer's standard unless otherwise indicated.
 4. Cooling: Forced air or natural convection as determined by manufacturer.

2.03 OVERCURRENT PROTECTIVE DEVICES

- A. Overload Relays:
 1. Provide overload relays and, where applicable, associated current elements/heaters selected for actual installed motor nameplate data, in accordance with manufacturer's recommendations and NFPA 70; include consideration for motor service factor and ambient temperature correction, where applicable.
 2. Comply with NEMA ICS 2.
 3. Inverse-Time Trip Class Rating: Class 20 unless otherwise indicated or required.
 4. Trip-free operation.
 5. Visible trip indication.
 6. Resettable:
 - a. Employ manual reset unless otherwise indicated.
 - b. Do not employ automatic reset with two-wire control.
- B. Fusible Disconnect Switches:
 1. Description: Quick-make, quick-break, dead-front fusible switch units complying with NEMA KS 1, and listed and labeled as complying with UL 98; ratings, configurations, and features as indicated or as required.
 2. Fuse Clips: As required to accept indicated fuses.
 3. Provide externally operable handle with means for locking in OFF position. Provide means for locking switch cover in closed position. Provide safety interlock to prevent opening of cover with switch in ON position with capability of overriding interlock for testing purposes.
- C. Circuit Breakers:
 1. Motor Circuit Protectors:
 - a. Description: Instantaneous-trip circuit breakers furnished with magnetic instantaneous tripping elements for short circuit protection, but not with thermal inverse time tripping elements for overload protection; UL 489 recognized only for use as part of listed combination motor controller with overload protection; ratings, configurations, and features as indicated or as required.
 - b. Provide field-adjustable magnetic instantaneous trip setting.
 - c. Provide following features and accessories where indicated or where required to complete installation:
 2. Molded Case Circuit Breakers:

- a. Description: Quick-make, quick-break, over center toggle, trip-free, trip-indicating circuit breakers; listed and labeled as complying with UL 489; ratings, configurations, and features as indicated or as required.
- b. Interrupting Capacity:
 - 1) Provide circuit breakers with interrupting capacity as required to provide short circuit current rating indicated, but not less than specified minimum requirements.
 - 2) Fully Rated Systems: Provide circuit breakers with interrupting capacity not less than short circuit current rating indicated.

2.04 ACCESSORIES

- A. Auxiliary Contacts:
 - 1. Comply with NEMA ICS 5.
 - 2. Provide number and type of contacts indicated or required to perform necessary functions, including holding (seal-in) circuit and interlocking, plus one normally open (NO) and one normally closed (NC) spare contact for each bypass motor starter, minimum.
- B. Control and Timing Relays:
 - 1. Comply with NEMA ICS 5.
 - 2. Provide number and type of relays indicated or required to perform necessary functions.

PART 3 EXECUTION

3.01 EXAMINATION

- A. Verify that field measurements are as indicated.
- B. Verify that ratings of controllers are consistent with indicated requirements.
- C. Verify that mounting surfaces are ready to accept controllers.
- D. Verify that conditions are satisfactory for installation prior to starting work.

3.02 INSTALLATION

- A. Install products in accordance with manufacturer's instructions.
- B. Install in accordance with NEMA ICS 7.1 and manufacturer's instructions.
- C. Do not exceed manufacturer's recommended maximum cable length between controller and motor.
- D. Arrange equipment to provide minimum clearances in accordance with manufacturer's instructions and NFPA 70.
- E. Provide required support and attachment in accordance with Section 23 05 29.
- F. Install controllers plumb and level.
- G. Provide grounding and bonding in accordance with Section 26 05 26.
- H. Install field-installed devices, components, and accessories.
- I. Provide fuses complying with Section 26 28 13 for fusible switches as indicated.
- J. Where accessories are not self-powered, provide control power source as indicated or as required to complete installation.
- K. Set field-adjustable settings of controllers and associated components according to installed motor requirements, in accordance with recommendations of manufacturers of controller and load.

3.03 ADJUSTING

- A. Adjust tightness of mechanical and electrical connections to manufacturer's recommended torque settings.

3.04 CLEANING

- A. Clean dirt and debris from controller enclosures and components according to manufacturer's instructions.
- B. Repair scratched or marred exterior surfaces to match original factory finish.

END OF SECTION

NOT FOR BIDDING

NOT FOR BIDDING

This page intentionally left blank

**SECTION 23 21 13
HYDRONIC PIPING**

PART 1 GENERAL

1.01 SECTION INCLUDES

- A. Hydronic system requirements.
- B. Condenser water piping, above grade.
- C. Equipment drains and overflows.
- D. Pipe hangers and supports.
- E. Unions, flanges, mechanical couplings, and dielectric connections.
- F. Valves:
 - 1. Ball valves.
 - 2. Butterfly valves.
 - 3. Check valves.
 - 4. Pressure independent temperature control valves and balancing valves.
- G. Flow controls.

1.02 RELATED REQUIREMENTS

- A. Section 23 05 23 - General-Duty Valves for HVAC Piping.
- B. Section 23 07 19 - HVAC Piping Insulation.

1.03 REFERENCE STANDARDS

- A. ASME B31.9 - Building Services Piping; 2020.
- B. ASTM F1476 - Standard Specification for Performance of Gasketed Mechanical Couplings for Use in Piping Applications; 2007 (Reapproved 2019).
- C. AWWA C606 - Grooved and Shouldered Joints; 2022.
- D. MSS SP-58 - Pipe Hangers and Supports - Materials, Design, Manufacture, Selection, Application, and Installation, 2018, with Amendment (2019).

1.04 SUBMITTALS

- A. See Section 01 30 00 - Administrative Requirements for submittal procedures.
- B. Product Data:
 - 1. Include data on pipe materials, pipe fittings, valves, and accessories.
 - 2. Indicate valve data and ratings.
 - 3. Show grooved joint couplings, fittings, valves, and specialties on drawings and product submittals, specifically identified with the manufacturer's style or series designation.
- C. Manufacturer's Installation Instructions: Indicate hanging and support methods, joining procedures.
- D. Project Record Documents: Record actual locations of valves.

1.05 DELIVERY, STORAGE, AND HANDLING

- A. Accept valves on site in shipping containers with labeling in place. Inspect for damage.
- B. Provide temporary protective coating on cast iron and steel valves.
- C. Protect piping systems from entry of foreign materials by temporary covers, completing sections of the work, and isolating parts of completed system.

PART 2 PRODUCTS

2.01 HYDRONIC SYSTEM REQUIREMENTS

- A. Comply with ASME B31.9 and applicable federal, state, and local regulations.

- B. Piping: Provide piping, fittings, hangers, and supports as required, as indicated, and as follows:
 - 1. Where more than one piping system material is specified, provide joining fittings that are compatible with piping materials and ensure that the integrity of the system is not jeopardized.
 - 2. Use non-conducting dielectric connections whenever jointing dissimilar metals.
 - 3. Grooved mechanical joints may be used in accessible locations only.
 - a. Accessible locations include those exposed on interior of building, in pipe chases, and in mechanical rooms, aboveground outdoors, and as approved by DEDC, LLC.
 - b. Use rigid joints unless otherwise indicated.
 - 4. Provide pipe hangers and supports in accordance with ASME B31.9 or MSS SP-58 unless indicated otherwise.
- C. Pipe-to-Valve and Pipe-to-Equipment Connections: Use flanges, unions, or grooved couplings to allow disconnection of components for servicing; do not use direct welded, soldered, or threaded connections.
- D. Valves: Provide valves where indicated:

2.02 CONDENSER WATER PIPING, ABOVE GRADE

2.03 EQUIPMENT DRAINS AND OVERFLOWS

2.04 PIPE HANGERS AND SUPPORTS

- A. Provide hangers and supports that comply with MSS SP-58.
 - 1. If type of hanger or support for a particular situation is not indicated, select appropriate type using MSS SP-58 recommendations.
- B. In grooved installations, use rigid couplings with offsetting angle-pattern bolt pads or with wedge-shaped grooves in header piping to permit support and hanging in accordance with ASME B31.9.

2.05 UNIONS, FLANGES, MECHANICAL COUPLINGS, AND DIELECTRIC CONNECTIONS

- A. Unions for Pipe of 2 Inches and Less:
- B. Flanges for Pipe 2 Inches and Greater:
- C. Mechanical Couplings for Grooved and Shouldered Joints: Two or more curved housing segments with continuous key to engage pipe groove, circular C-profile gasket, and bolts to secure and compress gasket.
 - 1. Dimensions and Testing: In accordance with AWWA C606.
 - 2. Mechanical Couplings: Comply with ASTM F1476.
 - 3. Bolts and Nuts: Hot dipped galvanized or zinc-electroplated steel.
 - 4. When pipe is field grooved, provide coupling manufacturer's grooving tools.

2.06 FLOW CONTROLS

- A. Construction: Class 125, Brass or bronze body with union on inlet and outlet, temperature and pressure test plug on inlet and outlet, blowdown/backflush drain.
- B. Calibration: Control flow within 10 percent of selected rating, over operating pressure range of 10 times minimum pressure required for control, minimum pressure 2 psi.

END OF SECTION

**SECTION 23 21 14
HYDRONIC SPECIALTIES**

PART 1 GENERAL

1.01 SECTION INCLUDES

- A. Air vents.
- B. Strainers.
- C. Suction diffusers.
- D. Pump connectors.
- E. Balancing valves.

1.02 RELATED REQUIREMENTS

- A. Section 23 21 13 - Hydronic Piping.
- B. Section 23 25 00 - HVAC Water Treatment: Pipe cleaning.

1.03 REFERENCE STANDARDS

- A. ASME B16.1 - Gray Iron Pipe Flanges and Flanged Fittings: Classes 25, 125, and 250; 2020.
- B. ASME B16.5 - Pipe Flanges and Flanged Fittings: NPS 1/2 through NPS 24 Metric/Inch Standard; 2020.
- C. ASME B16.11 - Forged Fittings, Socket-Welding and Threaded; 2021.
- D. NSF 61 - Drinking Water System Components - Health Effects; 2024.

1.04 ADMINISTRATIVE REQUIREMENTS

- A. Preinstallation Meeting: Conduct a preinstallation meeting one week prior to the start of the work of this section; require attendance by all affected installers.
- B. Sequencing: Ensure that utility connections are achieved in an orderly and expeditious manner.

1.05 SUBMITTALS

- A. See Section 01 30 00 - Administrative Requirements for submittal procedures.
- B. Product Data: Provide product data for manufactured products and assemblies required for this project. Include component sizes, rough-in requirements, service sizes, and finishes. Include product description and model.
- C. Manufacturer's Installation Instructions: Indicate hanging and support methods, joining procedures.
- D. Maintenance Contract.
- E. Project Record Documents: Record actual locations of flow controls.

1.06 DELIVERY, STORAGE, AND HANDLING

- A. Accept valves on site in shipping containers with labeling in place. Inspect for damage.
- B. Provide temporary protective coating on cast iron and steel valves.
- C. Provide temporary end caps and closures on piping and fittings. Maintain in place until installation.
- D. Protect piping systems from entry of foreign materials by temporary covers, completing sections of the work, and isolating parts of completed system.

PART 2 PRODUCTS

2.01 AIR VENTS

- A. Manufacturers:

1. Armstrong International, Inc: www.armstronginternational.com/#sle.
 2. Bell & Gossett, a brand of Xylem, Inc: www.bellgossett.com/#sle.
 3. Taco, Inc; _____: www.taco-hvac.com/#sle.
 4. Substitutions: See Section 01 60 00 - Product Requirements.
- B. Manual Air Vent: Short vertical sections of 2-inch diameter pipe to form air chamber, with 1/8 inch brass needle valve at top of chamber.
- C. Float Air Vent:
1. Brass or semi-steel body, copper, polypropylene, or solid non-metallic float, stainless steel valve and valve seat; suitable for system operating temperature and pressure; with isolating valve.
- D. Maximum Fluid Pressure: 150 psi.
- E. Maximum Fluid Temperature: 250 degrees F.

2.02 STRAINERS

- A. Manufacturers:
1. American Wheatley, a company of Global Flow Products, LLC: www.wheatleyhvac.com/#sle.
 2. Armstrong International, Inc: www.armstronginternational.com/#sle.
 3. Nexus Valve, Inc: www.nexusvalve.com/#sle.
 4. The Metraflex Company; LPD Y Strainer: www.metroflex.com/#sle.
 5. Substitutions: See Section 01 60 00 - Product Requirements.
- B. Size 2 inch and Under:
1. Provide threaded, grooved, or sweat brass or iron body for up to 175 psi working pressure, Y-pattern strainer with 1/32 inch stainless steel perforated screen.
 2. Body Material by Fluid Service:
 - a. Cast Iron or Brass:
 - 1) Steam: Up to 250 psi at 450 degrees F.
 - 2) Liquids: Up to 400 psi at 150 degrees F.
- C. Size 2-1/2 inch to 4 inch:
1. Provide flanged or grooved iron body for up to 175 psi working pressure, up to 250 degrees F working temperature, Y-pattern strainer with 1/16 inch or 3/64 inch stainless steel perforated screen.
 2. Body Material by Fluid Service:
 - a. Cast Iron:
 - 1) Steam: Up to 125 psi at 350 degrees F.
 - 2) Liquids: Up to 200 psi at 150 degrees F.

2.03 SUCTION DIFFUSERS

- A. Manufacturers:
1. American Wheatley, a company of Global Flow Products, LLC: www.wheatleyhvac.com/#sle.
 2. Anvil International: www.anvilintl.com/#sle.
 3. Bell & Gossett, a brand of Xylem, Inc: www.bellgossett.com/#sle.
 4. Substitutions: See Section 01 60 00 - Product Requirements.
- B. Fitting: Angle pattern, cast-iron body, threaded for 2 inch and smaller, flanged for 2-1/2 inch and larger, rated for 175 psi working pressure, with inlet vanes, cylinder strainer with 3/16 inch diameter openings, disposable 5/32 inch mesh strainer to fit over cylinder strainer, 20 mesh startup screen, and permanent magnet located in flow stream and removable for cleaning.
- C. Class 125:

1. Horizontally or vertically mounted angle-pattern fitting with integral-cast vanes, fine particle mesh screen and magnetic drain plugs for particle removal without disassembly.
2. Maximum Operating Service: 175 psi and 300 degrees F.
3. Sizes, Material, and Connection:
 - a. 2 inch and Smaller: Cast iron body, threaded.
 - b. 2-1/2 to 12 inch: Ductile iron body, flanged.
- D. Class 150, Size 1-1/2 to 4 inch:
 1. Angle-pattern flanged carbon steel fitted with integral vanes, removable strainer, and magnetic drain plugs for particle removal without disassembly.
 2. Maximum Operating Service:
 - a. Class 150: 150 psi at 450 degrees F.
- E. Accessories: Adjustable foot support, blowdown tapping in bottom, gauge tapping in side.

2.04 PUMP CONNECTORS

- A. Manufacturers:
 1. American Wheatley, a company of Global Flow Products, LLC: www.wheatleyhvac.com/#sle.
 2. Anvil International; AnviFlex: www.anvilintl.com/#sle.
 3. FNW: www.fnw.com/#sle.
 4. The Metraflex Company; Vane Flex: www.metraflex.com/#sle.
 5. Substitutions: See Section 01 60 00 - Product Requirements.
- B. Flexible Connectors: Flanged, braided type with wetted components of stainless steel, sized to match piping.
 1. Maximum Operating Service: 150 psi at 120 degrees F.
 2. Accommodate the Following:
 - a. Axial Deflection in Compression and Expansion: _____ inch.
 - b. Lateral Movement: _____ inch.
 - c. Angular Rotation: 15 degrees.
 - d. Force developed by 1.5 times specified maximum allowable operating pressure.
 3. End Connections: Same as specified for pipe jointing.
 4. End Connections: Flanged ductile iron; complying with ASME B16.1 Class 125.
 5. End Connections: Threaded; complying with ASME B16.11.
 6. Provide pump connector with integral vanes to reduce turbulent flow.
 7. Provide necessary accessories including, but not limited to, swivel joints.

2.05 BALANCING VALVES

- A. Manufacturers:
 1. American Wheatley, a company of Global Flow Products, LLC: www.wheatleyhvac.com/#sle.
 2. Armstrong International, Inc: www.armstronginternational.com/#sle.
 3. Bell & Gossett, a brand of Xylem, Inc: www.bellgossett.com/#sle.
 4. FNW: www.fnw.com/#sle.
 5. Taco, Inc: www.taco-hvac.com/#sle.
 6. Substitutions: See Section 01 60 00 - Product Requirements.
- B. Size 2 inch and Smaller:
 1. Provide ball or globe style with flow balancing, shut-off capabilities, memory stops, and minimum of two metering ports and female sweat, NPT threaded, press, or soldered connections.
 2. Metal construction materials consist of bronze or brass.
 3. Non-metal construction materials consist of Teflon, EPDM, engineered resin, or _____.

4. Maximum Service Operation: 300 psi at 250 degrees F.
- C. Size 2-1/2 inch and Larger:
 1. Provide ball, globe, or butterfly style with flow balancing, shut-off capabilities, memory stops, and minimum of two metering ports and flanged, grooved, or weld-end connections.
 2. Valve body construction materials consist of cast iron, carbon steel, or ductile iron.
 3. Internal components construction materials consist of brass, aluminum bronze, bronze, Teflon, EPDM, NORYL, engineered resin, or _____.
 4. Maximum Service Operation: 175 psi at 250 degrees F.

PART 3 EXECUTION

3.01 INSTALLATION

- A. Install specialties in accordance with manufacturer's instructions.
- B. Provide manual air vents at system high points and as indicated.
- C. For automatic air vents in ceiling spaces or other concealed locations, provide vent tubing to nearest drain.
- D. Provide pump suction fitting on suction side of base-mounted centrifugal pumps where indicated. Remove temporary strainers after cleaning systems.
- E. Support pump fittings with floor-mounted pipe and flange supports.
- F. Provide relief valves on pressure tanks, low-pressure side of reducing valves, heat exchangers, and expansion tanks.
- G. Pipe relief valve outlet to nearest floor drain.
- H. Clean and flush glycol system before adding glycol solution, see Section 23 25 00.

END OF SECTION

**SECTION 23 21 23
HYDRONIC PUMPS**

PART 1 GENERAL

1.01 SECTION INCLUDES

- A. End-suction pump systems.
- B. End-suction pumps.

1.02 RELATED REQUIREMENTS

- A. Section 03 30 00 - Cast-in-Place Concrete.
- B. Section 23 05 13 - Common Motor Requirements for HVAC Equipment.
- C. Section 23 05 48 - Vibration and Seismic Controls for HVAC.
- D. Section 23 07 19 - HVAC Piping Insulation.
- E. Section 23 09 23 - Direct-Digital Control System for HVAC.
- F. Section 23 09 34 - Variable-Frequency Motor Controllers for HVAC.
- G. Section 23 21 13 - Hydronic Piping.
- H. Section 23 21 14 - Hydronic Specialties.
- I. Section 25 35 00 - Integrated Automation Instrumentation and Terminal Devices for HVAC.
- J. Section 26 24 19 - Motor-Control Centers.

1.03 REFERENCE STANDARDS

- A. Modbus (PS) - The Modbus Organization Communications Protocol.; Latest Update.
- B. NEMA 250 - Enclosures for Electrical Equipment (1000 Volts Maximum); 2020.
- C. NFPA 70 - National Electrical Code: Most Recent Edition Adopted by Authority Having Jurisdiction, Including All Applicable Amendments and Supplements.
- D. UL 778 - Standard for Motor Operated Water Pumps; Current Edition, Including All Revisions.

1.04 SUBMITTALS

- A. See Section 01 30 00 - Administrative Requirements for submittal procedures.
- B. Product Data: Provide certified pump curves showing performance characteristics with pump and system operating point plotted. Include NPSH curve when applicable. Include electrical characteristics and connection requirements.
- C. Manufacturer's Installation Instructions: Indicate hanging and support requirements and recommendations.
- D. Operation and Maintenance Data: Include installation instructions, assembly views, lubrication instructions, and replacement parts list.

PART 2 PRODUCTS

2.01 MANUFACTURERS

- A. Bell & Gossett, a Xylem Inc. brand: www.bellgossett.com/#sle.
- B. Grundfos Pumps Corporation: www.grundfos.com/#sle.

2.02 GENERAL

- A. Provide pumps that operate at specified system fluid temperatures without vapor binding and cavitation, are non-overloading in parallel or individual operation, and operate within 25 percent of midpoint of published maximum efficiency curve.
- B. Electrical Requirements:

1. Listed and classified by UL or testing agency acceptable to authority having jurisdiction as suitable for the purpose specified and indicated.
2. Variable Frequency Drives (VFDs): Provide in accordance with Section 23 09 34, except for integral-VFDs.
3. Enclosures: Provide unspecified product(s) required to fit motor:
 - a. Starter(s) inside motor-control center as indicated on drawings; see Section 26 24 19.

2.03 END-SUCTION PUMPS

- A. Casing: Cast iron or ductile iron with renewable bronze casing wearing rings, seal flush connection, drain plug, flanged suction, and discharge flanged connections with gauge ports.
- B. Impeller: Stainless steel, balanced, fully enclosed, keyed to shaft.
- C. Bearings: Oil lubricated roller or ball bearings.
- D. Shaft: Alloy steel with copper, bronze, or stainless steel shaft sleeve.
- E. Drive: Flexible coupling with coupling guard.
- F. Baseplate: Cast iron or fabricated steel with integral drain rim.
- G. Electrical:
 1. Motor: 1,750 rpm, total-enclosed, fan-cooled (TEFC); see Section 23 05 13.
 2. Wiring Terminations: Provide terminal lugs to match branch circuit conductor quantities, sizes, and materials indicated. Enclose terminal lugs in terminal box sized to NFPA 70.

PART 3 EXECUTION

3.01 PREPARATION

- A. Verify that electric power is available and of the correct characteristics.

3.02 INSTALLATION

- A. Install in accordance with manufacturer's instructions.
- B. Provide access space around pumps for service. Provide no less than minimum space recommended by manufacturer.
- C. Decrease from line size with long radius reducing elbows or reducers. Support piping adjacent to pump such that no weight is carried on pump casings. For close-coupled or base-mounted pumps, provide supports under elbows on pump suction and discharge line sizes 4 inches and over.
- D. Provide line sized shut-off valve and strainer on pump suction, and line sized soft seat check valve and balancing valve on pump discharge.
- E. Provide air cock and drain connection on horizontal pump casings.
- F. Install close-coupled and base-mounted pumps on concrete housekeeping base, with anchor bolts, set and level, and grout in place. See Section 03 30 00.
- G. Lubricate pumps before start-up.
- H. Controls: Interface each pump starter or VFD with HVAC controller; see Section 23 09 23.
- I. Controls Human-Machine Interface (HMI): HVAC operator terminal; see Section 25 35 00.

END OF SECTION

**SECTION 23 23 00
REFRIGERANT PIPING**

PART 1 GENERAL

1.01 SECTION INCLUDES

- A. Piping.
- B. Refrigerant.
- C. Moisture and liquid indicators.
- D. Valves.
- E. Strainers.
- F. Check valves.
- G. Pressure regulators.
- H. Pressure relief valves.
- I. Filter-driers.
- J. Solenoid valves.
- K. Expansion valves.
- L. Receivers.
- M. Flexible connections.
- N. Engineered wall seals and insulation protection.
- O. Exterior penetration accessories.

1.02 RELATED REQUIREMENTS

- A. Section 23 07 16 - HVAC Equipment Insulation.
- B. Section 23 07 19 - HVAC Piping Insulation.
- C. Section 26 05 83 - Wiring Connections: Electrical characteristics and wiring connections.

1.03 REFERENCE STANDARDS

- A. AHRI 495 - Performance Rating of Refrigerant Liquid Receivers; 2005.
- B. AHRI 710 (I-P) - Performance Rating of Liquid-Line Driers; 2009.
- C. AHRI 711 (SI) - Performance Rating of Liquid-Line Driers; 2009.
- D. AHRI 760 (I-P) - Performance Rating of Solenoid Valves for Use with Volatile Refrigerants; 2014.
- E. ASHRAE Std 15 - Safety Standard for Refrigeration Systems; 2024, with Errata (2025).
- F. ASME B16.22 - Wrought Copper and Copper Alloy Solder-Joint Pressure Fittings; 2021.
- G. ASME B16.26 - Cast Copper Alloy Fittings for Flared Copper Tubes; 2018.
- H. ASME B31.5 - Refrigeration Piping and Heat Transfer Components; 2022.
- I. ASTM B88 - Standard Specification for Seamless Copper Water Tube; 2022.
- J. ASTM B88M - Standard Specification for Seamless Copper Water Tube (Metric); 2020.
- K. ASTM B280 - Standard Specification for Seamless Copper Tube for Air Conditioning and Refrigeration Field Service; 2023.
- L. ASTM E84 - Standard Test Method for Surface Burning Characteristics of Building Materials; 2023d.
- M. ASTM E96/E96M - Standard Test Methods for Gravimetric Determination of Water Vapor Transmission Rate of Materials; 2023.

- N. ASTM E283/E283M - Standard Test Method for Determining Rate of Air Leakage Through Exterior Windows, Skylights, Curtain Walls, and Doors Under Specified Pressure Differences Across the Specimen; 2019.
- O. ASTM E331 - Standard Test Method for Water Penetration of Exterior Windows, Skylights, Doors, and Curtain Walls by Uniform Static Air Pressure Difference; 2000 (Reapproved 2023).
- P. ASTM E2178 - Standard Test Method for Determining Air Leakage Rate and Calculation of Air Permeance of Building Materials; 2021a.
- Q. ASTM G21 - Standard Practice for Determining Resistance of Synthetic Polymeric Materials to Fungi; 2015, with Editorial Revision (2021).
- R. ASTM G153 - Standard Practice for Operating Enclosed Carbon Arc Light Apparatus for Exposure of Nonmetallic Materials; 2013 (Reapproved 2021).
- S. AWS A5.8M/A5.8 - Specification for Filler Metals for Brazing and Braze Welding; 2019.
- T. ICC (IMC)-2018 - International Mechanical Code; 2018.
- U. MSS SP-58 - Pipe Hangers and Supports - Materials, Design, Manufacture, Selection, Application, and Installation; 2018, with Amendment (2019).
- V. UL 207 - Standard for Refrigerant-Containing Components and Accessories, Nonelectrical; Current Edition, Including All Revisions.
- W. UL 429 - Electrically Operated Valves; Current Edition, Including All Revisions.

1.04 SUBMITTALS

- A. See Section 01 30 00 - Administrative Requirements for submittal procedures.
- B. Product Data: Provide general assembly of specialties, including manufacturers catalogue information. Provide manufacturers catalog data including load capacity.
- C. Shop Drawings: Indicate schematic layout of system, including equipment, critical dimensions, and sizes.
- D. Project Record Documents: Record exact locations of equipment and refrigeration accessories on record drawings.

1.05 DELIVERY, STORAGE, AND HANDLING

- A. Deliver and store piping and specialties in shipping containers with labeling in place.
- B. Protect piping and specialties from entry of contaminating material by leaving end caps and plugs in place until installation.
- C. Dehydrate and charge components such as piping and receivers, seal prior to shipment, until connected into system.

PART 2 PRODUCTS

2.01 SYSTEM DESCRIPTION

- A. Where more than one piping system material is specified ensure system components are compatible and joined to ensure integrity of system is not jeopardized. Provide necessary joining fittings. Ensure flanges, union, and couplings for servicing are consistently provided.
- B. Provide pipe hangers and supports in accordance with ASME B31.5 unless indicated otherwise.
- C. Liquid Indicators:
 - 1. Use line size liquid indicators in main liquid line leaving condenser.
 - 2. If receiver is provided, install in liquid line leaving receiver.
- D. Valves:
 - 1. Use service valves on suction and discharge of compressors.
 - 2. Use check valves on compressor discharge.

- E. Refrigerant Charging (Packed Angle) Valve: Use in liquid line between receiver shut-off valve and expansion valve.
- F. Strainers:
 - 1. Use line size strainer upstream of each automatic valve.
 - 2. Where multiple expansion valves with integral strainers are used, use single main liquid line strainer.
 - 3. Use shut-off valve on each side of strainer.
- G. Pressure Relief Valves: Use on ASME receivers.
- H. Filter-Driers:
 - 1. Use a filter-drier immediately ahead of liquid-line controls, such as thermostatic expansion valves, solenoid valves, and moisture indicators.

2.02 REGULATORY REQUIREMENTS

2.03 PIPING

- A. Copper Tube: ASTM B280, H58 hard drawn or O60 soft annealed.
 - 1. Fittings: ASME B16.22 wrought copper.
 - 2. Joints: Braze, AWS A5.8M/A5.8 BCuP silver/phosphorus/copper alloy.
 - 3. Push-to-Connect Fittings: Complying with UL 207.
 - 4. Mechanical Press Fittings: Double-pressed type complying with UL 207 and ICC (IMC)-2018.
- B. Copper Tube to 7/8-inch OD: ASTM B88 (ASTM B88M), Type K (A), annealed.
 - 1. Fittings: ASME B16.26 cast copper.
 - 2. Joints: Flared.
 - 3. Push-to-Connect Fittings: Complying with UL 207.
 - 4. Mechanical Press Sealed Fittings: Double pressed type complying with UL 207 and ICC (IMC)-2018.
- C. Pipe Supports and Anchors:
 - 1. Provide hangers and supports that comply with MSS SP-58.
 - a. If type of hanger or support for a particular situation is not indicated, select appropriate type using MSS SP-58 recommendations.
 - 2. Hangers for Pipe Sizes 2 Inches and Over: Carbon steel, adjustable, clevis.
 - 3. Multiple or Trapeze Hangers: Steel channels with welded spacers and hanger rods.
 - 4. Wall Support for Pipe Sizes to 3 Inches: Cast iron hook.
 - 5. Vertical Support: Steel riser clamp.
 - 6. Copper Pipe Support: Carbon steel ring, adjustable, copper plated.
 - 7. Hanger Rods: Mild steel threaded both ends, threaded one end, or continuous threaded.
 - 8. Inserts: Malleable iron case of galvanized steel shell and expander plug for threaded connection with lateral adjustment, top slot for reinforcing rods, lugs for attaching to forms; size inserts to suit threaded hanger rods.

2.04 REFRIGERANT

- A. Refrigerant: Use only refrigerants that have ozone depletion potential (ODP) of zero and global warming potential (GWP) no greater than that allowed by federal code.

2.05 MOISTURE AND LIQUID INDICATORS

- A. Indicators: Single port type, UL listed, with copper or brass body, flared or soldered ends, sight glass, color coded paper moisture indicator with removable element cartridge and plastic cap; for maximum temperature of 200 degrees F and maximum working pressure of 500 psi.

2.06 VALVES

- A. Ball Valves:

1. Two piece bolted forged brass body with teflon ball seals and copper tube extensions, brass bonnet and seal cap, chrome plated ball, stem with neoprene ring stem seals; for maximum working pressure of 500 psi and maximum temperature of 300 degrees F.
- B. Service Valves:
 1. Forged brass body with copper stubs, brass caps, removable valve core, integral ball check valve, flared or soldered ends, for maximum pressure of 500 psi.

2.07 STRAINERS

- A. Straight Line or Angle Line Type:
 1. Brass or steel shell, steel cap and flange, and replaceable cartridge, with screen of stainless steel wire or monel reinforced with brass; for maximum working pressure of 430 psi.

2.08 CHECK VALVES

- A. Straight Through Type:
 1. Brass body and disc, phosphor-bronze or stainless steel spring, neoprene seat; for maximum working pressure of 500 psi and maximum temperature of 200 degrees F.

2.09 PRESSURE REGULATORS

- A. Brass body, stainless steel diaphragm, direct acting, adjustable over 0 to 80 psi range, for maximum working pressure of 450 psi.

2.10 PRESSURE RELIEF VALVES

- A. Straight Through or Angle Type: Brass body and disc, neoprene seat, factory sealed and stamped with ASME UV and National Board Certification NB, selected to ASHRAE Std 15, with standard setting of 235 psi.

2.11 FILTER-DRIERS

- A. Performance:
 1. Flow Capacity - Liquid Line: As indicated in schedule, minimum, rated in accordance with AHRI 710 (I-P) (AHRI 711 (SI)).
 2. Pressure Drop: 2 psi, maximum, when operating at full connected evaporator capacity.
 3. Design Working Pressure: 350 psi, minimum.
- B. Cores: Molded or loose fill molecular sieve desiccant compatible with refrigerant, activated alumina, activated charcoal, and filtration to 40 microns, with secondary filtration to 20 microns; of construction that will not pass into refrigerant lines.
- C. Construction: UL listed.
 1. Connections: As specified for applicable pipe type.

2.12 SOLENOID VALVES

- A. Valve: AHRI 760 (I-P), pilot operated, copper, brass or steel body and internal parts, synthetic seat, stainless steel stem and plunger assembly (permitting manual operation in case of coil failure), integral strainer, with flared, soldered, or threaded ends; for maximum working pressure of 500 psi.
- B. Coil Assembly: UL 429 UL listed, replaceable with molded electromagnetic coil, moisture and fungus proof, with surge protector and color coded lead wires, integral junction box with pilot light.

2.13 EXPANSION VALVES

- A. Angle or Straight Through Type: AHRI 760 (I-P); design suitable for refrigerant, brass body, internal or external equalizer, bleed hole, adjustable superheat setting, replaceable inlet strainer, with nonreplaceable capillary tube and remote sensing bulb and remote bulb well.
- B. Selection: Evaluate refrigerant pressure drop through system to determine available pressure drop across valve. Select valve for maximum load at design operating pressure and minimum

10 degrees F superheat. Select to avoid being undersized at full load and excessively oversized at part load.

2.14 ELECTRONIC EXPANSION VALVES

- A. Valve:
 - 1. Brass body with flared or soldered connection, needle valve with floating needle and machined seat, stepper motor drive.
- B. Evaporation Control System:
 - 1. Electronic microprocessor based unit in enclosed case, proportional integral control with adaptive superheat, maximum operating pressure function, preselection allowance for electrical defrost and hot gas bypass.
- C. Refrigeration System Control: Electronic microprocessor based unit in enclosed case, with proportional integral control of valve, on/off thermostat, air temperature alarm (high and low), solenoid valve control, liquid injection adaptive superheat control, maximum operating pressure function, night setback thermostat, timer for defrost control.

2.15 RECEIVERS

- A. Internal Diameter 6 inch and Smaller:
 - 1. AHRI 495, UL listed, steel, brazed; 400 psi maximum pressure rating, with tappings for inlet, outlet, and pressure relief valve.

2.16 FLEXIBLE CONNECTORS

- A. Corrugated stainless steel hose with single layer of stainless steel exterior braiding, minimum 9 inches long with copper tube ends; for maximum working pressure of 500 psi.

2.17 ENGINEERED WALL SEALS AND INSULATION PROTECTION

- A. Pipe Penetration Wall Seal: Seals HVAC piping wall penetrations with compression gasket wall mounted rigid plastic outlet cover.
 - 1. Wall Outlet Size, Stucco and Masonry Applications: 7-1/2 inch wide by 10 inch high.
 - a. Elastomeric Sleeve Diameter: 1-11/16 inch.
 - 2. Outlet Cover Color: Gray.
 - 3. Water Penetration: Comply with ASTM E331.
 - 4. Air Leakage: Comply with ASTM E283/E283M.
 - 5. Air Permeance: Comply with ASTM E2178.
- B. Insulation Protection System: Mechanical line insulation and PVC cover.
 - 1. PVC Insulation Cover Color: Black with full-length velcro fastener.
 - 2. Weatherization and Ultraviolet Exposure Protection: Comply with ASTM G153.
 - 3. Water/Vapor Permeability: Comply with ASTM E96/E96M.
 - 4. Anti-Fungal and Anti-Microbial Resistance: Comply with ASTM G21.
 - 5. Flame Spread and Smoke Development Rating of 25/450: Comply with ASTM E84.
 - 6. Adhesive free.

2.18 EXTERIOR PENETRATION ACCESSORIES

- A. Flashing Panels for Exterior Wall Penetrations: Premanufactured components and accessories as required to preserve integrity of building envelope; suitable for conduits and facade materials to be installed.
- B. Sealing Systems for Roof Penetrations: Premanufactured components and accessories as required to preserve integrity of roofing system and maintain roof warranty; suitable for conduits and roofing system to be installed; designed to accommodate existing penetrations where applicable.

PART 3 EXECUTION

3.01 PREPARATION

- A. Ream pipe and tube ends. Remove burrs. Bevel plain end ferrous pipe.
- B. Remove scale and dirt on inside and outside before assembly.
- C. Prepare piping connections to equipment with flanges or unions.

3.02 INSTALLATION

- A. Install refrigeration specialties in accordance with manufacturer's instructions.
- B. Route piping in orderly manner, with plumbing parallel to building structure, and maintain gradient.
- C. Install piping to conserve building space and avoid interference with use of space.
- D. Group piping whenever practical at common elevations and locations. Slope piping one percent in direction of oil return.
- E. Install piping to allow for expansion and contraction without stressing pipe, joints, or connected equipment.
- F. Pipe Hangers and Supports:
 - 1. Install in accordance with ASME B31.5.
 - 2. Support horizontal piping as indicated.
 - 3. Place hangers within 12 inches of each horizontal elbow.
 - 4. Support vertical piping at every other floor. Support riser piping independently of connected horizontal piping.
 - 5. Provide copper plated hangers and supports for copper piping.
- G. Arrange piping to return oil to compressor. Provide traps and loops in piping, and provide double risers as required. Slope horizontal piping 0.40 percent in direction of flow.
- H. Provide clearance for installation of insulation and access to valves and fittings.
- I. Where pipe support members are welded to structural building frame, brush clean, and apply one coat of zinc rich primer to welding.
- J. Insulate piping and equipment.
- K. Follow ASHRAE Std 15 procedures for charging and purging of systems and for disposal of refrigerant.
- L. Provide replaceable cartridge filter-driers, with isolation valves and valved bypass.
- M. Locate expansion valve sensing bulb immediately downstream of evaporator on suction line.
- N. Fully charge completed system with refrigerant after testing.
- O. Provide electrical connection to solenoid valves. See Section 26 05 83.

END OF SECTION

SECTION 23 31 00
HVAC DUCTS AND CASINGS

PART 1 GENERAL

1.01 SECTION INCLUDES

- A. Metal ducts.
- B. Flexible ducts.

1.02 RELATED REQUIREMENTS

- A. Section 23 01 30.51 - HVAC Air-Distribution System Cleaning: Post install duct cleaning.
- B. Section 23 07 13 - Duct Insulation: External insulation and duct liner.
- C. Section 23 33 19 - Duct Silencers.
- D. Section 23 37 00 - Air Outlets and Inlets: Fabric air distribution devices.

1.03 REFERENCE STANDARDS

- A. ASTM A36/A36M - Standard Specification for Carbon Structural Steel; 2019.
- B. ASTM A653/A653M - Standard Specification for Steel Sheet, Zinc-Coated (Galvanized) or Zinc-Iron Alloy-Coated (Galvannealed) by the Hot-Dip Process; 2023.
- C. ASTM E84 - Standard Test Method for Surface Burning Characteristics of Building Materials; 2023d.
- D. NFPA 90A - Standard for the Installation of Air-Conditioning and Ventilating Systems; 2024.
- E. NFPA 90B - Standard for the Installation of Warm Air Heating and Air-Conditioning Systems; 2024.
- F. SMACNA (DCS) - HVAC Duct Construction Standards Metal and Flexible; 2020.
- G. SMACNA (LEAK) - HVAC Air Duct Leakage Test Manual; 2012.
- H. SMACNA (Phenolic) - Phenolic Duct Construction Standards; 2015.
- I. UL 181 - Standard for Factory-Made Air Ducts and Air Connectors; Current Edition, Including All Revisions.

1.04 SUBMITTALS

- A. See Section 01 30 00 - Administrative Requirements for submittal procedures.
- B. Product Data: Provide data for duct materials.
- C. Project Record Documents: Record actual locations of ducts and duct fittings. Record changes in fitting location and type. Show additional fittings used.

1.05 FIELD CONDITIONS

- A. Do not install duct sealants when temperatures are less than those recommended by sealant manufacturers.
- B. Maintain temperatures within acceptable range during and after installation of duct sealants.

PART 2 PRODUCTS

2.01 GENERAL REQUIREMENTS

- A. Provide UL Class 1 ductwork, fittings, hangers, supports, and appurtenances in accordance with NFPA 90A and SMACNA (DCS) guidelines unless stated otherwise.
- B. Provide metal duct unless otherwise indicated. Fibrous glass duct can be substituted at the Contractor's option.
- C. Acoustical Treatment: Provide sound-absorbing liners and sectional silencers for metal-based ducts in compliance with Section 23 33 19.

- D. Duct Shape and Material in accordance with Allowed Static Pressure Range:
 - 1. Round: Plus or minus 2 in-wc of galvanized steel.
 - 2. Rectangular: Plus or minus 1/2 in-wc of galvanized steel.
 - 3. Flexible Duct (Fabric and wire): Plus or minus 1/2 in-wc; see Section 23 37 00.
- E. Duct Sealing and Leakage in accordance with Static Pressure Class:
 - 1. Duct Pressure Class and Material for Common Mechanical Ventilation Applications:
 - a. Supply Air: 1/2 in-wc pressure class, galvanized steel.
 - b. Outside Air Intake: 1/2 in-wc pressure class, galvanized steel.
 - c. Return and Relief Air: 1/2 in-wc pressure class, galvanized steel.
 - d. General Exhaust Air: 1/2 in-wc pressure class, galvanized steel.
 - 2. Low Pressure Service: Up to 2 in-wc:
 - a. Seal: Class C, apply to seal off transverse joints.
 - b. Leakage:
 - 1) Rectangular: Class 24 or 24 cfm/100 sq ft.
 - 2) Round: Class 12 or 12 cfm/100 sq ft.
- F. Duct Fabrication Requirements:
 - 1. Duct and Fitting Fabrication and Support: SMACNA (DCS) including specifics for continuously welded round and oval duct fittings.
 - 2. Use reinforced and sealed sheet-metal materials at recommended gauges for indicated operating pressures or pressure class.
 - 3. Construct tees, bends, and elbows with radius of not less than 1-1/2 times width of duct on centerline. Where not possible and where rectangular elbows must be used, provide airfoil turning vanes of perforated metal with glass fiber insulation.
 - 4. Provide turning vanes of perforated metal with glass fiber insulation when acoustical lining is indicated.
 - 5. Increase duct sizes gradually, not exceeding 15 degrees divergence wherever possible; maximum 30 degrees divergence upstream of equipment and 45 degrees convergence downstream.
 - 6. Provide turning vanes of perforated metal with glass fiber insulation when an acoustical lining is required.
 - 7. Where ducts are connected to exterior wall louvers and duct outlet is smaller than louver frame, provide blank-out panels sealing louver area around duct. Use same material as duct, painted black on exterior side; seal to louver frame and duct.

2.02 METAL DUCTS

- A. Material Requirements:
 - 1. Galvanized Steel: Hot-dipped galvanized steel sheet, ASTM A653/A653M FS Type B, with G60/Z180 coating.
- B. Rectangular Metal Duct:
 - 1. Rectangular Double Wall Insulated: Rectangular spiral lock seam duct with galvanized steel outer wall, perforated galvanized steel inner wall; fitting with the solid inner wall.
 - a. Insulation:
 - 1) Thickness: 1 inch.
 - 2) Material: Air.
- C. Round Metal Ducts:
 - 1. Round Single Wall Duct: Round lock seam duct with galvanized steel outer wall.
 - 2. Round Double Wall Insulated Duct: Round spiral lock seam duct with galvanized steel outer wall, perforated galvanized steel inner wall; fitting with the solid inner wall.
 - a. Insulation:
 - 1) Thickness: 1 inch.
 - 2) Material: Air.

3. Round Connection System: Interlocking duct connection system in accordance with SMACNA (DCS).
- D. Connectors, Fittings, Sealants, and Miscellaneous:
 1. Fittings: Manufacture with solid inner wall of perforated galvanized steel.
 2. Transverse Duct Connection System: SMACNA "E" rated rigid class connection, interlocking angle and duct edge connection system with sealant, gasket, cleats, and corner clips in accordance with SMACNA (DCS).
 3. Joint Sealers and Sealants: Non-hardening, water resistant, mildew and mold resistant.
 - a. Type: Heavy mastic or liquid used alone or with tape, suitable for joint configuration and compatible with substrates, and recommended by manufacturer for pressure class of ducts.
 - b. Surface Burning Characteristics: Flame spread index of zero and smoke developed index of zero, when tested in accordance with ASTM E84.
 4. Gasket Tape:
 - a. Provide butyl rubber gasket tape for a flexible seal between transfer duct connector (TDC), transverse duct flange (TDF), applied flange connections, and angle ring connections.
 5. Hanger Rod: ASTM A36/A36M; steel, galvanized; threaded both ends, threaded one end, or continuously threaded.

2.03 FLEXIBLE DUCTS

- A. Flexible Ducts: UL 181, Class 1, polyethylene film, mechanically fastened and rolled using galvanized steel to form spiral helix.
 1. Pressure Rating: 10 in-wc positive and 5 in-wc negative.
 2. Maximum Velocity: 5500 fpm.
 3. Temperature Range: Minus 20 degrees F to 250 degrees F.
- B. Acoustic Flexible Ducts: UL 181, Class 1, spunbond nylon, mechanically fastened and rolled using galvanized steel to form spiral helix.
 1. Inner Core: Spunbonded, nonwoven inner core.
 2. Pressure Rating: 6 in-wc positive and 5 in-wc negative.
 3. Maximum Velocity: 4000 fpm.
 4. Temperature Range: Minus 20 degrees F to 250 degrees F.
- C. Flexible Air Ducts:
 1. UL 181, Class 1, aluminum laminate and polyester film with latex adhesive supported by helically wound spring steel wire.
 2. Pressure Rating: From 10 in-wc to 1 in-wc negative.
 3. Temperature Range: Minus 20 to 210 degrees F.

PART 3 EXECUTION

3.01 INSTALLATION

- A. Install, support, and seal ducts in accordance with SMACNA (DCS).
- B. Install products following the manufacturer's instructions.
- C. Comply with safety standards NFPA 90A and NFPA 90B.
- D. During construction, provide temporary closures of metal or taped polyethylene on open ductwork to prevent construction dust from entering the ductwork system.
- E. Increase duct sizes gradually, not exceeding 15 degrees divergence wherever possible; maximum 30 degrees divergence upstream of equipment and 45 degrees convergence downstream.
- F. Flexible Ducts: Connect to metal ducts with adhesive.
- G. Duct sizes indicated are precise inside dimensions. For lined ducts, maintain sizes inside lining.

- H. Provide openings in ductwork as indicated to accommodate thermometers and controllers. Provide pilot tube openings as indicated for testing of systems, complete with metal can with spring device or screw to insure against air leakage. For openings, insulate ductwork and install insulation material inside a metal ring.
- I. Locate ducts with sufficient space around equipment to allow normal operating and maintenance activities.
- J. Connect terminal units to supply ducts directly or with one foot maximum length of flexible duct. Do not use flexible duct to change direction.
- K. At exterior wall louvers, seal duct to louver frame and install blank-out panels.

3.02 CLEANING

- A. Clean thoroughly each duct system. See Section 23 01 30.51.
- B. Clean duct system by forcing air at high velocity through duct to remove accumulated dust. Clean half the system at a time to obtain sufficient air. Protect equipment that could be harmed by excessive dirt with temporary filters or bypass during cleaning.

END OF SECTION

NOT FOR BIDDING

**SECTION 23 33 00
AIR DUCT ACCESSORIES**

PART 1 GENERAL

1.01 SECTION INCLUDES

- A. Air turning devices/extractors.
- B. Backdraft dampers - metal.
- C. Backdraft dampers - fabric.
- D. Duct test holes.
- E. Flexible duct connectors.
- F. Volume control dampers.

1.02 RELATED REQUIREMENTS

- A. Section 23 31 00 - HVAC Ducts and Casings.

1.03 REFERENCE STANDARDS

- A. ASHRAE Std 135 - A Data Communication Protocol for Building Automation and Control Networks; 2020, with Addendum (2024).
- B. IEEE 802.11 - IEEE Standard for Information Technology--Telecommunications and Information Exchange between Systems - Local and Metropolitan Area Networks--Specific Requirements - Part 11: Wireless LAN Medium Access Control (MAC) and Physical Layer (PHY) Specifications; 2020, with Amendment (2023).
- C. IEEE 802.15.4 - IEEE Standard for Low-Rate Wireless Networks; 2024.
- D. NEMA 250 - Enclosures for Electrical Equipment (1000 Volts Maximum); 2020.
- E. NFPA 90A - Standard for the Installation of Air-Conditioning and Ventilating Systems; 2024.
- F. SMACNA (DCS) - HVAC Duct Construction Standards Metal and Flexible; 2020.

1.04 SUBMITTALS

- A. See Section 01 30 00 - Administrative Requirements for submittal procedures.
- B. Product Data: Provide for shop-fabricated assemblies including volume control dampers, duct access doors, duct test holes, and hardware used. Include electrical characteristics and connection requirements.
- C. Shop Drawings: Indicate for shop fabricated assemblies including volume control dampers.
- D. Project Record Drawings: Record actual locations of access doors and test holes.

1.05 DELIVERY, STORAGE, AND HANDLING

- A. Protect dampers from damage to operating linkages and blades.

PART 2 PRODUCTS

2.01 AIR TURNING DEVICES/EXTRACTORS

- A. Manufacturers:
 - 1. Carlisle HVAC Products; Dynair Hollow Vane and Rail (Double Wall Vane): www.carlislehvac.com/#sle.
 - 2. Ruskin Company: www.ruskin.com/#sle.
 - 3. Titus HVAC, a brand of Johnson Controls: www.titus-hvac.com/#sle.
- B. Multi-blade device with blades aligned in short dimension; steel construction; with individually adjustable blades, mounting straps.

2.02 BACKDRAFT DAMPERS - METAL

- A. Manufacturers:
 - 1. Louvers & Dampers, Inc, a brand of Mestek, Inc; _____: www.louvers-dampers.com/#sle.
 - 2. Nailor Industries, Inc: www.nailor.com/#sle.
 - 3. Ruskin Company: www.ruskin.com/#sle.
- B. Gravity Backdraft Dampers, Size 18 by 18 inches or Smaller, Furnished with Air Moving Equipment: Air moving equipment manufacturer's standard construction.
- C. Multi-Blade, Parallel Action Gravity Balanced Backdraft Dampers: Galvanized steel, with center pivoted blades of maximum 6 inch width, with felt or flexible vinyl sealed edges, linked together in rattle-free manner with 90 degree stop, steel ball bearings, and plated steel pivot pin; adjustment device to permit setting for varying differential static pressure.

2.03 BACKDRAFT DAMPERS - FABRIC

- A. Fabric Backdraft Dampers: Factory-fabricated.
 - 1. Blades: Neoprene coated fabric material.
 - 2. Birdscreen: 1/2 inch nominal mesh of galvanized steel or aluminum.
 - 3. Maximum Velocity: 1000 fpm (5 mps) face velocity.

2.04 DUCT TEST HOLES

- A. Temporary Test Holes: Cut or drill in ducts as required. Cap with neat patches, neoprene plugs, threaded plugs, or threaded or twist-on metal caps.
- B. Permanent Test Holes: Factory fabricated, air tight flanged fittings with screw cap. Provide extended neck fittings to clear insulation.

2.05 FLEXIBLE DUCT CONNECTORS

- A. Fabricate in accordance with SMACNA (DCS) and as indicated.
- B. Flexible Duct Connections: Fabric crimped into metal edging strip.
 - 1. Fabric: UL listed fire-retardant neoprene coated woven glass fiber fabric to NFPA 90A, minimum density 30 oz/sq yd.

2.06 VOLUME CONTROL DAMPERS

- A. Manufacturers:
 - 1. AireTechnologies, Inc, a DMI Company: www.airetechnologies.com/#sle.
 - 2. Louvers & Dampers, Inc, a brand of Mestek, Inc: www.louvers-dampers.com/#sle.
 - 3. Nailor Industries, Inc: www.nailor.com/#sle.
 - 4. Ruskin Company: www.ruskin.com/#sle.
- B. Fabricate in accordance with SMACNA (DCS) and as indicated.
- C. Single Blade Dampers:
 - 1. Fabricate for duct sizes up to 6 by 30 inch.
 - 2. Blade: 24 gauge, 0.0239 inch, minimum.
- D. Multi-Blade Damper: Fabricate consisting of opposed blades with maximum blade sizes 8 by 72 inches. Assemble center- and edge-crimped blades in prime-coated or galvanized-channel frame with suitable hardware.
 - 1. Blade: 18 gauge, 0.0478 inch, minimum.
- E. End Bearings: Except in round ducts 12 inches and smaller, provide end bearings. On multiple blade dampers, provide oil-impregnated nylon, thermoplastic elastomer, or sintered bronze bearings.

PART 3 EXECUTION

3.01 INSTALLATION

- A. Install accessories in accordance with manufacturer's instructions, NFPA 90A, and follow SMACNA (DCS). See Section 23 31 00 for duct construction and pressure class.
- B. Provide backdraft dampers on exhaust fans or exhaust ducts nearest to outside and where indicated.
- C. Provide duct test holes where indicated and required for testing and balancing purposes.
- D. At fans and motorized equipment associated with ducts, provide flexible duct connections immediately adjacent to the equipment.
- E. At equipment supported by vibration isolators, provide flexible duct connections immediately adjacent to the equipment.
- F. Provide balancing dampers at points on supply, return, and exhaust systems where branches are taken from larger ducts as required for air balancing. Install minimum two duct widths from duct take-off.

END OF SECTION

NOT FOR BIDDING

NOT FOR BIDDING

This page intentionally left blank

**SECTION 23 37 00
AIR OUTLETS AND INLETS**

PART 1 GENERAL

1.01 SECTION INCLUDES

- A. Diffusers:
 - 1. Perforated ceiling diffusers.
- B. Rectangular ceiling diffusers.
- C. Slot ceiling diffusers.
- D. Registers/grilles:
 - 1. Ceiling-mounted, exhaust and return register/grilles.
- E. Goosenecks.

1.02 REFERENCE STANDARDS

- A. ACGIH (IV) - Industrial Ventilation: A Manual of Recommended Practice for Design, 31st Edition; 2023, with Errata (2024).
- B. AHRI 880 (I-P) - Performance Rating of Air Terminals; 2017 (Reaffirmed 2023).
- C. ASHRAE Std 70 - Method of Testing the Performance of Air Outlets and Air Inlets; 2023.
- D. NFPA 90A - Standard for the Installation of Air-Conditioning and Ventilating Systems; 2024.
- E. SMACNA (ASMM) - Architectural Sheet Metal Manual; 2012.
- F. SMACNA (DCS) - HVAC Duct Construction Standards Metal and Flexible; 2020.
- G. UL 2518 - Standard for Safety Air Dispersion Systems; Current Edition, Including All Revisions.

1.03 SUBMITTALS

- A. See Section 01 30 00 - Administrative Requirements for submittal procedures.
- B. Product Data: Provide data for equipment required for this project. Review outlets and inlets as to size, finish, and type of mounting prior to submission. Submit schedule of outlets and inlets showing type, size, location, application, and noise level.
- C. Project Record Documents: Record actual locations of air outlets and inlets.

1.04 QUALITY ASSURANCE

- A. Test and rate air outlet and inlet performance in accordance with ASHRAE Std 70.

PART 2 PRODUCTS

2.01 MANUFACTURERS

- A. Price Industries: www.priceindustries.com/#sle.
- B. Titus, a brand of Air Distribution Technologies: www.titus-hvac.com/#sle.
- C. Tuttle and Bailey: www.tuttleandbailey.com/#sle.
- D. Substitutions: See Section 01 60 00 - Product Requirements.

2.02 RECTANGULAR CEILING DIFFUSERS

- A. Type: Provide square formed adjustable, backpan stamped, core removable, and multi-louvered ceiling diffusers constructed to maintain 360 degree discharge air pattern with sectorizing baffles where indicated.
- B. Connections: Round.
- C. Frame: Provide surface mount, snap-in, inverted T-bar, and spline type. In plaster ceilings, provide plaster frame and ceiling frame.
- D. Fabrication: Steel with baked enamel finish.

- E. Color: As indicated.
- F. Accessories: Provide radial opposed blade, butterfly, and combination splitter volume control damper; removable core, sectorizing baffle, safety chain, wire guard, equalizing grid, operating rod extension, anti-smudging device, and gaskets for surface mounted diffusers with damper adjustable from diffuser face.

2.03 PERFORATED FACE CEILING DIFFUSERS

- A. Type: Perforated face with fully adjustable pattern and removable face.
- B. Frame: Surface mount type. In plaster ceilings, provide plaster frame and ceiling frame.
- C. Fabrication: Steel with steel frame and baked enamel finish.
- D. Fabrication: Stainless steel.
- E. Color: As indicated.
- F. Accessories: Radial opposed blade damper and multi-louvered equalizing grid with damper adjustable from diffuser face.

2.04 CEILING SLOT DIFFUSERS

- A. Fabrication: Aluminum extrusions with factory clear lacquer finish.
- B. Color: As indicated.
- C. Frame: 1-1/4 inch margin with countersunk screw mounting and gasket, mitered end border.
- D. Plenum: Integral, galvanized steel, insulated.

2.05 CEILING EXHAUST AND RETURN REGISTERS/GRILLES

- A. Type: Streamlined blades, 3/4 inch minimum length, 3/4 inch maximum spacing, with blades set at 45 degrees, vertical face.
- B. Frame: 1-1/4 inch margin with countersunk screw mounting.
- C. Fabrication: Steel with 20 gauge, 0.0359 inch minimum frames and 22 gauge, 0.0299 inch minimum blades, steel and aluminum with 20 gauge, 0.0359 inch minimum frame, or aluminum extrusions, with factory baked enamel finish.
- D. Fabrication: Stainless steel with 20 gauge, 0.0359 inch minimum frames and 22 gauge, 0.0299 inch minimum blades, steel and aluminum with 20 gauge, 0.0359 inch minimum frame.
- E. Color: As indicated.
- F. Damper: Integral, gang-operated, opposed blade type with removable key operator, operable from face where not individually connected to exhaust fans.

2.06 GOOSENECKS

- A. Fabricate in accordance with of minimum 18 gauge, 0.0598 inch galvanized steel.
- B. Mount on minimum 12 inch high curb base where size exceeds 9 by 9 inch.

PART 3 EXECUTION

3.01 INSTALLATION

- A. Install in accordance with manufacturer's instructions.
- B. Comply with SMACNA (ASMM) for flashing/counter-flashing of roof penetrations and supports for roof curbs and roof mounted equipment.
- C. Check location of outlets and inlets and make necessary adjustments in position to comply with architectural features, symmetry, and lighting arrangement.
- D. Install diffusers to ductwork with air tight connection.
- E. Provide balancing dampers on duct take-off to diffusers and grilles and registers, despite whether dampers are specified as part of diffuser, or grille and register assembly.

- F. Paint ductwork visible behind air outlets and inlets matte black, see Section 09 91 23.

3.02 CLOSEOUT ACTIVITIES

- A. Demonstrate operational system to Owner's representative.
B. Instruct Owner's representative to maintain system and use occupant controls or interfaces, as required.

3.03 PROTECTION

- A. Protect installed products until completion of project.
B. Replace, repair, or touch-up damaged products before Substantial Completion.

END OF SECTION

NOT FOR BIDDING

NOT FOR BIDDING

This page intentionally left blank

SECTION 23 72 00
AIR-TO-AIR ENERGY RECOVERY EQUIPMENT

PART 1 GENERAL

1.01 SECTION INCLUDES

- A. Energy recovery ventilators.

1.02 RELATED REQUIREMENTS

- A. Section 07 72 00 - Roof Accessories: Equipment roof curb.
- B. Section 23 05 48 - Vibration and Seismic Controls for HVAC.
- C. Section 23 09 23 - Direct-Digital Control System for HVAC.
- D. Section 25 15 00 - Integrated Automation Software: BAS, BMS, or SCADA.
- E. Section 26 05 83 - Wiring Connections.

1.03 REFERENCE STANDARDS

- A. AHRI 1060 (I-P) - Performance Rating of Air-to-Air Exchangers for Energy Recovery Ventilation Equipment; 2023.
- B. ASHRAE Std 52.2 - Method of Testing General Ventilation Air-Cleaning Devices for Removal Efficiency by Particle Size; 2017, with Addendum (2022).
- C. ASHRAE Std 90.1 I-P - Energy Standard for Buildings Except Low-Rise Residential Buildings; Most Recent Edition Adopted by Authority Having Jurisdiction, Including All Applicable Amendments and Supplements.
- D. ASHRAE Std 135 - A Data Communication Protocol for Building Automation and Control Networks; 2020, with Addendum (2024).
- E. ASTM C1338 - Standard Test Method for Determining Fungi Resistance of Insulation Materials and Facings; 2019 (Reapproved 2023).
- F. ASTM G21 - Standard Practice for Determining Resistance of Synthetic Polymeric Materials to Fungi; 2015, with Editorial Revision (2021).
- G. NFPA 70 - National Electrical Code; Most Recent Edition Adopted by Authority Having Jurisdiction, Including All Applicable Amendments and Supplements.
- H. NFPA 90A - Standard for the Installation of Air-Conditioning and Ventilating Systems; 2024.
- I. UL (DIR) - Online Certifications Directory; Current Edition.
- J. UL 181 - Standard for Factory-Made Air Ducts and Air Connectors; Current Edition, Including All Revisions.

1.04 SUBMITTALS

- A. See Section 01 30 00 - Administrative Requirements for submittal procedures.
- B. Product Data: Manufacturer's installation instructions, product data, and engineering calculations.
- C. Shop Drawings: Show design and assembly of energy recovery unit and installation and connection details.
- D. Closeout Submittals: Submit manufacturer's operation and maintenance instructions.
- E. Maintenance Materials: Furnish the following for Del Tech's use in maintenance of project.
 - 1. See Section 01 60 00 - Product Requirements for additional provisions.
 - 2. Extra Stock Materials: One set of filters.

1.05 DELIVERY, STORAGE, AND HANDLING

- A. See Section 01 74 19 - Construction Waste Management and Disposal for packaging waste requirements.
- B. Store products in manufacturer's unopened packaging until ready for installation.
- C. Store equipment and products to be installed indoors in dry heated area.

1.06 WARRANTY

- A. See Section 01 78 00 - Closeout Submittals for additional warranty requirements.
- B. Manufacturer Warranty: Provide 1-year manufacturer warranty for equipment including parts, materials, workmanship, and operation commencing on date of Substantial Completion. Complete forms in Del Tech's name and register with manufacturer.

PART 2 PRODUCTS

2.01 MANUFACTURERS

- A. Greenheck: www.greenheck.com/#sle.
- B. LG Electronics U.S.A., Inc: www.lghvac.com/#sle.
- C. RenewAire: www.renewaire.com/#sle.
- D. Substitutions: See Section 01 60 00 - Product Requirements

2.02 ENERGY RECOVERY VENTILATOR

- A. Basis of Design: Greenheck[<>]: www.greenheck.com/#sle.
- B. ERV Equipment Construction Requirements:
 - 1. Energy Recovery Exchanger Type: Membrane plate.
 - 2. Supply and Return Duct Connection Orientation: As indicated on drawings.
 - 3. Casing and Frame:
 - a. Frame: Galvanized steel body or welded extruded aluminum tubular frame capable of supporting components and casings including integral base lifting holes.
 - b. Double Wall Panels: Minimum of 18 gauge, 0.040 inch galvanized steel.
 - c. Doors: Construct doors of same construction and thickness as wall panels. Include p-shaped extruded neoprene gasket, prop rod, chain with spring, exterior handle, and interior 3-point latching device. Label each door to identify equipment located within.
 - d. Insulation Requirements:
 - 1) Mold Resistance: "Pass" when tested in accordance with ASTM C1338.
 - 2) Fungal Resistance: No growth when tested in accordance with ASTM G21.
 - 3) Bacteria Resistance: No growth when tested in accordance with UL 181.
 - 4) Flame spread index of 25 or less and maximum smoke developed index of 50.
 - e. Isolation and Sealing: Form continuous, thermally isolated, weathertight seal between inner wall of panels and structural framing with closed cell PVC foam gasketing and seal seams to prevent job site caulking.
 - f. Access Panels: Provide access to components through a large, tightly sealed and easily removable hinged or screwed access panel.
 - g. Finish: Polyurethane enamel over weather-protected, corrosion-resistant assembly.
 - h. Nameplate: Permanent name plate listing manufacturer, model number, serial number, voltage with tolerance, and amp ratings mounted inside door near electrical panel.
- 4. Supply and Exhaust Fans:
 - a. Provide separate non-overloading, statically and dynamically balanced, draw-through, forward curved centrifugal fan or fan-array for each air stream.
 - b. Fan Motor: Constant Speed, high efficiency, load matched, belt-driven, open drip proof, thermal overload protected TEFC motor with variable-sheave belt drive, and

- adjustable-removable motor-slide base. Size drives to 150 percent of load, minimum.
- c. Belt Guards: Full sized, hinged, painted with high-visibility safety color, and accessible with standard tools.
- d. Motor Bearings: Permanently lubricated sealed ball bearings rated for not less than 200,000 hours of operation with accessible greased fittings.
- 5. Filter Sections:
 - a. Outdoor-Intake and Exhaust Sides: 2 inch thick, pleated, MERV 13 filters, ASHRAE Std 52.2.
 - b. Filter Racks: Bolt-on rack constructed of aluminum with minimum size of 1/12 inch thick. Include hinged side access door and snap fasteners.
- 6. Roof Curbs:
 - a. Curbs: Provide full perimeter, watertight, sloped, weight-supporting roof curb fabricated from minimum of 10 gauge, 0.1345 inch aluminized steel.
 - b. Isolation Rails: Provide factory-installed, 12 gauge, 0.1046 inch aluminized steel angles top and bottom, connected with flexible, outdoor rated membrane and factory-installed vibration isolation springs.
 - c. Gaskets: Provide closed cell PVC foam, field installed top of curb.
- 7. Vibration Isolation: Provide corrosion-resistant vibration isolation products for internal motors and other revolving parts. See Section 23 05 48.
- 8. Electrical:
 - a. 220 VAC, 3-phase with single-point power connection to nonfused main disconnect interlocked with control panel and other components.
 - b. Install internal wiring in accordance with NFPA 70 within flexible, liquid tight steel conduit.
- 9. Controls and Local Control Panel:
 - a. Unit Controls: Factory supplied DDC with sensors, limit switches, and frost control.
 - b. Provide fused disconnect within local control panel with power supplies, transformers, terminal strip or terminal blocks for interface of field installed components.
 - c. Service Status: Provide both local and remote indication of sensor readings and status of safeties and other status items including power on, wheel-rotation alarm, outside-air loaded filter and exhaust-air loaded filter.
 - d. Provide temperature, humidity, dewpoint temperature, CO2, and wheel rotation sensors.
 - e. Freeze Protection Thermostat: Provide and configure to stop unit when outdoor air intake temperature drops below 38 degrees F, adjustable.
- 10. BAS, SCADA, or other Integrated Automation Link: ASHRAE Std 135 BACnet MS/TP.
- 11. Configuration: Adjust listed requirements in conformance with ASHRAE Std 90.1 I-P.
- 12. Certification: AHRI 1060 (I-P) labeled, include copy of published ratings for operating conditions.

PART 3 EXECUTION

3.01 EXAMINATION

- A. Verify that structure is ready for installation including openings, ductwork, mechanical utilities, and electrical utilities.
- B. Rooftop Installation: Verify that equipment supplied roof curbs are installed and ready to receive intended unit otherwise provide equipment matched roof curbs; see Section 07 72 00.

3.02 INSTALLATION

- A. Install equipment in accordance with manufacturer's written installation instructions.
- B. Do not obstruct maintenance access to equipment piping, electrical conduit, or any other utility.
- C. Vibration Isolation: Provide corrosion-resistant equipment isolation products; see Section 23 05 48.

- D. Electrical: Provide equipment raceway, wiring, and cables; see Section 26 05 83.
- E. Coordinate installation and fire alarm system interface of system compatible duct-mounted smoke detectors and other appurtenances following NFPA 90A guidelines.
- F. Start system and adjust controls and equipment for satisfactory operation.
- G. Coordinate hardwired or software interfacing links to enable coordinate as minimum start-stop, occupied, unoccupied functions as well as specific schedules and setpoints functions with other DDC controls onboard airside systems serving common spaces; see Section 23 09 23.
- H. Coordinate BAS, BMS, or Integrated Automation linking between unit controller(s) and remote front-end interface; see Section 25 15 00.

3.03 SYSTEM STARTUP

- A. Provide services of manufacturer's authorized representative to provide start up of unit.

3.04 CLOSEOUT ACTIVITIES

- A. See Section 01 78 00 - Closeout Submittals for additional submittals.
- B. See Section 01 79 00 - Demonstration and Training for additional requirements.
- C. Demonstrate proper operation of equipment to Del Tech's designated representative.

END OF SECTION

SECTION 23 81 26.13
SMALL-CAPACITY SPLIT-SYSTEM AIR CONDITIONERS

PART 1 GENERAL

1.01 SECTION INCLUDES

- A. Air-source heat pumps.
- B. Air cooled condensing units.
- C. Indoor air handling (fan and coil) units for ductless systems.
- D. Controls.

1.02 RELATED REQUIREMENTS

- A. Section 26 05 83 - Wiring Connections: Electrical characteristics and wiring connections and installation and wiring of thermostats and other controls components.

1.03 REFERENCE STANDARDS

- A. AHRI 210/240 - Performance Rating of Unitary Air-Conditioning and Air-Source Heat Pump Equipment; 2023.
- B. AHRI 520 - Performance Rating of Positive Displacement Condensing Units; 2004.
- C. ASHRAE Std 15 - Safety Standard for Refrigeration Systems; 2024, with Errata (2025).
- D. ASHRAE Std 23 - Methods for Performance Testing Positive Displacement Refrigerant Compressors and Compressor Units; 2022.
- E. NFPA 90A - Standard for the Installation of Air-Conditioning and Ventilating Systems; 2024.
- F. NFPA 90B - Standard for the Installation of Warm Air Heating and Air-Conditioning Systems; 2024.
- G. UL 207 - Standard for Refrigerant-Containing Components and Accessories, Nonelectrical; Current Edition, Including All Revisions.
- H. UL 1995 - Heating and Cooling Equipment; Current Edition, Including All Revisions.

1.04 SUBMITTALS

- A. See Section 01 30 00 - Administrative Requirements, for submittal procedures.
- B. Product Data: Provide rated capacities, weights, accessories, electrical nameplate data, and wiring diagrams.
- C. Shop Drawings: Indicate assembly, required clearances, and location and size of field connections.
- D. Design Data: Indicate refrigerant pipe sizing.
- E. Manufacturer's Instructions: Indicate rigging, assembly, and installation instructions.
- F. Operation and Maintenance Data: Include manufacturer's descriptive literature, operating instructions, installation instructions, maintenance and repair data, and parts listing.
- G. Warranty: Submit manufacturers warranty and ensure forms have been filled out in Del Tech's name and registered with manufacturer.

1.05 WARRANTY

- A. See Section 01 78 00 - Closeout Submittals, for additional warranty requirements.

PART 2 PRODUCTS

2.01 SYSTEM DESIGN

- A. Split-System Heating and Cooling Units: Self-contained, packaged, matched factory-engineered and assembled, pre-wired indoor and outdoor units; UL listed.

1. Heating and Cooling: Air-source electric heat pump located in outdoor unit with evaporator.
 2. Provide refrigerant lines internal to units and between indoor and outdoor units, factory cleaned, dried, pressurized and sealed, with insulated suction line.
- B. Performance Requirements: See Drawings for additional requirements.
- C. Electrical Characteristics:
1. Disconnect Switch: Factory mount disconnect switch on equipment under provisions of Section 26 05 83.

2.02 INDOOR AIR HANDLING UNITS FOR DUCTLESS SYSTEMS

- A. Indoor Units: Self-contained, packaged, factory assembled, pre-wired unit consisting of cabinet, supply fan, evaporator coil, and controls; wired for single power connection with control transformer.
1. Location: High-wall.
 2. Cabinet: Galvanized steel.
 - a. Finish: White.
 3. Filter return air with washable, antioxidant pre-filter and a pleated anti-allergy enzyme filter.
- B. Evaporator Coils: Copper tube aluminum fin assembly, galvanized or polymer drain pan sloped in all directions to drain, drain connection, refrigerant piping connections, restricted distributor or thermostatic expansion valve.
1. Construction and Ratings: In accordance with AHRI 210/240 and UL 207.
 2. Manufacturer: System manufacturer.

2.03 OUTDOOR UNITS

- A. Outdoor Units: Self-contained, packaged, pre-wired unit consisting of cabinet, with compressor and condenser.
1. Refrigerant: R-454B.
 2. Construction and Ratings: In accordance with AHRI 210/240 with testing in accordance with ASHRAE Std 23 and UL 207.
- B. Air Cooled Condenser: Aluminum fin and copper tube coil, AHRI 520 with direct drive axial propeller fan resiliently mounted, galvanized fan guard.
- C. Accessories: Filter drier, high-pressure switch (manual reset), low pressure switch (automatic reset), service valves and gauge ports, thermometer well (in liquid line).
1. Provide thermostatic expansion valves.
- D. Operating Controls:
1. Control by room thermostat to maintain room temperature setting.

PART 3 EXECUTION

3.01 EXAMINATION

- A. Verify that substrates are ready for installation of units and openings are as indicated on shop drawings.
- B. Verify that proper power supply is available and in correct location.
- C. Verify that proper fuel supply is available for connection.

3.02 INSTALLATION

- A. Install in accordance with NFPA 90A and NFPA 90B.
- B. Install refrigeration systems in accordance with ASHRAE Std 15.

END OF SECTION

SECTION 23 81 29
VARIABLE REFRIGERANT FLOW HVAC SYSTEMS

PART 1 GENERAL

1.01 SECTION INCLUDES

- A. Air-source outdoor units.
- B. Refrigerant piping.
- C. Refrigerant branch units.
- D. Indoor units.

1.02 RELATED REQUIREMENTS

- A. Section 23 05 29 - Hangers and Supports for HVAC Piping and Equipment.
- B. Section 23 07 19 - HVAC Piping Insulation.
- C. Section 23 23 00 - Refrigerant Piping.
- D. Section 25 15 00 - Integrated Automation Software.

1.03 REFERENCE STANDARDS

- A. AHRI 210/240 - Performance Rating of Unitary Air-Conditioning and Air-Source Heat Pump Equipment; 2023.
- B. AHRI 1230 - Performance Rating of Variable Refrigerant Flow (VRF) Multi-Split Air-Conditioning and Heat Pump Equipment; 2021.
- C. ASCE 7 - Minimum Design Loads and Associated Criteria for Buildings and Other Structures; Most Recent Edition Cited by Referring Code or Reference Standard.
- D. ASHRAE Std 15 - Safety Standard for Refrigeration Systems; 2024, with Errata (2025).
- E. ITS (DIR) - Directory of Listed Products, Current Edition.
- F. NEMA 250 - Enclosures for Electrical Equipment (1000 Volts Maximum); 2020.
- G. NFPA 70 - National Electrical Code; Most Recent Edition Adopted by Authority Having Jurisdiction, Including All Applicable Amendments and Supplements.
- H. UL 1995 - Heating and Cooling Equipment; Current Edition, Including All Revisions.

1.04 SUBMITTALS

- A. See Section 01 30 00 - Administrative Requirements for submittal procedures.
- B. Product Data. Submit manufacturer's standard data sheets showing the following for each item of equipment, marked to correlate to equipment item markings indicated in Contract Documents:
 - 1. Outdoor Units:
 - a. Refrigerant Type and Size of Charge.
 - b. Output and Input Cooling Capacity: Btu/h.
 - c. Output and Input Heating Capacity: Btu/h.
 - d. Operating Temperature Range, Cooling and Heating.
 - e. Fan Capacity: Flow in cfm with respective fan curves.
 - f. External Static Pressure (ESP): In-wc.
 - g. Sound Pressure Level: dB(A).
 - h. Electrical Data: Complete including motor size.
 - i. Maximum number of indoor units that can be served.
 - j. Maximum refrigerant piping run from outdoor unit to indoor unit(s).
 - k. Maximum height difference between outdoor unit to Indoor unit(s), both above and below.

2. Indoor Units:
 - a. Output and Input Cooling Capacity: Btu/h.
 - b. Output and Input Heating Capacity: Btu/h.
 - c. Fan Capacity: Flow in cfm with respective fan curves.
 - d. External Static Pressure (ESP): In-wc.
 - e. Electrical Data: Complete including motor size.
 - f. Maximum Lift of Built-in Condensate Pump.
3. Control Panels: Complete data of controllers, input-output points, and zones.
- C. Shop Drawings: Installation drawings custom-made for this project; include as-designed HVAC layouts, locations of equipment items, refrigerant piping sizes and locations, condensate piping sizes and locations, remote sensing devices, control components, electrical connections, control wiring connections. Include:
 1. Detailed piping diagrams, with branch balancing devices.
 2. Condensate piping routing, size, and pump connections.
 3. Detailed power wiring diagrams.
 4. Detailed control wiring diagrams.
 5. Locations of required access through fixed construction.
 6. Drawings required by manufacturer.
- D. Operating and Maintenance Data:
 1. Manufacturer's complete standard instructions for each unit of equipment and control panel.
 2. Custom-prepared system operation, troubleshooting, and maintenance instructions and recommendations.
 3. Identification of replaceable parts and local source of supply.
- E. Warranty: Executed warranty, made out in Del Tech's name.
- F. Project Record Documents: Record the following:
 1. As-installed routing of refrigerant piping and condensate piping.
 2. Locations of access panels.
 3. Locations of control panels.

1.05 DELIVERY, STORAGE AND HANDLING

- A. Deliver, store, and handle equipment and refrigerant piping according to manufacturer's recommendations.

1.06 WARRANTY

- A. See Section 01 75 00 - Closeout Submittals for additional warranty requirements.

PART 2 PRODUCTS

2.01 MANUFACTURERS

- A. Daikin: www.daikinac.com/#sle.
- B. LG Electronics U.S.A., Inc: www.lghvac.com/#sle.
- C. Mitsubishi Electric Trane HVAC US, LLC: www.metahvac.com/#sle.
- D. Substitutions: Systems manufactured by other manufacturers will not be considered.

2.02 VARIABLE REFRIGERANT FLOW SYSTEM

- A. Minimum System Requirements:
 1. System Testing, Capacity Rating, and Performance:
 - a. AHRI 1230 when cooling capacity is equal or greater than 65,000 Btu/h.
 - b. AHRI 210/240 when cooling capacity is below 65,000 Btu/h.
 2. Safety Certification: Bear UL 1995 tested and ITS (DIR) listed certification label.

3. Outdoor Units: Furnish installation and surface support hardware products in accordance with ASCE 7 for wind restraint.
4. Cooling Mode Interior Performance:
 - a. Daytime Setpoint: 68 degrees F, plus or minus 2 degrees F.
 - b. Setpoint Range: 57 degrees F to 77 degrees F.
 - c. Night Setback: 78 degrees F.
 - d. Interior Relative Humidity: 20 percent, maximum.
- B. System Design and Installation Considerations:
 1. Conditioned spaces and zones are indicated on drawings.
 2. Outside unit locations are indicated on drawings.
 3. Indoor unit locations are indicated on drawings.
 4. Required equipment unit capacities are indicated on drawings.
 5. Refrigerant piping sizes are not indicated on drawings.
 6. Condensate piping to nearest drain is indicated on drawings.
 7. Provide calculations showing ASHRAE Std 15 guideline compliance.

2.03 AIR-SOURCE OUTDOOR UNITS

- A. Air Conditioning Type:
 1. DX refrigeration unit piped to one or more compatible indoor units either directly or indirectly through one or more intermediate refrigeration branch units.
- B. Unit Cabinet:
 1. Capable of being installed with wiring and piping to the left, right, rear or bottom.
 2. Designed to allow side-by-side installation with minimum spacing and vibration isolation.
 3. Weatherproof and corrosion resistant; rust-proofed mild steel panels coated with baked enamel finish.
 4. Sound Pressure Level: 55 dB measured at 3 feet from front of unit.
- C. Heat Sink Side:
 1. Condenser Fans:
 - a. Provide minimum of 2 fans for each condenser within the outdoor unit.
 - b. Minimum External Static Pressure: Factory set at 0.12 in-wc.
 - c. Fan Type: Vertical discharging, direct-driven propeller type with variable speed operation using DC-controlled ECM motors mechanically connected using permanently lubricated bearings having whole assembly protected with fan guards.
 2. Condenser Coils:
 - a. Hi-X seamless copper tubes expanded into aluminum fins to form mechanical bond; waffle louver fin and rifled bore tube design to ensure high efficiency performance.
- D. Refrigeration Side:
 1. Factory assembled and wired with instrumentation, switches, and controller(s) to handle unit specifics with direct coordination of remote controller(s) from indoor unit(s).
 2. Refrigeration Circuit: ECM driven dual scroll compressors, fans, condenser heat sink coil, expansion valves, solenoid valves, distribution headers, capillaries, filters, shutoff valves, oil separators, service ports, and refrigerant regulator.
 3. Variable Volume Control: Modulate compressed refrigerant capacity automatically to maintain constant suction and condensing pressures under varying refrigerant volume required to handle remote loads. Include defrost control.
 4. Provide refrigerant subcooling to ensure the liquid refrigerant does not flash when supplying to use indoor units.
 5. Capable of heating operation at low end of operating range as specified, without additional low ambient controls or auxiliary heat source; during heating operation, reverse cycle, oil return, or defrost is not permitted due to potential reduction in space temperature.

6. Power Failure Mode: Automatically restarts operation after power failure without loss of programmed settings.
 7. Safety Devices: High pressure sensor with cut-out switch, low pressure sensor with cut-out switch, control circuit fuses, crankcase heaters, fusible plug, overload relay, inverter overload protector, thermal protectors for compressor and fan motors, overcurrent protection for the inverter and antirecycling timers.
 8. Oil Recovery Cycle: Automatic, occurring 2 hours after start of operation and then every 8 hours of operation; maintain continuous heating during oil return operation.
- E. Local Controls:
- F. Power:
1. Electrical Requirement: 208 to 230 VAC, 3-phase, 60 Hz.
 2. Outdoor Mounted: Provide fused NEMA 250 Type 4X disconnect switch.

2.04 REFRIGERANT PIPING

- A. Two-Pipe Run: Provide low-pressure vapor and high-pressure vapor gas pipes for each indoor unit selected for seasonal heating or cooling service.
- B. Three-Pipe Run: Provide low-pressure vapor, high-pressure vapor gas, and liquid pipes for each indoor unit selected for off-season heating and cooling changeover service.
- C. Refrigerant Flow Balancing: Provide refrigerant piping joints and headers specifically designed to ensure proper refrigerant balance and flow for optimum system capacity and performance; T-style joints are prohibited.

2.05 REFRIGERANT BRANCH UNITS

- A. Outdoor unit interface to handle two or more indoor units required to do automatic off-season heating and cooling changeover.
- B. Concealed box consisting internally of refrigeration loops, subcooling heat exchanger, and other devices coordinated by electronic valves to facilitate off-season load management between outdoor and indoor units.
- C. Minimum Requirements:
 1. Control direction of refrigerant flow using electronic expansion valves; use of solenoid valves for changeover and pressure equalization is not permitted due to refrigerant noise; use of multi-port branch selector boxes is not permitted unless spare ports are provided for redundancy.
 2. Provide one electronic expansion valve for each downstream indoor unit served except when multiple indoor units are connected, provide balancing joints in downstream piping to keep total capacity within branch unit capacity.
 3. Energize subcooling heat exchanger during simultaneous heating and cooling service.
 4. Casing: Galvanized steel sheet with flame and heat resistant foamed polyethylene sound and thermal insulation.
 5. Refrigerant Connections: Braze type.
 6. Condensate Drainage: Provide unit that does not require condensate drainage.

2.06 INDOOR UNITS

- A. Minimum Unit Requirements:
 1. DX Evaporator Coil:
 - a. Copper tubes expanded into aluminum fins to form a mechanical bond; waffle louver fin and high heat exchange, rifled bore tube design; factory tested.
 - b. 2-, 3-, or 4-row cross fin design with 14 to 17 fins per inch and flare end-connections.
 - c. Provide thermistor on liquid and gas lines wired into local controller.
 - d. Refrigerant circuits factory-charged with dehydrated air for field charging.
 2. Fan Section:

- a. Variable or three-speed ECM fan with automatic airflow adjustment; external static pressure selectable during commissioning.
 - b. Thermally protected, direct-drive motor with statically and dynamically balanced fan blades.
 - c. Minimum-adjustable external static pressure 0.32 in-wc; provide for mounting of field-installed ducts.
 3. Local Unit Controls:
 - a. Temperature Control: Return air control using thermistor tied to computerized Proportional-Integral-Derivative (PID) control of superheat.
 - b. Temperature Zones:
 - 1) Single Indoor Unit: Set served space(s) as the local temperature zone.
 - 2) Multiple Indoor Units: For large zones, group and coordinate related indoor units with served spaces as the local temperature zone with each indoor unit as sub-zone.
 4. Return Air Filter:
 5. Condensate:
 - a. Built-in condensate drain pan with PVC drain connection for drainage.
 - b. Units With Built-In Condensate Pumps: Provide condensate safety shutoff and alarm.
 - c. Units Without Built-In Condensate Pump: Provide built-in condensate float switch and wiring connections.
 6. Cabinet Insulation: Sound absorbing foamed polystyrene and polyethylene insulation.
- B. Wall Mounted, Indoor Units:
1. DX coil, tubed drain pan, and built-in controls with thermostat remotely coordinated by outdoor air unit to maintain local air temperature setpoint.
 2. Variable or three-speed ECM cross-flow fan with automatic airflow adjustment; external static pressure selectable during commissioning.
 3. Return Air Filter: Manufacturer's standard.
 4. Provide exposed unit casing with removable front grille; foamed polystyrene and polyethylene sound insulation; wall mounting plate; polystyrene condensate drain pan.
 5. Airflow Control: Auto-swing louver that closes automatically when unit stops; five (5) steps of discharge angle, set using remote controller; upon restart, discharge angle defaults to same angle as previous operation.
 6. Sound Pressure Range: Measured at low speed at 3.3 feet below and away from unit.
 7. Condensate Pump: Built-in, concealed.
 8. Condensate Drain Connection: Back, with piping concealed in wall.

PART 3 EXECUTION

3.01 EXAMINATION

- A. Verify that required electrical services have been installed and are in the proper locations prior to starting installation.
- B. Verify that condensate piping has been installed and is in the proper location prior to starting installation.
- C. Notify DEDC, LLC if conditions for installation are unsatisfactory.

3.02 INSTALLATION

- A. Install in accordance with manufacturer's instructions.
- B. Install refrigerant piping in accordance with equipment manufacturer's instructions.
- C. Perform wiring in accordance with NFPA 70, National Electric Code (NEC).
- D. Coordinate with installers of systems and equipment connecting to this system.

- E. Connect indoor units to condensate piping.
- F. Coordinate BAS, BMS, or Integrated Automation linking between local controller(s) and remote front-end interface; see Section 25 15 00.

3.03 SYSTEM STARTUP

- A. Provide manufacturer's field representative to perform system startup.
- B. Prepare and start equipment and system in accordance with manufacturer's instructions and recommendations.
- C. Adjust equipment for proper operation within manufacturer's published tolerances.

3.04 CLOSEOUT ACTIVITIES

- A. See Section 01 78 00 - Closeout Submittals for additional submittals.
- B. See Section 01 79 00 - Demonstration and Training for additional requirements.
- C. Demonstrate proper operation of equipment to Del Tech's designated representative.
- D. Demonstration: Demonstrate operation of system to Del Tech's personnel.
 - 1. Use operation and maintenance data as reference during demonstration.
 - 2. Briefly describe function, operation, and maintenance of each component.
- E. Training: Train Del Tech's personnel on operation and maintenance of system.
 - 1. Use operation and maintenance manual as training reference, supplemented with additional training materials as required.
 - 2. Provide minimum of two hours of training.

3.05 PROTECTION

- A. Protect installed components from subsequent construction operations.
- B. Replace exposed components broken or otherwise damaged beyond repair.

END OF SECTION

SECTION 23 81 46
WATER-SOURCE UNITARY HEAT PUMPS

PART 1 GENERAL

1.01 SECTION INCLUDES

- A. Horizontal/vertical WSHP.
- B. High-efficiency, dual-stage, horizontal/vertical WSHP.

1.02 RELATED REQUIREMENTS

- A. Section 22 10 05 - Plumbing Piping: Condensate drains.
- B. Section 23 05 93 - Testing, Adjusting, and Balancing for HVAC.
- C. Section 23 21 13 - Hydronic Piping.
- D. Section 23 21 14 - Hydronic Specialties.
- E. Section 23 21 23 - Hydronic Pumps.
- F. Section 23 31 00 - HVAC Ducts and Casings.
- G. Section 23 33 00 - Air Duct Accessories.
- H. Section 25 14 00 - Integrated Automation Local Control Units.
- I. Section 25 15 00 - Integrated Automation Software.
- J. Section 25 35 19 - Integrated Automation Control Valves.
- K. Section 26 05 83 - Wiring Connections.

1.03 ABBREVIATIONS AND ACRONYMS

- A. BACnet/IP: BACnet communications over internet protocol.
- B. BACnet/MSTP: BACnet communications over Master-Slave/Token-Pass protocol.
- C. BAS: Building Automation System; controls.
- D. BMS: Building Management System; controls.
- E. COP: Coefficient of Performance; applicable when heating.
- F. DDC: Direct Digital Control.
- G. DX: Direct expansion cooling or refrigeration equipment.
- H. EAT: Entering Air Temperature.
- I. ECM: Electronically Commutated Motor.
- J. EER: Energy Efficiency Ratio; applicable when cooling.
- K. EFT: Entering Fluid Temperature; coil or heat exchanger.
- L. EMS: Energy Management System; BAS or BMS add-on.
- M. EWT: Entering Water Temperature; coil or heat exchanger.
- N. HDPE: High Density Polyethylene.
- O. IAQ: Indoor Air Quality.
- P. LAT: Leaving Air Temperature.
- Q. LED: Light Emitting Diode.
- R. WSHP: Water-Source Heat Pump.

1.04 REFERENCE STANDARDS

- A. ASHRAE Std 52.2 - Method of Testing General Ventilation Air-Cleaning Devices for Removal Efficiency by Particle Size; 2017, with Addendum (2022).

- B. ASHRAE Std 90.1 I-P - Energy Standard for Buildings Except Low-Rise Residential Buildings; Most Recent Edition Adopted by Authority Having Jurisdiction, Including All Applicable Amendments and Supplements.
- C. ASHRAE Std 135 - A Data Communication Protocol for Building Automation and Control Networks; 2020, with Addendum (2024).
- D. ASHRAE Std 13256-1 - Water-Source Heat Pumps - Testing and Rating for Performance - Part 1: Water-to-Air and Brine-to-Air Heat Pumps; 2021.
- E. ASTM E84 - Standard Test Method for Surface Burning Characteristics of Building Materials; 2023d.
- F. UL 94 - Tests for Flammability of Plastic Materials for Parts in Devices and Appliances; Current Edition, Including All Revisions.
- G. UL 508 - Industrial Control Equipment; Current Edition, Including All Revisions.
- H. UL 723 - Standard for Test for Surface Burning Characteristics of Building Materials; Current Edition, Including All Revisions.
- I. UL 1995 - Heating and Cooling Equipment; Current Edition, Including All Revisions.

1.05 SUBMITTALS

- A. See Section 01 30 00 - Administrative Requirements for submittal procedures.
- B. Product Data: Provide drawings indicating dimensions, rough-in connections, and electrical characteristics and connection requirements.
- C. Manufacturer's Instructions: Include assembly instructions, support details, connection requirements, and start-up instructions.
- D. Sustainable Design Documentation: Submit manufacturer's product data on refrigerant used, showing compliance with specified requirements.
- E. Operation and Maintenance Data: Provide maintenance data, parts lists, controls, and accessories. Include trouble-shooting guide.
- F. Warranty Documentation: Submit manufacturer warranty and ensure that forms have been completed in Del Tech's name and registered with manufacturer.

1.06 WARRANTY

- A. See Section 01 78 00 - Closeout Submittals for additional warranty requirements.

PART 2 PRODUCTS

2.01 GENERAL HEAT PUMP FABRICATION REQUIREMENTS

- A. Energy Efficiency: ASHRAE Std 90.1 I-P EER and COP ratings, minimum.
- B. ASHRAE Std 13256-1, factory-assembled unit including safety-controls, accessories, filters, piping, cables, wires, and precharged with R-454B refrigerant prior to testing.
- C. Include marked terminal strip to interface field-mounted components, accessories, and thermostat.
- D. Comply with UL 1995; place service and caution labels on unit.
- E. Cabinet Assembly:
 - 1. Construct of zinc-coated, heavy-gauge, galvanized steel with exposed edges rounded.
 - 2. Finish: Factory apply electrostatic powder paint or baked enamel finish. Coordinate with DEDC, LLC for specific color finish requirements of console units or other units installed within occupied spaces.
 - 3. Provide access panels for inspection, cleaning, and servicing of refrigerant, controls, condensate drain pan, coil, and blower.
 - 4. Furnish 1-inch or 3-inch duct flange on open-discharge selections.

-
5. Interior Insulation: Minimum 1/2 inch thick, dual density, bonded glass fiber.
 6. Provide flame spread of less than 25, and smoke developed classification of less than 50 in compliance with ASTM E84 and UL 723.
 7. Sound and Noise Suppression:
 - a. Mechanical Rooms: 18 gauge, 0.05 inch, minimum.
 - b. Occupied Spaces: 16 gauge, 0.06 inch, minimum.
 - c. Compressor enclosure lined with 1/2 inch thick insulation.
 - d. Include vibration isolation between compressor and heat exchanger.
 - e. Include length-wise, unit base stiffeners.
 - f. Foam gasket sealant around compressor and end panel perimeter.
- F. Blower Section:
1. Draw-through, forward curved fan, constructed of corrosion-resistant, galvanized material and designed for efficient, quiet operation.
 2. Factory program for both soft start and constant flow output over static pressure range.
 3. Provide preinstalled neutral wire protection when required to support specified fan type.
 4. Motor to include thermal overload protection, quick disconnect plug, and permanently lubricated bearings.
 5. Belt-Driven Motor Requirements: Provide adjustable blower motor/sheave combination device based on indicated flow performance requirements.
 6. Variable Speed Control: Configure controller to maintain adjustable flow setpoint for modulating or speed-switched units.
 7. Fan Turndown: Design control features to allow fan speed reduction to adjustable 50 percent of its capacity when the zone set point temperature is satisfied or when unit runs in fan-only mode.
- G. Evaporator Section:
1. Internally finned, aluminum or copper tubes mechanically bonded to configured aluminum plate fin, corrosion inhibitor coated as indicated.
 2. Refrigerant Coil Distributor Assembly: Orifice style with round copper distributor tubes.
 3. Thermostatic Expansion Valve: Factory select and install for wide control range.
 4. Factory leak test to minimum 450 psi and pressure test to minimum 600 psi.
 5. Tubes: Size tubes consistent with coil capacity. Fabricate suction header from rounded copper pipe.
 6. Completely evacuate air and charge with proper column of refrigerant prior to shipment.
 7. Drain Pan:
 - a. Construct of ABS plastic, HDPE, stainless steel, or other corrosion-resistant material and frame rated in accordance with UL 94 when using polymers.
 - b. Slope on two planes to pitch condensate to drain connection.
 - c. Float Switch: UL 508, rated for protection against condensate overflow, controller connected.
- H. Compressor Section:
1. Provide rubber mounting devices located underneath compressor mounting base.
 2. Safety Interlocked Devices:
 - a. Thermal overload protection.
 - b. High pressure switch for protection against excessive discharge pressure.
 - c. Low pressure safety for protection against loss of refrigerant charge.
- I. Refrigerant Tubing Lines:
1. Tubing made of copper with service pressure ports on high- and low-pressure sides.
 2. Free from contaminants and conditions such as drilling fragments, dirt, and oil.
 3. Include drier, thermal expansion valve, and other related components.
 4. Freeze Protection: 30 degrees F, thermistor based.

-
5. Insulation: Evaporator and heat exchanger sides; minimum 3/8 inch thick elastomeric insulation.
- J. Refrigerant Load Control:
1. Hot-Gas Bypass: Provide to increase heat transfer efficiency at low temperatures.
 2. Hot-Gas Reheat Coil:
 - a. Humidity Control: Upgrade thermostat to include humidity sensor tied to unit controller for integral dehumidification control.
 - b. Coil Assembly: Aluminum or copper tubes mechanically expanded into evenly spaced aluminum fins.
 - c. Coil Testing: Proof test at minimum of 1.5 times maximum operating pressure, then leak test at maximum operating pressure.
 3. Hot-Water Generator:
 - a. Secondary coil or heat exchanger, reversing valve, and accessories.
 - b. Storage: Interconnect to existing water heater or external storage tanks.
- K. Water-to-Refrigerant Heat Exchanger:
1. Coaxial Type: Provide aluminum or copper tube and fins.
 2. Brazed-Plate Type: Stainless steel, with bidirectional liquid line filter drier.
 3. Insulate heat exchanger, water lines, and refrigerant suction lines for prevention of condensation at temperatures below 60 degrees F.
 4. Provide rubber isolation to heat exchanging device for enhanced sound attenuation.
 5. Freeze Protection: 35 degrees F by thermistor sensing.
 6. Minimum Working Pressure: 400 psi water side, 600 psi DX side.
 7. End Connections: Copper NPT. Provide flow shut-off ball valves.
 8. Accessories:
 - a. Strainer, PT test plug, and flow regulator.
 - b. Unit-controlled, return-water-side solenoid valve.
- L. Waterside Economizer Section:
1. Thermostat-controlled, metered, pre-piped return air coil with 3-way valve assembly tied and coordinated by unit controller.
 2. Provide assembly factory-installed or shipped loose for field installation as indicated.
 3. Performance Requirements: As indicated on drawings.
 4. Air-to-Water Hydronic Coil:
 - a. Aluminum or copper tubes and aluminum plate fin combination.
 - b. Accessible, cleanable, dual sloped, noncorrosive drain pan.
 - c. Leak test at maximum operating pressure.
 - d. Factory proof test at minimum 1.5 times maximum operating pressure.
 5. Modulating or position-adjusted control valve to engage and control coil at listed EWT.
- M. Filter Section:
1. ASHRAE Std 52.2, minimum efficiency reported value or MERV listing.
 2. Filter Box: Provide field-installed return duct-mounted filter housing with side access.
- N. Electrical:
1. Provide factory-installed phase loss safety device for 3-phase units.
 2. Configure unit for single point connection, include terminal for field-installed components.
 3. Include separate holes and knockouts with plastic ferrules for respective electrical and controls wiring.
- O. Unit Controls:
1. DDC:
 - a. Tested to monitor and handle sequencing functions and other operational modes using field-mounted thermostat and other sensors.
 - b. Coordination and Sequencing:

- 1) Internal Devices: Include compressors, blower, sensors, switches, valves, safeties, other components.
 - 2) Field-Installed Devices: Solenoid valves, thermostat, EWT sensors, LWT sensors, load-pump contact, source pump contact, and other devices required for operation.
 - 3) Safeties: At minimum include anti-short-cycle compressor protection, condensate overflow, refrigerant high pressure, refrigerant low pressure, loss-of-charge, refrigerant freeze protection, and freezestat.
2. Thermostat:
- a. Field mounted and wired, tied into prewired control-interface terminals.
 - b. Smart Thermostat:
 - 1) BAS- or BMS-linked programmable thermostat; see Section 25 14 00.
 - c. Programmable Thermostat:
 - 1) Electro-mechanical type with key- or pushbutton-operated display.
 - 2) Programmable occupied/unoccupied weekly and holiday schedule.
 - d. Nonprogrammable Thermostat:
 - 1) Electro-mechanical type with key- or pushbutton-operated display.
 - 2) User-configurable, precoded options aligned with equipment functions.
 - e. Thermostat: Single-gang-box-mounted platinum or thermistor.
 - 1) Local Interface to Include:
 - (a) Filter maintenance indicating status.

2.02 HORIZONTAL/VERTICAL WATER-SOURCE HEAT PUMP

- A. Cabinet Air Discharge Configuration: As indicated on drawings.
- B. Compressor: Hermetically sealed, single-stage rotary or single-stage scroll type.
- C. Water-to-Refrigerant Heat Exchanger: Coaxial type.
- D. Blower Section: Provide high-static, permanent split capacitor (PSC) motor fan type.
- E. Filter Section: Include MERV 4 rated air filter.
- F. Electrical: 277 VAC, 1 phase, 60 Hz with field-installed disconnect switch.
- G. Accessories: Provide ball valves, hoses, and Y-strainer.
- H. Unit Controls: Factory-supplied DDC with thermostat.
 1. BAS, SCADA, or other Integrated Automation Link: BACnet MS/TP in accordance with ASHRAE Std 135.
 2. Control Valve: Return-installed, position-adjusted, ball type; see Section 25 35 19.

2.03 HIGH-EFFICIENCY, DUAL-STAGE, HORIZONTAL/VERTICAL WATER-SOURCE HEAT PUMP

- A. Cabinet Air Discharge Configuration: As indicated on drawings.
- B. Compressors: High-efficiency, hermetically sealed, dual-stage scroll type.
- C. Water-to-Refrigerant Heat Exchanger: Coaxial type with factory-supplied water economizer.
- D. Blower Section: Provide static or flow-controlled, variable-speed, belt-driven fan motor.
- E. Filter Section: Include MERV 13 rated air filter.
- F. Electrical: 277 VAC, 1 phase, 60 Hz with factory-provided disconnect switch.
- G. Accessories: Provide ball valves, hoses, and Y-strainer.
- H. Unit Controls: Factory-installed DDC with thermostat; see Section 25 14 00.
 1. BAS, SCADA, or other Integrated Automation Link: BACnet MS/TP in accordance with ASHRAE Std 135.
 2. Control Valve: Return-installed, modulating, pressure-independent ball type; see Section 25 35 19.

2.04 HOSE KITS, VALVES, FITTINGS, AND ACCESORIES

- A. Manufacturers:
 - 1. Griswold Controls: www.griswoldcontrols.com/#sle.
 - 2. Hays Fluid Controls: www.haysfluidcontrols.com/#sle.
 - 3. IMI Flow Design, a brand of IMI Hydronic Engineering Division of IMI plc: www.flowdesign.com/#sle.
 - 4. Substitutions: See Section 01 60 00 - Product Requirements.
- B. Hoses:
 - 1. Provide hoses for units for connection to main water supply and return headers.
 - 2. Length: 2 feet.
 - 3. Material: Braided stainless steel rated to minimum 400 psi at 265 degrees F.
- C. Ball Valves:
 - 1. Brass body for shutoff and hydronic balancing.
 - 2. Provide pressure/temperature ports.
 - 3. Provide with balancing valves.
- D. Y Strainers:
 - 1. Bronze body.
 - 2. "Y" type configuration with brass cap.
 - 3. Maximum Operating Pressure: Minimum 450 psi.
 - 4. Screen: Stainless steel.

PART 3 EXECUTION

3.01 INSTALLATION

- A. Install in accordance with manufacturer's instructions.
- B. Suspended Units: Suspend from structure with threaded steel rods and 0.25 inch minimum static deflection rubber-in-shear vibration isolators and seismic restraints.
- C. Ductwork:
 - 1. Provide as indicated on drawings; see Sections 23 31 00 and 23 33 00.
- D. Pumps: Connect to system or booster pump in accordance with Section 23 21 23.
- E. Electrical: Provide equipment raceway, wiring, and cables; see Section 26 05 83.
- F. Coordinate installation of units with architectural, mechanical, and electrical work.
- G. On water coils, provide shut-off valve on supply line and balancing valve on return line. Provide manual air vents at high points complete with stop valve.
- H. Install wall-mounted thermostats, humidistats, and switch controls in electrical outlet boxes at heights to match lighting controls. Provide thermal break barrier for outdoor walls.

3.02 CONNECTIONS

- A. Connect supply/return piping from heat pump to appropriate water source piping; see Section 23 21 13. Complete end connections with unions and shut-off valves; see Section 23 21 14.
- B. Connect condensate drain pan to indirect waste connection with P-trap of adequate depth to seal against fan pressure; see Section 22 10 05.
- C. Install cleanouts at each directional change in piping.
- D. Connect supply/return air ducts with flexible connectors; see Section 23 33 00.
- E. Installation of piping adjacent to heat pump to allow for maintenance and service.
- F. Field Install all electrical devices provided by the heat pump manufacturer not specified to be factory-installed.

3.03 SYSTEM STARTUP

- A. Provide manufacturer's field representative to perform systems startup; see Section 23 05 93.
- B. Prepare and start equipment and systems in accordance with manufacturers' instructions and recommendations.
- C. Adjust for proper operation within manufacturer's published tolerances.

3.04 FIELD QUALITY CONTROL

- A. See Section 01 40 00 - Quality Requirements for additional requirements.
- B. Provide manufacturer's field representative to test, inspect, instruct, and observe.
- C. Inspect for and remove blocks, shipping bolts, and tie-down straps.
- D. Test the heat pumps for performance compliance upon completion of the installation and energization of all electrical circuitry.
- E. Operational Test: Start units to confirm unit operation and motor rotation.
- F. Controls and Safety Switches: Test, adjust, and replace damaged/malfunctioning controls and equipment.
- G. Coordinate BAS, BMS, or Integrated Automation linking between unit controller(s) and remote front-end interface; see Section 25 15 00.
- H. Malfunctioning Units: Remove, replace, and retest as specified above.

3.05 CLOSEOUT ACTIVITIES

- A. See Section 01 78 00 - Closeout Submittals for closeout submittals.
- B. See Section 01 79 00 - Demonstration and Training for additional requirements.
- C. Demonstrate proper operation of equipment to the designated representative of the Del Tech.
- D. Demonstration: Demonstrate operation of system to Del Tech personnel.
 - 1. Use operation and maintenance data as reference during demonstration.
 - 2. Conduct walking tour of project.
 - 3. Briefly describe function, operation, and maintenance of each component.
- E. Training: Train Del Tech's personnel on operation and maintenance of system.
 - 1. Use operation and maintenance manual as training reference, supplemented with additional training materials as required.
 - 2. Provide minimum of two hours of training.

END OF SECTION

NOT FOR BIDDING

This page intentionally left blank

**SECTION 26 05 05
SELECTIVE DEMOLITION FOR ELECTRICAL**

PART 3 EXECUTION

1.01 EXAMINATION

- A. Verify that abandoned wiring and equipment serve only abandoned facilities.
- B. Demolition drawings are based on casual field observation and existing record documents.
- C. Report discrepancies to DEDC, LLC before disturbing existing installation.
- D. Beginning of demolition means installer accepts existing conditions.

1.02 PREPARATION

- A. Disconnect electrical systems in walls, floors, and ceilings to be removed.
- B. Coordinate utility service outages with utility company.
- C. Provide temporary wiring and connections to maintain existing systems in service during construction. When work must be performed on energized equipment or circuits, use personnel experienced in such operations.
- D. Existing Electrical Service: Maintain existing system in service until new system is complete and ready for service. Disable system only to make switchovers and connections. Minimize outage duration.
- E. Existing Telephone System: Maintain existing system in service until new system is complete and ready for service. Disable system only to make switchovers and connections. Minimize outage duration.
 - 1. Notify Del Tech at least 24 hours before partially or completely disabling system.

1.03 DEMOLITION AND EXTENSION OF EXISTING ELECTRICAL WORK

- A. Remove, relocate, and extend existing installations to accommodate new construction.
- B. Remove abandoned wiring to source of supply.
- C. Remove exposed abandoned conduit, including abandoned conduit above accessible ceiling finishes. Cut conduit flush with walls and floors, and patch surfaces.
- D. Disconnect abandoned outlets and remove devices. Remove abandoned outlets if conduit servicing them is abandoned and removed. Provide blank cover for abandoned outlets that are not removed.
- E. Disconnect and remove abandoned luminaires. Remove brackets, stems, hangers, and other accessories.
- F. Repair adjacent construction and finishes damaged during demolition and extension work.
- G. Maintain access to existing electrical installations that remain active. Modify installation or provide access panel as appropriate.

1.04 CLEANING AND REPAIR

- A. See Section 01 74 19 - Construction Waste Management and Disposal for additional requirements.
- B. Clean and repair existing materials and equipment that remain or that are to be reused.
- C. Panelboards: Clean exposed surfaces and check tightness of electrical connections. Replace damaged circuit breakers and provide closure plates for vacant positions. Provide typed circuit directory showing revised circuiting arrangement.

END OF SECTION

NOT FOR BIDDING

This page intentionally left blank

SECTION 26 05 19
LOW-VOLTAGE ELECTRICAL POWER CONDUCTORS AND CABLES

PART 1 GENERAL

1.01 RELATED REQUIREMENTS

- A. Section 07 84 00 - Firestopping.
- B. Section 26 05 05 - Selective Demolition for Electrical: Disconnection, removal, and/or extension of existing electrical conductors and cables.
- C. Section 26 05 53 - Identification for Electrical Systems: Identification products and requirements.
- D. Section 28 46 00 - Fire Detection and Alarm: Fire alarm system conductors and cables.

1.02 REFERENCE STANDARDS

- A. ASTM B3 - Standard Specification for Soft or Annealed Copper Wire, 2013 (Reapproved 2018).
- B. ASTM B8 - Standard Specification for Concentric-Lay-Stranded Copper Conductors, Hard, Medium-Hard, or Soft; 2023.
- C. ASTM B33 - Standard Specification for Tin-Coated Soft or Annealed Copper Wire for Electrical Purposes; 2010, with Editorial Revision (2020).
- D. ASTM B787/B787M - Standard Specification for 19 Wire Combination Unilay-Stranded Copper Conductors for Subsequent Insulation; 2004 (Reapproved 2020).
- E. ASTM B800 - Standard Specification for 8000 Series Aluminum Alloy Wire for Electrical Purposes - Annealed and Intermediate Temper; 2005 (Reapproved 2021).
- F. ASTM B801 - Standard Specification for Concentric-Lay-Stranded Conductors of 8000 Series Aluminum Alloy for Subsequent Covering or Insulation; 2018 (Reapproved 2023).
- G. ASTM D3005 - Standard Specification for Low-Temperature Resistant Vinyl Chloride Plastic Pressure-Sensitive Electrical Insulating Tape; 2017.
- H. NECA 1 - Standard for Good Workmanship in Electrical Construction; 2023.
- I. NECA 104 - Standard for Installing Aluminum Building Wire and Cable; 2012.
- J. NECA 120 - Standard for Installing Armored Cable (AC) and Type Metal-Clad (MC) Cable; 2018.
- K. NEMA WC 70 - Power Cables Rated 2000 Volts or Less for the Distribution of Electrical Energy; 2021.
- L. NFPA 70 - National Electrical Code; Most Recent Edition Adopted by Authority Having Jurisdiction, Including All Applicable Amendments and Supplements.
- M. UL 44 - Thermoset-Insulated Wires and Cables; Current Edition, Including All Revisions.
- N. UL 83 - Thermoplastic-Insulated Wires and Cables; Current Edition, Including All Revisions.
- O. UL 267 - Outline of Investigation for Wire-Pulling Compounds; Current Edition, Including All Revisions.
- P. UL 486A-486B - Wire Connectors; Current Edition, Including All Revisions.
- Q. UL 486C - Splicing Wire Connectors; Current Edition, Including All Revisions.
- R. UL 486D - Sealed Wire Connector Systems; Current Edition, Including All Revisions.
- S. UL 510 - Polyvinyl Chloride, Polyethylene, and Rubber Insulating Tape; Current Edition, Including All Revisions.
- T. UL 1569 - Metal-Clad Cables; Current Edition, Including All Revisions.

1.03 ADMINISTRATIVE REQUIREMENTS

- A. Coordination:
 - 1. Coordinate sizes of raceways, boxes, and equipment enclosures installed under other sections with the actual conductors to be installed, including adjustments for conductor sizes increased for voltage drop.
 - 2. Coordinate with electrical equipment installed under other sections to provide terminations suitable for use with the conductors to be installed.
 - 3. Notify DEDC, LLC of any conflicts with or deviations from Contract Documents. Obtain direction before proceeding with work.

1.04 SUBMITTALS

- A. See Section 01 30 00 - Administrative Requirements, for submittal procedures.
- B. Product Data: Provide manufacturer's standard catalog pages and data sheets for conductors and cables, including detailed information on materials, construction, ratings, listings, and available sizes, configurations, and stranding.

1.05 QUALITY ASSURANCE

- A. Comply with requirements of NFPA 70.

1.06 DELIVERY, STORAGE, AND HANDLING

- A. Receive, inspect, handle, and store conductors and cables in accordance with manufacturer's instructions.

PART 2 PRODUCTS

2.01 CONDUCTOR AND CABLE APPLICATIONS

- A. Do not use conductors and cables for applications other than as permitted by NFPA 70 and product listing.
- B. Provide single conductor building wire installed in suitable raceway unless otherwise indicated, permitted, or required.
- C. Nonmetallic-sheathed cable is not permitted.
- D. Underground feeder and branch-circuit cable is not permitted.
- E. Service entrance cable is not permitted.
- F. Armored cable is not permitted.
- G. Metal-clad cable is permitted only as follows:
 - 1. Where not otherwise restricted, may be used:
 - a. Where concealed above accessible ceilings for final connections from junction boxes to luminaires.
 - 1) Maximum Length: 6 feet.
 - b. Where concealed in hollow stud walls, above accessible ceilings, and under raised floors for branch circuits up to 20 A.
 - 1) Exception: Provide single conductor building wire in raceway for circuit homerun from first outlet to panelboard.
 - 2. In addition to other applicable restrictions, may not be used:
 - a. Where exposed to damage.
 - b. For damp, wet, or corrosive locations, unless provided with a PVC jacket listed as suitable for those locations.
- H. Manufactured wiring systems are not permitted.

2.02 CONDUCTOR AND CABLE GENERAL REQUIREMENTS

- A. Provide products that comply with requirements of NFPA 70.

- B. Provide products listed, classified, and labeled as suitable for the purpose intended.
- C. Unless specifically indicated to be excluded, provide all required conduit, boxes, wiring, connectors, etc. as required for a complete operating system.
- D. Comply with NEMA WC 70.
- E. Thermoplastic-Insulated Conductors and Cables: Listed and labeled as complying with UL 83.
- F. Thermoset-Insulated Conductors and Cables: Listed and labeled as complying with UL 44.
- G. Conductor Material:
 - 1. Provide copper conductors except where aluminum conductors are specifically indicated or permitted for substitution. Conductor sizes indicated are based on copper unless specifically indicated as aluminum. Conductors designated with the abbreviation "AL" indicate aluminum.
 - a. Substitution of aluminum conductors for copper is permitted, when approved by Del Tech and authority having jurisdiction, only for the following:
 - 1) Services: Copper conductors size 1/0 AWG and larger.
 - 2) Feeders: Copper conductors size 1/0 AWG and larger.
 - b. Where aluminum conductors are substituted for copper, comply with the following:
 - 1) Size aluminum conductors to provide, when compared to copper sizes indicated, equivalent or greater ampacity and equivalent or less voltage drop.
 - 2) Increase size of raceways, boxes, wiring gutters, enclosures, etc. as required to accommodate aluminum conductors.
 - 3) Equip electrical distribution equipment with compression lugs for terminating aluminum conductors.
 - 2. Copper Conductors: Soft drawn annealed, 93 percent conductivity, uncoated copper conductors complying with ASTM B3, ASTM B8, or ASTM B787/B787M unless otherwise indicated.
 - 3. Tinned Copper Conductors: Comply with ASTM B33.
 - 4. Aluminum Conductors (only where specifically indicated or permitted for substitution): AA-8000 series aluminum alloy conductors recognized by ASTM B800 and compact stranded in accordance with ASTM B801 unless otherwise indicated.
- H. Minimum Conductor Size:
 - 1. Branch Circuits: 12 AWG.
 - a. Exceptions:
 - 1) 20 A, 120 V circuits longer than 75 feet: 10 AWG, for voltage drop.
 - 2) 20 A, 120 V circuits longer than 150 feet: 8 AWG, for voltage drop.
 - 3) 20 A, 277 V circuits longer than 150 feet: 10 AWG, for voltage drop.
 - 2. Control Circuits: 14 AWG.
- I. Where conductor size is not indicated, size to comply with NFPA 70 but not less than applicable minimum size requirements specified.
- J. Conductor Color Coding:
 - 1. Color code conductors as indicated unless otherwise required by the authority having jurisdiction. Maintain consistent color coding throughout project.
 - 2. Color Coding Method: Integrally colored insulation.
 - a. Conductors size 4 AWG and larger may have black insulation color coded using vinyl color coding electrical tape.
 - 3. Color Code:
 - a. 480Y/277 V, 3 Phase, 4 Wire System:
 - 1) Phase A: Brown.
 - 2) Phase B: Orange.
 - 3) Phase C: Yellow.

- 4) Neutral/Grounded: Gray.
- b. 208Y/120 V, 3 Phase, 4 Wire System:
 - 1) Phase A: Black.
 - 2) Phase B: Red.
 - 3) Phase C: Blue.
 - 4) Neutral/Grounded: White.
- c. Equipment Ground, All Systems: Green.
- d. For modifications or additions to existing wiring systems, comply with existing color code when existing code complies with NFPA 70 and is approved by the authority having jurisdiction.
- e. For control circuits, comply with manufacturer's recommended color code.

2.03 SINGLE CONDUCTOR BUILDING WIRE

- A. Description: Single conductor insulated wire.
- B. Conductor Stranding:
 - 1. Feeders and Branch Circuits:
 - a. Size 10 AWG and Smaller: Solid.
 - b. Size 8 AWG and Larger: Stranded.
- C. Insulation Voltage Rating: 600 V.
- D. Insulation:
 - 1. Copper Building Wire: Type THHN/THWN or THHN/THWN-2, except as indicated below.

2.04 METAL-CLAD CABLE

- A. Description: NFPA 70, Type MC cable listed and labeled as complying with UL 1569, and listed for use in classified firestop systems to be used.
- B. Conductor Stranding:
 - 1. Size 10 AWG and Smaller: Solid.
 - 2. Size 8 AWG and Larger: Stranded.
- C. Insulation Voltage Rating: 600 V.
- D. Insulation: Type THHN, THHN/THWN, or THHN/THWN-2.
- E. Grounding: Full-size integral equipment grounding conductor.
- F. Armor: Steel, interlocked tape.
- G. Provide PVC jacket applied over cable armor.

2.05 WIRING CONNECTORS

- A. Description: Wiring connectors appropriate for the application, suitable for use with the conductors to be connected, and listed as complying with UL 486A-486B or UL 486C as applicable.
- B. Wiring Connectors for Splices and Taps:
 - 1. Copper Conductors Size 8 AWG and Smaller: Use twist-on insulated spring connectors.
 - 2. Copper Conductors Size 6 AWG and Larger: Use mechanical connectors or compression connectors.
 - 3. Connectors for Aluminum Conductors: Use compression connectors.
- C. Twist-on Insulated Spring Connectors: Rated 600 V, 221 degrees F for standard applications and 302 degrees F for high temperature applications; pre-filled with sealant and listed as complying with UL 486D for damp and wet locations.
- D. Mechanical Connectors: Provide bolted type or set-screw type.
- E. Compression Connectors: Provide circumferential type or hex type crimp configuration.

2.06 ACCESSORIES

- A. Electrical Tape:
 - 1. Vinyl Color Coding Electrical Tape: Integrally colored to match color code indicated; listed as complying with UL 510; minimum thickness of 7 mil; resistant to abrasion, corrosion, and sunlight; suitable for continuous temperature environment up to 221 degrees F.
 - 2. Vinyl Insulating Electrical Tape: Complying with ASTM D3005 and listed as complying with UL 510; minimum thickness of 7 mil; resistant to abrasion, corrosion, and sunlight; conformable for application down to 0 degrees F and suitable for continuous temperature environment up to 221 degrees F.
- B. Oxide Inhibiting Compound: Listed; suitable for use with the conductors or cables to be installed.
- C. Wire Pulling Lubricant:
 - 1. Listed and labeled as complying with UL 267.
 - 2. Suitable for use with conductors/cables and associated insulation/jackets to be installed.
 - 3. Suitable for use at installation temperature.
- D. Cable Ties: Material and tensile strength rating suitable for application.

PART 3 EXECUTION

3.01 EXAMINATION

- A. Verify that interior of building has been protected from weather.
- B. Verify that work likely to damage wire and cable has been completed.
- C. Verify that raceways, boxes, and equipment enclosures are installed and are properly sized to accommodate conductors and cables in accordance with NFPA 70.
- D. Verify that field measurements are as indicated.
- E. Verify that conditions are satisfactory for installation prior to starting work.

3.02 INSTALLATION

- A. Circuiting Requirements:
 - 1. Unless dimensioned, circuit routing indicated is diagrammatic.
- B. Install products in accordance with manufacturer's instructions.
- C. Perform work in accordance with NECA 1 (general workmanship).
- D. Install aluminum conductors in accordance with NECA 104.
- E. Install metal clad cable (Type MC) in accordance with NECA 120.
- F. Installation in Raceway:
 - 1. Tape ends of conductors and cables to prevent infiltration of moisture and other contaminants.
 - 2. Pull all conductors and cables together into raceway at same time.
 - 3. Do not damage conductors and cables or exceed manufacturer's recommended maximum pulling tension and sidewall pressure.
 - 4. Use suitable wire pulling lubricant where necessary, except when lubricant is not recommended by the manufacturer.
- G. Paralleled Conductors: Install conductors of the same length and terminate in the same manner.
- H. Secure and support conductors and cables in accordance with NFPA 70 using suitable supports and methods approved by the authority having jurisdiction. Provide independent support from building structure. Do not provide support from raceways, piping, ductwork, or other systems.

- I. Terminate cables using suitable fittings.
 - 1. Metal-Clad Cable (Type MC):
 - a. Use listed fittings.
 - b. Cut cable armor only using specialized tools to prevent damaging conductors or insulation. Do not use hacksaw or wire cutters to cut armor.
- J. Install conductors with a minimum of 12 inches of slack at each outlet.
- K. Neatly train and bundle conductors inside boxes, wireways, panelboards and other equipment enclosures.
- L. Group or otherwise identify neutral/grounded conductors with associated ungrounded conductors inside enclosures in accordance with NFPA 70.
- M. Make wiring connections using specified wiring connectors.
 - 1. Make splices and taps only in accessible boxes. Do not pull splices into raceways or make splices in conduit bodies or wiring gutters.
 - 2. Remove appropriate amount of conductor insulation for making connections without cutting, nicking or damaging conductors.
 - 3. Do not remove conductor strands to facilitate insertion into connector.
 - 4. Clean contact surfaces on conductors and connectors to suitably remove corrosion, oxides, and other contaminants. Do not use wire brush on plated connector surfaces.
 - 5. Connections for Aluminum Conductors: Fill connectors with oxide inhibiting compound where not pre-filled by manufacturer.
 - 6. Mechanical Connectors: Secure connections according to manufacturer's recommended torque settings.
 - 7. Compression Connectors: Secure connections using manufacturer's recommended tools and dies.
- N. Insulate splices and taps that are made with uninsulated connectors using methods suitable for the application, with insulation and mechanical strength at least equivalent to unspliced conductors.
- O. Insulate ends of spare conductors using vinyl insulating electrical tape.
- P. Field-Applied Color Coding: Where vinyl color coding electrical tape is used in lieu of integrally colored insulation as permitted in Part 2 under "Color Coding", apply half overlapping turns of tape at each termination and at each location conductors are accessible.
- Q. Install firestopping to preserve fire resistance rating of partitions and other elements, using materials and methods specified in Section 07 84 00.
- R. Unless specifically indicated to be excluded, provide final connections to all equipment and devices, including those furnished by others, as required for a complete operating system.

3.03 FIELD QUALITY CONTROL

- A. See Section 01 40 00 - Quality Requirements, for additional requirements.
- B. Correct deficiencies and replace damaged or defective conductors and cables.

END OF SECTION

SECTION 26 05 26
GROUNDING AND BONDING FOR ELECTRICAL SYSTEMS

PART 1 GENERAL

1.01 RELATED REQUIREMENTS

- A. Section 26 05 19 - Low-Voltage Electrical Power Conductors and Cables: Additional requirements for conductors for grounding and bonding, including conductor color coding.
- B. Section 26 05 53 - Identification for Electrical Systems: Identification products and requirements.

1.02 REFERENCE STANDARDS

- A. NFPA 70 - National Electrical Code; Most Recent Edition Adopted by Authority Having Jurisdiction, Including All Applicable Amendments and Supplements.
- B. UL 467 - Grounding and Bonding Equipment; Current Edition, Including All Revisions.

PART 2 PRODUCTS

2.01 GROUNDING AND BONDING REQUIREMENTS

- A. Do not use products for applications other than as permitted by NFPA 70 and product listing.
- B. Unless specifically indicated to be excluded, provide all required components, conductors, connectors, conduit, boxes, fittings, supports, accessories, etc. as necessary for a complete grounding and bonding system.
- C. Where conductor size is not indicated, size to comply with NFPA 70 but not less than applicable minimum size requirements specified.

2.02 GROUNDING AND BONDING COMPONENTS

- A. General Requirements:
 - 1. Provide products listed, classified, and labeled as suitable for the purpose intended.
 - 2. Provide products listed and labeled as complying with UL 467 where applicable.
- B. Conductors for Grounding and Bonding, in Addition to Requirements of Section 26 05 26:
 - 1. Use insulated copper conductors unless otherwise indicated.
 - a. Exceptions:
 - 1) Use bare copper conductors where installed underground in direct contact with earth.
 - 2) Use bare copper conductors where directly encased in concrete (not in raceway).
- C. Connectors for Grounding and Bonding:
 - 1. Description: Connectors appropriate for the application and suitable for the conductors and items to be connected; listed and labeled as complying with UL 467.
 - 2. Unless otherwise indicated, use exothermic welded connections for underground, concealed and other inaccessible connections.
 - 3. Unless otherwise indicated, use mechanical connectors, compression connectors, or exothermic welded connections for accessible connections.

END OF SECTION

NOT FOR BIDDING

This page intentionally left blank

**SECTION 26 05 29
HANGERS AND SUPPORTS FOR ELECTRICAL SYSTEMS**

PART 2 PRODUCTS

1.01 SUPPORT AND ATTACHMENT COMPONENTS

- A. General Requirements:
1. Comply with the following. Where requirements differ, comply with most stringent.
 - a. NFPA 70.
 - b. Requirements of authorities having jurisdiction.
 2. Provide required hangers, supports, anchors, fasteners, fittings, accessories, and hardware as necessary for complete installation of electrical work.
 3. Provide products listed, classified, and labeled as suitable for purpose intended, where applicable.
 4. Where support and attachment component types and sizes are not indicated, select in accordance with manufacturer's application criteria as required for load to be supported with minimum safety factor of _____. Include consideration for vibration, equipment operation, and shock loads where applicable.
 5. Do not use products for applications other than as permitted by NFPA 70 and product listing.
 6. Steel Components: Use corrosion-resistant materials suitable for environment where installed.
 - a. Zinc-Plated Steel: Electroplated in accordance with ASTM B633.
 - b. Galvanized Steel: Hot-dip galvanized after fabrication in accordance with ASTM A123/A123M or ASTM A153/A153M.
- B. Conduit and Cable Supports: Straps and clamps suitable for conduit or cable to be supported.
1. Conduit Straps: One-hole or two-hole type; steel or malleable iron.
 2. Conduit Clamps: Bolted type unless otherwise indicated.
- C. Outlet Box Supports: Hangers and brackets suitable for boxes to be supported.
- D. Metal Channel/Strut Framing Systems:
1. Description: Factory-fabricated, continuous-slot, metal channel/strut and associated fittings, accessories, and hardware required for field assembly of supports.
 2. Comply with NFPA 70.
- E. Hanger Rods: Threaded, zinc-plated steel unless otherwise indicated.
- F. Anchors and Fasteners:
1. Unless otherwise indicated and where not otherwise restricted, use anchor and fastener types indicated for specified applications.

END OF SECTION

NOT FOR BIDDING

This page intentionally left blank

**SECTION 26 05 33.13
CONDUIT FOR ELECTRICAL SYSTEMS**

PART 1 GENERAL

1.01 SECTION INCLUDES

- A. Galvanized steel rigid metal conduit (RMC).
- B. Galvanized steel electrical metallic tubing (EMT).
- C. Stainless steel electrical metallic tubing (EMT).
- D. Aluminum electrical metallic tubing (EMT).
- E. Rigid polyvinyl chloride (PVC) conduit.

1.02 RELATED REQUIREMENTS

- A. Section 07 84 00 - Firestopping.
- B. Section 26 05 19 - Low-Voltage Electrical Power Conductors and Cables: Cable assemblies consisting of conductors protected by integral metal armor.
- C. Section 26 05 26 - Grounding and Bonding for Electrical Systems.
- D. Section 26 05 29 - Hangers and Supports for Electrical Systems.
- E. Section 26 05 33.16 - Boxes for Electrical Systems.

1.03 REFERENCE STANDARDS

- A. ANSI C80.1 - American National Standard for Electrical Rigid Steel Conduit (ERSC); 2020.
- B. ANSI C80.3 - American National Standard for Electrical Metallic Tubing -- Steel (EMT-S); 2020.
- C. NECA 1 - Standard for Good Workmanship in Electrical Construction; 2023.
- D. NECA 101 - Standard for Installing Steel Conduits (Rigid, IMC, EMT); 2020.
- E. NECA 111 - Standard for Installing Nonmetallic Raceways (RNC, ENT, LFNC); 2017.
- F. NEMA FB 1 - Fittings, Cast Metal Boxes, and Conduit Bodies for Conduit, Electrical Metallic Tubing, and Cable; 2014.
- G. NEMA TC 2 - Electrical Polyvinyl Chloride (PVC) Conduit; 2020.
- H. NEMA TC 3 - Polyvinyl Chloride (PVC) Fittings for Use with Rigid PVC Conduit and Tubing; 2021.
- I. NFPA 70 - National Electrical Code; Most Recent Edition Adopted by Authority Having Jurisdiction, including All Applicable Amendments and Supplements.
- J. UL 6 - Electrical Rigid Metal Conduit-Steel; Current Edition, Including All Revisions.
- K. UL 514B - Conduit, Tubing, and Cable Fittings; Current Edition, Including All Revisions.
- L. UL 651 - Schedule 40, 80, Type EB and A Rigid PVC Conduit and Fittings; Current Edition, Including All Revisions.
- M. UL 797 - Electrical Metallic Tubing-Steel; Current Edition, Including All Revisions.
- N. UL 797A - Electrical Metallic Tubing - Aluminum and Stainless Steel; Current Edition, Including All Revisions.
- O. UL 2419 - Outline of Investigation for Electrically Conductive Corrosion Resistant Compounds; Current Edition, Including All Revisions.

1.04 ADMINISTRATIVE REQUIREMENTS

- A. Coordination:
 - 1. Coordinate minimum sizes of conduits with actual type and quantity of conductors to be installed, including adjustments for conductor sizes increased for voltage drop.

2. Coordinate arrangement of conduits with structural members, ductwork, piping, equipment, and other potential conflicts.
 3. Verify exact conduit termination locations required for boxes, enclosures, and equipment.
 4. Coordinate work to provide roof penetrations that preserve integrity of roofing system and do not void roof warranty.
 5. Notify DEDC, LLC of conflicts with or deviations from Contract Documents. Obtain direction before proceeding with work.
- B. Sequencing:
1. Do not begin installation of conductors and cables until installation of conduit between termination points is complete.

PART 2 PRODUCTS

2.01 CONDUIT APPLICATIONS

- A. Do not use conduit and associated fittings for applications other than as permitted by NFPA 70, manufacturer's instructions, and product listing.

2.02 CONDUIT - GENERAL REQUIREMENTS

- A. Comply with NFPA 70.
- B. Provide conduit, fittings, supports, and accessories required for complete raceway system.
- C. Provide products listed, classified, and labeled as suitable for purpose intended.
- D. Minimum Conduit Size, Unless Otherwise Indicated:
1. Branch Circuits: 3/4-inch trade size.
 2. Branch Circuit Homeruns: 3/4-inch trade size.
 3. Underground, Interior: 3/4-inch trade size.
 4. Underground, Exterior: 1-inch trade size.
- E. Where conduit size is not indicated, size to comply with NFPA 70 but not less than applicable minimum size requirements specified.

2.03 GALVANIZED STEEL RIGID METAL CONDUIT (RMC)

- A. Description: NFPA 70, Type RMC galvanized steel rigid metal conduit complying with ANSI C80.1 and listed and labeled as complying with UL 6.
- B. Fittings:
1. Nonhazardous Locations: Use fittings complying with NEMA FB 1 and listed and labeled as complying with UL 514B or UL 6.
 2. Material: Use steel or malleable iron.
 3. Connectors and Couplings: Use threaded type fittings only. Threadless fittings, including set screw and compression/gland types, are not permitted.

2.04 GALVANIZED STEEL ELECTRICAL METALLIC TUBING (EMT)

- A. Description: NFPA 70, Type EMT galvanized steel electrical metallic tubing complying with ANSI C80.3 and listed and labeled as complying with UL 797.
- B. Fittings:
1. Description: Fittings complying with NEMA FB 1 and listed and labeled as complying with UL 514B.
 2. Material: Use steel or malleable iron.
 3. Connectors and Couplings: Use compression/gland or set-screw type.
 - a. Do not use indenter type connectors and couplings.

2.05 STAINLESS STEEL ELECTRICAL METALLIC TUBING (EMT)

- A. Description: NFPA 70, Type EMT stainless steel electrical metallic tubing complying with ANSI C80.3 and listed and labeled as complying with UL 797A.

- B. Fittings:
 - 1. Description: Fittings complying with NEMA FB 1 and listed and labeled as complying with UL 514B.
 - 2. Connectors and Couplings: Use compression/gland or set-screw type.

2.06 ALUMINUM ELECTRICAL METALLIC TUBING (EMT)

- A. Description: NFPA 70, Type EMT aluminum electrical metallic tubing listed and labeled as complying with UL 797A.
- B. Fittings:
 - 1. Description: Fittings complying with NEMA FB 1 and listed and labeled as complying with UL 514B; listed for use with aluminum EMT.
 - 2. Material: Use aluminum.
 - 3. Connectors and Couplings: Use compression/gland or set-screw type.
 - a. Do not use indenter type connectors and couplings.

2.07 RIGID POLYVINYL CHLORIDE (PVC) CONDUIT

- A. Description: NFPA 70, Type PVC rigid polyvinyl chloride conduit complying with NEMA TC 2 and listed and labeled as complying with UL 651; Schedule 40 unless otherwise indicated, Schedule 80 where subject to physical damage; rated for use with conductors rated 90 degrees C.
- B. Fittings:
 - 1. Manufacturer: Same as manufacturer of conduit to be connected.
 - 2. Description: Fittings complying with NEMA TC 3 and listed and labeled as complying with UL 651; material to match conduit.

2.08 ACCESSORIES

- A. Corrosion Protection Tape: PVC-based, minimum thickness of 20 mil, 0.020 inch.
- B. Conduit Joint Compound: Corrosion-resistant, electrically conductive compound listed as complying with UL 2419; suitable for use with conduit to be installed.
- C. Solvent Cement for PVC Conduit and Fittings: As recommended by manufacturer of conduit and fittings to be installed.
- D. Pull Strings: Use nylon or polyester tape with average breaking strength of not less than 1,250 lbf.

PART 3 EXECUTION

3.01 INSTALLATION

- A. Install products in accordance with manufacturer's instructions.
- B. Install conduit in accordance with NECA 1.
- C. Galvanized Steel Rigid Metal Conduit (RMC): Install in accordance with NECA 101.
- D. Rigid Polyvinyl Chloride (PVC) Conduit: Install in accordance with NECA 111.
- E. Conduit Support:
 - 1. Secure and support conduits in accordance with NFPA 70 using suitable supports and methods approved by authorities having jurisdiction; see Section 26 05 29.
 - 2. Provide independent support from building structure. Do not provide support from piping, ductwork, or other systems.
- F. Connections and Terminations:
 - 1. Use approved zinc-rich paint or conduit joint compound on field-cut threads of galvanized steel conduits prior to making connections.
 - 2. Where two threaded conduits must be joined and neither can be rotated, use three-piece couplings or split couplings. Do not use running threads.

3. Use suitable adapters where required to transition from one type of conduit to another.
 4. Terminate threaded conduits in boxes and enclosures using threaded hubs or double lock nuts for dry locations and raintight hubs for wet locations.
 5. Provide insulating bushings, insulated throats, or listed metal fittings with smooth, rounded edges at conduit terminations to protect conductors.
 6. Secure joints and connections to provide mechanical strength and electrical continuity.
- G. Penetrations:
1. Do not penetrate or otherwise notch or cut structural members, including footings and grade beams, without approval of Structural Engineer.
 2. Make penetrations perpendicular to surfaces unless otherwise indicated.
 3. Provide sleeves for penetrations as indicated or as required to facilitate installation. Set sleeves flush with exposed surfaces unless otherwise indicated or required.
 4. Conceal bends for conduit risers emerging above ground.
 5. Where conduits penetrate waterproof membrane, seal as required to maintain integrity of membrane.
 6. Make penetrations for roof-mounted equipment within associated equipment openings and curbs where possible to minimize roofing system penetrations. Where penetrations are necessary, seal as indicated or as required to preserve integrity of roofing system and maintain roof warranty.
 7. Install firestopping to preserve fire resistance rating of partitions and other elements; see Section 07 84 00.
- H. Conduit Movement Provisions: Where conduits are subject to movement, provide expansion and expansion/deflection fittings to prevent damage to enclosed conductors or connected equipment. This includes, but is not limited to:
1. Where conduits cross structural joints intended for expansion, contraction, or deflection.
 2. Where calculated in accordance with NFPA 70 for rigid polyvinyl chloride (PVC) conduit installed above ground to compensate for thermal expansion and contraction.
 3. Where conduits are subject to earth movement by settlement or frost.
- I. Conduit Sealing:
1. Use foam conduit sealant to prevent entry of moisture and gases. This includes, but is not limited to:
 - a. Where conduits enter building from outside.
 - b. Where service conduits enter building from underground distribution system.
 - c. Where conduits enter building from underground.
 - d. Where conduits may transport moisture to contact live parts.
 2. Where conduits cross barriers between areas of potential substantial temperature differential, use foam conduit sealant at accessible point near penetration to prevent condensation. This includes, but is not limited to:
 - a. Where conduits pass from outdoors into conditioned interior spaces.
 - b. Where conduits pass from unconditioned interior spaces into conditioned interior spaces.
- J. Provide grounding and bonding; see Section 26 05 26.

3.02 FIELD QUALITY CONTROL

- A. Repair cuts and abrasions in galvanized finishes using zinc-rich paint recommended by manufacturer. Replace components that exhibit signs of corrosion.
- B. Correct deficiencies and replace damaged or defective conduits.

3.03 PROTECTION

- A. Immediately after installation of conduit, use suitable manufactured plugs to provide protection from entry of moisture and foreign material and do not remove until ready for installation of conductors.

END OF SECTION

NOT FOR BIDDING

NOT FOR BIDDING

This page intentionally left blank

SECTION 26 05 53
IDENTIFICATION FOR ELECTRICAL SYSTEMS

PART 1 GENERAL

1.01 SECTION INCLUDES

- A. Electrical identification requirements.
- B. Identification nameplates and labels.
- C. Wire and cable markers.
- D. Voltage markers.
- E. Warning signs and labels.

1.02 RELATED REQUIREMENTS

- A. Section 26 05 19 - Low-Voltage Electrical Power Conductors and Cables: Color coding for power conductors and cables 600 V and less; vinyl color coding electrical tape.

1.03 REFERENCE STANDARDS

- A. UL 969 - Marking and Labeling Systems; Current Edition, Including All Revisions.

PART 2 PRODUCTS

2.01 IDENTIFICATION REQUIREMENTS

- A. Identification for Equipment:
 - 1. Use identification nameplate to identify each piece of electrical distribution and control equipment and associated sections, compartments, and components.
 - a. Panelboards:
 - 1) Use typewritten circuit directory to identify load(s) served for panelboards with a door. Identify spares and spaces using pencil.
 - 2) For power panelboards without a door, use identification nameplate to identify load(s) served for each branch device. Do not identify spares and spaces.
 - 2. Use voltage marker to identify highest voltage present for each piece of electrical equipment.
 - 3. Use identification nameplate to identify disconnect location for equipment with remote disconnecting means.
 - 4. Use identification label or handwritten text using indelible marker on inside of door at each fused switch to identify required NEMA fuse class and size.
- B. Identification for Conductors and Cables:
 - 1. Color Coding for Power Conductors 600 V and Less: Comply with Section 26 05 19.
 - 2. Use identification nameplate or identification label to identify color code for ungrounded and grounded power conductors inside door or enclosure at each piece of feeder or branch-circuit distribution equipment when premises has feeders or branch circuits served by more than one nominal voltage system.
- C. Identification for Devices:
 - 1. Use identification label or engraved wallplate to identify serving branch circuit for all receptacles.

2.02 IDENTIFICATION NAMEPLATES AND LABELS

- A. Identification Nameplates:
 - 1. Materials:
 - 2. Mounting Holes for Mechanical Fasteners: Two, centered on sides for sizes up to 1 inch high; Four, located at corners for larger sizes.
- B. Identification Labels:

1. Materials: Use self-adhesive laminated plastic labels; UV, chemical, water, heat, and abrasion resistant.
2. Text: Use factory pre-printed or machine-printed text. Do not use handwritten text unless otherwise indicated.

2.03 WIRE AND CABLE MARKERS

- A. Markers for Conductors and Cables: Use wrap-around self-adhesive vinyl cloth, wrap-around self-adhesive vinyl self-laminating, heat-shrink sleeve, plastic sleeve, plastic clip-on, or vinyl split sleeve type markers suitable for the conductor or cable to be identified.
- B. Markers for Conductor and Cable Bundles: Use plastic marker tags secured by nylon cable ties.
- C. Legend: Power source and circuit number or other designation indicated.
- D. Text: Use factory pre-printed or machine-printed text, all capitalized unless otherwise indicated.
- E. Minimum Text Height: 1/8 inch.
- F. Color: Black text on white background unless otherwise indicated.

2.04 VOLTAGE MARKERS

- A. Markers for Boxes and Equipment Enclosures: Use factory pre-printed self-adhesive vinyl or self-adhesive vinyl cloth type markers.
- B. Minimum Size:
 1. Markers for Equipment: 1 1/8 by 4 1/2 inches.
- C. Legend:
 1. Markers for Voltage Identification: Highest voltage present.
- D. Color: Black text on orange background unless otherwise indicated.

2.05 WARNING SIGNS AND LABELS

- A. Comply with ANSI Z535.2 or ANSI Z535.4 as applicable.
- B. Warning Signs:
 1. Materials:
 2. Minimum Size: 7 by 10 inches unless otherwise indicated.
- C. Warning Labels:
 1. Materials: Use factory pre-printed or machine-printed self-adhesive polyester or self-adhesive vinyl labels; UV, chemical, water, heat, and abrasion resistant; produced using materials recognized to UL 969.
 2. Machine-Printed Labels: Use thermal transfer process printing machines and accessories recommended by label manufacturer.
 3. Minimum Size: 2 by 4 inches unless otherwise indicated.

PART 3 EXECUTION

3.01 PREPARATION

- A. Clean surfaces to receive adhesive products according to manufacturer's instructions.

3.02 INSTALLATION

- A. Install products in accordance with manufacturer's instructions.
- B. Install identification products to be plainly visible for examination, adjustment, servicing, and maintenance. Unless otherwise indicated, locate products as follows:
 1. Surface-Mounted Equipment: Enclosure front.
 2. Flush-Mounted Equipment: Inside of equipment door.
 3. Free-Standing Equipment: Enclosure front; also enclosure rear for equipment with rear access.

4. Elevated Equipment: Legible from the floor or working platform.
 5. Branch Devices: Adjacent to device.
 6. Interior Components: Legible from the point of access.
 7. Conductors and Cables: Legible from the point of access.
 8. Devices: Outside face of cover.
- C. Install identification products centered, level, and parallel with lines of item being identified.
 - D. Secure nameplates to exterior surfaces of enclosures using stainless steel screws and to interior surfaces using self-adhesive backing or epoxy cement.
 - E. Install self-adhesive labels and markers to achieve maximum adhesion, with no bubbles or wrinkles and edges properly sealed.
 - F. Mark all handwritten text, where permitted, to be neat and legible.

3.03 FIELD QUALITY CONTROL

- A. Replace self-adhesive labels and markers that exhibit bubbles, wrinkles, curling or other signs of improper adhesion.

END OF SECTION

NOT FOR BIDDING

NOT FOR BIDDING

This page intentionally left blank

**SECTION 26 05 83
WIRING CONNECTIONS**

PART 1 GENERAL

1.01 SECTION INCLUDES

- A. Electrical connections to equipment.

1.02 RELATED REQUIREMENTS

- A. Section 26 28 16.16 - Enclosed Switches.

1.03 ADMINISTRATIVE REQUIREMENTS

- A. Coordination:
 - 1. Obtain and review shop drawings, product data, manufacturer's wiring diagrams, and manufacturer's instructions for equipment furnished under other sections.
 - 2. Determine connection locations and requirements.
- B. Sequencing:
 - 1. Install rough-in of electrical connections before installation of equipment is required.
 - 2. Make electrical connections before required start-up of equipment.

PART 2 PRODUCTS

2.01 MATERIALS

- A. Disconnect Switches: As specified in Section 26 28 16.16 and in individual equipment sections.

2.02 EQUIPMENT CONNECTIONS

PART 3 EXECUTION

3.01 ELECTRICAL CONNECTIONS

- A. Make electrical connections in accordance with equipment manufacturer's instructions.
- B. Make conduit connections to equipment using flexible conduit. Use liquidtight flexible conduit with watertight connectors in damp or wet locations.
- C. Connect heat producing equipment using wire and cable with insulation suitable for temperatures encountered.
- D. Provide receptacle outlet to accommodate connection with attachment plug.
- E. Provide cord and can where field-supplied attachment plug is required.
- F. Install suitable strain-relief clamps and fittings for cord connections at outlet boxes and equipment connection boxes.
- G. Install disconnect switches, controllers, control stations, and control devices to complete equipment wiring requirements.
- H. Install terminal block jumpers to complete equipment wiring requirements.
- I. Install interconnecting conduit and wiring between devices and equipment to complete equipment wiring requirements.

END OF SECTION

NOT FOR BIDDING

This page intentionally left blank

**SECTION 26 09 23
LIGHTING CONTROL DEVICES**

PART 1 GENERAL

1.01 SECTION INCLUDES

- A. Occupancy sensors.
- B. Digital load controllers.
- C. Accessories.

1.02 RELATED REQUIREMENTS

- A. Section 26 05 19 - Low-Voltage Electrical Power Conductors and Cables.
- B. Section 26 05 29 - Hangers and Supports for Electrical Systems
- C. Section 26 05 33.16 - Boxes for Electrical Systems.
- D. Section 26 05 53 - Identification for Electrical Systems: Identification products and requirements.
- E. Section 26 27 26 - Wiring Devices: Devices for manual control of lighting, including wall switches, wall dimmers, and fan speed controllers.
- F. Section 26 51 00 - Interior Lighting.

1.03 REFERENCE STANDARDS

- A. NECA 1 - Standard for Good Workmanship in Electrical Construction; 2023.
- B. NECA 130 - Standard for Installing and Maintaining Wiring Devices; 2016.
- C. NFPA 70 - National Electrical Code; Most Recent Edition Adopted by Authority Having Jurisdiction, Including All Applicable Amendments and Supplements.
- D. UL 2043 - Fire Test for Heat and Visible Smoke Release for Discrete Products and Their Accessories Installed in Air-Handling Spaces; Current Edition, Including All Revisions.

1.04 ADMINISTRATIVE REQUIREMENTS

- A. Coordination:
 - 1. Coordinate placement of lighting control devices with millwork, furniture, equipment and other potential conflicts.
 - 2. Coordinate placement of wall switch occupancy sensors with installed door swings.
 - 3. Coordinate placement of occupancy sensors with millwork, furniture, equipment and other potential obstructions to motion detection coverage.
 - 4. Coordinate lighting control device product selections with luminaire characteristics; see Section 26 51 00 and lighting fixture schedule.
 - 5. Notify DEDC, LLC of conflicts or deviations from Contract Documents to obtain direction prior to proceeding with work.

1.05 SUBMITTALS

- A. Product Data: Include ratings, operating modes or sequence of functions, configurations, standard wiring diagrams, dimensions, colors, service condition requirements, and installed features.
 - 1. Occupancy Sensors: Include detailed motion detection coverage range diagrams.
- B. Shop Drawings:
 - 1. Occupancy Sensors: Provide lighting plan indicating location, model number, and orientation of each occupancy sensor and associated system component.
 - 2. Digital Load Controllers: Provide dimensioned plan views indicating locations of system components, required clearances, and field connection locations. Include system interconnection schematic diagrams showing factory and field connections. Include

manufacturer product characteristics and application instructions for wired and wireless applications, including start-up and commissioning.

- C. Field quality control reports.

1.06 QUALITY ASSURANCE

- A. Comply with NFPA 70.
- B. Manufacturer Qualifications: Company specializing in manufacturing products specified in this section with minimum three years documented experience.

1.07 DELIVERY, STORAGE, AND PROTECTION

- A. Store products in clean, dry space in original manufacturer's packaging in accordance with manufacturer's written instructions until ready for installation.

1.08 FIELD CONDITIONS

- A. Maintain field conditions within manufacturer's required service conditions during and after installation.

1.09 WARRANTY

- A. Provide five year manufacturer warranty for occupancy sensors.
- B. Provide five year manufacturer warranty for utility grade locking receptacle-mounted outdoor photo controls.
- C. Provide five year manufacturer warranty for digital load controllers.

PART 2 PRODUCTS

2.01 LIGHTING CONTROL DEVICES - GENERAL REQUIREMENTS

- A. Provide products listed, classified, and labeled as suitable for purpose intended.
- B. Unless specifically indicated as excluded, provide components necessary for complete operating system including, but not limited to, conduit, wiring, connectors, hardware, and accessories.

2.02 OCCUPANCY SENSORS

- A. Manufacturers:
 - 1. Acuity Brands, Inc: www.acuitybrands.com/#sle.
 - 2. Hubbell Incorporated: www.hubbell.com/#sle.
 - 3. Legrand North America, Inc: www.legrand.us/#sle.
 - 4. Leviton: www.leviton.com.
- B. General Requirements:
 - 1. Description: Factory-assembled commercial specification grade devices for indoor use capable of sensing both major motion, such as walking, and minor motion, such as small desktop level movements, according to published coverage areas, for automatic control of load indicated.
 - 2. Sensor Technology:
 - a. Passive Infrared (PIR) Occupancy Sensors: Designed to detect occupancy by sensing movement of thermal energy between zones.
 - b. Ultrasonic Occupancy Sensors: Designed to detect occupancy by sensing frequency shifts in emitted and reflected inaudible sound waves.
 - c. Passive Infrared/Ultrasonic Dual Technology Occupancy Sensors: Designed to detect occupancy using combination of both passive infrared and ultrasonic technologies.
 - d. Passive Infrared/Acoustic Dual Technology Occupancy Sensors: Designed to detect occupancy using combination of both passive infrared and audible sound sensing technologies.

3. Provide LED to visually indicate motion detection with separate color LEDs for each sensor type in dual technology units.
 4. Operation: Unless otherwise indicated, occupancy sensor to turn load on when occupant presence is detected and to turn load off when no occupant presence is detected during adjustable turn-off delay time interval.
 5. Turn-Off Delay: Field adjustable, with time delay settings up to 30 minutes.
 6. Compatibility (Non-Dimming Sensors): Suitable for controlling incandescent lighting, low-voltage lighting with electronic and magnetic transformers, fluorescent lighting with electronic and magnetic ballasts, and fractional motor loads, with no minimum load requirements.
- C. Wall Switch Occupancy Sensors:
1. General Requirements:
 - a. Description: Occupancy sensors designed for installation in standard wall box at standard wall switch mounting height with field of view of 180 degrees, integrated manual control capability, and no leakage current to load in off mode.
 - b. Manual-Off Override Control: When used to turn off load while in automatic-on mode, unit to revert back to automatic mode after no occupant presence is detected during delayed-off time interval.
- D. Ceiling Mounted Occupancy Sensors:
1. General Requirements:
 - a. Description: Low profile occupancy sensors designed for ceiling installation.
 - b. Unless otherwise indicated or required to control load indicated on drawings, provide low voltage units, for use with separate compatible accessory power packs.
 - c. Occupancy sensor to be field selectable as either manual-on/automatic-off or automatic on/off.
 - d. Finish: White unless otherwise indicated.
- E. Power Packs for Low-Voltage Occupancy Sensors:
1. Description: Plenum rated self-contained low-voltage class 2 transformer and relay compatible with specified low voltage occupancy sensors for switching of line-voltage loads.
 2. Provide quantity and configuration of power and slave packs with associated wiring and accessories as required to control load indicated on drawings.
 3. Input Supply Voltage: Dual rated for 120/277 V ac.
 4. Load Rating: As required to control load indicated on drawings.

2.03 DIGITAL LOAD CONTROLLERS

- A. System Description:
1. Stand-alone system, including interconnected modules and accessories, for lighting and plug load low-voltage control as indicated on drawings, schedules, written sequences of operation, and reviewed shop drawings.
 2. Product standard system configurations preconfigured out of box, plug-and-play, automatically self-addressing devices for communications, and without need to field configure or program features, or requiring device setting adjustments. LEDs on unit indicate operation and troubleshooting without software intervention.
 3. Provide quantity and configuration of power and slave packs, communication modules, and load expansion modules, including associated wiring, wired and wireless components, and accessories to control loads indicated.
- B. General Requirements:
1. Listed for powering and controlling line-voltage loads, power packs, contactors, relays, and other lighting control devices.
 2. Input Supply Voltage: Dual rated for 120/277 VAC.
 3. Cabling Terminations:

4. Provide UL 2043 plenum rated control unit with self-contained relay(s) and low-voltage class 2 transformer, compatible with specified wired and wireless sensors, components, and ballasts/drivers.
 - a. Comply with NFPA 70 for use in plenum spaces.
 - b. Provide UL 2043 plenum rating for associated system control components for control indicated.
5. Surface Mounting: Standard junction box attachments.
6. Provide one auxiliary contact closure output where indicated.
7. Control Inputs:
 - a. Digital: Two.
8. Output Control Capability:
 - a. Single Zone Switching Modules: One programmable channel.
 - b. Multi-Zone Switching Modules: Up to three separately programmable channels.

PART 3 EXECUTION

3.01 EXAMINATION

- A. Verify that field measurements are as indicated.
- B. Verify that outlet boxes are installed in proper locations and at proper mounting heights and are properly sized to accommodate devices and conductors in accordance with NFPA 70.
- C. Verify that openings for outlet boxes are neatly cut and will be completely covered by devices or wall plates.
- D. Verify that final surface finishes are complete, including painting.
- E. Verify that branch circuit wiring installation is completed, tested, and ready for connection to lighting control devices.
- F. Verify that service voltage and ratings of lighting control devices are appropriate for service voltage and load requirements at location to be installed.
- G. Verify that conditions are satisfactory for installation prior to starting work.

3.02 INSTALLATION

- A. Install lighting control devices in accordance with NECA 1 (general workmanship) and, where applicable, NECA 130, including mounting heights specified in those standards unless otherwise indicated.
- B. Coordinate locations of outlet boxes as required for installation of lighting control devices; see Section 26 05 33.10.
- C. Maintain separation of remote-control, signaling, and power-limited circuits.
 1. See manufacturer instructions and Section 26 05 19 for control wiring conductors, wiring methods, and identification requirements.
- D. Install lighting control devices in accordance with manufacturer's instructions.
- E. Unless otherwise indicated, connect lighting control device grounding terminal or conductor to branch circuit equipment grounding conductor and to outlet box with bonding jumper.
- F. Install lighting control devices plumb and level, and held securely in place.
- G. Where required and not furnished with lighting control device, provide wall plate; see Section 26 27 26.
- H. Provide required supports; see Section 26 05 29.
- I. Where applicable, install lighting control devices and associated wall plates to fit completely flush to mounting surface with no gaps and rough opening completely covered without strain on wall plate. Repair or reinstall improperly installed outlet boxes or improperly sized rough openings. Do not use oversized wall plates in lieu of meeting this requirement.

3.03 FIELD QUALITY CONTROL

- A. Inspect each lighting control device for damage and defects.
- B. Test occupancy sensors to verify proper operation, including time delays and ambient light thresholds where applicable. Verify optimal coverage for entire room or area. Record test results in written report to be included with submittals.
- C. Correct wiring deficiencies and replace damaged or defective conductors, cables, and lighting control devices.

3.04 ADJUSTING

- A. Adjust devices and wall plates to be flush and level.
- B. Adjust occupancy sensor settings to minimize undesired activations while optimizing energy savings, and to achieve desired function as indicated or as directed by DEDC, LLC.

3.05 CLEANING

- A. Clean exposed surfaces to remove dirt, paint, or other foreign material and restore to match original factory finish.

3.06 CLOSEOUT ACTIVITIES

- A. Demonstration: Demonstrate proper operation of lighting control devices to DEDC, LLC, and correct deficiencies or make adjustments as directed.
- B. Training: Train Del Tech's personnel on operation, adjustment, programming, and maintenance of lighting control devices.
 - 1. Use operation and maintenance manual as training reference, supplemented with additional training materials as required.
 - 2. Provide minimum of two hours of training.
 - 3. Instructor: Qualified contractor familiar with the project and with sufficient knowledge of installed lighting control devices.
 - 4. Location: At project site.

END OF SECTION

NOT FOR BIDDING

This page intentionally left blank

**SECTION 26 24 16
PANELBOARDS**

PART 2 PRODUCTS

1.01 PANELBOARDS - GENERAL REQUIREMENTS

- A. Provide products listed, classified, and labeled as suitable for the purpose intended.
- B. Unless otherwise indicated, provide products suitable for continuous operation under the following service conditions:
 - 1. Altitude: Less than 6,600 feet.
 - 2. Ambient Temperature:
 - a. Panelboards Containing Circuit Breakers: Between 23 degrees F and 104 degrees F.
- C. Short Circuit Current Rating:
- D. Mains: Configure for top or bottom incoming feed as indicated or as required for the installation.
- E. Branch Overcurrent Protective Devices: Replaceable without disturbing adjacent devices.
- F. Bussing: Sized in accordance with UL 67 temperature rise requirements.
 - 1. Provide solidly bonded equipment ground bus in each panelboard, with a suitable lug for each feeder and branch circuit equipment grounding conductor.
- G. Conductor Terminations: Suitable for use with the conductors to be installed.
- H. Enclosures: Comply with NEMA 250, and list and label as complying with UL 50 and UL 50E.
 - 1. Environment Type per NEMA 250: Unless otherwise indicated, as specified for the following installation locations:
 - 2. Boxes: Galvanized steel unless otherwise indicated.
 - a. Provide wiring gutters sized to accommodate the conductors to be installed.
 - 3. Fronts:
 - a. Fronts for Surface Mounted Enclosures: Same dimensions as boxes.
 - b. Fronts for Flush-Mounted Enclosures: Overlap boxes on all sides to conceal rough opening.
 - 4. Lockable Doors: All locks keyed alike unless otherwise indicated.
- I. Future Provisions: Prepare all unused spaces for future installation of devices including bussing, connectors, mounting hardware and all other required provisions.

1.02 POWER DISTRIBUTION PANELBOARDS

- A. Description: Panelboards complying with NEMA PB 1, power and feeder distribution type, circuit breaker type, and listed and labeled as complying with UL 67; ratings, configurations and features as indicated on the drawings.
- B. Conductor Terminations:
 - 1. Main and Neutral Lug Material: Aluminum, suitable for terminating aluminum or copper conductors.
 - 2. Main and Neutral Lug Type: Mechanical.
- C. Bussing:
 - 1. Phase and Neutral Bus Material: Aluminum.
 - 2. Ground Bus Material: Aluminum.
- D. Circuit Breakers:
 - 1. Provide bolt-on type or plug-in type secured with locking mechanical restraints.
- E. Enclosures:
 - 1. Provide surface-mounted enclosures unless otherwise indicated.

1.03 LIGHTING AND APPLIANCE PANELBOARDS

- A. Description: Panelboards complying with NEMA PB 1, lighting and appliance branch circuit type, circuit breaker type, and listed and labeled as complying with UL 67; ratings, configurations and features as indicated on the drawings.
- B. Conductor Terminations:
 - 1. Main and Neutral Lug Material: Aluminum, suitable for terminating aluminum or copper conductors.
 - 2. Main and Neutral Lug Type: Mechanical.
- C. Bussing:
 - 1. Phase Bus Connections: Arranged for sequential phasing of overcurrent protective devices.
 - 2. Phase and Neutral Bus Material: Aluminum.
 - 3. Ground Bus Material: Aluminum.
- D. Circuit Breakers: Thermal magnetic bolt-on type unless otherwise indicated.
- E. Enclosures:
 - 1. Provide surface-mounted or flush-mounted enclosures as indicated.
 - 2. Provide clear plastic circuit directory holder mounted on inside of door.

1.04 OVERCURRENT PROTECTIVE DEVICES

- A. Molded Case Circuit Breakers:
 - 1. Description: Quick-make, quick-break, over center toggle, trip-free, trip-indicating circuit breakers listed and labeled as complying with UL 489, and complying with FS W-C-375 where applicable; ratings, configurations and features as indicated on the drawings.
 - 2. Interrupting Capacity:
 - a. Provide circuit breakers with interrupting capacity as required to provide the short circuit current rating indicated but not less than:
 - b. Fully Rated Systems: Provide circuit breakers with interrupting capacity not less than the short circuit current rating indicated.
 - 3. Conductor Terminations:
 - a. Lug Material: Aluminum, suitable for terminating aluminum or copper conductors.
 - 4. Thermal Magnetic Circuit Breakers: For each pole, furnish thermal inverse time tripping element for overload protection and magnetic instantaneous tripping element for short circuit protection.
 - 5. Multi-Pole Circuit Breakers: Furnish with common trip for all poles.

END OF SECTION

SECTION 26 27 26
WIRING DEVICES

PART 2 PRODUCTS

1.01 WIRING DEVICES - GENERAL REQUIREMENTS

- A. Provide wiring devices suitable for intended use with ratings adequate for load served.

END OF SECTION

NOT FOR BIDDING

NOT FOR BIDDING

This page intentionally left blank

**SECTION 26 28 13
FUSES**

PART 2 PRODUCTS

1.01 FUSES

- A. Provide products listed, classified, and labeled as suitable for the purpose intended.
- B. Unless specifically indicated to be excluded, provide fuses for all fusible equipment as required for a complete operating system.
- C. Provide fuses of the same type, rating, and manufacturer within the same switch.
- D. Comply with UL 248-1.
- E. Unless otherwise indicated, provide cartridge type fuses complying with NEMA FU 1, Class and ratings as indicated.
- F. Voltage Rating: Suitable for circuit voltage.

END OF SECTION

NOT FOR BIDDING

NOT FOR BIDDING

This page intentionally left blank

**SECTION 26 51 00
INTERIOR LIGHTING**

PART 2 PRODUCTS

1.01 LUMINAIRES

- A. Provide products that comply with requirements of NFPA 70.
- B. Provide products that are listed and labeled as complying with UL 1598, where applicable.
- C. Provide products listed, classified, and labeled as suitable for the purpose intended.
- D. Unless otherwise indicated, provide complete luminaires including lamp(s) and all sockets, ballasts, reflectors, lenses, housings and other components required to position, energize and protect the lamp and distribute the light.
- E. Unless specifically indicated to be excluded, provide all required conduit, boxes, wiring, connectors, hardware, supports, trims, accessories, etc. as necessary for a complete operating system.
- F. Provide products suitable to withstand normal handling, installation, and service without any damage, distortion, corrosion, fading, discoloring, etc.

END OF SECTION