



Pennsylvania
Duane Morris Plaza
30 S. 17th Street
Suite 830
Philadelphia, PA 19103
Phone
267.804.7286

Delaware
315 S. Chapel Street
Newark, DE 19711
Phone
302.738.7172
Fax
302.738.7175
www.dedc-eng.com

DELAWARE STATE POLICE
HEADQUARTERS BUILDING
OMB/DFM# MC1002001111A
ADDENDUM #2

QUESTIONS:

- A. M200 drawing states to demo existing breeching in chimney. Has an existing chimney breeching been confirmed?
 - a. This is based on the documentation available, but the chimney has not been opened to confirm if the breeching runs all the way up.*
- B. What days are best for crane picks, weekdays, weekends?
 - a. All crane picks are to occur over a weekend (Saturday & Sunday).*
- C. M-500 detail-2 notes to route breeching up through chimney. Does a weather cape need to be provide to close off chimney top to new breeching? If so, what type of metal, can a detail be provided?
 - a. The contractor is to seal the top of the chimney weather tight when installing the breeching.*

SUMMARY:

- A. Addendum #2
 - 1. Addendum #2 (this document) (1 page)

Summarized By: DEDC, LLC
Matt Lano
Date: September 8, 2026