

**Addendum
No. 2**

Addendum Date: October 7, 2026
Project: Cooling Tower Replacement at TMC
DFM Project No: MC5508000005A

The work herein shall be considered part of the bid documents for the referenced project and carried out in accordance with the following supplemental instructions issued in accordance with the Contract Documents without change in Contract Sum or Contract Time. Acknowledge receipt of addendum on the bid form as indicated.

Bidder RFIs and Responses

1. Question: The hydronic piping specifications call for the cooling tower drains to be either galvanized steel or copper tubing. The existing cooling tower drains appear to be schedule 40 PVC. Is it acceptable to use schedule 40 PVC for the new work on the cooling tower?
Response: No.

Changes to Specifications:

None at this time.

Changes to Drawings:

None at this time.

Attachments:

None at this time.

END